



BYPASS / OVERFLOW INCIDENT REPORT

State Form 48373 (R9 / 7-22)
Indiana Department of Environmental Management
Office of Water Quality

Follow-up to Bypass report
previously sent on: _____

INSTRUCTIONS: Complete all parts of this form and e-mail signed copies to wwreports@idem.IN.gov. Submittal of this report will satisfy the Office of Water Quality (OWQ) telephone and written bypass/overflow reporting requirements of your NPDES permit. Please use and the second page of this form as necessary to identify **separate locations caused by the same event**. If you have any questions while filling out this form, please call (317) 232-7150.

To report a spill or if the release is resulting in a fish kill or other severe environmental damage, immediately report the release to the Emergency Response Section spill response line at: (317) 233-7745 or toll free within Indiana at (888) 233-7745.

GENERAL INFORMATION			
(1) Facility Name (Organization) Gary Sanitary District	(2) Mailing Address (reporting organization) 3600 W 3rd Avenue	(3) County Lake	(4) NPDES Permit IN0022977

RELEASE INFORMATION (Location 1)					
(5) Outfall Number 001A	(6) Date (mm/dd/yy) and Time Release Began 6/23/24, 6:00 <input checked="" type="checkbox"/> AM <input type="checkbox"/> PM	(7) Date (mm/dd/yy) and Time Release Stopped 6/23/24, 9:50 <input checked="" type="checkbox"/> AM <input type="checkbox"/> PM	(8) Location of Release (streets address or Manhole, Lift Station, Force Main etc.) GSD WWTP	(9) Latitude (Deg Min Sec) 41 36 29	(9) Longitude (Deg Min Sec) 87 23 19
(10) Amount of Flow Released (Always provide a volume.) Check one: <input checked="" type="checkbox"/> Estimated <input type="checkbox"/> Actual 50 Gallons			(11) WWTP Flow During Release 130 MGD	(12) WWTP Peak Design Flow Rate 120 MGD	

(13) Overflow Type (Select one.) <input type="checkbox"/> Sanitary Sewer Overflow <input checked="" type="checkbox"/> Treatment Bypass (at wastewater plant) <input type="checkbox"/> Prohibited Combined Sewer Overflow <input type="checkbox"/> Dry Weather Combined Sewer Overflow <input type="checkbox"/> Combined Sewer System Release	(14) Describe any damage to aquatic life or receiving stream: None
---	---

(15) Reason for Bypass / Overflow (Select one or more.)
 Construction Related Power Failure Equipment Failure Unknown Exceeded Max Capacity Precipitation 1.15 Inches

(16) System Component(s) (Select one or more.) <input type="checkbox"/> Manhole <input type="checkbox"/> House Lateral <input type="checkbox"/> Pipe Failure <input type="checkbox"/> Pump Station Failure <input checked="" type="checkbox"/> Treatment Bypassed <input type="checkbox"/> Other <input type="checkbox"/> Influent Structure <input type="checkbox"/> Air Relief Valve <input type="checkbox"/> Sewer Clean Out Describe Other: (in the box below)	(17) Additional Description of the Bypass / Overflow Event: Electrical Power was lost during a rain event to our Filter Building. Bypass was opened to avoid flooding and overwhelming an o/s building until power was restored.	(18) Description of the Area Impacted (Check all that apply.) <input type="checkbox"/> Affected Private Property <input type="checkbox"/> Basement Backup <input type="checkbox"/> Occurred at Treatment Plant <input type="checkbox"/> Reached Public Land <input checked="" type="checkbox"/> Reached Receiving Water Name of Receiving Water Impacted: Grand Calumet River
--	---	--

(19) Additional organizations notified by facility, if necessary (Select one or more.)
 IDEM Emergency Response Health Department DNR Fish and Wildlife Local Emergency Management Other:

(20) Actions Taken to Prevent, Minimize, or Mitigate Damage including Clean-up and Treatment of Affected Area (Select one or more of the following, then add a written description.)
 Removed Blockage Repaired Pipe Repaired Pump Station Other Lime Clean-Up Debris
 Increased chlorine/bisulfite usage during bypass event to kill E.Coli that would enter outfall.

(21) Resolution: Actions Taken or Planned to Prevent Recurrence
 Power was restored to filter building within an hour of power being lost, thanks to our on-call electrician. Upgrading our electrical grid is being considered/more power safety checks.

(22) CERTIFICATION AND SIGNATURE

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations. (The area below is for a handwritten signature or an electronic substitute. Scan the completed form to PDF and e-mail to wwreports@idem.IN.gov)

SIGNATURE:	DATE (month, day, year): 6/24/24			
Individual Making Report (printed) Tim Alston	Telephone Number 2199441211	Contact E-mail talston@garysan.com	Date (month, day, year) / Time IDEM Notified 6/24/24, 2:00	<input type="checkbox"/> AM <input checked="" type="checkbox"/> PM