



MONTHLY REPORT OF OPERATION WATER TREATMENT PLANT

State Form 34609 (R11 / 1-17)

INDIANA DEPARTMENT OF
ENVIRONMENTAL MANAGEMENT

System Name MARYSVILLE-OTISCO-NABB WATER CORPORATION PWSID Number 5210006

For the Month of MAY Year 2024 IDEM Field Rep. ANNA READLE

Signed *J. Anthony Masingso* Title SUPERINTENDENT

I certify **under penalty of law**, by this signature that this document was prepared by me, or under my direction, and the information submitted is to the best of my knowledge and belief, true, accurate, and complete. I am also aware that there are significant penalties for submitting false information.

Certification Number DS976939

PHYSICAL AND CHEMICAL DATA *

Date	Turbidity		Alkalinity		pH		Hardness		Iron		Manganese		Phosphate	Fluoride
	Raw	Finished	Raw	Finished	Raw	Finished	Raw	Finished	Raw	Finished	Raw	Finished	Finished	Finished
1														
2														
3														
4														
5														
6									N/A					
7														
8														
9														
10														
11														
12														
13														
14														
15														
16														
17														
18														
19														
20														
21														
22														
23														
24														
25														
26														
27														
28														
29														
30														
31														

* All parameters are to be expressed in mg/l except pH and turbidity.
DUE BY THE 10TH OF THE MONTH FOLLOWING THE REPORTING PERIOD.

Date	Water Treated 1000 gallons	Chemicals Used – Pounds								Filters		Chlorine Residual				Remarks
		Salt	Alum	Lime	Soda Ash	Carbon	Chlorine	Fluoride	Phosphate	Filter Run (hours)	Gallons per wash x 1000	Plant Tap		D. S.		
												Free	Total	Free	Total	
1	396															
2	389											0.9		0.9		
3	459											0.8				
4	459											0.9		1.0		
5	459															
6	453															
7	343											0.8				
8	429											0.8				
9	395											1.2				
10	395											0.8				
11	395											0.7				
12	395															
13	437													1.0		
14	424											0.8		1.0		
15	425											0.9				
16	438											1.2		0.7		
17	437											1.0				
18	437											0.7				
19	437													0.9		
20	437															
21	484											0.7				
22	457											0.8				Monthly Water Treatment
23	456											0.9			Total Gallons	13468
24	441											0.9			Max. Day	484
25	467											1.0			Min. Day	343
26	467														Avg. Daily	434
27	467													1.1		E-Mail To:
28	467											1.0				DWBMRO@idem.in.gov
29	395											1.0				Mail To:
30	451											0.7				Indiana Department of Environmental Management
31	483											1.0				Drinking Water Branch
												1.1				100 N. Senate Ave. Room N1201 Indianapolis, IN 46204-2237