



# MONTHLY REPORT OF OPERATION WATER TREATMENT PLANT

State Form 34609 (R11 / 1-17)

INDIANA DEPARTMENT OF  
ENVIRONMENTAL MANAGEMENT

System Name Marshall Water Works PWSID Number 5261003

For the Month of May Year 2024 IDEM Field Rep. J. Stupinski

Signed Tom Kuysho Title Operator

I certify **under penalty of law**, by this signature that this document was prepared by me, or under my direction, and the information submitted is to the best of my knowledge and belief, true, accurate, and complete.  
*I am also aware that there are significant penalties for submitting false information.*

Certification Number 070257110042

### PHYSICAL AND CHEMICAL DATA \*

Date	Turbidity		Alkalinity		pH		Hardness		Iron		Manganese		Phosphate	Fluoride
	Raw	Finished	Raw	Finished	Raw	Finished	Raw	Finished	Raw	Finished	Raw	Finished	Finished	Finished
1														
2														
3														
4														
5														
6														
7														
8														
9														
10														
11														
12														
13														
14														
15														
16														
17														
18														
19														
20														
21														
22														
23														
24														
25														
26														
27														
28														
29														
30														
31														

\* All parameters are to be expressed in mg/l except pH and turbidity.

**DUE BY THE 10<sup>TH</sup> OF THE MONTH FOLLOWING THE REPORTING PERIOD.**

Date	Water Treated 1000 gallons	Chemicals Used – Pounds								Filters		Chlorine Residual				Remarks	
		Salt	Alum	Lime	Soda Ash	Carbon	Chlorine	Fluoride	Phos- phate	Filter Run (hours)	Gallons per wash x 1000	Plant Tap		D. S.			
												Free	Total	Free	Total		
1	19													.54	.55		
2	20													.55	.57		
3	18													.54	.55		
4	29													.55	.56		
5	43													.56	.58		
6	38													.57	.59		
7	32													.59	.60		
8	13													.58	.59		
9	22													.55	.56		
10	23													.56	.57		
11	21													.54	.55		
12	23													.53	.55		
13	23													.55	.56		
14	23													.56	.58		
15	24													.55	.57		
16	22													.54	.55		
17	22													.53	.54		
18	23													.52	.53		
19	23													.54	.55		
20	23													.55	.56		
21	22													.56	.58	Monthly Water Treatment	
22	28													.57	.58	Total Gallons	725,253
23	21													.55	.56	Max. Day	42,600
24	21													.54	.57	Min. Day	12,900
25	22													.56	.57	Avg. Daily	23,395
26	22													.57	.58	E-Mail To: DWB MRO@idem.in.gov	
27	19													.54	.55		
28	24													.53	.55	Mail To: <b>Indiana Department of Environmental Management</b> Drinking Water Branch 100 N. Senate Ave. Room N1201 Indianapolis, IN 46204-2237	
29	24													.55	.57		
30	22													.54	.55		
31	25													.53	.54		