



**UNDERGROUND STORAGE
TANK INSPECTION REPORT**

INDIANA DEPARTMENT OF
ENVIRONMENTAL MANAGEMENT

UST FAC ID: **25416**

| | |
|-------------------|------------------|
| Inspector's Name: | Brandon Blystone |
| Date: | June 25, 2024 |
| Time In: | 10:15 |
| Time Out: | 10:45 |
| Inspection Type: | Initial |

FACILITY NAME / LOCATION

| | | | | |
|-------------------------------|--------------------|---|-------------------|-----------------|
| FACILITY NAME Kroger J 405 | | FACILITY ADDRESS (number and street) 4210 N Clinton St | | |
| ADDRESS (line 2) | CITY Fort Wayne | STATE IN | ZIP CODE 46805 | COUNTY Allen |

UST OWNER

| | | | | | |
|--|--------------------------|---|-------------------|---|--|
| UST Owner Name (Business Name as registered with the Secretary of State) Kroger Limited Partnership I | | | | BUSINESS ID (From the Secretary of State) LP97110042 | |
| PREFIX | FIRST NAME Shenevelyn | MI | LAST NAME Ross | SUFFIX | |
| TELEPHONE NUMBER (317) 579-8119 | | EMAIL ADDRESS shenevelyn.ross@kroger.com | | | |

UST OPERATOR


| | | | | | |
|---|------------------------|--|----------------------|---|--|
| UST Operator Name (Business Name as registered with the Secretary of State) Kroger Limited Partnership I | | | | BUSINESS ID (From the Secretary of State) LP97110042 | |
| PREFIX | FIRST NAME Danielle | MI | LAST NAME Sanders | SUFFIX | |
| TELEPHONE NUMBER (317) 579-8119 | | EMAIL ADDRESS danielle.sanders@kroger.com | | | |

PROPERTY OWNER


| | | | | | |
|--|----------------------|---|-----------------------|--|--|
| UST Property Owner Name (Business Name as registered with the Secretary of State) Las Lomas LLC | | | | BUSINESS ID (From the Secretary of State) 2004012200206 | |
| PREFIX | FIRST NAME Martin | MI | LAST NAME Quintana | SUFFIX | |
| TELEPHONE NUMBER (260) 426-1118 | | EMAIL ADDRESS martinquintana@gmail.com | | | |

COMPLIANCE ELEMENTS

| | | | | | | |
|--|-------------------------------------|-----|-------------------------------------|----|--------------------------|-----|
| All USTs properly registered and up-to-date notification form on file | <input checked="" type="checkbox"/> | YES | <input type="checkbox"/> | NO | <input type="checkbox"/> | UNK |
| O/O is in compliance with reporting & record keeping requirements | <input checked="" type="checkbox"/> | YES | <input type="checkbox"/> | NO | <input type="checkbox"/> | UNK |
| O/O is in compliance with release reporting or investigation | <input checked="" type="checkbox"/> | YES | <input type="checkbox"/> | NO | <input type="checkbox"/> | N/A |
| O/O is in compliance with all UST closure requirements | <input checked="" type="checkbox"/> | YES | <input type="checkbox"/> | NO | <input type="checkbox"/> | N/A |
| O/O has met all financial responsibility requirements | <input checked="" type="checkbox"/> | YES | <input type="checkbox"/> | NO | <input type="checkbox"/> | N/A |
| 40 CFR 280, Subpart A installation requirements (partially excluded) met | <input checked="" type="checkbox"/> | YES | <input type="checkbox"/> | NO | <input type="checkbox"/> | N/A |
| 40 CFR 280, Subpart B installation and upgrade requirements met | <input checked="" type="checkbox"/> | YES | <input type="checkbox"/> | NO | <input type="checkbox"/> | UNK |
| 40 CFR 280, Subpart C spill/overfill control requirements met | <input checked="" type="checkbox"/> | YES | <input type="checkbox"/> | NO | <input type="checkbox"/> | N/A |
| 40 CFR 280, Subpart C compatibility requirements met | <input checked="" type="checkbox"/> | YES | <input type="checkbox"/> | NO | <input type="checkbox"/> | N/A |
| 40 CFR 280, Subpart C O&M and testing requirements met | <input type="checkbox"/> | YES | <input checked="" type="checkbox"/> | NO | <input type="checkbox"/> | UNK |
| Annual Walkthrough Inspection | | | | | | |
| 40 CFR 280, Subpart D release detection requirements met | <input checked="" type="checkbox"/> | YES | <input type="checkbox"/> | NO | <input type="checkbox"/> | UNK |
| 40 CFR 280, Subpart J operator training requirements met | <input checked="" type="checkbox"/> | YES | <input type="checkbox"/> | NO | <input type="checkbox"/> | UNK |










Cool Storage













57.99

XactAir

VISA

AIR

Instructions / No-Brackets





U

DIESEL
ULTRA-LOW
SULFUR

U














EASE TANK

WARNING








UNLEADED
PREMIUM



UNLEADED
PREMIUM























SYSTEMS
ED
IN BASE
DATE REC'D




DATE REC'D
DATE REC'D




OPEN FOR MAINTENANCE SYSTEMS
DATE BELOW CAST IRON BASE
DATE MFG

DATE MFG
DATE BELOW CAST IRON BASE
DATE MFG





















Kroger

8

55¢ FOR A YEAR!

Save \$ 8268
Balance 2397

87 89 93


NO SMOKING · STOP ENGINE


Kroger


8

0

\$ 6.99









2

Sale \$ **49.15**
 Gallons **130.4**

DIESEL

DIESEL 87 89 93
 REGULAR DIESEL 87
 PREMIUM DIESEL 89
 PREMIUM DIESEL 93

NO SMOKING · STOP ENGINE




LOW PRICE
 MotoTech Windshield Clean
2.99

LOW PRICE
 MotoTech Windshield Clean
2.99

SALE
 MotoTech Premium Antifreeze
9.99









Kroger

4


4X FUEL POINTS

33.75
9.78


NO SMOKING · STOP ENGINE

Kroger

More Scratch-offs from the KROGER LOTTERY Now Available at the Fuel Kiosks!









5

55¢ FOR A YEAR!

SAVE UP TO 55¢ PER GALLON

FOR A YEAR!

APPLY TODAY

Kroger

Rate \$ 5.132
Gallons 14.259

DIESEL

NO SMOKING · STOP ENGINE



SALE
Motor Oil All Grades
Walmart.com
4.49

LOW PRICE
Motor Oil
5.49

SALE
Blue-DEE Diesel Exhaust Fluid
16.99







Kroger

55¢ FOR A YEAR!

25¢

Save \$ 65.00
Gallons 180.60


87 89 93

NO SMOKING · STOP ENGINE

Kroger








TLS-450

VEEDER-ROOT



Low Fuel Alarm!
Call Carrier to see when next fuel delivery is expected.
Klemm Transport - 9-1-800-584-1698
Then call:
John Taylor 9-1-317-579-8119

The report
that prints at
Loam goes in
Liquid States Book
Circle Desk.

54
209001
RY REPORT

12063 GALS
12027 GALS
7718 GALS
5741 GALS
69.18 INCHES
0.00 INCHES
0 GALS
64.23 DEG F

7695 GALS
1690 GALS
6206 GALS
5476 GALS
81.64 INCHES
0.00 INCHES
0 GALS
64.87 DEG F

2201 GALS
2203 GALS
8213 GALS
7175 GALS
82.19 INCHES
0.00 INCHES
0 GALS
64.88 DEG F

INSPECTED
PLUMBING WORK

INSPECTED
PLUMBING WORK

INSPECTED
ELECTRICAL WORK
7-10 Day

INSPECTED
ELECTRICAL WORK
7-10 DAY

INSPECTED
ELECTRICAL WORK

06/25/24 10:18 AM

KROGER J-405
4210 N Clinton St.
FT Wayne, In.
SER# P08233533205001

CURRENT INVENTORY REPORT

TANK 1: UNL
VOLUME = 15379 GALS
FUEL TC = 15220 GALS
100% ULLAGE= 4403 GALS
90% ULLAGE = 2425 GALS
HEIGHT = 85.31 INCHES
WATER = 0.00 INCHES
WATER VOL = 0 GALS
TEMP = 74.75 DEG F

TANK 2: PRM
VOLUME = 2729 GALS
FUEL TC = 2711 GALS
100% ULLAGE= 5172 GALS
90% ULLAGE = 4382 GALS
HEIGHT = 44.52 INCHES
WATER = 0.00 INCHES
WATER VOL = 0 GALS
TEMP = 69.19 DEG F

TANK 3: DSL
VOLUME = 3296 GALS
FUEL TC = 3286 GALS
100% ULLAGE= 7124 GALS
90% ULLAGE = 6082 GALS
HEIGHT = 42.41 INCHES
WATER = 0.00 INCHES
WATER VOL = 0 GALS
TEMP = 66.90 DEG F

06/25/24 10:19 AM

KROGER J-405
4210 N Clinton St.
FT Wayne, In.
SER# P08233533205001

SENSOR HISTORY BY PERIOD - BY MONTH

Selected Range:

Range:07/01/23 12:00 AM - 06/25/24 11:59 PM

PERIOD: June 2024

| SENSOR | LABEL | DATE/TIME | STATUS |
|--------|---------------------|-------------------|--------|
| L 1 | DISPENSER 1-2 SUMP | 06/01/24 12:00 AM | NORMAL |
| L 2 | DISPENSER 3-4 SUMP | 06/01/24 12:00 AM | NORMAL |
| L 3 | DISPENSER 5-6 SUMP | 06/01/24 12:00 AM | NORMAL |
| L 4 | DISPENSER 7-8 SUMP | 06/01/24 12:00 AM | NORMAL |
| L 5 | DISPENSER 9-10 SUMP | 06/01/24 12:00 AM | NORMAL |
| L 6 | UNL. SUBPUMP SUMP | 06/01/24 12:00 AM | NORMAL |
| L 7 | PREM. SUBPUMP SUMP | 06/01/24 12:00 AM | NORMAL |
| L 8 | DIESEL SUBPUMP SUMP | 06/01/24 12:00 AM | NORMAL |
| L 10 | PREM FILL SUMP | 06/01/24 12:00 AM | NORMAL |
| L 11 | DIESEL FILL SUMP | 06/01/24 12:00 AM | NORMAL |
| L 12 | TANK INTERSTICE T1 | 06/01/24 12:00 AM | NORMAL |
| L 13 | TANK INTERSTICE T2- | 06/01/24 12:00 AM | NORMAL |

PERIOD: May 2024

| SENSOR | LABEL | DATE/TIME | STATUS |
|--------|---------------------|-------------------|--------|
| L 1 | DISPENSER 1-2 SUMP | 05/01/24 12:00 AM | NORMAL |
| L 2 | DISPENSER 3-4 SUMP | 05/01/24 12:00 AM | NORMAL |
| L 3 | DISPENSER 5-6 SUMP | 05/01/24 12:00 AM | NORMAL |
| L 4 | DISPENSER 7-8 SUMP | 05/01/24 12:00 AM | NORMAL |
| L 5 | DISPENSER 9-10 SUMP | 05/01/24 12:00 AM | NORMAL |
| L 6 | UNL. SUBPUMP SUMP | 05/01/24 12:00 AM | NORMAL |
| L 7 | PREM. SUBPUMP SUMP | 05/01/24 12:00 AM | NORMAL |
| L 8 | DIESEL SUBPUMP SUMP | 05/01/24 12:00 AM | NORMAL |
| L 10 | PREM FILL SUMP | 05/01/24 12:00 AM | NORMAL |
| L 11 | DIESEL FILL SUMP | 05/01/24 12:00 AM | NORMAL |
| L 12 | TANK INTERSTICE T1 | 05/01/24 12:00 AM | NORMAL |
| L 13 | TANK INTERSTICE T2- | 05/01/24 12:00 AM | NORMAL |

PERIOD: April 2024

| SENSOR | LABEL | DATE/TIME | STATUS |
|--------|---------------------|-------------------|--------|
| L 1 | DISPENSER 1-2 SUMP | 04/01/24 12:00 AM | NORMAL |
| L 2 | DISPENSER 3-4 SUMP | 04/01/24 12:00 AM | NORMAL |
| L 3 | DISPENSER 5-6 SUMP | 04/01/24 12:00 AM | NORMAL |
| L 4 | DISPENSER 7-8 SUMP | 04/01/24 12:00 AM | NORMAL |
| L 5 | DISPENSER 9-10 SUMP | 04/01/24 12:00 AM | NORMAL |
| L 6 | UNL. SUBPUMP SUMP | 04/01/24 12:00 AM | NORMAL |
| L 7 | PREM. SUBPUMP SUMP | 04/01/24 12:00 AM | NORMAL |
| L 8 | DIESEL SUBPUMP SUMP | 04/01/24 12:00 AM | NORMAL |
| L 10 | PREM FILL SUMP | 04/01/24 12:00 AM | NORMAL |
| L 11 | DIESEL FILL SUMP | 04/01/24 12:00 AM | NORMAL |
| L 12 | TANK INTERSTICE T1 | 04/01/24 12:00 AM | NORMAL |
| L 13 | TANK INTERSTICE T2- | 04/01/24 12:00 AM | NORMAL |

PERIOD: March 2024

| SENSOR | LABEL | DATE/TIME | STATUS |
|--------|---------------------|-------------------|--------|
| L 1 | DISPENSER 1-2 SUMP | 03/01/24 12:00 AM | NORMAL |
| L 2 | DISPENSER 3-4 SUMP | 03/01/24 12:00 AM | NORMAL |
| L 3 | DISPENSER 5-6 SUMP | 03/01/24 12:00 AM | NORMAL |
| L 4 | DISPENSER 7-8 SUMP | 03/01/24 12:00 AM | NORMAL |
| L 5 | DISPENSER 9-10 SUMP | 03/01/24 12:00 AM | NORMAL |
| L 6 | UNL. SUBPUMP SUMP | 03/01/24 12:00 AM | NORMAL |
| L 7 | PREM. SUBPUMP SUMP | 03/01/24 12:00 AM | NORMAL |
| L 8 | DIESEL SUBPUMP SUMP | 03/01/24 12:00 AM | NORMAL |
| L 9 | UNL FILL SUMP | 03/01/24 12:00 AM | NORMAL |
| L 10 | PREM FILL SUMP | 03/01/24 12:00 AM | NORMAL |
| L 11 | DIESEL FILL SUMP | 03/01/24 12:00 AM | NORMAL |
| L 12 | TANK INTERSTICE T1 | 03/01/24 12:00 AM | NORMAL |
| L 13 | TANK INTERSTICE T2- | 03/01/24 12:00 AM | NORMAL |

| PERIOD: February 2024 | | DATE/TIME | STATUS |
|-----------------------|---------------------|-------------------|--------|
| SENSOR | LABEL | | |
| L 1 | DISPENSER 1-2 SUMP | 02/01/24 12:00 AM | NORMAL |
| L 2 | DISPENSER 3-4 SUMP | 02/01/24 12:00 AM | NORMAL |
| L 3 | DISPENSER 5-6 SUMP | 02/01/24 12:00 AM | NORMAL |
| L 4 | DISPENSER 7-8 SUMP | 02/01/24 12:00 AM | NORMAL |
| L 5 | DISPENSER 9-10 SUMP | 02/01/24 12:00 AM | NORMAL |
| L 6 | UNL. SUBPUMP SUMP | 02/01/24 12:00 AM | NORMAL |
| L 7 | PREM. SUBPUMP SUMP | 02/01/24 12:00 AM | NORMAL |
| L 8 | DIESEL SUBPUMP SUMP | 02/01/24 12:00 AM | NORMAL |
| L 9 | UNL FILL SUMP | 02/01/24 12:00 AM | NORMAL |
| L 10 | PREM FILL SUMP | 02/01/24 12:00 AM | NORMAL |
| L 11 | DIESEL FILL SUMP | 02/01/24 12:00 AM | NORMAL |
| L 12 | TANK INTERSTICE T1 | 02/01/24 12:00 AM | NORMAL |
| L 13 | TANK INTERSTICE T2- | 02/01/24 12:00 AM | NORMAL |

| PERIOD: January 2024 | | DATE/TIME | STATUS |
|----------------------|---------------------|-------------------|--------|
| SENSOR | LABEL | | |
| L 1 | DISPENSER 1-2 SUMP | 01/01/24 12:00 AM | NORMAL |
| L 2 | DISPENSER 3-4 SUMP | 01/01/24 12:00 AM | NORMAL |
| L 3 | DISPENSER 5-6 SUMP | 01/01/24 12:00 AM | NORMAL |
| L 4 | DISPENSER 7-8 SUMP | 01/01/24 12:00 AM | NORMAL |
| L 5 | DISPENSER 9-10 SUMP | 01/01/24 12:00 AM | NORMAL |
| L 6 | UNL. SUBPUMP SUMP | 01/01/24 12:00 AM | NORMAL |
| L 7 | PREM. SUBPUMP SUMP | 01/01/24 12:00 AM | NORMAL |
| L 8 | DIESEL SUBPUMP SUMP | 01/01/24 12:00 AM | NORMAL |
| L 9 | UNL FILL SUMP | 01/01/24 12:00 AM | NORMAL |
| L 10 | PREM FILL SUMP | 01/01/24 12:00 AM | NORMAL |
| L 11 | DIESEL FILL SUMP | 01/01/24 12:00 AM | NORMAL |
| L 12 | TANK INTERSTICE T1 | 01/01/24 12:00 AM | NORMAL |
| L 13 | TANK INTERSTICE T2- | 01/01/24 12:00 AM | NORMAL |

| PERIOD: December 2023 | | DATE/TIME | STATUS |
|-----------------------|---------------------|-------------------|--------|
| SENSOR | LABEL | | |
| L 1 | DISPENSER 1-2 SUMP | 12/01/23 12:00 AM | NORMAL |
| L 2 | DISPENSER 3-4 SUMP | 12/01/23 12:00 AM | NORMAL |
| L 3 | DISPENSER 5-6 SUMP | 12/01/23 12:00 AM | NORMAL |
| L 4 | DISPENSER 7-8 SUMP | 12/01/23 12:00 AM | NORMAL |
| L 5 | DISPENSER 9-10 SUMP | 12/01/23 12:00 AM | NORMAL |
| L 6 | UNL. SUBPUMP SUMP | 12/01/23 12:00 AM | NORMAL |
| L 7 | PREM. SUBPUMP SUMP | 12/01/23 12:00 AM | NORMAL |
| L 8 | DIESEL SUBPUMP SUMP | 12/01/23 12:00 AM | NORMAL |
| L 9 | UNL FILL SUMP | 12/01/23 12:00 AM | NORMAL |
| L 10 | PREM FILL SUMP | 12/01/23 12:00 AM | NORMAL |
| L 11 | DIESEL FILL SUMP | 12/01/23 12:00 AM | NORMAL |
| L 12 | TANK INTERSTICE T1 | 12/01/23 12:00 AM | NORMAL |
| L 13 | TANK INTERSTICE T2- | 12/01/23 12:00 AM | NORMAL |

| PERIOD: November 2023 | | DATE/TIME | STATUS |
|-----------------------|---------------------|-------------------|--------|
| SENSOR | LABEL | | |
| L 1 | DISPENSER 1-2 SUMP | 11/01/23 12:00 AM | NORMAL |
| L 2 | DISPENSER 3-4 SUMP | 11/01/23 12:00 AM | NORMAL |
| L 3 | DISPENSER 5-6 SUMP | 11/01/23 12:00 AM | NORMAL |
| L 4 | DISPENSER 7-8 SUMP | 11/01/23 12:00 AM | NORMAL |
| L 5 | DISPENSER 9-10 SUMP | 11/01/23 12:00 AM | NORMAL |
| L 6 | UNL. SUBPUMP SUMP | 11/01/23 12:00 AM | NORMAL |
| L 7 | PREM. SUBPUMP SUMP | 11/01/23 12:00 AM | NORMAL |
| L 8 | DIESEL SUBPUMP SUMP | 11/01/23 12:00 AM | NORMAL |
| L 9 | UNL FILL SUMP | 11/01/23 12:00 AM | NORMAL |
| L 10 | PREM FILL SUMP | 11/01/23 12:00 AM | NORMAL |
| L 11 | DIESEL FILL SUMP | 11/01/23 12:00 AM | NORMAL |
| L 12 | TANK INTERSTICE T1 | 11/01/23 12:00 AM | NORMAL |
| L 13 | TANK INTERSTICE T2- | 11/01/23 12:00 AM | NORMAL |

| PERIOD: October 2023 | | DATE/TIME | STATUS |
|----------------------|---------------------|-------------------|--------|
| SENSOR | LABEL | | |
| L 1 | DISPENSER 1-2 SUMP | 10/01/23 12:00 AM | NORMAL |
| L 2 | DISPENSER 3-4 SUMP | 10/01/23 12:00 AM | NORMAL |
| L 3 | DISPENSER 5-6 SUMP | 10/01/23 12:00 AM | NORMAL |
| L 4 | DISPENSER 7-8 SUMP | 10/01/23 12:00 AM | NORMAL |
| L 5 | DISPENSER 9-10 SUMP | 10/01/23 12:00 AM | NORMAL |
| L 6 | UNL. SUBPUMP SUMP | 10/01/23 12:00 AM | NORMAL |
| L 7 | PREM. SUBPUMP SUMP | 10/01/23 12:00 AM | NORMAL |
| L 8 | DIESEL SUBPUMP SUMP | 10/01/23 12:00 AM | NORMAL |
| L 9 | UNL FILL SUMP | 10/01/23 12:00 AM | NORMAL |
| L 10 | PREM FILL SUMP | 10/01/23 12:00 AM | NORMAL |
| L 11 | DIESEL FILL SUMP | 10/01/23 12:00 AM | NORMAL |
| L 12 | TANK INTERSTICE T1 | 10/01/23 12:00 AM | NORMAL |
| L 13 | TANK INTERSTICE T2- | 10/01/23 12:00 AM | NORMAL |

PERIOD: September 2023

| SENSOR | LABEL | DATE/TIME | STATUS |
|--------|---------------------|-------------------|--------|
| L 1 | DISPENSER 1-2 SUMP | 09/01/23 12:00 AM | NORMAL |
| L 2 | DISPENSER 3-4 SUMP | 09/01/23 12:00 AM | NORMAL |
| L 3 | DISPENSER 5-6 SUMP | 09/01/23 12:00 AM | NORMAL |
| L 4 | DISPENSER 7-8 SUMP | 09/01/23 12:00 AM | NORMAL |
| L 5 | DISPENSER 9-10 SUMP | 09/01/23 12:00 AM | NORMAL |
| L 6 | UNL. SUBPUMP SUMP | 09/01/23 12:00 AM | NORMAL |
| L 7 | PREM. SUBPUMP SUMP | 09/01/23 12:00 AM | NORMAL |
| L 8 | DIESEL SUBPUMP SUMP | 09/01/23 12:00 AM | NORMAL |
| L 9 | UNL FILL SUMP | 09/01/23 12:00 AM | NORMAL |
| L 10 | PREM FILL SUMP | 09/01/23 12:00 AM | NORMAL |
| L 11 | DIESEL FILL SUMP | 09/01/23 12:00 AM | NORMAL |
| L 12 | TANK INTERSTICE T1 | 09/01/23 12:00 AM | NORMAL |
| L 13 | TANK INTERSTICE T2- | 09/01/23 12:00 AM | NORMAL |

PERIOD: August 2023

| SENSOR | LABEL | DATE/TIME | STATUS |
|--------|---------------------|-------------------|--------|
| L 1 | DISPENSER 1-2 SUMP | 08/01/23 12:00 AM | NORMAL |
| L 2 | DISPENSER 3-4 SUMP | 08/01/23 12:00 AM | NORMAL |
| L 3 | DISPENSER 5-6 SUMP | 08/01/23 12:00 AM | NORMAL |
| L 4 | DISPENSER 7-8 SUMP | 08/01/23 12:00 AM | NORMAL |
| L 5 | DISPENSER 9-10 SUMP | 08/01/23 12:00 AM | NORMAL |
| L 6 | UNL. SUBPUMP SUMP | 08/01/23 12:00 AM | NORMAL |
| L 7 | PREM. SUBPUMP SUMP | 08/01/23 12:00 AM | NORMAL |
| L 8 | DIESEL SUBPUMP SUMP | 08/01/23 12:00 AM | NORMAL |
| L 9 | UNL FILL SUMP | 08/01/23 12:00 AM | NORMAL |
| L 10 | PREM FILL SUMP | 08/01/23 12:00 AM | NORMAL |
| L 11 | DIESEL FILL SUMP | 08/01/23 12:00 AM | NORMAL |
| L 12 | TANK INTERSTICE T1 | 08/01/23 12:00 AM | NORMAL |
| L 13 | TANK INTERSTICE T2- | 08/01/23 12:00 AM | NORMAL |

PERIOD: July 2023

| SENSOR | LABEL | DATE/TIME | STATUS |
|--------|---------------------|-------------------|--------|
| L 1 | DISPENSER 1-2 SUMP | 07/01/23 12:00 AM | NORMAL |
| L 2 | DISPENSER 3-4 SUMP | 07/01/23 12:00 AM | NORMAL |
| L 3 | DISPENSER 5-6 SUMP | 07/01/23 12:00 AM | NORMAL |
| L 4 | DISPENSER 7-8 SUMP | 07/01/23 12:00 AM | NORMAL |
| L 5 | DISPENSER 9-10 SUMP | 07/01/23 12:00 AM | NORMAL |
| L 6 | UNL. SUBPUMP SUMP | 07/01/23 12:00 AM | NORMAL |
| L 7 | PREM. SUBPUMP SUMP | 07/01/23 12:00 AM | NORMAL |
| L 8 | DIESEL SUBPUMP SUMP | 07/01/23 12:00 AM | NORMAL |
| L 9 | UNL FILL SUMP | 07/01/23 12:00 AM | NORMAL |
| L 10 | PREM FILL SUMP | 07/01/23 12:00 AM | NORMAL |
| L 11 | DIESEL FILL SUMP | 07/01/23 12:00 AM | NORMAL |
| L 12 | TANK INTERSTICE T1 | 07/01/23 12:00 AM | NORMAL |
| L 13 | TANK INTERSTICE T2- | 07/01/23 12:00 AM | NORMAL |

06/25/24 10:19 AM

KROGER J-405
4210 N Clinton St.
FT Wayne, In.
SER# P08233533205001

PRESSURE LINE LEAK REPORTS
PASSED TESTS HISTORY

Ln 1: Unleaded

Gross Test
Prev 24 Hours 137
Since Midnight 34

Last Gross 06/25/24 10:15 AM
Last Periodic 06/24/24 11:34 PM
First Periodic 06/01/24 11:26 PM

Ln 2: Premium

Gross Test
Prev 24 Hours 32
Since Midnight 7

Last Gross 06/25/24 10:00 AM
Last Periodic 06/25/24 9:30 AM
First Periodic 06/01/24 11:29 AM

Ln 3: Diesel

Gross Test
Prev 24 Hours 3
Since Midnight 0

Last Gross 06/24/24 3:44 PM
Last Periodic 06/24/24 12:50 PM
First Periodic 06/01/24 6:40 PM

Kroger Compliance Test

210405

| Site Name | Line Leak Sensor Number | Label | Leak Test Date Time | DIY Collection Date Time | Line Test Type Description | Line Leak Detection Type Description | Line Test Results Description |
|-----------|-------------------------|------------|------------------------|--------------------------|----------------------------|--------------------------------------|-------------------------------|
| 210405 | | 3 Diesel | 6/30/2023 8:39:00 PM | 7/1/2023 3:31:28 AM | 3.0 | PLLD | PASS |
| 210405 | | 3 Diesel | 7/31/2023 8:50:00 PM | 8/1/2023 3:30:14 AM | 3.0 | PLLD | PASS |
| 210405 | | 3 Diesel | 8/31/2023 1:12:00 PM | 9/1/2023 3:30:12 AM | 3.0 | PLLD | PASS |
| 210405 | | 3 Diesel | 9/30/2023 6:40:00 PM | 10/1/2023 3:30:09 AM | 3.0 | PLLD | PASS |
| 210405 | | 3 Diesel | 10/31/2023 8:41:00 PM | 11/1/2023 3:30:11 AM | 3.0 | PLLD | PASS |
| 210405 | | 3 Diesel | 11/30/2023 5:55:00 PM | 12/1/2023 4:30:12 AM | 3.0 | PLLD | PASS |
| 210405 | | 3 Diesel | 12/30/2023 9:37:00 PM | 12/31/2023 4:30:09 AM | 3.0 | PLLD | PASS |
| 210405 | | 3 Diesel | 1/31/2024 8:35:00 PM | 2/1/2024 4:30:11 AM | 3.0 | PLLD | PASS |
| 210405 | | 3 Diesel | 2/29/2024 9:16:00 PM | 3/1/2024 4:30:14 AM | 3.0 | PLLD | PASS |
| 210405 | | 3 Diesel | 3/31/2024 9:44:00 PM | 4/1/2024 3:30:12 AM | 3.0 | PLLD | PASS |
| 210405 | | 3 Diesel | 4/30/2024 9:28:00 PM | 5/1/2024 3:30:14 AM | 3.0 | PLLD | PASS |
| 210405 | | 3 Diesel | 5/13/2024 7:28:00 PM | 5/14/2024 3:30:16 AM | 3.0 | PLLD | PASS |
| 210405 | | 2 Premium | 6/30/2023 10:39:00 PM | 7/1/2023 3:31:28 AM | 3.0 | PLLD | PASS |
| 210405 | | 2 Premium | 7/31/2023 9:20:00 PM | 8/1/2023 3:30:14 AM | 3.0 | PLLD | PASS |
| 210405 | | 2 Premium | 8/31/2023 10:40:00 PM | 9/1/2023 3:30:12 AM | 3.0 | PLLD | PASS |
| 210405 | | 2 Premium | 9/30/2023 11:55:00 PM | 10/1/2023 3:30:09 AM | 3.0 | PLLD | PASS |
| 210405 | | 2 Premium | 10/30/2023 9:01:00 PM | 10/31/2023 3:30:14 AM | 3.0 | PLLD | PASS |
| 210405 | | 2 Premium | 11/30/2023 10:59:00 PM | 12/1/2023 4:30:12 AM | 3.0 | PLLD | PASS |
| 210405 | | 2 Premium | 12/30/2023 9:55:00 PM | 12/31/2023 4:30:09 AM | 3.0 | PLLD | PASS |
| 210405 | | 2 Premium | 1/31/2024 10:38:00 PM | 2/1/2024 4:30:11 AM | 3.0 | PLLD | PASS |
| 210405 | | 2 Premium | 2/29/2024 10:33:00 PM | 3/1/2024 4:30:14 AM | 3.0 | PLLD | PASS |
| 210405 | | 2 Premium | 3/31/2024 10:30:00 PM | 4/1/2024 3:30:12 AM | 3.0 | PLLD | PASS |
| 210405 | | 2 Premium | 4/30/2024 10:48:00 PM | 5/1/2024 3:30:14 AM | 3.0 | PLLD | PASS |
| 210405 | | 2 Premium | 5/13/2024 10:45:00 PM | 5/14/2024 3:30:16 AM | 3.0 | PLLD | PASS |
| 210405 | | 1 Unleaded | 6/30/2023 1:04:00 AM | 6/30/2023 3:33:16 AM | 3.0 | PLLD | PASS |
| 210405 | | 1 Unleaded | 7/31/2023 3:12:00 AM | 7/31/2023 3:30:13 AM | 3.0 | PLLD | PASS |
| 210405 | | 1 Unleaded | 8/31/2023 11:45:00 PM | 9/1/2023 3:30:12 AM | 3.0 | PLLD | PASS |
| 210405 | | 1 Unleaded | 9/30/2023 10:50:00 PM | 10/1/2023 3:30:09 AM | 3.0 | PLLD | PASS |
| 210405 | | 1 Unleaded | 10/31/2023 12:41:00 AM | 10/31/2023 3:30:14 AM | 3.0 | PLLD | PASS |
| 210405 | | 1 Unleaded | 11/29/2023 11:16:00 PM | 11/30/2023 4:30:15 AM | 3.0 | PLLD | PASS |
| 210405 | | 1 Unleaded | 12/31/2023 1:20:00 AM | 12/31/2023 4:30:09 AM | 3.0 | PLLD | PASS |
| 210405 | | 1 Unleaded | 1/31/2024 2:13:00 AM | 1/31/2024 4:30:15 AM | 3.0 | PLLD | PASS |
| 210405 | | 1 Unleaded | 2/29/2024 12:36:00 AM | 2/29/2024 4:30:11 AM | 3.0 | PLLD | PASS |
| 210405 | | 1 Unleaded | 3/31/2024 11:13:00 PM | 4/1/2024 3:30:12 AM | 3.0 | PLLD | PASS |
| 210405 | | 1 Unleaded | 4/30/2024 2:10:00 AM | 4/30/2024 3:30:11 AM | 3.0 | PLLD | PASS |
| 210405 | | 1 Unleaded | 5/14/2024 3:14:00 AM | 5/14/2024 3:30:16 AM | 3.0 | PLLD | PASS |

Kroger Sensor Status Report

210405

| Site Name | Sensor Number | Sensor Description | Test Date Time | Sensor Status Description |
|-----------|---------------|--------------------|-----------------------|---------------------------|
| 210405 | 1 | DISPENSER 1-2 SUMP | 6/30/2023 4:15:00 AM | Sensor Normal |
| 210405 | 1 | DISPENSER 1-2 SUMP | 7/31/2023 4:13:00 AM | Sensor Normal |
| 210405 | 1 | DISPENSER 1-2 SUMP | 8/31/2023 4:12:00 AM | Sensor Normal |
| 210405 | 1 | DISPENSER 1-2 SUMP | 9/30/2023 4:12:00 AM | Sensor Normal |
| 210405 | 1 | DISPENSER 1-2 SUMP | 10/31/2023 4:11:00 AM | Sensor Normal |
| 210405 | 1 | DISPENSER 1-2 SUMP | 11/30/2023 4:10:00 AM | Sensor Normal |
| 210405 | 1 | DISPENSER 1-2 SUMP | 12/31/2023 4:16:00 AM | Sensor Normal |
| 210405 | 1 | DISPENSER 1-2 SUMP | 1/31/2024 4:17:00 AM | Sensor Normal |
| 210405 | 1 | DISPENSER 1-2 SUMP | 2/29/2024 4:17:00 AM | Sensor Normal |
| 210405 | 1 | DISPENSER 1-2 SUMP | 3/31/2024 4:16:00 AM | Sensor Normal |
| 210405 | 1 | DISPENSER 1-2 SUMP | 4/30/2024 4:15:00 AM | Sensor Normal |
| 210405 | 1 | DISPENSER 1-2 SUMP | 5/14/2024 4:14:00 AM | Sensor Normal |
| 210405 | 2 | DISPENSER 3-4 SUMP | 6/30/2023 4:15:00 AM | Sensor Normal |
| 210405 | 2 | DISPENSER 3-4 SUMP | 7/31/2023 4:13:00 AM | Sensor Normal |
| 210405 | 2 | DISPENSER 3-4 SUMP | 8/31/2023 4:12:00 AM | Sensor Normal |
| 210405 | 2 | DISPENSER 3-4 SUMP | 9/30/2023 4:12:00 AM | Sensor Normal |
| 210405 | 2 | DISPENSER 3-4 SUMP | 10/31/2023 4:11:00 AM | Sensor Normal |
| 210405 | 2 | DISPENSER 3-4 SUMP | 11/30/2023 4:10:00 AM | Sensor Normal |
| 210405 | 2 | DISPENSER 3-4 SUMP | 12/31/2023 4:16:00 AM | Sensor Normal |
| 210405 | 2 | DISPENSER 3-4 SUMP | 1/31/2024 4:17:00 AM | Sensor Normal |
| 210405 | 2 | DISPENSER 3-4 SUMP | 2/29/2024 4:17:00 AM | Sensor Normal |
| 210405 | 2 | DISPENSER 3-4 SUMP | 3/31/2024 4:16:00 AM | Sensor Normal |
| 210405 | 2 | DISPENSER 3-4 SUMP | 4/30/2024 4:15:00 AM | Sensor Normal |
| 210405 | 2 | DISPENSER 3-4 SUMP | 5/14/2024 4:14:00 AM | Sensor Normal |
| 210405 | 3 | DISPENSER 5-6 SUMP | 6/30/2023 4:15:00 AM | Sensor Normal |
| 210405 | 3 | DISPENSER 5-6 SUMP | 7/31/2023 4:13:00 AM | Sensor Normal |
| 210405 | 3 | DISPENSER 5-6 SUMP | 8/31/2023 4:12:00 AM | Sensor Normal |
| 210405 | 3 | DISPENSER 5-6 SUMP | 9/30/2023 4:12:00 AM | Sensor Normal |
| 210405 | 3 | DISPENSER 5-6 SUMP | 10/31/2023 4:11:00 AM | Sensor Normal |
| 210405 | 3 | DISPENSER 5-6 SUMP | 11/30/2023 4:10:00 AM | Sensor Normal |
| 210405 | 3 | DISPENSER 5-6 SUMP | 12/31/2023 4:16:00 AM | Sensor Normal |
| 210405 | 3 | DISPENSER 5-6 SUMP | 1/31/2024 4:17:00 AM | Sensor Normal |
| 210405 | 3 | DISPENSER 5-6 SUMP | 2/29/2024 4:17:00 AM | Sensor Normal |
| 210405 | 3 | DISPENSER 5-6 SUMP | 3/31/2024 4:16:00 AM | Sensor Normal |
| 210405 | 3 | DISPENSER 5-6 SUMP | 4/30/2024 4:15:00 AM | Sensor Normal |
| 210405 | 3 | DISPENSER 5-6 SUMP | 5/14/2024 4:14:00 AM | Sensor Normal |
| 210405 | 4 | DISPENSER 7-8 SUMP | 6/30/2023 4:15:00 AM | Sensor Normal |
| 210405 | 4 | DISPENSER 7-8 SUMP | 7/31/2023 4:13:00 AM | Sensor Normal |
| 210405 | 4 | DISPENSER 7-8 SUMP | 8/31/2023 4:12:00 AM | Sensor Normal |

| Site Name | Sensor Number | Sensor Description | Test Date Time | Sensor Status Description |
|-----------|---------------|---------------------|-----------------------|---------------------------|
| 210405 | 4 | DISPENSER 7-8 SUMP | 9/30/2023 4:12:00 AM | Sensor Normal |
| 210405 | 4 | DISPENSER 7-8 SUMP | 10/31/2023 4:11:00 AM | Sensor Normal |
| 210405 | 4 | DISPENSER 7-8 SUMP | 11/30/2023 4:10:00 AM | Sensor Normal |
| 210405 | 4 | DISPENSER 7-8 SUMP | 12/31/2023 4:16:00 AM | Sensor Normal |
| 210405 | 4 | DISPENSER 7-8 SUMP | 1/31/2024 4:17:00 AM | Sensor Normal |
| 210405 | 4 | DISPENSER 7-8 SUMP | 2/29/2024 4:17:00 AM | Sensor Normal |
| 210405 | 4 | DISPENSER 7-8 SUMP | 3/31/2024 4:16:00 AM | Sensor Normal |
| 210405 | 4 | DISPENSER 7-8 SUMP | 4/30/2024 4:15:00 AM | Sensor Normal |
| 210405 | 4 | DISPENSER 7-8 SUMP | 5/14/2024 4:14:00 AM | Sensor Normal |
| 210405 | 5 | DISPENSER 9-10 SUMP | 6/30/2023 4:15:00 AM | Sensor Normal |
| 210405 | 5 | DISPENSER 9-10 SUMP | 7/31/2023 4:13:00 AM | Sensor Normal |
| 210405 | 5 | DISPENSER 9-10 SUMP | 8/31/2023 4:12:00 AM | Sensor Normal |
| 210405 | 5 | DISPENSER 9-10 SUMP | 9/30/2023 4:12:00 AM | Sensor Normal |
| 210405 | 5 | DISPENSER 9-10 SUMP | 10/31/2023 4:11:00 AM | Sensor Normal |
| 210405 | 5 | DISPENSER 9-10 SUMP | 11/30/2023 4:10:00 AM | Sensor Normal |
| 210405 | 5 | DISPENSER 9-10 SUMP | 12/31/2023 4:16:00 AM | Sensor Normal |
| 210405 | 5 | DISPENSER 9-10 SUMP | 1/31/2024 4:17:00 AM | Sensor Normal |
| 210405 | 5 | DISPENSER 9-10 SUMP | 2/29/2024 4:17:00 AM | Sensor Normal |
| 210405 | 5 | DISPENSER 9-10 SUMP | 3/31/2024 4:16:00 AM | Sensor Normal |
| 210405 | 5 | DISPENSER 9-10 SUMP | 4/30/2024 4:15:00 AM | Sensor Normal |
| 210405 | 5 | DISPENSER 9-10 SUMP | 5/14/2024 4:14:00 AM | Sensor Normal |
| 210405 | 6 | UNL. SUBPUMP SUMP | 6/30/2023 4:15:00 AM | Sensor Normal |
| 210405 | 6 | UNL. SUBPUMP SUMP | 7/31/2023 4:13:00 AM | Sensor Normal |
| 210405 | 6 | UNL. SUBPUMP SUMP | 8/31/2023 4:12:00 AM | Sensor Normal |
| 210405 | 6 | UNL. SUBPUMP SUMP | 9/30/2023 4:12:00 AM | Sensor Normal |
| 210405 | 6 | UNL. SUBPUMP SUMP | 10/31/2023 4:11:00 AM | Sensor Normal |
| 210405 | 6 | UNL. SUBPUMP SUMP | 11/30/2023 4:10:00 AM | Sensor Normal |
| 210405 | 6 | UNL. SUBPUMP SUMP | 12/31/2023 4:16:00 AM | Sensor Normal |
| 210405 | 6 | UNL. SUBPUMP SUMP | 1/31/2024 4:17:00 AM | Sensor Normal |
| 210405 | 6 | UNL. SUBPUMP SUMP | 2/29/2024 4:17:00 AM | Sensor Normal |
| 210405 | 6 | UNL. SUBPUMP SUMP | 3/31/2024 4:16:00 AM | Sensor Normal |
| 210405 | 6 | UNL. SUBPUMP SUMP | 4/30/2024 4:15:00 AM | Sensor Normal |
| 210405 | 6 | UNL. SUBPUMP SUMP | 5/14/2024 4:14:00 AM | Sensor Normal |
| 210405 | 7 | PREM. SUBPUMP SUMP | 6/30/2023 4:15:00 AM | Sensor Normal |
| 210405 | 7 | PREM. SUBPUMP SUMP | 7/31/2023 4:13:00 AM | Sensor Normal |
| 210405 | 7 | PREM. SUBPUMP SUMP | 8/31/2023 4:12:00 AM | Sensor Normal |
| 210405 | 7 | PREM. SUBPUMP SUMP | 9/30/2023 4:12:00 AM | Sensor Normal |
| 210405 | 7 | PREM. SUBPUMP SUMP | 10/31/2023 4:11:00 AM | Sensor Normal |
| 210405 | 7 | PREM. SUBPUMP SUMP | 11/30/2023 4:10:00 AM | Sensor Normal |
| 210405 | 7 | PREM. SUBPUMP SUMP | 12/31/2023 4:16:00 AM | Sensor Normal |
| 210405 | 7 | PREM. SUBPUMP SUMP | 1/31/2024 4:17:00 AM | Sensor Normal |
| 210405 | 7 | PREM. SUBPUMP SUMP | 2/29/2024 4:17:00 AM | Sensor Normal |
| 210405 | 7 | PREM. SUBPUMP SUMP | 3/31/2024 4:16:00 AM | Sensor Normal |

| Site Name | Sensor Number | Sensor Description | Test Date Time | Sensor Status Description |
|-----------|---------------|---------------------|-----------------------|---------------------------|
| 210405 | 7 | PREM. SUBPUMP SUMP | 4/30/2024 4:15:00 AM | Sensor Normal |
| 210405 | 7 | PREM. SUBPUMP SUMP | 5/14/2024 4:14:00 AM | Sensor Normal |
| 210405 | 8 | DIESEL SUBPUMP SUMP | 6/30/2023 4:15:00 AM | Sensor Normal |
| 210405 | 8 | DIESEL SUBPUMP SUMP | 7/31/2023 4:13:00 AM | Sensor Normal |
| 210405 | 8 | DIESEL SUBPUMP SUMP | 8/31/2023 4:12:00 AM | Sensor Normal |
| 210405 | 8 | DIESEL SUBPUMP SUMP | 9/30/2023 4:12:00 AM | Sensor Normal |
| 210405 | 8 | DIESEL SUBPUMP SUMP | 10/31/2023 4:11:00 AM | Sensor Normal |
| 210405 | 8 | DIESEL SUBPUMP SUMP | 11/30/2023 4:10:00 AM | Sensor Normal |
| 210405 | 8 | DIESEL SUBPUMP SUMP | 12/31/2023 4:16:00 AM | Sensor Normal |
| 210405 | 8 | DIESEL SUBPUMP SUMP | 1/31/2024 4:17:00 AM | Sensor Normal |
| 210405 | 8 | DIESEL SUBPUMP SUMP | 2/29/2024 4:17:00 AM | Sensor Normal |
| 210405 | 8 | DIESEL SUBPUMP SUMP | 3/31/2024 4:16:00 AM | Sensor Normal |
| 210405 | 8 | DIESEL SUBPUMP SUMP | 4/30/2024 4:15:00 AM | Sensor Normal |
| 210405 | 8 | DIESEL SUBPUMP SUMP | 5/14/2024 4:14:00 AM | Sensor Normal |
| 210405 | 9 | UNL FILL SUMP | 4/30/2023 4:16:00 AM | Sensor Normal |
| 210405 | 9 | UNL FILL SUMP | 5/31/2023 4:15:00 AM | Sensor Normal |
| 210405 | 9 | UNL FILL SUMP | 6/30/2023 4:15:00 AM | Sensor Normal |
| 210405 | 9 | UNL FILL SUMP | 7/31/2023 4:13:00 AM | Sensor Normal |
| 210405 | 9 | UNL FILL SUMP | 8/31/2023 4:12:00 AM | Sensor Normal |
| 210405 | 9 | UNL FILL SUMP | 9/30/2023 4:12:00 AM | Sensor Normal |
| 210405 | 9 | UNL FILL SUMP | 10/31/2023 4:11:00 AM | Sensor Normal |
| 210405 | 9 | UNL FILL SUMP | 11/30/2023 4:10:00 AM | Sensor Normal |
| 210405 | 9 | UNL FILL SUMP | 12/31/2023 4:16:00 AM | Sensor Normal |
| 210405 | 9 | UNL FILL SUMP | 1/31/2024 4:17:00 AM | Sensor Normal |
| 210405 | 9 | UNL FILL SUMP | 2/29/2024 4:17:00 AM | Sensor Normal |
| 210405 | 9 | UNL FILL SUMP | 3/14/2024 4:16:00 AM | Sensor Normal |
| 210405 | 10 | PREM FILL SUMP | 6/30/2023 4:15:00 AM | Sensor Normal |
| 210405 | 10 | PREM FILL SUMP | 7/31/2023 4:13:00 AM | Sensor Normal |
| 210405 | 10 | PREM FILL SUMP | 8/31/2023 4:12:00 AM | Sensor Normal |
| 210405 | 10 | PREM FILL SUMP | 9/30/2023 4:12:00 AM | Sensor Normal |
| 210405 | 10 | PREM FILL SUMP | 10/31/2023 4:11:00 AM | Sensor Normal |
| 210405 | 10 | PREM FILL SUMP | 11/30/2023 4:10:00 AM | Sensor Normal |
| 210405 | 10 | PREM FILL SUMP | 12/31/2023 4:16:00 AM | Sensor Normal |
| 210405 | 10 | PREM FILL SUMP | 1/31/2024 4:17:00 AM | Sensor Normal |
| 210405 | 10 | PREM FILL SUMP | 2/29/2024 4:17:00 AM | Sensor Normal |
| 210405 | 10 | PREM FILL SUMP | 3/31/2024 4:16:00 AM | Sensor Normal |
| 210405 | 10 | PREM FILL SUMP | 4/30/2024 4:15:00 AM | Sensor Normal |
| 210405 | 10 | PREM FILL SUMP | 5/14/2024 4:14:00 AM | Sensor Normal |
| 210405 | 11 | DIESEL FILL SUMP | 6/30/2023 4:15:00 AM | Sensor Normal |
| 210405 | 11 | DIESEL FILL SUMP | 7/31/2023 4:13:00 AM | Sensor Normal |
| 210405 | 11 | DIESEL FILL SUMP | 8/31/2023 4:12:00 AM | Sensor Normal |
| 210405 | 11 | DIESEL FILL SUMP | 9/30/2023 4:12:00 AM | Sensor Normal |
| 210405 | 11 | DIESEL FILL SUMP | 10/31/2023 4:11:00 AM | Sensor Normal |

| Site Name | Sensor Number | Sensor Description | Test Date Time | Sensor Status Description |
|-----------|---------------|----------------------|-----------------------|---------------------------|
| 210405 | 11 | DIESEL FILL SUMP | 11/30/2023 4:10:00 AM | Sensor Normal |
| 210405 | 11 | DIESEL FILL SUMP | 12/31/2023 4:16:00 AM | Sensor Normal |
| 210405 | 11 | DIESEL FILL SUMP | 1/31/2024 4:17:00 AM | Sensor Normal |
| 210405 | 11 | DIESEL FILL SUMP | 2/29/2024 4:17:00 AM | Sensor Normal |
| 210405 | 11 | DIESEL FILL SUMP | 3/31/2024 4:16:00 AM | Sensor Normal |
| 210405 | 11 | DIESEL FILL SUMP | 4/30/2024 4:15:00 AM | Sensor Normal |
| 210405 | 11 | DIESEL FILL SUMP | 5/14/2024 4:14:00 AM | Sensor Normal |
| 210405 | 12 | TANK INTERSTICE T1 | 6/30/2023 4:15:00 AM | Sensor Normal |
| 210405 | 12 | TANK INTERSTICE T1 | 7/31/2023 4:13:00 AM | Sensor Normal |
| 210405 | 12 | TANK INTERSTICE T1 | 8/31/2023 4:12:00 AM | Sensor Normal |
| 210405 | 12 | TANK INTERSTICE T1 | 9/30/2023 4:12:00 AM | Sensor Normal |
| 210405 | 12 | TANK INTERSTICE T1 | 10/31/2023 4:11:00 AM | Sensor Normal |
| 210405 | 12 | TANK INTERSTICE T1 | 11/30/2023 4:10:00 AM | Sensor Normal |
| 210405 | 12 | TANK INTERSTICE T1 | 12/31/2023 4:16:00 AM | Sensor Normal |
| 210405 | 12 | TANK INTERSTICE T1 | 1/31/2024 4:17:00 AM | Sensor Normal |
| 210405 | 12 | TANK INTERSTICE T1 | 2/29/2024 4:17:00 AM | Sensor Normal |
| 210405 | 12 | TANK INTERSTICE T1 | 3/31/2024 4:16:00 AM | Sensor Normal |
| 210405 | 12 | TANK INTERSTICE T1 | 4/30/2024 4:15:00 AM | Sensor Normal |
| 210405 | 12 | TANK INTERSTICE T1 | 5/14/2024 4:14:00 AM | Sensor Normal |
| 210405 | 13 | TANK INTERSTICE T2-3 | 6/30/2023 4:15:00 AM | Sensor Normal |
| 210405 | 13 | TANK INTERSTICE T2-3 | 7/31/2023 4:13:00 AM | Sensor Normal |
| 210405 | 13 | TANK INTERSTICE T2-3 | 8/31/2023 4:12:00 AM | Sensor Normal |
| 210405 | 13 | TANK INTERSTICE T2-3 | 9/30/2023 4:12:00 AM | Sensor Normal |
| 210405 | 13 | TANK INTERSTICE T2-3 | 10/31/2023 4:11:00 AM | Sensor Normal |
| 210405 | 13 | TANK INTERSTICE T2-3 | 11/30/2023 4:10:00 AM | Sensor Normal |
| 210405 | 13 | TANK INTERSTICE T2-3 | 12/31/2023 4:16:00 AM | Sensor Normal |
| 210405 | 13 | TANK INTERSTICE T2-3 | 1/31/2024 4:17:00 AM | Sensor Normal |
| 210405 | 13 | TANK INTERSTICE T2-3 | 2/29/2024 4:17:00 AM | Sensor Normal |
| 210405 | 13 | TANK INTERSTICE T2-3 | 3/31/2024 4:16:00 AM | Sensor Normal |
| 210405 | 13 | TANK INTERSTICE T2-3 | 4/30/2024 4:15:00 AM | Sensor Normal |
| 210405 | 13 | TANK INTERSTICE T2-3 | 5/14/2024 4:14:00 AM | Sensor Normal |

Automatic Tank Gauge Operation Inspection

Main Office
4422 Earth Drive
Fort Wayne, IN 46809
(260) 747-5088



Branch
4389 W. 96th Street
Indianapolis, IN 46268
(317) 876-8856

www.gasolineequipment.com

Ref RP1200-19 Appendix A-6

| | |
|---|---------------------------------------|
| Name: Kroger #405 Fort Wayne | Owner: Kroger foods |
| Address: 4210 N Clinton str | |
| City, State, Zip Code: Fort Wayne, IN 46805 | |
| Facility I.D. #: | Phone #: 260-747-4161 Date: 1/30/2024 |

Testing Company: Gasoline Equipment Service 4422 Earth Drive, Fort Wayne, IN 46809
 This procedure is to determine whether the automatic tank gauge (ATG) is operating properly. See PEI/RP1200 Section 8.2 for the inspection procedure.
 This procedure is applicable to tank level monitor stems that touch the bottom of the tank when in place.

| Tank Number | 1 | 2 | 3 |
|---|---------------------|---------------------|---------------------|
| Product Stored | Unlead | Premium | Diesel |
| ATG Brand and Model | Veeder root tls 450 | Veeder root tls 450 | Veeder root tls 450 |
| 1. Tank Volume, gallons | 19782 | 7901 | 10420 |
| 2. Tank Diameter, inches | 118.4 | 118.4 | 118.4 |
| 3. After removing the ATG from the tank, it has been inspected and any damaged or missing parts replaced? Y/N | Y | Y | Y |
| 4. Float moves freely on the stem without binding? Y/N | Y | Y | Y |
| 5. Fuel float level agrees with the value programmed into the console? Y/N | Y | Y | Y |
| 6. Water float level agrees with the value programmed into the console? Y/N | Y | Y | Y |
| 7. Inch level from bottom of stem when 90% alarm is triggered. | 99-1/2" | 99-3/4" | 98-1/2" |
| 8. Inch level at which the overfill alarm activates corresponds with value programmed in the gauge? Y/N | Y | Y | Y |
| 9. Inch level from the bottom when the water float first triggers an alarm. | 1" | 1" | 1" |
| 10. Inch level at which the water float alarm activates corresponds with value programmed in the gauge? Y/N | Y | Y | Y |
| Test Results | PASS | PASS | PASS |

If any answers in Lines 3, 4, 5, or 6 are "No," the system has failed the test.

Tester Signature James Rattle

UST License # UC2018IN12489

LIQUID SENSOR FUNCTIONALITY TESTING

Main Office
4422 Earth Drive
Fort Wayne, IN 46809
(260) 747-5088



www.gasolineequipment.com

Branch
4389 W. 96th Street
Indianapolis, IN 46268
(317) 876-8856

| | | | | | | | | |
|---|--|--------------------|--------------------|------------------------|--------------------|--------------------|--------------------|--------------------|
| Facility Name: | Kroger #405 Fort Wayne | | | Owner: | Kroger foods | | | |
| Address: | 4210 N Clinton str | | | Address: | | | | |
| City, State, Zip Code: | Fort Wayne, IN 46805 | | | City, State, Zip Code: | | | | |
| Facility LD. : | | | | Phone : | | | Date: | 1/30/2024 |
| Testing Company: Gasoline Equipment Service 4422 Earth Drive, Fort Wayne, IN 46809 | | | | Phone : 260-747-5088 | | | | |
| This procedure is to determine whether liquid sensors located in the interstitial space of UST systems are able to detect the presence of water and fuel. See PE /RP1200, Section 8.3 for the test procedure. | | | | | | | | |
| Sensor Location | Disp 1/2 L1 | Disp 3/4 L2 | Disp 5/6 L3 | Disp 7/8 L4 | Disp 9/10 L5 | Unlead sump L6 | Prem sump L7 | Diesel sump L8 |
| Product Stored | U.P.D | U.P.D | U.P.D | Un/Prem | Un/Prem | Unlead | Premium | Diesel |
| Type of Sensor | Non discriminating | Non discriminating | Non discriminating | Non discriminating | Non discriminating | Non discriminating | Non discriminating | Non discriminating |
| Test Liquid | Water | Water | Water | Water | Water | Water | Water | Water |
| Is the ATG console clear of any active or recurring warnings or alarms regarding the liquid sensor? If the sensor is in alarm and functioning indicate why. Y/N | Y | Y | Y | Y | Y | Y | Y | Y |
| Is the sensor alarm circuit operational? Y/N | Y | Y | Y | Y | Y | Y | Y | Y |
| Has sensor been inspected and in good operating condition? Y/N | Y | Y | Y | Y | Y | Y | Y | Y |
| When placed in the test liquid, does the sensor trigger an alarm? Y/N | Y | Y | Y | Y | Y | Y | Y | Y |
| When an alarm is triggered, is the sensor properly identified on the ATG console? Y/N | Y | Y | Y | Y | Y | Y | Y | Y |
| Any "No" answers indicates the sensor fails the test. | | | | | | | | |
| Test Results | PASS | PASS | PASS | PASS | PASS | PASS | PASS | PASS |
| Comments: | All dispenser and sump sensors alarm and report location | | | | | | | |
| Tester's Name (Print) | James Rattie | | | Tester Signature | James Rattie | | | |

LIQUID SENSOR FUNCTIONALITY TESTING

Main Office
4422 Earth Drive
Fort Wayne, IN 46809
(260) 747-5088



www.gasolineequipment.com

Branch
4389 W. 96th Street
Indianapolis, IN 46268
(317) 876-8856

| | | | | | |
|---|---|-------------------|------------------------|--------------|-----------|
| Facility Name: | Kroger #405 Fort Wayne | | Owner: | Kroger foods | |
| Address: | 4210 N Clinton str | | Address: | | |
| City, State, Zip Code: | Fort Wayne, IN 46805 | | City, State, Zip Code: | | |
| Facility I.D. : | | Phone : | | Date: | 1/30/2024 |
| Testing Company: Gasoline Equipment Service 4422 Earth Drive, Fort Wayne, IN 46809 | | | Phone : 260-747-5088 | | |
| This procedure is to determine whether liquid sensors located in the interstitial space of UST systems are able to detect the presence of water and fuel. See PE /RP1200, Section 8.3 for the test procedure. | | | | | |
| Sensor Location | Unlead int L12 | Prem/Dies int L13 | | | |
| Product Stored | Unlead int | Prem/Diesel | | | |
| Type of Sensor | Brine | Brine | | | |
| Test Liquid | Brine | Brine | | | |
| Is the ATG console clear of any active or recurring warnings or alarms regarding the lea sensor? If the sensor is in alarm and functioning, indicate why. Y/N | Y | Y | | | |
| Is the sensor alarm circuit operational? Y/N | Y | Y | | | |
| Has sensor been inspected and in good operating condition? Y/N | Y | Y | | | |
| When placed in the test liquid, does the sensor trigger an alarm? Y/N | Y | Y | | | |
| When an alarm is triggered, is the sensor properly identified on the ATG console? Y/N | Y | Y | | | |
| Any "No" answers indicates the sensor fails the test. | | | | | |
| Test Results | PASS | PASS | | | |
| Comments: | Interstice sensors function as designed | | | | |
| Tester's Name (Print) | James Rattie | Tester Signature | James Ratie | | |

Mechanical and Electrical Line Leak Detector Test

Main Office
4422 Earth Drive
Fort Wayne, IN 46809
(260) 747-5088



Branch
4389 W. 96th Street
Indianapolis, IN 46268
(317) 876-8856

Ref: RP 1200 APPENDIX C-9

www.gasolineequipment.com

MECHANICAL AND ELECTRONIC LINE LEAK DETECTORS PERFORMANCE TESTS

| | | | | | |
|---|------------------------|------------------------|--------------|-------|-----------|
| Facility Name: | Kroger #405 Fort Wayne | Owner: | Kroger foods | | |
| Address: | 4210 N Clinton str | Address: | | | |
| City, State, Zip Code: | Fort Wayne, IN 46805 | City, State, Zip Code: | | | |
| Facility I.D. #: | | Phone #: | | Date: | 1/30/2024 |
| Testing Company: Gasoline Equipment Service 4422 Earth Drive, Fort Wayne, IN 46809 | Phone #: 260-747-5088 | | | | |

For mechanical line leak detectors (MLLD) and electronic line leak detectors (ELLD) with submersible turbine pump (STP) systems. Ref PEI/RP1200 Sections 9.1 and 9.2.

| Line Number | 1 | 2 | 3 | | | |
|----------------------------|-------------|-------------------|-------------------|--|--|--|
| Product Stored | Unleaded | Premium | Diesel | | | |
| Leak Detector Manufacturer | Veeder Root | Veeder Root | Veeder Root | | | |
| Leak Detector Model | DPLLD 85908 | Digital PLLD 8590 | Digital PLLD 8590 | | | |
| Type of Leak Detector | ELLD | ELLD | ELLD | | | |

MLLD (ALL PRESSURE MEASUREMENTS ARE MADE IN PSIG)

| | | | | | | |
|--|--|--|--|--|--|--|
| STP Full Operating Pressure | | | | | | |
| Check Valve Holding Pressure | | | | | | |
| Line Resiliency (ml) (line bleed back volume as measured from check valve holding pressure to 0 psig) | | | | | | |
| Step Through Time in Seconds (time the MLLD hesitates at motoring pressure before going to full operating pressure as measured from 0 psig with no leak induced on the line) | | | | | | |
| Metering Pressure (STP pressure when simulated leak rate 3 gph at 10 psig) | | | | | | |
| Opening Time in Seconds (the time the MLLD opens to allow full pressure after simulated leak is stopped) | | | | | | |
| Does the STP pressure remain at or below the metering pressure for at least 60 seconds when the simulated leak is induced? Y/N | | | | | | |
| Does the leak detector reset (trip) when the line pressure is bled off to zero psig? Y/N | | | | | | |
| Does the STP properly cycle on/off under normal fuel system operation conditions? Y/N | | | | | | |

A "No" answer to either of the above questions indicates the MLLD fails the test.

ELLD (ALL PRESSURE MEASUREMENTS ARE MADE IN PSIG)

| | | | | | | |
|--|------|------|------|--|--|--|
| STP Full Operating Pressure | 30.2 | 28.9 | 47.7 | | | |
| How many test cycles are observed before alarm/shutdown occurs? | 1 | 1 | 1 | | | |
| Does the simulated leak cause an alarm? Y/N | Y | Y | Y | | | |
| A "No" answer to the above question indicates the ELLD fails the test. | Y | Y | Y | | | |
| Does the simulated leak cause an STP shutdown? Y/N/NA | Y | Y | Y | | | |
| Test Results | PASS | PASS | PASS | | | |

All detectors function as designed and shut down.

| | | | |
|-----------------------|--------------|------------------|--------------|
| Tester's Name (print) | James Rattie | Tester Signature | James Rattie |
|-----------------------|--------------|------------------|--------------|

Spill Bucket Hydrostatic Test

Main Office
4422 Earth Drive
Fort Wayne, IN 46809
(260) 747-5088



Branch
4389 W. 96th Street
Indianapolis, IN 46268
(317) 876-8856

www.gasolineequipment.com

Ref: RP 1200 APPENDIX C-3

| | | | | | |
|----------------|---------------------|--------------|--|--------|--------------|
| Facility Name: | Kroger #405 Fort Wa | Facility ID# | | Owner: | Kroger foods |
|----------------|---------------------|--------------|--|--------|--------------|

SPILL BUCKET INTEGRITY TESTING HYDROSTATIC TEST METHOD SINGLE- AND DOUBLE-WALLED VACUUM TEST METHOD

| | | | |
|---|-----------------------|-------|-----------|
| Testing Company: Gasoline Equipment Service 4422 Earth Drive, Fort Wayne, IN 46809 | Phone #: 260-747-5088 | Date: | 1/30/2024 |
|---|-----------------------|-------|-----------|

This procedure is to test the leak integrity of single- and double-walled spill buckets. See PEI/RP1200 Section 6.2 for hydrostatic test method, Section 6.3 for single-walled vacuum test method and Section 6.4 for double-walled vacuum test method.

| Tank Number | 1 | 1 | 2 | 2 | 3 | |
|--|---------------|---------------|---------------|---------------|---------------|--|
| Product Stored | Unlead prod | Unlead vapor | Prem prod | Prem vapor | Diesel prod | |
| Spill Bucket Capacity | 5 gal | 5 gal | 5 gal | 5 gal | 5 gal | |
| Manufacturer | OPW | OPW | OPW | OPW | OPW | |
| Construction | Single walled | Single walled | Single walled | Single walled | Single walled | |
| Test Type | Hydrostatic | Hydrostatic | Hydrostatic | Hydrostatic | Hydrostatic | |
| Spill Bucket Type | Product | Vapor | Product | Vapor | Product | |
| Liquid and debris removed from spill bucket? * Y/N | Y | Y | Y | Y | Y | |
| Visual inspection (No cracks, loose parts or separation of the bucket from the fill pipe.) PASS/FAIL | PASS | PASS | PASS | PASS | PASS | |
| Tank riser cap included in test? Y/N | Y | Y | Y | Y | Y | |
| Drain valve included in test? Y/N/NA | N/A | N/A | N/A | N/A | N/A | |
| Starting Level | 10 3/8" | 10 3/4" | 10 1/2" | 11 1/2" | 10 3/8" | |
| Test Start Time | 12:20pm | 12:20pm | 12:20pm | 12:20pm | 12:20pm | |
| Ending Level | 10 1/8" | 10 1/4" | 10 1/2" | 11 1/2" | 10 3/8" | |
| Test End Time | 1:20pm | 1:20pm | 1:20pm | 1:20pm | 1:20pm | |
| Test Period | 1 hr | 1 hr | 1 hr | 1 hr | 1 hr | |
| Level Change | 1/2" | 1/2" | 0 | 0 | 0 | |

Pass/fail criteria: Must pass visual inspection. Hydrostatic: Water level drop of less than 1/8 inch; Vacuum single-walled only: Maintain at least 26 inches water column; Vacuum double-walled: maintain at least 12 inches water column.

| | | | | | | |
|--------------|------|------|------|------|------|--|
| Test Results | FAIL | FAIL | PASS | PASS | PASS | |
|--------------|------|------|------|------|------|--|

Comments:
*All liquids and debris must be disposed of properly.
Both unleaded product and vapor spill buckets lost 1/2" of water in the hour period.

| | | | |
|----------------------|--------------|------------------|--------------|
| Tester Name (Print): | James Rattle | Tester Signature | James Rattle |
|----------------------|--------------|------------------|--------------|

Containment Sump

Main Office
4422 Earth Drive
Fort Wayne, IN 46809
(260) 747-5088



Branch
4389 W. 96th Street
Indianapolis, IN 46268
(317) 876-8856

Ref: RP 1200 APPENDIX C-4

www.gasolineequipment.com

CONTAINMENT SUMP INTEGRITY TESTING HYDROSTATIC TESTING METHOD

| | | | | | |
|---|------------------------|------------------------|--------------|-------|-----------|
| Facility Name: | Kroger #405 Fort Wayne | Owner: | Kroger Foods | | |
| Address: | 4210 N Clinton str | Address: | | | |
| City, State, Zip Code: | Fort Wayne, IN 46805 | City, State, Zip Code: | | | |
| Facility I.D. #: | | Phone #: | | Date: | 1/30/2024 |
| Testing Company: Gasoline Equipment Service 4422 Earth Drive, Fort Wayne, IN 46809 | | Phone #: 260-747-5088 | | | |

This procedure is to test the leak integrity of containment sumps. See PEI/RP1200 Section 6.5 for the test method.

| Containment Sump ID | Unlead sump | Premium sump | Diesel sump | | | |
|---|-------------|--------------|-------------|--|--|--|
| Containment Sump Material | Fiberglass | Fiberglass | Fiberglass | | | |
| Liquid and debris removed from sump?* | Y | Y | Y | | | |
| Visual Inspection (No cracks, loose parts or separation of the containment sump.) | PASS | PASS | PASS | | | |
| Containment Sump Depth | 50" | 47" | 46" | | | |
| Height From Bottom to Top of Highest Penetration | 12" | 12" | 13" | | | |
| Starting Water Level | 18 1/2" | 17" | 17 7/8" | | | |
| Test Start Time | 1:05pm | 12:40pm | 12:30pm | | | |
| Ending Water Level | 18 1/2" | 17" | 17 7/8" | | | |
| Test End Time | 2:05pm | 1:40pm | 1:30pm | | | |
| Test Period (Minimum test time: 1 hour) | 1 HR | 1 HR | 1 HR | | | |
| Water Level Change | 0 | 0 | 0 | | | |

Pass/fail criteria: Must pass visual inspection. Water level drop of less than 1/8 inch.

| | | | | | | |
|--------------|------|------|------|--|--|--|
| Test Results | PASS | PASS | PASS | | | |
|--------------|------|------|------|--|--|--|

Comments:

*All liquids and debris must be disposed of properly.

All sumps held water for allotted test time.

| | | | |
|-----------------------|--------------|------------------|--------------|
| Tester's Name (print) | James Rattle | Tester Signature | James Rattle |
|-----------------------|--------------|------------------|--------------|

Containment Sump

Main Office
4422 Earth Drive
Fort Wayne, IN 46809
(260) 747-5088



Branch
4389 W. 96th Street
Indianapolis, IN 46268
(317) 876-8856

Ref: RP 1200 APPENDIX C-4

www.gasolineequipment.com

CONTAINMENT SUMP INTEGRITY TESTING HYDROSTATIC TESTING METHOD

| | | | | | |
|---|------------------------|------------------------|--------------|-------|-----------|
| Facility Name: | Kroger #405 Fort Wayne | Owner: | Kroger Foods | | |
| Address: | 4210 N Clinton str | Address: | | | |
| City, State, Zip Code: | Fort Wayne, IN 46805 | City, State, Zip Code: | | | |
| Facility I.D. #: | | Phone #: | | Date: | 1/30/2024 |
| Testing Company: Gasoline Equipment Service 4422 Earth Drive, Fort Wayne, IN 46809 | | Phone #: 260-747-6088 | | | |

This procedure is to test the leak integrity of containment sumps. See PEI/RP1200 Section 6.5 for the test method.

| Containment Sump ID | Disp 1/2 | Disp 3/4 | Disp 5/6 | Disp 7/8 | Disp 9/10 | |
|---|----------|----------|----------|----------|-----------|--|
| Containment Sump Material | Poly | Poly | Poly | Poly | Poly | |
| Liquid and debris removed from sump?* | Y | Y | Y | Y | Y | |
| Visual Inspection (No cracks, loose parts or separation of the containment sump.) | PASS | PASS | PASS | PASS | PASS | |
| Containment Sump Depth | 17" | 17" | 17" | 17" | 17" | |
| Height From Bottom to Top of Highest Penetration | 5" | 5" | 5" | 5" | 5" | |
| Starting Water Level | 12 3/8" | 11 5/8" | 11 3/4" | 11 7/8" | 11 1/8" | |
| Test Start Time | 8:45am | 8:41am | 8:39am | 8:47am | 8:37am | |
| Ending Water Level | 12 3/8" | 11 5/8" | 11 3/4" | 11 7/8" | 11 1/8" | |
| Test End Time | 9:45am | 9:41am | 9:39am | 9:47am | 9:37am | |
| Test Period (Minimum test time: 1 hour) | 1 HR | 1 HR | 1 HR | 1 HR | 1 HR | |
| Water Level Change | 0 | 0 | 0 | 0 | 0 | |

Pass/fail criteria: Must pass visual inspection. Water level drop of less than 1/8 inch.

| | | | | | | |
|--------------|------|------|------|------|------|--|
| Test Results | PASS | PASS | PASS | PASS | PASS | |
|--------------|------|------|------|------|------|--|

| | | | | | | |
|-----------|--|--|--|--|--|--|
| Comments: | <p>*All liquids and debris must be disposed of properly.</p> <p>All OPW disp sumps passed hydrostatic testing.</p> | | | | | |
|-----------|--|--|--|--|--|--|

| | | | |
|-----------------------|--------------|------------------|--------------|
| Tester's Name (print) | James Rattie | Tester Signature | James Rattie |
|-----------------------|--------------|------------------|--------------|

Overfill Alarm Operation Inspection

Main Office
4422 Earth Drive
Fort Wayne, IN 46809
(260) 747-5088



www.gasolineequipment.com

Branch
4389 W. 96th Street
Indianapolis, IN 46268
(317) 876-8856

| | | | |
|------------------------|------------------|------------------------|--------------|
| Kroger #405 Fort Wayne | Facility NAME: | Owner: | Kroger foods |
| 4210 N Clinton str | ADDRESS: | Address: | |
| Fort Wayne, IN 46805 | City, State, ZIP | City, State, Zip Code: | |
| | Facility ID# | Phone #: | |

| | | | |
|---|-----------------------|-------|-----------|
| Testing Company: Gasoline Equipment Service 4422 Earth Drive, Fort Wayne, IN 46809 | Phone #: 260-747-5088 | Date: | 1/30/2024 |
|---|-----------------------|-------|-----------|

This procedure is to determine whether the high level alarm is operational and will trigger when the tank is no more than 90% full. See PEI/RP1200 Section 7.3 for the inspection procedure. This procedure is applicable to tank level monitor stems that touch the bottom of the tank when in place.

| Tank Number | 1 | 2 | 3 | |
|---|--------------------|--------------------|--------------------|--|
| Product Stored | Unlead | Premium | Diesel | |
| Tank Level Monitor Brand and Model | Veeder root t1s450 | Veeder root t1s450 | Veeder root t1s450 | |
| 1. Tank Volume, gallons | 19782 | 7901 | 10420 | |
| 2. Tank Diameter, inches | 118.4 | 118.4 | 118.4 | |
| 3. Overfill alarm activates in the fast mode at the console? Y/N | Y | Y | Y | |
| 4. When activated, overfill alarm can be heard or seen while delivering to the tank? Y/N | Y | Y | Y | |
| 5. After removing the probe from the tank, it has been inspected and any damaged or missing parts replaced? | Y | Y | Y | |
| 6. Float moves freely on the stem without binding? | Y | Y | Y | |
| 7. Moving product level float up the stem trigger alarm? | Y | Y | Y | |
| 8. Inch level from bottom of stem when 90% alarm is triggered. | 99-1/8" | 99-3/4" | 98-1/2" | |
| 9. Tank volume at Inch level in Line 8. | 17645 | 7104 | 9378 | |
| 10. Calculate (Line 9 / Line 1) x 100 | 89.919 | 89.87 | 90 | |
| 11. Is Line 10 less than 90%? Y/N | Y | Y | Y | |
| 12. Fuel float level on the console agrees with the gauge stick reading? Y/N | Y | Y | Y | |
| 13. Overfill alarm activates at any product level above 90% tank capacity? Y/N | N | N | N | |

If any answers in Lines 3, 4, 5, 6, 7 or 11 are "No," or Line 13 is "Yes," the system has failed the test.

| | | | | |
|--|------------------|------|---------------|--|
| Test Results | PASS | PASS | PASS | |
| Comments: | Tester Signature | | James Rattie | |
| Retest from original test date of 11/29/2023, all alarms sound as programmed | UST License # | | UC2018IN12489 | |

Pressure Vacuum Vent Cap Test

Main Office
4422 Earth Drive
Fort Wayne, IN 46809
(260) 747-5088



Branch
4389 W. 96th Street
Indianapolis, IN 46268
(317) 876-8856

Pressure Vacuum Vent Cap Test

| | | | | | |
|---|------------------------|------------------------|--------------|-------|-----------|
| Facility Name: | Kroger #405 Fort Wayne | Owner: | Kroger foods | | |
| Address: | 4210 N Clinton str | Address: | | | |
| City, State, Zip Code: | Fort Wayne, IN 46805 | City, State, Zip Code: | | | |
| Facility I.D. #: | | Phone #: | | Date: | 1/30/2024 |
| Testing Company: Gasoline Equipment Service 4422 Earth Drive, Fort Wayne, IN 46809 | | Phone #: 260-747-5088 | | | |

| | | | | | |
|---|---------------|---|--------------|--------------|------|
| Product Type | Unlead | | | | |
| Manufacturer's Specified Positive Leak Rate | 2.5-6 IN W.C. | Manufacturer's Specified Negative Leak Rate | 6-10 IN W.C. | | |
| Measured Positive Leak Rate | 0.04 | Measured Negative Leak Rate | 0.02 | | |
| Positive Cracking Pressure | 3.35 | Negative Cracking Pressure | -8.62 | | |
| Results | PASS | Valve Manufacturer | Husky | Model Number | 4885 |

| | | | | | |
|---|---------------|---|--------------|--------------|------|
| Product Type | Premium | | | | |
| Manufacturer's Specified Positive Leak Rate | 2.5-6 IN W.C. | Manufacturer's Specified Negative Leak Rate | 6-10 IN W.C. | | |
| Measured Positive Leak Rate | 0.03 | Measured Negative Leak Rate | 0.01 | | |
| Positive Cracking Pressure | 4.52 | Negative Cracking Pressure | -9.09 | | |
| Results | PASS | Valve Manufacturer | Husky | Model Number | 4885 |

| | | | | | |
|---|--|---|--|--------------|--|
| Product Type | | | | | |
| Manufacturer's Specified Positive Leak Rate | | Manufacturer's Specified Negative Leak Rate | | | |
| Measured Positive Leak Rate | | Measured Negative Leak Rate | | | |
| Positive Cracking Pressure | | Negative Cracking Pressure | | | |
| Results | | Valve Manufacturer | | Model Number | |

| | | | | | |
|---|--|---|--|--------------|--|
| Product Type | | | | | |
| Manufacturer's Specified Positive Leak Rate | | Manufacturer's Specified Negative Leak Rate | | | |
| Measured Positive Leak Rate | | Measured Negative Leak Rate | | | |
| Positive Cracking Pressure | | Negative Cracking Pressure | | | |
| Results | | Valve Manufacturer | | Model Number | |

| | | | | | |
|-----------------------|--------------|--------------------|---------------|--|--|
| Comments: | | UST Licence Number | UC2018IN12489 | | |
| Tester's Name (print) | James Rattle | Tester Signature | James Rattle | | |

Shear Valve Inspection

Main Office
4422 Earth Drive
Fort Wayne, IN 46809
(260) 747-5088



Branch
4389 W. 96th Street
Indianapolis, IN 46268
(317) 876-8856

Ref: RP 1200 APPENDIX C-10

www.gasolineequipment.com

SHEAR VALVE OPERATION INSPECTION

| | | | |
|--|------------------------|-----------------------|--------------|
| Facility Name: | Kroger #405 Fort Wayne | Owner: | Kroger foods |
| Address: | 4210 N Clinton str | Address: | |
| Facility I.D. #: | Fort Wayne, IN 46805 | Date: | 1/30/2024 |
| Testing Company: Gasoline Equipment Service 4422 Earth Drive, Fort Wayne, IN 46809 | | Phone #: 260-747-5088 | |

This data sheet is for inspecting shear valves located inside dispensers. See PEI/RP1200 Section 10 for the inspection procedure. Product Grade

| Dispenser ID# | Disp 1/2 | Disp 3/4 | Disp 5/6 | Disp 7/8 | Disp 9/10 | | | | |
|---|---------------|---------------|---------------|-------------|-------------|--|--|--|--|
| Shear Valve Type (Product/Vapor) | product U,P,D | product U,P,D | product U,P,D | product U,P | product U,P | | | | |
| 1. Is the shear valve rigidly anchored to the dispenser box frame or dispenser island? Y/N | Y | Y | Y | Y | Y | | | | |
| 2. Is the shear section positioned between 3/8 inch above or below the top surface of the dispenser (3/8" max)? | Y | Y | Y | Y | Y | | | | |
| 3. Is the lever arm free to move? Y/N | Y | Y | Y | Y | Y | | | | |
| 4. Does the lever arm snap shut the poppet valve? Y/N | Y | Y | Y | Y | Y | | | | |
| 5. Can any product be dispensed when the product shear valve is closed? Y/N | N | N | N | N | N | | | | |

A "No" to Lines 1-4 or a "Yes" for Line 5 indicates a test failure.

| | | | | | | | | | |
|---------------|------|------|------|------|------|--|--|--|--|
| Test Results: | PASS | PASS | PASS | PASS | PASS | | | | |
|---------------|------|------|------|------|------|--|--|--|--|

Comments:

| | | | |
|-----------------------|--------------|------------------|--------------|
| Tester's Name (print) | James Rattie | Tester Signature | James Rattie |
|-----------------------|--------------|------------------|--------------|

UST WALKTHROUGH INSPECTION CHECKLIST

DIVISION: CENTRAL

YEAR: 2023



STORE NUMBER: 405

SITE ADDRESS: 4210 N. Clinton St. Fort Wayne, IN 46805

Please respond to ALL of the following questions with a Y (Yes), N (No), or NA (Not Applicable) answer. Fuel Manager upload to compliance database monthly

| Month of Inspection | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec |
|---------------------|-----|-----|-----|-----|--------|-----|-----|-----|-----|-----|-----|-----|
| Date of Inspection | | | | | 25-May | | | | | | | |

Monthly Inspection - Release Detection

| | | | | | | | | | | | | |
|--|--|--|--|--|---|--|--|--|--|--|--|--|
| 1. Release detection equipment is operating with no alarms or other unusual operating conditions | | | | | Y | | | | | | | |
| 2. Release detection tanks and programs reviewed and tested (RPLD and Liquid Status Reports) | | | | | Y | | | | | | | |

Monthly Inspection - Spill Prevention Equipment (Spill Buckets)

| | | | | | | | | | | | | |
|---|--|--|--|--|-----|--|--|--|--|--|--|--|
| 3. Spill Buckets are undamaged, intact and free from defects | | | | | Y | | | | | | | |
| 4. Spill Buckets are free from debris, water, or fuel | | | | | Y | | | | | | | |
| 5. No Pipe is undistructed | | | | | Y | | | | | | | |
| 6. All caps are secure on fill pipe | | | | | Y | | | | | | | |
| 7. Double wall spill Buckets, interior or exterior, free from leaks | | | | | N/A | | | | | | | |
| 8. Double wall spill Buckets, interior or exterior, free from leaks | | | | | Y | | | | | | | |
| 9. Double wall spill Buckets, interior or exterior, free from leaks | | | | | Y | | | | | | | |

UID of Manager performing inspection:

DH79003

Annual Inspection - Containment Sumps (Performed by Class B Operator)

| | | | | | | | | | | | | |
|---|--|--|--|--|---|--|--|--|--|--|--|--|
| 10. Visual inspection of contained sumps and containment is free from debris, water, and fuel | | | | | Y | | | | | | | |
| 11. The penetrat or fittings for conduits and piping entering the sump are intact | | | | | Y | | | | | | | |
| 12. Double wall containment sumps with interstitial monitoring | | | | | Y | | | | | | | |

Signature of Class B Operator

X

Date:

5/25/2023

KROGER FUEL MANAGER FORT WAYNE IN 46805

UST WALKTHROUGH INSPECTION CHECKLIST

DIVISION: 021-Central
 STORE NUMBER: 405
 SITE ADDRESS: 4120 N. Clinton St. Fort Wayne, IN 46805

YEAR: 2023



Please respond to ALL of the following questions with a Y (Yes), N (No), or NA (Not Applicable) answer. Fuel Manager upload to compliance database monthly

| Month of Inspection | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec |
|---------------------|----------|----------|----------|----------|----------|----------|----------|----------|----------|-----------|-----------|-----------|
| Date of Inspection | 1/1/2023 | 2/1/2023 | 3/1/2023 | 4/1/2023 | 5/1/2023 | 6/1/2023 | 7/1/2023 | 8/1/2023 | 9/1/2023 | 10/1/2023 | 11/1/2023 | 12/1/2023 |

Monthly Inspection - Release Detection

| | | | | | | | | | | | | |
|---|---|---|---|---|---|---|---|---|---|---|---|---|
| 1 | Release detection equipment is operating with no alarms or other unusual operating conditions | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y |
| 2 | Records of release detection (tanks and piping) are reviewed and current - (PLLD and Liquid Status Reports) | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y |

Monthly Inspection - Spill Prevention Equipment (Spill Buckets)

| | | | | | | | | | | | | |
|---|---|---|-----|---|-----|-----|-----|-----|-----|-----|-----|-----|
| 3 | Spill Buckets are undamaged, intact and free from defects | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y |
| 4 | Spill Buckets are free from debris, water, or fuel | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y |
| 5 | Fill Pipe is unobstructed | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y |
| 6 | Fill cap is securely on fill pipe | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y |
| 7 | Double wall spill buckets - Interstitial area is free from leaks | Y | N/A | Y | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 8 | Emergency spill response supplies inventoried and restocked if low (two red bags including Spill Pads, Sock Booms, Disposable Bags, Goggles, Plastic Gloves) In addition FM186 plus scrub broom all in the kiosk) | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y |
| 9 | Inspect dispenser hoses, nozzles and breakaways - All in good condition and show no signs of leaks or deterioration | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y | Y |

| | | | | | | | | | | | | |
|---------------------------------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| EUID of Manager performing inspection | ZK35875 | MG80899 | JP38960 | HC15296 | FB90014 | FB90014 | HC15296 | JW12560 | HC15296 | KM97977 | bs64911 | hc15296 |
|---------------------------------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|

Annual Inspection - Containment Sumps (Performed by Class B Operator)

| | | | | | | | | | | | | |
|----|--|--|--|--|--|--|--|--|--|--|--|--|
| 10 | Visual inspection of containment sump indicates no damage and it is free from debris, water and fuel | | | | | | | | | | | |
| 11 | The penetration fittings for conduits and piping entering the STP sumps are intact | | | | | | | | | | | |
| 12 | Double wall containment sumps with interstitial monitoring - Interstitial area is free from leaks | | | | | | | | | | | |

Signature of Class B Operator

Date:

UST WALKTHROUGH INSPECTION CHECKLIST

DIVISION: 021-Central _____

YEAR: 2024 _____

STORE NUMBER: 405 _____

SITE ADDRESS: 4120 N. Clinton St. Fort Wayne, IN 46805 _____



Please respond to ALL of the following questions with a Y (Yes), N (No), or NA (Not Applicable) answer. Fuel Manager upload to compliance database monthly

| Month of Inspection | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec |
|---------------------|----------|----------|----------|----------|----------|----------|----------|----------|----------|-----------|-----------|-----------|
| Date of Inspection | 1/1/2024 | 2/1/2024 | 3/1/2024 | 4/1/2024 | 5/1/2024 | 6/1/2024 | 7/1/2024 | 8/1/2024 | 9/1/2024 | 10/1/2024 | 11/1/2024 | 12/1/2024 |

Monthly Inspection - Release Detection

| | | | | | | | | | | | | |
|---|---|---|---|---|---|---|--|--|--|--|--|--|
| 1 | Release detection equipment is operating with no alarms or other unusual operating conditions | y | Y | Y | Y | y | | | | | | |
| 2 | Records of release detection (tanks and piping) are reviewed and current - (PLLD and Liquid Status Reports) | y | Y | Y | Y | y | | | | | | |

Monthly Inspection - Spill Prevention Equipment (Spill Buckets)

| | | | | | | | | | | | | |
|---|---|---|---|---|---|---|--|--|--|--|--|--|
| 3 | Spill Buckets are undamaged, intact and free from defects | y | Y | Y | Y | y | | | | | | |
| 4 | Spill Buckets are free from debris, water, or fuel | y | Y | Y | Y | y | | | | | | |
| 5 | Fill Pipe is unobstructed | y | Y | Y | Y | y | | | | | | |
| 6 | Fill cap is securely on fill pipe | y | Y | Y | Y | y | | | | | | |
| 7 | Double wall spill buckets - Interstitial area is free from leaks | y | Y | Y | Y | y | | | | | | |
| 8 | <small>Emergency spill response supplies inventoried and restocked if low (two red bags including Spill Pads, Sock Booms, Disposable Bags, Goggles, Plastic Gloves) in addition FM185 plus scrub broom all in the closet)</small> | y | Y | Y | Y | y | | | | | | |
| 9 | Inspect dispenser hoses, nozzles and breakaways - All in good condition and show no signs of leaks or deterioration | y | Y | Y | Y | y | | | | | | |

| | | | | | | | | | | | | |
|---------------------------------------|---------|---------|---------|---------|---------|--|--|--|--|--|--|--|
| EUID of Manager performing inspection | hc15296 | bs64911 | bs64911 | hc15296 | hc15296 | | | | | | | |
|---------------------------------------|---------|---------|---------|---------|---------|--|--|--|--|--|--|--|

Annual Inspection - Containment Sumps (Performed by Class B Operator)

| | | | | | | | | | | | | |
|----|--|--|--|--|--|--|--|--|--|--|--|--|
| 10 | Visual inspection of containment sump indicates no damage and it is free from debris, water and fuel | | | | | | | | | | | |
| 11 | The penetration fittings for conduits and piping entering the STP sumps are intact | | | | | | | | | | | |
| 12 | Double wall containment sumps with interstitial monitoring - Interstitial area is free from leaks | | | | | | | | | | | |

Signature of Class B Operator _____

Date: _____

UST WALKTHROUGH INSPECTION CHECKLIST

DIVISION CENTRAL

YEAR 2024

STORE NUMBER 405

SITE ADDRESS 4210 N CLINTON ST. FORT WAYNE, IN 46805



Please respond to ALL of the following questions with a Y (Yes), N (No), or NA (Not Applicable) answer. Fuel Manager upload to compliance database monthly

| Month of Inspection | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec |
|---------------------|-----|-----|-----|-----|--------|-----|-----|-----|-----|-----|-----|-----|
| Date of Inspection | | | | | 21-May | | | | | | | |

Monthly Inspection - Release Detection

| | | | | | | | | | | | | |
|---|---|--|--|--|--|---|--|--|--|--|--|--|
| 1 | Release detection equipment is operating with no alarms or other unusual operating conditions | | | | | Y | | | | | | |
| 2 | Records of release detection (tanks and piping) are reviewed and current - (PLLD and Liquid Status Reports) | | | | | Y | | | | | | |

Monthly Inspection - Spill Prevention Equipment (Spill Buckets)

| | | | | | | | | | | | | |
|---|---|--|--|--|--|------------|--|--|--|--|--|--|
| 3 | Spill Buckets are undamaged, intact and free from defects | | | | | Y | | | | | | |
| 4 | Spill Buckets are free from debris, water, or fuel | | | | | Y | | | | | | |
| 5 | Fill Pipe is unobstructed | | | | | Y | | | | | | |
| 6 | Fill cap is securely on fill pipe | | | | | Y | | | | | | |
| 7 | Double wall spill buckets - Interstitial area is free from leaks | | | | | UNLEADED Y | | | | | | |
| 8 | <small>Emergency spill response supplies inventoried and restocked if low (two red bags including Spill Pads, Sock Booms, Disposable Bags, Goggles, Plastic Gloves) in addition FM186 plus scrub broom all in the work)</small> | | | | | Y | | | | | | |
| 9 | Inspect dispenser hoses, nozzles and breakaways - All in good condition and show no signs of leaks or deterioration | | | | | Y | | | | | | |

| | | | | | | | | | | | | |
|---------------------------------------|--|--|--|--|--|---------|--|--|--|--|--|--|
| EUID of Manager performing inspection | | | | | | DH79003 | | | | | | |
|---------------------------------------|--|--|--|--|--|---------|--|--|--|--|--|--|

Annual Inspection - Containment Sumps (Performed by Class B Operator)

| | | | | | | | | | | | | |
|----|--|--|--|--|--|-----|--|--|--|--|--|--|
| 10 | Visual inspection of containment sump indicates no damage and it is free from debris, water and fuel | | | | | Y | | | | | | |
| 11 | The penetration fittings for conduits and piping entering the STP sumps are intact | | | | | Y | | | | | | |
| 12 | Double wall containment sumps with interstitial monitoring - Interstitial area is free from leaks | | | | | N/A | | | | | | |

Signature of Class B Operator

Date:

5/21/2024



Indiana Department of Environmental Management

A Underground Storage Tank Program
Operator Training Certification

100 North Senate Ave
Indianapolis, Indiana, 46204
(800) 451-6027 . (317) 232-8603
www.idem.IN.gov

Certificate of Completion

Awarded to:
Shenevelyn Ross

*For completion of IDEM's Underground Storage Tank "A" Operator Training in
accordance with 329 IAC 9.*

License #: 19015

Issue Date: August 17, 2021

Expiration Date: August 17, 2024

Bruno L. Pigott, Commissioner

IDEM may require operator retraining if a UST System managed by the operator has documented deficiencies per 329 IAC 9.



Indiana Department of Environmental Management

B Underground Storage Tank Program
Operator Training Certification

100 North Senate Ave
Indianapolis, Indiana, 46204
(800) 451-6027 • (317) 232-8603
www.idem.IN.gov

Certificate of Completion

Awarded to:

Nate Davis

*For completion of IDEM's Underground Storage Tank "B" Operator Training in
accordance with 329 IAC 9.*

License #: 23359

Issue Date: January 20, 2024

Expiration Date: January 20, 2027

Brian C. Rockensuess, Commissioner

IDEM may require operator retraining if a UST System managed by the operator has documented deficiencies per 329 IAC 9.

| | | | | | | | | | | 2024-Class C Training: Fuel Center Safety | | |
|--------------|----------|---------------------------------------|-------------------------------|--------------|----------|-------|----------|------------------|-----------|---|-----------------|--------------------------------|
| Course Title | Person # | Last, First Name | Job Title | Division | District | Loc | Job Code | Dept Name | Dept Code | Hire Date | Completion Date | System (Myinfo or Fresh Start) |
| | 3614841 | MUMMA, USHA | FUEL CENTER/CLERK | 0021 Central | 04 | 00405 | 2430110 | Fuel | SUEL | 7/24/2021 | 4/3/2024 | Myinfo |
| | 3642050 | JONES, ALYSIA | FUEL CENTER/CLERK | 0021 Central | 04 | 00405 | 2430110 | Fuel | SUEL | 9/29/2021 | 4/5/2024 | Myinfo |
| | 3690871 | MAAHS, KELLY | STR MGMT/ASST STORE LEADER HM | 0021 Central | 04 | 00405 | 2013164 | Store Operations | SADM | 11/15/2021 | 3/30/2024 | Myinfo |
| | 6531357 | Sistrunk, Sharon | FUEL CENTER/CLERK | 0021 Central | 04 | 00405 | 2430110 | Fuel | SUEL | 10/21/2023 | 4/8/2024 | Myinfo |
| | 6576281 | gahl, ashton | FUEL CENTER/CLERK | 0021 Central | 04 | 00405 | 2430110 | Fuel | SUEL | 2/20/2024 | 2/26/2024 | Myinfo |
| | 681831 | WAIKEL, ROBIN - Deceased as of 5/5/24 | FUEL CENTER/LEAD CLERK | 0021 Central | 04 | 00405 | 2430111 | Fuel | SUEL | 6/27/2007 | 4/2/2024 | Myinfo |
| | 684043 | HEISER, COLTON | STR MGMT/STORE LEADER | 0021 Central | 04 | 00405 | 2013142 | Store Operations | SADM | 8/7/2007 | 4/2/2024 | Myinfo |
| | 701409 | THOMAS, MELODIE | FRONT END/DEPT LEADER | 0021 Central | 04 | 00405 | 0500121 | Front End | SFRT | 6/18/2007 | 3/22/2024 | Myinfo |
| | 716974 | STETTLER, BRENDA | STR MGMT/ASST STORE LEADER HM | 0021 Central | 04 | 00405 | 2013164 | Store Operations | SADM | 6/21/2007 | 3/18/2024 | Myinfo |

Applied filters: Course Title is Class C Fuel Safety (Myinfo)

Shaffer, Caitlin

From: Sanders, Danielle D <danielle.sanders@kroger.com>
Sent: Wednesday, May 15, 2024 8:52 AM
To: IDEM USTCompliance (USTcompliance)
Subject: UST Facility ID# 25416 - Kroger J405

Categories: Caitlin

**** This is an EXTERNAL email. Exercise caution. DO NOT open attachments or click links from unknown senders or unexpected email. ****

Hi IDEM,

I sent the records for UST Facility ID# 25416 yesterday for the records request dated 5/8/24. The Spill Bucket testing had 2 fails, below is the service call of where they were replaced.

Thank you
Danielle Sanders
Kroger Accounting Dept. / 021 Central
5960 Castleway W Dr
Indianapolis, IN 46250
317-579-8126
danielle.sanders@kroger.com

From: Davis, Nathan J <nate.davis@stores.kroger.com>
Sent: Tuesday, May 14, 2024 6:20 PM
To: Sanders, Danielle D <danielle.sanders@kroger.com>
Subject: RE: 405 Kroger #405 Spill Bucket Failures

Those buckets were replaced under PO 17966915:

Summary of Call **17966915** (Call is Not Open)

Call

Call Status Completed Call Type Repair Service Customer Log Open Date 01 Feb 2024 15:10

Customer And Address

Customer Name 00405-1033 Site 00405-1033 - Scotts Store 405
Center Logged 021 - Central KMA Address 4120 N. Clinton St., Ft. Wayne, IN, 46805, US
Phone Number 260-484-7021

Product Information

Product FUEL_TANK - Fuel Underground StorageTank Service FTNK.0001 - Fuel Underground Tank Repair
Symptom Needs Repair Equipment #
Asset # Serial #
Equipment Comments

Warranty

Warranty Warranty Ind Warranty No
Labor Expiry Labor Warranty Processed Labor Warranty Processed Date
Part Expiry Part Warranty Processed Part Warranty Processed Date
Comments

[Product History](#) [Open Actions for Site](#) [Completed Actions for Site](#) [Print](#) [Notes *](#) [Submit](#)

Actions

| Action | Type | Status | Duration | Required Date From | Required Date To | Refrigeration Report Complete | Has Faults |
|--------|-------------------------|--------|----------|--------------------|-------------------|-------------------------------|-------------------------------------|
| 1 | SITE VISIT FIELD REPAIR | Closed | 00:30 | 01 Feb 2024 15:10 | 26 Feb 2024 11:41 | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 2 | SITE VISIT FIELD REPAIR | Closed | 00:30 | 07 Feb 2024 14:30 | 03 Mar 2024 11:01 | <input type="checkbox"/> | <input type="checkbox"/> |

Action Dependencies

There are no dependencies related to the Call.

Notes

- Note 01 Feb 2024 15:11 (NATHAN DAVIS):** RUL fill and vapor buckets failed hydrostatic testing
- 07 Feb 2024 14:30 (DAVID CONTRERA S HIGGINS):** I talked to Nate and he said due to condition of multiport to send action to LBC and have the unleaded removed and re-piped.
- 07 Feb 2024 14:31 (DAVID CONTRERA S HIGGINS):** Please send action 2 to LBC to remove multiport and set buckets in concrete.
- 12 Feb 2024 09:23 (DAVID CONTRERA S HIGGINS):** EVENT ACTION: REJECT-BUSY. Please send to Nate Davis
- 19 Mar 2024 20:16 (NATHAN DAVIS):** EVENT ACTION: CLOSE ACTION. part usage multiport replacement
- 01 May 2024 08:43 (VICKI WINCHESTER):** EVENT ACTION: CLOSE ACTION. rec'd invoice 91854 \$8598.75

Add Note

[Submit](#)

To: Davis, Nathan J <nate.davis@stores.kroger.com>

Subject: 405 Kroger #405 Spill Bucket Failures

Nate,

I received a Records Request for store 405 and there are 2 fails on the spill buckets. Did you ever log a service hub call?

Thank you

Danielle Sanders

Kroger Accounting Dept. / 021 Central

5960 Castleway W Dr

Indianapolis, IN 46250

317-579-8126

danielle.sanders@kroger.com

From: Davis, Nathan J <nate.davis@stores.kroger.com>

Sent: Wednesday, January 31, 2024 9:33 AM

To: Buening, Becky <becky.buening@kroger.com>

Cc: Ross, Shenevelyn <shenevelyn.ross@kroger.com>

Subject: FW: Kroger #405 annual and 3 yr test

I'll send a service hub number when I get a chance to log it for the 2 buckets.

From: Jim Rattie <jim@gasequip.net>

Sent: Wednesday, January 31, 2024 8:44 AM

To: Davis, Nathan J <nate.davis@stores.kroger.com>

Cc: Brandon Shisler <brandon@gasequip.net>

Subject: Kroger #405 annual and 3 yr test

[EXTERNAL EMAIL]: Do not click links or open attachments unless you recognize the sender and know the content is safe.

Here are your results Nate, as stated yesterday both unlead product and vapor both lost ½ " of water in the hour time frame.

James Rattie

Compliance & Testing Manager

Gasoline Equipment Service

4422 Earth Drive

Fort Wayne, IN 46809

Office: (260) 747-5088

Cell:(260) 312-6527

Jim@gasequip.net

Summary of Call **17966915** (Call is Not Open)

Call

Call Status Completed Call Type Repair Service Customer Log Open Date 01 Feb 2024 15:10

Customer And Address

Customer Name 00405-1033 Site 00405-1033 - Scotts Store 405
Center Logged 021 - Central KMA Address 4120 N. Clinton St., Ft. Wayne, IN, 46805, US
Phone Number 260-484-7021

Product Information

Product FUEL_TANK - Fuel Underground StorageTank Service FTNK.0001 - Fuel Underground Tank Repair
Symptom Needs Repair Equipment #
Asset # Serial #
Equipment Comments

Warranty

Warranty Warranty Ind Warranty No
Labor Expiry Labor Warranty Processed Labor Warranty Processed Date
Part Expiry Part Warranty Processed Part Warranty Processed Date
Comments

[Product History](#) [Open Actions for Site](#) [Completed Actions for Site](#) [Print](#) [Notes *](#) [Submit](#)

Actions

| Action | Type | Status | Duration | Required Date From | Required Date To | Refrigeration Report Complete | Has Faults |
|--------|-------------------------|--------|----------|--------------------|-------------------|-------------------------------|-------------------------------------|
| 1 | SITE VISIT FIELD REPAIR | Closed | 00:30 | 01 Feb 2024 15:10 | 26 Feb 2024 11:41 | <input type="checkbox"/> | <input checked="" type="checkbox"/> |
| 2 | SITE VISIT FIELD REPAIR | Closed | 00:30 | 07 Feb 2024 14:30 | 03 Mar 2024 11:01 | <input type="checkbox"/> | <input type="checkbox"/> |

Action Dependencies

There are no dependencies related to the Call.

Notes

- Note 01 Feb 2024 15:11 (NATHAN DAVIS):** RUL fill and vapor buckets failed hydrostatic testing
- 07 Feb 2024 14:30 (DAVID CONTRERA S HIGGINS):** I talked to Nate and he said due to condition of multiport to send action to LBC and have the unleaded removed and re-piped.
- 07 Feb 2024 14:31 (DAVID CONTRERA S HIGGINS):** Please send action 2 to LBC to remove multiport and set buckets in concrete.
- 12 Feb 2024 09:23 (DAVID CONTRERA S HIGGINS):** EVENT ACTION: REJECT-BUSY. Please send to Nate Davis
- 19 Mar 2024 20:16 (NATHAN DAVIS):** EVENT ACTION: CLOSE ACTION. part usage multiport replacement
- 01 May 2024 08:43 (VICKI WINCHESTER):** EVENT ACTION: CLOSE ACTION. rec'd invoice 91854 \$8598.75

Add Note

[Submit](#)

Spill Bucket Testing Report Form

This form is intended for use by contractors performing annual testing of UST spill containment structures. The completed form and printouts from tests (if applicable), should be provided to the facility owner/operator for submittal to the local regulatory agency.

1. FACILITY INFORMATION

| | |
|--|---------------------------------|
| Facility Name: <u>Scotts Store #905</u> | Date of Testing: <u>3-15-24</u> |
| Facility Address: <u>4120 N. Clinton St. Ft. Wayne, IN 46805</u> | |
| Facility Contact: <u>Nate Davis</u> | Phone: <u>317-649-3566</u> |
| Date Local Agency Was Notified of Testing: <u>N/A</u> | |
| Name of Local Agency Inspector (if present during testing): <u>N/A</u> | |

2. TESTING CONTRACTOR INFORMATION

| | |
|---|--|
| Company Name: <u>Lawrence Building Corp</u> | |
| Technician Conducting Test: <u>Steve Allen</u> | |
| Credentials ¹ : <input type="checkbox"/> CSLB Contractor <input type="checkbox"/> ICC Service Tech. <input type="checkbox"/> SWRCB Tank Tester <input checked="" type="checkbox"/> Other (Specify) <u>IDEM UST</u> | |
| License Number(s): <u>UC20020H640706</u> | |

3. SPILL BUCKET TESTING INFORMATION

| | | | | |
|--|--|---|--|--|
| Test Method Used: | <input checked="" type="checkbox"/> Hydrostatic <input type="checkbox"/> Vacuum <input type="checkbox"/> Other | | | |
| Test Equipment Used: | <u>Water / Tape measure</u> | | Equipment Resolution: | |
| Identify Spill Bucket (By Tank Number, Stored Product, etc.) | 1 <u>UNL - Fill</u> | 2 <u>UNL - Vapor</u> | 3 | 4 |
| Bucket Installation Type: | <input checked="" type="checkbox"/> Direct Bury <input type="checkbox"/> Contained in Sump | <input checked="" type="checkbox"/> Direct Bury <input type="checkbox"/> Contained in Sump | <input type="checkbox"/> Direct Bury <input type="checkbox"/> Contained in Sump | <input type="checkbox"/> Direct Bury <input type="checkbox"/> Contained in Sump |
| Bucket Diameter: | <u>11"</u> | <u>11"</u> | | |
| Bucket Depth: | <u>11"</u> | <u>11"</u> | | |
| Wait time between applying vacuum/water and start of test: | <u>3hr</u> | <u>3hr</u> | | |
| Test Start Time (T _i): | <u>10:30</u> | <u>10:30</u> | | |
| Initial Reading (R _i): | <u>10"</u> | <u>10"</u> | | |
| Test End Time (T _F): | <u>12:00</u> | <u>12:00</u> | | |
| Final Reading (R _F): | <u>10"</u> | <u>10"</u> | | |
| Test Duration (T _F - T _i): | <u>1.5hr</u> | <u>1.5hr</u> | | |
| Change in Reading (R _F - R _i): | <u>0</u> | <u>0</u> | | |
| Pass/Fail Threshold or Criteria: | <u>Pass</u> | <u>Pass</u> | | |
| Test Result: | <input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail | <input checked="" type="checkbox"/> Pass <input type="checkbox"/> Fail | <input type="checkbox"/> Pass <input type="checkbox"/> Fail | <input type="checkbox"/> Pass <input type="checkbox"/> Fail |

Comments – (include information on repairs made prior to testing, and recommended follow-up for failed tests)

CERTIFICATION OF TECHNICIAN RESPONSIBLE FOR CONDUCTING THIS TESTING

I hereby certify that all the information contained in this report is true, accurate, and in full compliance with legal requirements.

Technician's Signature: Steve Allen

Date: 3-15-24

¹ State laws and regulations do not currently require testing to be performed by a qualified contractor. However, local requirements may be more stringent.