



MONTHLY REPORT OF OPERATION WATER TREATMENT PLANT

State Form 34609 (R11 / 1-17)

INDIANA DEPARTMENT OF
ENVIRONMENTAL MANAGEMENT

System Name Reelsville Water PWSID Number IN5267006

For the Month of May Year 2024 IDEM Field Rep. John Summerlin

Signed [Signature] Title Operator

I certify under penalty of law, by this signature that this document was prepared by me, or under my direction, and the information submitted is to the best of my knowledge and belief, true, accurate, and complete. I am also aware that there are significant penalties for submitting false information.

Certification Number WT008391

PHYSICAL AND CHEMICAL DATA *

Date	Turbidity		Alkalinity		pH		Hardness		Iron		Manganese		Phosphate	Fluoride
	Raw	Finished	Raw	Finished	Raw	Finished	Raw	Finished	Raw	Finished	Raw	Finished	Finished	Finished
1					7.2	7.3			.22	.03				
2					7.1	7.3			.23	.0				
3					7.2	7.3			.25	0				
4														
5														
6					7.2	7.3			.13	0	.238	.09		
7					7.2	7.3			.21	0				
8					7.1	7.2			.24	0				
9					7.2	7.3			.39	0				
10					7.2	7.3			.49	0				
11														
12														
13					7.2	7.3			.57	0	.268	.134		
14					7.1	7.2			.29	0				
15					7.2	7.3			.69	0				
16					7.1	7.4			.7	0				
17					7.2	7.3			.6	0				
18														
19														
20					7.1	7.3			.39	.07	.261	.098		
21					7.2	7.3			.2	.01				
22					7.2	7.3			1.1	0				
23					7.1	7.2			.67	0				
24					7.1	7.3			.09	0				
25														
26														
27					7.1	7.1			.86	.04	.218	.072		
28					7.7	7.2			.69	.06				
29					7.2	7.3			.5	.0				
30					7.2	7.3			1.1	0				
31					7.2	7.3			.31	0				

* All parameters are to be expressed in mg/l except pH and turbidity.

DUE BY THE 10TH OF THE MONTH FOLLOWING THE REPORTING PERIOD.

Date	Water Treated 1000 gallons	Chemicals Used – Pounds								Filters		Chlorine Residual				Remarks	
		Salt	Alum	Lime	Soda Ash	Carbon	Chlorine	Fluoride	Phosphate	Filter Run (hours)	Gallons per wash x 1000	Plant Tap		D. S.			
												Free	Total	Free	Total		
1	330						7			5.1		.7	.8	.6	.7		
2	438						6			6	43	.8	.9	.7	.8		
3	467						13			7.5		.8	.9	.7	.8		
4	432						4			7.4		.9	1.0	.6	.9		
5	333						4			5.7		.7	.9	.5	.8		
6	392						5			5.9		.7	.9	.6	.7		
7	471						7			6.9	43	.9	1.0	.8	.9		
8	385						8			6.7		.8	1.0	.7	.8		
9	312						4			4.6	43	.8	.9	.7	.8		
10	442						8			7.0		.6	.8	.6	.7		
11	441						7			7.0		.7	.8	.6	.7		
12	460						7			7.5		.8	.9	.5	.7		
13	396						7			7.1		.8	.9	.7	.8		
14	401						5			5.0	43	.7	.8	.6	.7		
15	403						6			6.5		.6	.7	.5	.6		
16	405						8			6.5		.6	.8	.4	.7		
17	401						7			6.5		.8	.9	.7	.8		
18	399						10			6.3		.7	.8	.7	.8		
19	386						3			6.3		.8	.9	.5	.7		
20	488						7			7.5	43	.8	.9	.7	.8		
21	513						7			7.8		.6	.9	.7	.8	Monthly Water Treatment	
22	390						9			6.3		.8	.9	.7	.8	Total Gallons	13,054,000
23	375						6			6.0		.8	.9	.7	.8	Max. Day	540,000
24	410						11			6.5	43	.7	.8	.7	.8	Min. Day	312,000
25	456						9			7.3		.6	.9	.6	.8	Avg. Daily	421,000
26	443						7			7.0		.7	.8	.5	.8	E-Mail To: DWBMRO@idem.in.gov	
27	381						7			6.0		.8	.9	.5	.8		
28	540						8			8.4	43	.9	1.0	.7	.9	Mail To: Indiana Department of Environmental Management Drinking Water Branch 100 N. Senate Ave. Room N1201 Indianapolis, IN 46204-2237	
29	516						5			7.3		.7	.8	.6	.7		
30	434						8			7.0		.8	.9	.7	.8		
31	384						12			6.1		.8	.9	.7	.8		