

ENVIRONMENT & HEALTH

MAI 133954

Indiana Department of Environmental Management Office of Air Quality, Air Permits Branch ATTN: Incoming Application 100 N. Senate Avenue, IGCN 1003 Indianapolis, IN 46204-2251 Received State of Indiana

JUN 25 2024

Dept of Environmental Mgmt Office of Air Quality

RE:

APPLICATION FOR NEW SOURCE MINOR PSD CONSTRUCTION

APPROVAL AND TITLE V OPERATING PERMIT

SITE SBN100

55001 LARRISON BLVD.

**NEW CARLISLE, ST. JOSEPH COUNTY, INDIANA 46552** 

Dear Sir or Madam:

On behalf of our client, Razor5 LLC (Razor5), Ramboll Americas Engineering Solutions, Inc. (Ramboll) has prepared this application to obtain a New Source Minor PSD Construction Approval and a Title V Operating Permit for installation and operation of a data center facility at the above referenced location (identified as "SBN100"). The detailed description of the facility, regulatory applicability, application forms, potential emission calculations with necessary supporting information are enclosed within this submittal.

Additionally, an information checklist used to determine if two or more plants should be combined is included within this submittal for SBN100 and a proposed separate data center site (SBN201).

If you have any questions or require further information, please do not hesitate to contact the undersigned via email or phone.

Yours sincerely,

**Tingting Wang** 

Senior Managing Consultant M +1 312-288-3860

lighting Wang

twang@ramboll.com

### Enclosures:

Information checklist used to determine if two or more plants should be combined, and

Application for New Source Minor PSD Construction Approval and Title V Operating Permit

April 19, 2024

Ramboll Americas Engineering Solutions, Inc. 4245 North Fairfax Drive, Suite 700 Arlington, VA 22203 USA T +1 703 516 2300 www.ramboll.com

### Information checklist used to determine if two or more plants should be combined

### Permit Reviewer:

### **Pending Application No.:**

Application Contact Name, Email & Tel.: Tingting Wang, Ramboll, twang@ramboll.com, 312-292-6872

For each plant below, list plant name, plant ID number and location address:

- Proposed Site SBN100, located at 55001 Larrison Blvd., New Carlisle, St. Joseph County, Indiana 46552.
- Proposed Site SBN201, located at the intersection of Western Avenue and Larrison Blvd., New Carlisle, Indiana. See the attached Figure A for the locations of SBN100 and SBN201.


### Criteria **Detailed Information** 1. Common Control and Common Ownership SBN100 and SBN201 will be under common control of Razor5, LLC (a) Please state the details of ownership. Common ownership may exist in several forms. If one party has ownership of 51% or more in two or more plants, common ownership exists. If two or more plants share common corporate officers, in whole or in substantial part, who are responsible for the day-to-day operations of the plant, common ownership exists. If one plant owner has 51% or greater ownership of another plant, common ownership exists. (b) Does one plant assist another plant by No, neither facility will provide operational support for the other; supplying material or a service? If so, does the operations at each site will be self-sufficient. They can and will plant supplying the material or service provide operate independently of each other. a majority of its output to this other plant? Does any plant have day-to-day control over another plant? Please see IDEM Nonrule Policy Documents Air-005 and Air-006 at https://www.in.gov/idem/resources/nonrulepolicies/effective-nonrule-policies/ on IDEM's website for additional information. 2. SIC Codes and Support Relationships (a) List the two-digit SIC Code for each plant's Plant A two-digit SIC Code:\_73\_\_\_\_ primary product or activity. More information Plant B two-digit SIC Code:\_73\_\_\_\_\_ about SIC Codes is available at: Plant C two-digit SIC Code:\_\_\_\_\_ https://www.osha.gov/data/sic-manual on the Plant D two-digit SIC Code: Internet. (b) For each plant, state the percentage of the Each site will be operated as a data center facility. Each site will have plant's total output that is provided to each of its own emergency generators for backup power supply when the the other plants. For example, Plant A makes local electric supply is interrupted. The electricity generated by the only widgets and sends 90% to Plant B. Plant B lemergency generators at one site will not provide backup power to paints all of the widgets. Plant B does not support operations at the other site. Water treatment/cooling systems produce or paint any other products. for the generators will be dedication installations at each site. Each

site will have its own, independent fuel storage dedicated to each

site. Fuel will not be supplied to any other location.

3. Contiguous and Adjacent Properties	THE PROPERTY OF THE PARTY OF TH
Distances  (a) List the plants located on the same property contiguous properties. Contiguous properties share a common property line.	
	The shortest distance between the south boundary of SBN100 and the north boundary of SBN201 is approximately 0.87 miles.  Development of the SBN201 and SBN250 facilities may be as separate facilities or a single facility, but regardless of the final decision, SBN201 and SBN250 will be permitted under a single air permit.
Relationships  (c) Are any materials transferred between the plants? If so, list each material, state how o it is transferred and the rough percentage o each plant's total output that is transferred t each of the other plants.	ıf
(d) List any production employees or production managers common to two or more plants. Feach type of employee please state how off they travel between the plants.	For will not be shared with the other site.
(e) Is any production process split in any way between the plants? If so, please describe.	No, the data center operation at each site will be self-contained.  As said in the response to 2(b), each site will have its own emergency generators for backup power supply when the local electric supply is interrupted. The electricity generated by the emergency generators at one site will not be provided to supply the operations at the other site. Each site will have its own fuel storage for the emergency generators and will not supply fuel to the other site.
4. Additional Questions	
(a) Describe or attach any evidence or docume that indicate that these plants are operating one source.	
(b) Describe or attach any evidence or docume that indicate that these plants are separate sources.	nts
(c) If any of the plants indicated that they shou be combined or separated, please provide a facts that support that position.	
<ul> <li>(d) List any production employees or production managers common to two or more plants. Feach type of employee please state how off they travel between the plants.</li> <li>(e) Is any production process split in any way between the plants? If so, please describe.</li> <li>4. Additional Questions</li> <li>(a) Describe or attach any evidence or docume that indicate that these plants are operating one source.</li> <li>(b) Describe or attach any evidence or docume that indicate that these plants are separate sources.</li> <li>(c) If any of the plants indicated that they shou be combined or separated, please provide at the separated of the plants indicated that they shou be combined or separated, please provide at the second of the plants indicated that they shou be combined or separated, please provide at the second of the plants indicated that they shou be combined or separated, please provide at the second of the plants indicated that they shou be combined or separated, please provide at the second of the plants indicated that they should be combined or separated, please provide at the second of the plants indicated that they should be combined or separated.</li> </ul>	will not be shared with the other site.  The company may have the same administrative team (e.g., administrative assistants, human resources, payroll, etc.) to serve two sites, as well as other sites in this region. However, the administrative team does not affect the day-to-day operation at e site.  No, the data center operation at each site will be self-contained. As said in the response to 2(b), each site will have its own emergency generators for backup power supply when the local electric supply is interrupted. The electricity generated by the emergency generators at one site will not be provided to supply to operations at the other site. Each site will have its own fuel storage for the emergency generators and will not supply fuel to the other site.  The two sites will operate as two separate sources.  Ints  Id Each site will operate independently of each other and will not re

(d)	Set out any air compliance inspector's recommendation on whether the plants are one source.	
(e)	State any other issues or facts that should be considered.	
5.	Emissions Estimates	
(a)		The PTE of NOx and CO of each site will be greater than 100 tpy. The main emission units at each site are emergency generators, which are intermittent sources used only to provide power in the event of a utility outage and for routine testing/maintenance. Actual operations of the emergency generators will primarily depend on the local utility supply. The applicant proposes to limit the emissions of NOx (key pollutant from fuel combustion) from each site to be no more than 249 tpy.
	Is the combined/unlimited PTE any single/combined HAPs equal to or greater than 10/25 tpy, respectively?	No



SITE BOUNDARY

LOCATIONS OF SITES SBN100, SBN201, and SBN250

FIGURE A

Submitted to:

Indiana Department of Environmental Management Indianapolis, Indiana

Prepared for:

Razor5 LLC Site SBN100 New Carlisle, Indiana

Prepared by:

**Ramboll Americas Engineering Solutions, Inc** 

Date

April 2024

Project Number: **1940106677** 

# APPLICATION FOR NEW SOURCE MINOR PSD CONSTRUCITON APPROVAL AND TITLE V OPERATING PERMIT SBN100 SITE NEW CARLISLE, INDIANA

Ramboll 10851 Mastin St # 100 Overland Park, KS 66210 USA T +1 913-553-5922

www.ramboll.com

### CONTENTS

1.	Introduction	3
2.	Project Description	4
2.1	Generator Installation	4
2.2	Diesel Storage Tanks	5
3.	potential Emissions	7
3.1	Emergency Generators	7
3.2	Diesel Storage Tank Emissions	8
3.3	Facility Wide Potential Emissions	8
3.3.1	Proposed Permit Limits	9
4.	Regulatory Applicability	11
4.1	Federal Regulatory Requirements	11
4.1.1	New Source Review	11
4.1.2	Title V Operating Permit	11
4.1.3	New Source Performance Standards (NSPS), 40 CFR 60 Subpart	
	IIII	11
4.1.4	National Emissions Standards for Hazardous Air Pollutants	
	(NESHAP), 40 CFR 63 Subpart ZZZZ	13
4.2	Indiana Regulatory Requirements	13
4.2.1	326 IAC-5-2-1 – Opacity Limits	13
4.2.2	326 IAC 4-1 – Open Burning	13
4.2.3	326 IAC 6-4 – Fugitive Dust Emissions	13
4.2.4	326 IAC 6-2-1(d) – Particulate Emissions	13
4.2.5	326 IAC 6.5-1-2 - Particulate Emission Limitations	14
4.2.6	326 IAC 9 – Carbon Monoxide Emission Rules	14
4.2.7	326 IAC 10 - Nitrogen Oxides Rules	14

### FIGURES

Figure 1: Site Location Map
Figure 2: Site Layout Map
Figure 3: Process Flow Diagram

### APPENDICES

Appendix A: IDEM Permit Application Forms

Appendix B: Potential Emission Calculations

Appendix C: Generator Specifications and Emission Data

### 1. INTRODUCTION

Razor 5 LLC (Razor5) proposes to construct and operate a data center facility at an unimproved location at 55001 Larrison Blvd., New Carlisle, St. Joseph County, Indiana 46552 (referred to as "SBN100" or the "Site"). SBN100 will have two hundred and forty-eight (248) emergency back-up generators in various sizes with a total power generation capacity of 654 Megawatts (MW) and associated diesel fuel storage tanks in a phased construction schedule to provide back-up power to the data center operations. A Site Location Map and a Site Layout Map are included within this submittal as **Figure 1** and **Figure 2**, respectively.

Pursuant to Title 326 of the Indiana Administrative Code (326 IAC), Article 2 – Permit Review Rules, Rule 2-5.1-3, Razor5 is requesting the issuance of a New Source Minor Prevention of Significant Deterioration (PSD) Construction Approval, for the proposed construction since SBN100's potential-to-emit (PTE) is below the PSD major source thresholds. Additionally, this submittal also serves as a permit application to obtain a Part 70 Operating Permit under 326 IAC, Rule 2-7.

Section 2 of this application includes a description of the proposed emission units at the Site. Section 3 contains a description of the emission calculation methodologies used and proposed emission limits for the Site. Section 4 contains a discussion of applicable federal and state requirements for the proposed operations.

The completed Indiana Department of Environmental Management (IDEM) Permit Application Forms are included in **Appendix A**. Potential emission calculations for the emergency generators and diesel fuel storage tanks are provided in **Appendix B**. The manufacturer provided equipment specifications for generators and control devices, as well as performance and emission data, are included in **Appendix C**.

### 2. PROJECT DESCRIPTION

Electrical generators are used to supply emergency power to the operations at SBN100 as needed to protect critical data center functions during any interruptions in electrical service. Each emergency generator is composed of two (2) distinct parts, a diesel engine and the associated electric generator. Ultra-low sulfur diesel (ULSD) will be used to fuel the engines.

### 2.1 Generator Installation

The Site will install multiple types and quantities of emergency generators, as summarized in **Table 1** below.

For the critical emergency generators CEG No. 1-234 and the house generators HG No. 1-9, two model options have been chosen for each type of generators (Caterpillar or Cummins), but a final selection has not been made. The applicant requests to retain flexibility to select either model for installation. The manufacturer provided equipment specifications and emission data for all the models listed in **Table 1** are provided in **Appendix C**.

The following emergency generators meet the insignificant criteria in 326 IAC 2-7-1(21)(xxii)(bb) as they are emergency generators, burn diesel fuel only, and each has a power capacity less than 1,600 horsepower (1,193 kW):

- House emergency generators HG No. 1 9 (750 kW each)
- Ancillary emergency generator CAB Gen No. 1 (400 kW)
- Ancillary emergency generator CLB Gen No. 1 (400 kW)
- Ancillary emergency generator ACB Gen No. 1 (250 kW)

**Table 1 – List of Proposed Emergency Generators** 

Gen ID No.	Description	Model	Power Capacity per Gen	EPA Tier Level	Quantity
CEG No. 1 - 234	Critical	To be determined	2,750 kW	Tier 4-	234
	emergency	(CAT 3516E or		equivalent1	
	generators	Cummins DQLF)			
WTP Gens No. 1 & No. 2	Ancillary	CAT 3512C	1,500 kW	Tier 2	2
	emergency				
	generators for				
	water treatment				
	system				
HG No. 1 - 9	House	To be determined	750 kW	Tier 2	9
[Insignificant per 326	emergency	(CAT C18 or			
IAC 2-7-1(21)(xxii)(bb)]	generators (one	Cummins DQFAA)			
	for each data				
	center building)				
CAB Gen No. 1	Ancillary	CAT C15	400 kW	Tier 3	1
[Insignificant per 326	emergency				
IAC 2-7-1(21)(xxii)(bb)]	generator for				
	Admin Building				

Gen ID No.	Description	Model	Power Capacity per Gen	EPA Tier Level	Quantity
CLB Gen No. 1 [Insignificant per 326 IAC 2-7-1(21)(xxii)(bb)]	Ancillary emergency generator for Logistics Building	CAT C15	400 kW	Tier 3	1
ACB Gen No. 1 [Insignificant per 326 IAC 2-7-1(21)(xxii)(bb)]	Ancillary emergency generator for Security Building	CAT C9	250 kW	Tier 3	1

### Note:

 The 234 critical emergency generators will be powered by Tier 2-certified engines. Each critical emergency generator set will be equipped with a control system (SCR, DPF, DOC) to meet the Tier 4 emission standards.

As required under federal New Source Performance Standards Subpart for Stationary Compression Ignition Internal Combustion Engines (40 CFR 60 Subpart IIII), the engines will be certified to meet the United States Environmental Protection Agency (USEPA) applicable Tier emission standards in 40 CFR Part 1039, Appendix I. Specifically, the engines with a rated power capacity greater than 450 kW each will be certified to meet the Tier 2 emission standards and the engines less than 450 kW each will be certified to meet the Tier 3 emission standards.

Additionally, to be classified as emergency engines, the Site will operate all the engines in accordance with the run time restrictions for maintenance checks and readiness testing and use in non-emergency situations in accordance with 40 CFR 60.4211(f). The engines will not be used for peak shaving or demand response.

Each of the critical emergency generators CEG No. 1-234 (2750 kW each) will be equipped with an emission control system, which is a combined after-treatment system that integrates selective catalytic reduction (SCR), diesel oxidation catalyst (DOC), and diesel particulate filter (DPF) to meet the Tier 4 equivalent emission limits and avoid major source (i.e., PSD) permitting. A process flow diagram showing the operation of the critical engines is presented on **Figure 3**.

### 2.2 Diesel Storage Tanks

The proposed emergency generators will be equipped with individual belly tanks for storage of diesel fuel. The quantities and volume capacities of the belly tanks are listed in **Table 2** below.

Table 2 - List of Proposed Fuel Belly Tanks for Emergency Generators

Belly Tank ID No.	Volume Capacity	Quantity
BT No. 1 - 234	6,300 gallons each	234
BT HG No. 1 - 9	Up to 1,500 gallons each	9
BT WTP No. 1 & 2	5,000 gallons each	2
BT CAB No. 1	Up to 1,000 gallons	1
BT LCB No. 1	Up to 1,000 gallons	1
BT ACB No. 1	Up to 1,000 gallons	1

In addition to the above listed belly tanks, the Site will also have nine (9) bulk diesel fuel storage tanks (TK No. 1 – 9), each with a volume capacity of 12,000 gallons.

The above listed diesel fuel storage tanks meet the insignificant activity criteria in 326 IAC 2-7-1(21)(E)(iv) and the trivial activity criteria in 2-7-1 (42)(C)(i)&(ii)(DD).

### 3. POTENTIAL EMISSIONS

Emissions from SBN100 will be primarily from the combustion of fuel in the diesel-fired engines. These emissions include nitrogen oxides (NOx), volatile organic compounds (VOC), carbon monoxide (CO), sulfur dioxide (SO<sub>2</sub>), particulate matter (PM), particulate matter less than 10 micrometers in diameter (PM<sub>10</sub>), particulate matter less than 2.5 micrometers in diameter (PM<sub>2.5</sub>), hazardous air pollutants (HAPs) and greenhouse gases (GHGs). Additionally, VOC emissions may also result from the standing loss and working loss from the diesel storage tanks. This section describes the methodologies used to quantify the potential emissions from the emergency generators and tanks. Detailed emission calculations are included in **Appendix B**.

### **3.1 Emergency Generators**

Potential emissions of NO<sub>x</sub>, CO, PM, and VOC from the emergency generators are calculated using exhaust emission data (**Appendix C**) provided by the equipment manufacturer for each engine model. The manufacturer data includes emission factors in mass per power output per hour (i.e., grams per brake horsepower hour or g/BHP-hr) at various operating loads for the engine-generators (10%, 25%, 50%, 75%, and 100%). For each pollutant and each engine model, the maximum (worst-case) emission factor across all load levels is selected for a conservative estimate of the potential hourly emissions (see **Appendix B**, **Tables B.5.a – e** and **Tables B.7.a – f**).

As previously mentioned in Section 2.1, the final models for the critical emergency generators CEG No. 1-234 and the house generators HG No. 1-9, respectively, have not been selected. For a conservative estimate of the potential-to-emit (PTE) of each pollutant, the higher emission factor between the two model options is used in emission calculations for each type of generators.

As previously stated in Section 2.1, emission controls (SCR, DOC, and DRF) will be applied for the critical emergency generators CEG No. 1-234 to meet the EPA Tier 4 emission standards. Two sets of control systems, manufactured by Miratech and Safety Power, respectively, have been chosen as two options, but a final selection has not been made. The manufacturer provided control efficiencies of each system are provided in **Table 3** below. The specification sheets of the two control systems are attached in **Appendix C**. The post-controlled potential emissions from CEG No. 1-234 are conservatively calculated based on Miratech's control efficiencies, which are lower than Safety Power's control efficiencies, except VOC. The control efficiency for VOC is further reduced to 45% to provide a more conservative estimate of the potential VOC emissions.

Table 3 – Manufacturer Provided Control Efficiencies (Miratech & Safety Power)

Pollutant	Miratech Provided Control Efficiency	Safety Power Provided Control Efficiency	Control Efficiency used in PTE Calculations
NOx	91.7%	91.9%	91.7%
СО	70%	80%	70%
VOC	50%	60%	45%
Filterable PM	68.6%	75.6%	68.6%

Potential emissions of  $SO_2$  and HAPs are calculated based on the emission factors from AP-42 Chapter 3.3 – *Gasoline and Diesel Industrial Engines* for engines less than 600 kW and the emission factors from Chapter 3.4 – *Large Stationary Diesel and All Stationary Dual-fuel Engines* for engines greater than 600 kW.  $SO_2$  emissions are based on the use of ULSD, i.e. containing less than 0.0015% sulfur. GHG emissions are expressed in  $CO_2$  equivalent ( $CO_2$ e) emissions, using the global warming potentials for each compound published in 40 CFR 98, Table A-1 to Subpart A.

Potential annual pollutant emissions from the emergency generators are calculated based on the Site's anticipated annual fuel usage per engine type multiplied by an emission factor in pounds per gallon (lbs/gal) of fuel input. The lbs/gal factor for each engine type at each operating load is derived from the hourly emission rate (lbs/hr) divided by the corresponding hourly fuel consumption rate (gal/hr) from the manufacturer performance data. For each pollutant, the maximum lbs/gal emission factor across all load levels is selected for a conservative estimate of the potential annual emissions (see **Appendix B, Tables B.8.a-f** and **Tables B.10 – B.13**).

### 3.2 Diesel Storage Tank Emissions

VOC emissions may result from the standing and working losses from the proposed diesel fuel storage tanks associated with the engines. Potential emissions from the diesel fuel storage tanks, including the belly tanks and central fuel storage tanks, are calculated following the methodologies presented in AP-42, Chapter 7.1 (Organic Liquid Storage Tanks) and are provided in **Appendix B, Table B.14**.

The potential VOC emissions from all the diesel fuel storage tanks combined are approximately 0.21 tpy. No specific emission limits are proposed for the fuel storage tanks.

### 3.3 Facility Wide Potential Emissions

The calculated potential pollutant emissions from the proposed emission units at SBN100 are summarized in **Table 4** below. Although some of the emergency generators (HG No. 1-9, CAB Gen No. 1, CLB Gen No. 1, ACB Gen No. 1) and the diesel fuel storage tanks can be classified as insignificant activities under 326 IAC 2-7-1(21), their potential emissions are included in the facility wide emissions for source level determination. As shown in the table, the potential facility wide emissions of all criteria pollutants are below the PSD major source thresholds.

SBN100 will be a Title V source as the potential  $NO_X$  and CO emissions exceed 100 tpy. The potential HAP emissions from the Site are below the major HAP source thresholds (10 tpy for any single HAP and 25 tpy for any combination of HAPs).

Table 4 - Summary of Facility Wide Potential Emissions

Table 4 – Summary of Facility Wide Potential Emissions										
Emission Units	NOx	CO	PM/PM <sub>10</sub> /PM <sub>2.5</sub>	VOC	SO <sub>2</sub>	Max. Single HAP	Total HAPs			
CEG No. 1 - 234	236.80	90.41	10.52	38.44	0.54	0.17	0.35			
All Support Tier 2/Tier 3 Gens	12.05	19.19	1.33	7.75	1.53	0.004	0.01			
All Diesel Fuel Storage Tanks	<u>-</u>	<u>-</u>	-	0.21	-	Neg.	Neg.			
Total	Total 248.85 109.6		11.85	46.40	2.08	0.18	0.36			
PSD Threshold	250	250	250	250	250	-	-			
PSD Triggered?	No	No	No	No	No	-	-			
Major Title V Threshold	100	100	100	100	100	10	25			
Title V	Yes	Yes	No	No	No	No	No			

### 3.3.1 Proposed Permit Limits

Triggered?

Razor5 requests not to set operating hour limits for the emergency generators, except those run time restrictions set in the federal NSPS rule 40 CFR 60.4211(f) for emergency internal combustion engines (further discussed in Section 4.1.3.2 below).

The Site requests to limit the facility wide  $NO_X$  emissions below 249 tpy to avoid becoming a PSD major source. By limiting  $NO_X$  emissions below 249 tpy, the potential emissions of other criteria pollutants are inherently below the PSD major source thresholds. The Site also requests to limit the HAP emissions below 9 tpy for any single HAP and 24 tpy for any combination of HAPs to avoid becoming a major source of HAPs. The proposed emission limits are listed below:

Pollutant	<b>Proposed Emission Limits</b>
NO <sub>X</sub>	249 tpy
Single HAP	9 tpy
Total HAPs	24 tpy

In lieu of setting fuel usage limits for the emergency generators, the Site requests to comply with the proposed emission limits by tracking actual emissions using the following calculation methodology:

249 tpy of NO<sub>X</sub> 
$$\geq \sum_{i=1}^{n} \frac{EFNOxi*Qi}{2000 \ lbs/_{ton}}$$
 Where:

 $EF_{NOx}i = NO_X$  emission factor for engine model i (lbs/gal), Qi = Diesel fuel usage recorded per engine model (gal/yr).

The  $NO_X$  emission factor in lbs/gal for each engine model is derived from the manufacturer provided emission data (see **Appendix B**, **Tables B.8.a-f**). The maximum lbs/gal emission factors across all load levels will be used for actual emission tracking. The same calculation methodology will also be used to track actual emissions of other criteria pollutants and HAPs. The Site will maintain records of diesel fuel usage per engine model on a monthly and 12-month rolling basis for emission tracking.

### 4. REGULATORY APPLICABILITY

This section summarizes the applicability and non-applicability of key Federal and state regulations to the emission units at SBN100.

### 4.1 Federal Regulatory Requirements

Federal air quality regulations reviewed include federal permitting programs as well as New Source Performance Standards (NSPS) (40 CFR Part 60), pollutant- and category-specific National Emission Standards for Hazardous Air Pollutants (NESHAPs) (40 CFR Parts 61 and 63).

### 4.1.1 New Source Review

The current attainment status designations for areas within the State of Indiana are summarized in 40 CFR Section 81.315. The proposed site location is in St. Joseph County, which is designated as attainment or unclassifiable for all criteria pollutants. The New Source Review (NSR) program that potentially applies is PSD permitting requirements. State Rule 326 IAC 2-2 refers to the federal regulations 40 CFR 51.166 and 40 CFR 52.21 for implementation of PSD at major stationary sources. 40 CFR 51.21(b) defines "major stationary source" as "any stationary source which emits, or has the potential to emit, 250 tons per year or more of a regulated NSR pollutant".

As shown in Table 4 and Appendix B, Table B.1, potential site-wide emissions for attainment pollutants are below the PSD major source thresholds; therefore, the Site will be a non-PSD source after construction of the proposed emergency generators.

### 4.1.2 Title V Operating Permit

40 CFR Part 70 establishes the federal Title V operating permit program. IDEM has incorporated the provisions of this federal program in 326 IAC Rule 2-7. As demonstrated in Appendix B, the proposed Site is a major source with respect to Title V permitting because the Site has the potential to emit more than 100 tpy of NO<sub>X</sub> and CO.

The Site will not be a major source of HAPs because its potential HAP emissions will not exceed 10 tpy for any single HAP or 25 tpy for any combination of HAPs.

### 4.1.3 New Source Performance Standards (NSPS), 40 CFR 60 Subpart IIII

NSPS Subpart IIII applies to new, modified, and reconstructed compression ignition (CI) internal combustion engines (ICE). Pursuant to 40 CFR 60.4200(a)(2), new engines are subject to this regulation if construction of the CI ICE commenced after July 11, 2005, and if the engine was manufactured after April 1, 2006, for CI ICE that are not fire pump engines. This rule is applicable to all CI ICE that will be operated at SBN100 Site.

All generators at the Site will meet the definition of emergency stationary ICE in 40 CFR 60.4219. The engines installed at the facility will be emergency generators and will not operate as fire pump engines.

### 4.1.3.1 Emission Standards and Fuel Requirements

All generators at the site will be classified as emergency generators under this regulation and the engines will each have a displacement of less than 10 liters per cylinder. Per 40 CFR 60.4205(b)

and 60.4202, these engines must comply with the emission standards for Tier 2 or Tier 3 emission standards for new nonroad CI engines for the same rated power as described in 40 CFR part 1039, appendix I, for all pollutants. The applicable Tier 2/Tier 3 emission standards are depicted in **Table 5** below.

Table 5 - Applicable Emission Standards in 40 CFR 1039, Appendix I

Rated Power (kW)	Tier Level	Starting Model Year	NOX + NMHC (g/kW-hr)	CO (g/kW-hr)	PM (g/kW-hr)
130 ≤ kW ≤ 560	Tier 3	2006	4.0	3.5	0.2
kW > 560	Tier 2	2006	6.4	3.5	0.2

Additionally, smoke opacity from the engines may not exceed the following standards in 40 CFR 1039.105(b):

- 20 percent during the acceleration mode.
- 15 percent during the lugging mode.
- 50 percent during the peaks in either the acceleration or lugging modes.

Pursuant to 40 CFR 60.4207 and 40 CFR 1090.305, engines with a displacement of less than 30 liters per cylinder must use ultra-low sulfur diesel fuel that meets the following criteria:

- Maximum sulfur content of 15 ppm; and
- Either a minimum cetane index of 40 or a maximum aromatic content of 35 volume percent.

The SBN100 site will comply with the above-described emission standards by purchasing engines certified by the manufacturer to comply with the applicable Tier 2 or Tier 3 emission standards. Further, the site will operate and maintain each engine according to the manufacturer's emission-related written instructions and only change those emission-related settings that are permitted by the manufacturer.

### 4.1.3.2 Run Time Restrictions for Emergency ICE

For a stationary engine to be considered an emergency ICE under NSPS Subpart IIII, it must meet the run time restrictions in 40 CFR 60.4211(f).

Pursuant to 40 CFR 60.4211(f)(1), there is no restriction on usage of an emergency ICE in emergency situations. Each engine is restricted to a maximum of 100 hours per calendar year of operation for maintenance checks and readiness testing pursuant to 40 CFR 60.4211(f)(3). Each engine is allowed up to 50 hours per calendar year of non-emergency operation other than maintenance, testing; however, any non-emergency run time must be counted as part of the 100 hours per calendar year for maintenance and testing pursuant to 40 CFR 60.4211(f)(3). Pursuant to 40 CFR 60.4209(a), all engines at SBN100 Site will be equipped with non-resettable hour meters prior to startup of the engines for tracking of operating hours during emergency and non-emergency runs.

### 4.1.3.3 Notifications, Reporting and Recordkeeping

Pursuant to 40 CFR 60.4214(b), an initial notification under NSPS Subpart A is not required for emergency stationary ICE. The Site will retain records of the emergency and non-emergency runs for each engine, as recorded through the engine's non-resettable hour meter. The records will indicate the time of operation of the engine and the reason the engine was in operation during that time.

## 4.1.4 National Emissions Standards for Hazardous Air Pollutants (NESHAP), 40 CFR 63 Subpart ZZZZ

NESHAP Subpart ZZZZ applies to new and existing stationary reciprocating internal combustion engines (RICE) located at both major and area sources of HAP emissions. Pursuant to 40 CFR 63.6590(c), for new or reconstructed stationary RICE located at an area source of HAP emissions, the only requirement under NESHAP Subpart ZZZZ is to meet the requirements of NSPS Subpart IIII for CI ICE. Since the proposed generators at the Site will comply with NSPS Subpart IIII, the units will also maintain compliance with NESHAP Subpart ZZZZ. No further requirements apply to these engines under this regulation.

### 4.2 Indiana Regulatory Requirements

In addition to federal air regulations, Indiana has developed state regulations which apply to sources of air pollution. A summary of regulations applicable or potentially applicable to the proposed facility is provided in the following sections.

### 4.2.1 326 IAC-5-2-1 - Opacity Limits

Based on the location of the proposed Site, opacity shall meet the following:

- (a) Opacity shall not exceed an average of forty percent (40%) in any one (1) six (6) minute averaging period as determined in 326 IAC 5-1-4.
- (b) Opacity shall not exceed sixty percent (60%) for more than a cumulative total of fifteen (15) minutes (sixty (60) readings as measured according to 40 CFR 60, Appendix A, Method 9 or fifteen (15) one (1) minute nonoverlapping integrated averages for a continuous opacity monitor) in a six (6) hour period.

### 4.2.2 326 IAC 4-1 - Open Burning

The facility shall not open burn any material except as identified in 326 IAC 4-1-3, 326 IAC 4-1-4 or 326 IAC 4-1-6 unless provided an open burning approval by the Commissioner.

### 4.2.3 326 IAC 6-4 - Fugitive Dust Emissions

This condition is not applicable to the facility as they are not expected to be a source of fugitive dust. The facility will not allow "fugitive dust to escape beyond the property line or boundaries of the property, right-of-way, or easement on which the source is located" as it will not generate any of emissions from this category.

### 4.2.4 326 IAC 6-2-1(d) - Particulate Emissions

"Particulate emissions from the combustion of fuel for indirect heating from all facilities receiving permits to construct on or after September 21, 1983, shall be limited by section 4 of this rule." The facility does not produce heat or power by indirect heat transfer, therefore the particulate rules in Article 6 Section 4 are not applicable and the facility will comply with particulate rules

established in 326 IAC 2-8 where limits are set to limit source's potential to less than major source levels in agreement with Section 502(a) of the Clean Air Act.

### 4.2.5 326 IAC 6.5-1-2 - Particulate Emission Limitations

Pursuant to 326 IAC 6.5-1-1(a)(2), if the Site has:

- (A) the potential to emit 100 tons or more; or
- (B) actual emissions of 10 tons or more;

of PM per year, PM emissions from each emission unit shall not exceed seven-hundredths (0.07) gram per dry standard cubic meter (g/dscm) (three-hundredths (0.03) grain per dry standard cubic foot (dscf)).


### 4.2.6 326 IAC 9 - Carbon Monoxide Emission Rules

Sources are exempt from this rule if subject to a carbon monoxide emission limit, and the generators will be subject to NSPS IIII.

### 4.2.7 326 IAC 10 - Nitrogen Oxides Rules

326 IAC 10-1 is applicable to sources only in Clark and Floyd Counties; the facility is located in St. Joseph County and therefore the rule is not applicable.

**FIGURES** 




# INDIANA KEY MAP

RAZOR5 LLC - SBN100 55001 LARRISON BOULEVARD NEW CARLISLE, INDIANA

RAMBOLL AMERICAS ENGINEERING SOLUTIONS, INC.
A RAMBOLL COMPANY





- PROFER IV EQUIDARY (ASPECDIMATE)

SILUNG

SEMERATOR PAGE

Substation

3059 Potes


SITE LAYOUT MAP

RAZORS LLC - S8N100 SEXVI LARRESON (XXAD IPEW CARLERE, MAJANA

FIGURE 02

PANBOLL PARRICAS ELIGINEETIDIO SCALLHONS, RAS, KRUROSI COMPRA

RAMBÖLL



PROCESSS FLOW DIAGRAM

FIGURE 03

RAZOR5 LLC - SBN100 55001 LARRISON BOULEVARD NEW CARLISLE, INDIANA RAMBOLL AMERICAS ENGINEERING SOLUTIONS, INC. A RAMBOLL COMPANY



Razor5 LLC - Application for New Source Minor PSD Construciton Approval and Title V Operating Permit

APPENDIX A IDEM PERMIT APPLICATION FORMS



### AIR PERMIT APPLICATION COVER SHEET

State Form 50639 (R4 / 1-10)
INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

IDEM – Office of Air Quality – Permits Branch 100 N. Senate Avenue, MC 61-53 Room 1003 Indianapolis, IN 46204-2251 Telephone: (317) 233-0178 or Toll Free: 1-800-451-6027 x30178 (within Indiana) Facsimile Number: (317) 232-6749

www.IN.gov/idem

### NOTES:

- The purpose of this cover sheet is to obtain the core information needed to
  process the air permit application. This cover sheet is required for <u>all</u> air
  permit applications submitted to IDEM, OAQ. Place this cover sheet on
  top of all subsequent forms and attachments that encompass your air
  permit application packet.
- Submit the completed air permit application packet, including all forms and attachments, to IDEM Air Permits Administration using the address in the upper right hand corner of this page.
- IDEM will send a bill to collect the filing fee and any other applicable fees.
- Detailed instructions for this form are available on the Air Permit Application Forms website.

FOR OFFICE USE ONLY PERMIT NUMBER:
I LIGHT ROMBLIX.
DATE APPLICATION WAS RECEIVED:
State of Indiana
JUN 25 2024 CM. J
Dept of Environmental Mgmt Office of Air Quality

B .					_		 	 	 	 	-			
Š.														
	com H con o													
1 4	TOVIETA	la moon le	200											
1 .	Tax ID N	unu	JEI.											

	PART A: Purpose of Application					
8	• •	ose of this air permit app nt site as a whole and NO	• •	oses of this form, the term ons units.		
2.	Source / Company Name	: Razor5 LLC		3. Plant ID:		
4.	Billing Address:	251 Little Falls Drive				
	City: Wilmington		State: DE	ZIP Code: 19807_		
5.	Permit Level: Exe	emption	□SSOA □MSOP [	☐ FESOP ☐ TVOP ☐ PBR		
6.	Application Summary: Clarific choices selected below.	heck all that apply. Multiple p	permit numbers may be ass	signed as needed based on the		
		☐ Renewal of Operating P	ermit	sphalt General Permit		
	Review Request	☐ Revocation of Operating	Permit	Iternate Emission Factor Request		
	☐ Interim Approval	☐ Relocation of Portable S	Source	cid Deposition (Phase II)		
	Site Closure	☐ Emission Reduction Cre	dit Registry			
	☐ Transition (between per	rmit levels) From:		То:		
	☐ Administrative Amendm	nent: 🔲 Company Name (	Change	☐ Change of Responsible Official		
		☐ Correction to Non	-Technical Information	☐ Notice Only Change		
<u> </u>		Other (specify):				
l	☐ Modification: ☐ Nev	v Emission Unit or Control Devic	e  Modified Emission L	Init or Control Device		
	☐ New	v Applicable Permit Requirement	Change to Applicable	ility of a Permit Requirement		
	☐ Prev	vention of Significant Deterioration	on 🔲 Emission Offset	☐ MACT Preconstruction Review		
	☐ Mine	or Source Modification	Significant Source Modification	on		
	☐ Mind	or Permit Modification	Significant Permit Modificatio	n		
	☐ Othe	er (specify):				
7.	Is this an application for an	initial construction and/or op	erating permit for a "Gree	nfield" Source? 🔲 Yes 🛛 No		
8.	ls this an application for co	nstruction of a new emissions	s unit at an <b>Existing Sour</b>	ce? ☐ Yes ⊠ No		

PART B: Pre-Application Meeting
Part B specifies whether a meeting was held or is being requested to discuss the permit application.
9. Was a meeting held between the company and IDEM prior to submitting this application to discuss the details of the project?
⊠ No ☐ Yes: Date:
10. Would you like to schedule a meeting with IDEM management and your permit writer to discuss the details of this project?
☐ No
PART C: Confidential Business Information  Part C identifies permit applications that require special care to ensure that confidential business information is kept separate from the public file.  Claims of confidentiality must be made at the time the information is submitted to IDEM, and must follow the requirements set out in the Indiana Administrative Code (IAC). To ensure that your information remains confidential, refer to the IDEM, OAQ information regarding submittal of confidential business information. For more information on confidentiality for certain types of business information, please review IDEM's Nonrule Policy Document Air-031-NPD regarding Emission Data.  11. Is any of the information contained within this application being claimed as Confidential
Business Information?  ⊠ No ☐ Yes
NO ☐ 1es
PART D: Certification Of Truth, Accuracy, and Completeness  Part D is the official certification that the information contained within the air permit application packet is truthful, accurate, and complete. Any air permit application packet that we receive without a signed certification will be deemed incomplete and may result in denial of the permit.  For a Part 70 Operating Permit (TVOP) or a Source Specific Operating Agreement (SSOA), a "responsible official" as defined in 326 IAC 2-7-1(34) must certify the air permit application. For all other applicants, this person is an "authorized Individual" as defined in 326 IAC 2-1.1-1(1).
I certify under penalty of law that, based on information and belief formed after reasonable inquiry, the statements and information contained in this application are true, accurate, and complete.
Pamela A. Gregorski President  Name (typed) Title
Signature Title 4/11/24



# OAQ AIR PERMIT APPLICATION – FORMS CHECKLIST State Form 51607 (R5 / 1-10) INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

IDEM – Office of Air Quality – Permits Branch
100 N. Senate Avenue, MC 61-53 Room 1003
indianapolis, IN 46204-2251
Telephone: (317) 233-0178 or
Toll Free: 1-800-451-6027 x30178 (within Indiana)
Facsimile Number: (317) 232-6749
www.IN.gov/idem

NOTES:

- . The purpose of this checklist is to help the applicant and IDEM, OAQ ensure that the air permit application packet is administratively complete. This checklist is a required form.
- Check the appropriate box indicating whether each application form is applicable for the current permit application. The source must submit only those forms pertinent to the current permit application.
- Place this checklist between the cover sheet and all subsequent forms and attachments that encompass your air permit application packet.

		Part	A: General S	ource Data
Applicable?	Form ID	Title of Form	State Form Number	When should this form be included in my application packet?
⊠Y □N	COVER	Application Cover Sheet	50639	Include for every application, modification, and renewal, including source specific operating agreements (SSOA).
⊠Y □N	CHECKLIST	Forms Checklist	51607	Include for every application, modification, and renewal, including SSOA.
⊠Y □N	GSD-01	Basic Source Level Information	50640	Include for every application, modification, and renewal, including SSOA.
⊠Y □N	GSD-02	Plant Layout Diagram	51605	Include for every new source application, and modification.
⊠Y □N	GSD-03	Process Flow Diagram	51599	Include one for every process covered by the application.
⊠Y □N	GSD-04	Stack / Vent Information	51606	Include for every new source application, and modification.
⊠Y □N	GSD-05	Emissions Unit Information	51610	Include for every process covered by the application.
⊠Y □N	GSD-06	Particulate Emissions Summary	51612	Include if the process has particulate emissions (PM).
⊠Y □N	GSD-07	Criteria Pollutant Emissions Summary	51602	Include if the process has criteria pollutant emissions.
⊠Y □N	GSD-08	HAP Emissions Summary	51604	Include if the process has hazardous air pollutant emissions (HAP).
□Y ⊠N	GSD-09	Summary of Additional Information	51611	Include if the additional information is included.
⊠Y □N	GSD-10	Insignificant Activities	51596	Include if there are unpermitted insignificant activities.
□Y ⊠N	GSD-11	Alternative Operating Scenario	51601	Include if an AOS is requested.
□Y ⊠N	GSD-12	Affidavit of Nonapplicability	51600	Include if the standard notification requirements do not apply.
⊠Y □N	GSD-13	Affidavit of Applicability	51603	Include if the standard notification requirements apply.
⊠Y □N	GSD-14	Owners and Occupants Notified	51609	Include if the standard notification requirements apply.
⊠Y □N	GSD-15	Government Officials Notified	51608	Include if the standard notification requirements apply.
□Y ⊠N	RENEWAL	Renewal Checklist	51755	Include with every operating permit renewal packet.

<b>(</b> )		Pai	t B: Process	nformation
Applicable?	Form ID	Title of Form	State Form Number	When should this form be included in my application packet?
⊠Y □N	AEF-01	Alternate Emission Factor Request	51860	Submit if you are requesting to use an emission factor other than AP-42.
□Y ⊠N	PI-01	Miscellaneous Processes	52534	Include one form for each process for which there is not a specific PI form.
⊠Y □N	PI-02A	Combustion Unit Summary	52535	Include one form to summarize all combustion units (unless SSOA).
□Y ⊠N	PI-02B	Combustion: Boilers, Process Heaters, & Furnaces	52536	Include one form for each boiler, process heater, or furnace (unless SSOA).
⊠Y □N	PI-02C	Combustion: Turbines & Internal Combustion Engines	52537	Include one form for each turbine or internal combustion engine (unless SSOA).
□Y ⊠N	PI-02D	Combustion: Incinerators & Combustors	52538	Include one form for each incinerator or combustor (unless SSOA).
□Y ⊠N	PI-02E	Combustion: Kilns	52539	Include one form for each kiln (unless SSOA).
⊠Y □N	PI-02F	Combustion: Fuel Use	52540	Include one form for each combustion unit (unless SSOA).
⊠Y □N	PI-02G	Combustion: Emission Factors	52541	Include one form for each combustion unit (unless SSOA).
⊠Y □N	PI-02H	Combustion: Federal Rule Applicability	52542	Include one form for each combustion unit (unless SSOA).
⊠Y □N	PI-03	Storage and Handling of Bulk Material	52543	Include if the process involves the storage and handling of bulk materials.
□Y ⊠N	PI-04	Asphalt Plants	52544	Include for each asphalt plant process (unless general permit).
□Y ⊠N	PI-05	Brick / Clay Products	52545	Include for each brick and/or clay products process.
□Y ⊠N	PI-06	Electroplating Operations	52546	Include for each electroplating process.
□Y ⊠N	PI-07	Welding Operations	52547	Include for each welding process.
□Y ⊠N	PI-08	Concrete Batchers	52548	Include for each concrete batcher (unless SSOA).
□Y ⊠N	PI-09	Degreasing	52549	Include for each degreasing process (unless SSOA).
□Y ⊠N	PI-10	Dry Cleaners	52550	Include for each dry cleaning process
□Y ⊠N	PI-11	Foundry Operations	52551	Include for each foundry process
□Y ⊠N	PI-12	Grain Elevators	52552	Include for each grain elevator (unless SSOA).
□Y ⊠N	PI-13	Lime Manufacturing	52553	Include for each lime manufacturing process.
□Y ⊠N	PI-14	Liquid Organic Compound Storage	52554 (doc)	Include if the process involves the storage of liquid organic compounds.
□Y ⊠N	PI-14ALT	Alternate version of Liquid Organic Compound Storage	52555 (xls)	Include if the process involves the storage of liquid organic compounds and there are several storage vessels.
□Y ⊠N	PI-15	Portland Cement Manufacturing	52556	Include for each Portland cement manufacturing process.
□Y ⊠N	PI-16	Reinforced Plastics & Composites	52557	Include for each reinforced plastics and composites process.

Continued on Next Page

Indiana Department of Environmental Management Office of Air Quality State Form 51607 (R5 / 1-10)

	F 100 200	Par	t B: Process I	nformation
Applicable?	Form ID	Title of Form	State Form Number	When should this form be included in my application packet?
□Y ⊠N	PI-17	Blasting Operations	52558	Include for each blasting process (unless SSOA).
□Y ⊠N	PI-18	Mineral Processing	52559	Include if the process involves mineral processing (unless SSOA).
□Y ⊠N	PI-19	Surface Coating & Printing Operations	52560	Include for each surface coating or printing process (unless SSOA).
□Y ⊠N	PI-20	Woodworking / Plastic Machining	52561	Include for each woodworking or plastic machining process (unless SSOA).
□Y ⊠N	PI-21	Site Remediation	52570	Include for each soil remediation process.
□Y ⊠N	PI-22	Ethanol Plants (Under Development)	None	Include for each ethanol plant.

	Part C: Control Equipment					
Applicable?	Form ID	Title of Form	State Form Number	When should this form be included in my application packet?		
⊠Y □N	CE-01	Control Equipment Summary	51904	Include if add-on control equipment will be used for the process.		
□Y ⊠N	CE-02	Particulates – Baghouse / Fabric Filter	51953	Include for each baghouse or fabric filter.		
□Y ⊠N	CE-03	Particulates – Cyclone	52620	Include for each cyclone.		
□Y ⊠N	CE-04	Particulates – Electrostatic Precipitator	52621	Include for each electrostatic precipitator.		
□Y ⊠N	CE-05	Particulates – Wet Collector / Scrubber / Absorber	52622	Include for each wet collector, scrubber, or absorber.		
□Y ⊠N	CE-06	Organics - Flare / Oxidizer / Incinerator	52623	Include for each flare, oxidizer, or incinerator.		
□Y ⊠N	CE-07	Organics – Adsorbers	52624	Include for each adsorber.		
□Y ⊠N	CE-08	Organics – Condenser	52625	Include for each condenser.		
□Y ⊠N	CE-09	Reduction Technology	52626	Include for each control device using reduction technology (e.g., SCR, SNCR).		
⊠Y □N	CE-10	Miscellaneous Control Equipment	52436	Include one form for equipment for which there is not a specific CE form.		

	Part D: Compliance Determination for Part 70 Sources					
Applicable?	Form ID	Title of Form	State Form Number	When should this form be included in my application packet?		
⊠Y □N	CD-01	Emissions Unit Compliance Status	51861	Include for every Title V application, including modifications.		
⊠Y □N	CD-02	Compliance Plan by Applicable Requirement	51862	Include for every Title V application, including modifications.		
⊠Y □N	CD-03	Compliance Plan by Emissions Unit	51863	Include for every Title V application, including modifications.		
N N N	CD-04	Compliance Schedule and Certification	51864	Include for every Title V application, including modifications and renewal.		
⊠Y □N	FED-03	Compliance Assurance Monitoring	53377	Include for every Title V application, including modifications.		

	Part E: Best Available Control Technology						
Applicable?	Form ID	Title of Form	State Form Number	When should this form be included in my application packet?			
□Y ⊠N	BACT-01	Analysis of Best Available Control Technology	None	Include for every BACT application.			
□Y ⊠N	BACT-01a	Background Search: Existing BACT Determinations	None	Include for every BACT application.			
□Y ⊠N	BACT-01b	Cost/Economic Impact Analysis	None	Include for every BACT application.			
□Ү □И	BACT-02	Summary of Best Available Control Technology	None	Include for every BACT application.			
□Y ⊠N	PSD / EO-01	PSD / Emission Offset Checklist	None	Include for every PSD application and every NSR application that requires emission offsets.			

	Part F: Emission Credit Registry					
Applicable?	Form ID	Title of Form	State Form Number	When should this form be included in my application packet?		
□Y⊠N	EC-01	Generation of Emission Credits	51783	Include if the modification results in emission reductions.		
□Y ⊠N	EC-02	Transfer of Emission Credits	51784	Submit whenever registered emission credits are transferred.		
□Y ⊠N	EC-03	Use of Emission Credits	51785	Include if the modification requires the use of emission credits for offsets.		
□Y ⊠N	EC-04	Emission Credit Request	51906	Submit if you are looking for emission credits for offsets.		

Continued on Next Page

Indiana Department of Environmental Management Office of Air Quality State Form 51607 (R5 / 1-10)

<b>C</b> .	Part G: Plantwide Applicability Limits						
Applicable?	Form ID	Title of Form	State Form Number	When should this form be included in my application packet?			
□Y ⊠N	PAL-01	Actuals Plantwide Applicability Limit	52451	Include if the modification results in emission reductions.			
□Y ⊠N	PAL-02	Revised Plantwide Applicability Limit	52452	Submit whenever registered emission credits are transferred.			
□Y ⊠N	PAL-03	Plantwide Applicability Limit Renewal	52453	Include if the modification requires the use of emission credits for offsets.			
□Y ⊠N	PAL-04	Request for Termination of Plantwide Applicability Limit	52454	Submit if you are looking for emission credits for offsets.			

			Part H: Air T	oxics
Applicable?	Form ID	Title of Form	State Form Number	When should this form be included in my application packet?
⊠Y □N	FED-01	Summary of Federal Requirements – NSPS & NESHAP	53512	Include for each 40 CFR Part 60 NSPS, 40 CFR Part 61 NESHAP, and 40 CFR Part 63 NESHAP applicable to the process.
□Y ⊠N	FED-02	MACT Pre-Construction Review	51905	Include if constructing or modifying a process subject to a Part 63 NESHAP.
□Y ⊠N	No Form ID	MACT Initial Notification	None	This form is available on the U.S. EPA website. Completed notifications should be submitted to the IDEM Compliance Branch.

11.4		Pa	rt I: Special	Permits -
Applicable?	Form ID	Title of Form	State Form Number	When should this form be included in my application packet?
□Y ⊠N	INTERIM	Interim Approval	None	Submit if you are applying for interim operating approval.
□Y ⊠N	ASPHALT	Asphalt General Permit	None	Submit if you are applying for or modifying an asphalt plant general permit.
□Y ⊠N	NOXBTP	NO <sub>x</sub> Budget Permit	None	Submit if you are a power plant or if you have opted in to the NO <sub>X</sub> budget trading program.
□Y ⊠N	ACIDRAIN	Phase 2 Acid Rain Permit	None	Submit if you are applying for, modifying, or renewing a Phase 2 Acid Rain permit.

Part J: Source Specific Operating Agreements (SSOA)								
Applicable? Form ID		Title of Form	State Form Number	When should this form be included in my application packet?				
□Y ⊠N	OA-01	Summary of Application and Existing Agreements	53438	Submit if you are applying for or modifying a Source Specific Operating Agreement.				
□Y ⊠N	OA-02	Industrial / Commercial Surface Coating Operations -OR- Graphic Arts Operations (326 IAC 2-9-2.5)	53439	Submit if you are applying for or modifying a SSOA for industrial or commercial surface coating operations not subject to 326 IAC 8-2; or graphic arts operations not subject to 326 IAC 8-5-5.				
□Y ⊠N	OA-03	Surface Coating or Graphic Arts Operations (326 IAC 2-9-3)	53440	Submit if you are applying for or modifying a SSOA for surface coating or graphic arts operations.				
□Y ⊠N	OA-04	Woodworking Operations (326 IAC 2-9-4)	53441	Submit if you are applying for or modifying a SSOA for woodworking operations.				
□Y ⊠N	OA-05	Abrasive Cleaning Operations (326 IAC 2-9-5)	53442	Submit if you are applying for or modifying a SSOA for abrasive cleaning operations.				
□Y ⊠N	OA-06	Grain Elevators (326 IAC 2-9-6)	53443	Submit if you are applying for or modifying a SSOA for grain elevators.				
□Y ⊠N	OA-07	Sand And Gravel Plants (326 IAC 2-9-7)	53444	Submit if you are applying for or modifying a SSOA for sand and gravel plants.				
□Y ⊠N	0A-08	Crushed Stone Processing Plants (326 IAC 2-9-8)	53445	Submit if you are applying for or modifying a SSOA for crushed stone processing plants.				
□Y ⊠N	OA-09	Ready-Mix Concrete Batch Plants (326 IAC 2-9-9)	53446	Submit if you are applying for or modifying a SSOA for ready-mix concrete batch plants.				
□Y ⊠N	OA-10	Coal Mines And Coal Preparation Plants (326 IAC 2-9-10)	53447	Submit if you are applying for or modifying a SSOA for coal mines and coal preparation plants.				
□Y ⊠N	OA-11	Automobile Refinishing Operations (326 IAC 2-9-11)	53448	Submit if you are applying for or modifying a SSOA for automobile refinishing operations.				
□Y ⊠N	OA-12	Degreasing Operations (326 IAC 2-9-12)	53449	Submit if you are applying for or modifying a SSOA for degreasing operations.				
□Y ⊠N	OA-13	External Combustion Sources (326 IAC 2-9-13)	53450	Submit if you are applying for or modifying a SSOA for external combustion sources.				
□Y ⊠N	OA-14	Internal Combustion Sources (326 IAC 2-9-14)	53451	Submit if you are applying for or modifying a SSOA for internal combustion sources.				



# OAQ GENERAL SOURCE DATA APPLICATION GSD-01: Basic Source Level Information

State Form 50640 (R5 / 1-10)
INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

JUN 25 2024

R. A.

IDEM - Office of Air Quality - Permits Branch 100 N. Senate Avenue, MC 61-53 Room 1003

Indianapolis, IN 46204-2251 Telephone: (317) 233-0178 or Toll Free: 1-800-451-6027 x30178 (within Indiana)

Facsimile Number: (317) 232-6749 www.lN.gov/idem

### NOTES:

- Dept of Environmental Migmt

  The purpose of GSD-01 is to provide section in the purpose of GSD-01 is to provide section in the entire source of air pollutant emissions. GSD-01 is a required form.
- Detailed instructions for this form are available on the Air Permit Application Forms website.
- All information submitted to IDEM will be made available to the public unless it is submitted under a claim of confidentiality. Claims
  of confidentiality must be made at the time the information is submitted to IDEM, and must follow the requirements set out in 326
  IAC 17.1-4-1. Failure to follow these requirements exactly will result in your information becoming a public record, available for
  public inspection.

PART A: Source / Company Location Information								
1. Source / Company Name: Razor 5 LLC	2. Plant ID: —							
3. Location Address: 55001 Larrison Blvd.								
City: New Carlisle	State: IN ZIP Code: 46552 –							
4. County Name: St. Joseph	5. Township Name: Olive							
6. Geographic Coordinates:								
Latitude: 41.693524	<b>Latitude</b> : 41.693524 <b>Longitude</b> : -86.461739							
7. Universal Transferal Mercadum Coordinates (if know								
Zone: 16T Horizontal: 54	4799.23 <b>Vertical</b> : 4615885.88							
8. Adjacent States: Is the source located within 50 miles of an adjacent state?								
☐ No ☐ Yes – Indicate Adjacent State(s): ☐ Illinois (IL	☐ No ☐ Yes – Indicate Adjacent State(s): ☐ Illinois (IL) ☐ Michigan (MI) ☐ Ohio (OH) ☐ Kentucky (KY)							
9. Attainment Area Designation: Is the source located within a non-attainment area for any of the criteria air pollutants?								
No ☐ Yes – Indicate Nonattainment Pollutant(s): ☐ CO ☐ Pb ☐ NO <sub>x</sub> ☐ O <sub>3</sub> ☐ PM ☐ PM <sub>10</sub> ☐ PM <sub>2.5</sub> ☐ SO <sub>2</sub>								
10. Portable / Stationary: Is this a portable or stationary source? ☐ Portable ☒ Stationary								
PART B: Source Summary								
11. Company Internet Address (optional):								
12. Company Name History: Has this source operated under any other name(s)?								
No								
13. Portable Source Location History: Will the location of the portable source be changing in the near future?								
⊠ Not Applicable ☐ No ☐ Yes – Complete								
14. Existing Approvals: Have any exemptions, registrations, or permits been issued to this source?								
15. Unpermitted Emissions Units: Does this source have any unpermitted emissions units?								
No ☐ Yes – List all unpermitted emissions units in Part N, Unpermitted Emissions Units.								
16. New Source Review: Is this source proposing to construct or modify any emissions units?								
☐ No ☐ Yes – List all proposed new construction in Part O, New or Modified Emissions Units.								
17. Risk Management Plan: Has this source submitted a Risk Management Plan?								
Not Required								

PART C: Source C	ontact Information						
IDEM will send the original, signed permit decise. This person MUST be an employee of the permitte	sion to the person i	dentified in this section.					
18. Name of Source Contact Person: Pamela Gregorski							
19. Title (optional): President							
20. Mailing Address: 251 Little Falls Drive							
City: Wilmington	State: DE	<b>ZIP Code</b> : 19807 —					
21. Electronic Mail Address (optional): pamela.gregorski@	cscgfm.com						
<b>22.</b> Telephone Number: (312 ) 288 = 3860							
PART D: Authorized Individual/	Responsible Official Inf	ormation					
IDEM will send a copy of the permit decision to the Individual or Responsible Official is different from t	[1] Francisco Control of Contr						
24. Name of Authorized Individual or Responsible Official: Pamela Gregorski							
25. Title: President							
26. Mailing Address: 251 Little Falls Drive							
City: Wilmington	State: DE	<b>ZIP Code</b> : 19807_					
<b>27. Telephone Number</b> : (312) 288 - 3860	28. Facsimile Number	28. Facsimile Number (optional): ( ) –					
29. Request to Change the Authorized Individual or Responsible Official: Is the source officially requesting to change the person designated as the Authorized Individual or Responsible Official in the official documents issued by IDEM, OAQ? The permit may list the title of the Authorized Individual or Responsible Official in lieu of a specific name.							
PART F: Own	er Information						
30. Company Name of Owner: Razor5 LLC	G=IIIIOIIIIIIIIII						
31. Name of Owner Contact Person: Pamela Gregorski							
32. Mailing Address: 251 Little Falls Drive							
City: Wilmington	State: DE	<b>ZIP Code</b> : 19807					
33. Telephone Number: ( 312) 288 _ 3860	34. Facsimile Number						
34. Operator: Does the "Owner" company also operate the s	Diskoidanteija situria kales						
□ No − Proceed to Part F below. ☐ Yes − Enter "SAME AS OWNER" on line 35 and proceed to Part G below.							
	The Country of the State of the Country of the Coun	10 10 10 10 10 10 10 10 10 10 10 10 10 1					
	tor Information						
35. Company Name of Operator: Same as Owner							
36. Name of Operator Contact Person:							
37. Mailing Address:		<del></del>					
City:	State:	ZIP Code: –					
38. Telephone Number: ( ) –	39. Facsimile Number	r (optional): (      )					

PART G: Age	nt Information	THE REPORT OF THE PARTY OF THE				
40. Company Name of Agent: Ramboll Americas Engineer	ing Solutions, Inc.					
41. Type of Agent:						
42. Name of Agent Contact Person: Tingting Wang						
43. Mailing Address: 333 W. Wacker Dr., Suite 1050	r					
City: Chicago	State: IL	<b>ZIP Code</b> : 60606 –				
44. Electronic Mail Address (optional): twang@ram	iboll.com					
45. Telephone Number: (312) 292 – 6872       46. Facsimile Number (optional): ( ) –						
47. Request for Follow-up: Does the "Agent" wish to receive a copy of the preliminary findings ☐ No ☐ Yes during the public notice period (if applicable) and a copy of the final determination?						
during the public horice period (ii applicable) and a copy	Of the illar determination					
PART H: Local Li	brary Information					
48. Date application packet was filed with the local librar	y:					
49. Name of Library: New Carlisle-Olive Township Public	Library					
50. Name of Librarian (optional):						
51. Mailing Address: 408 S. Bray St.						
City: New Carlisle	State: IN	<b>ZIP Code</b> : 46552 –				
52. Internet Address (optional): https://ncpl.lib.in.us/						
53. Electronic Mail Address (optional):						
<b>54.</b> Telephone Number: (574) 654 - 3046	55. Facsimile Number (optional): ( ) –					
PART I: Company Nam	e History (if applicable					
Complete this section only if the source has previously opera above in Section A.	The transport of the second se	하는 아이들 마음이 얼마나 아이들의 사람들이 되었다. 그 그들은 그는 그는 그를 모르는 그를 모르는 것이 되었다. 그를 모르는				
56. Legal Name of Company		57. Dates of Use				
		to				
		to				
		to				
		to				
		to				
		to				
		to				
		to				
		to				
		to				
58. Company Name Change Request: Is the source officia	lly requesting to change	the legal name that will be printed				
on all official documents issued by IDEM, OAQ?	IN CITAL CON CONTRACTOR	ANDREAN E PRIMINENT DE COORDES E L'ANTREA ANNA MAINTE AND EUR PARE DE CONTRA DE L'ARREST DE CONTRA DE L'ARREST				

Address:

**County Name:** 

City:

Air Permit Application FORM GSD-01 Page 4 of 6

9. Plant ID	60. Location of the Portable Source	61. Dates at this Location
		to
		to
_		to
		to
_		to
		to
_		to
		to
		to
_		to
		to
		to
-		to
		to
		to

PART J: Portable Source Location History (if applicable)

State:

ZIP Code:

PART L Complete this section to summarize the main pro	:: Source Process Description ocesses at the source.		
64. Process Description	65. Products  The main emission units at the source will be the	66. SIC Code	67. NAICS Code
A data center facility with emergency generators for back-up electrical power and associated diesel fuel storage tanks	emergency generators, which generate electricity to supply back-up power for the data center facility.	7374	518210

	PART M: Existing Approvals (if applicable)							
Complete this se	Complete this section to summarize the approvals issued to the source since issuance of the main operating permit.							
68. Permit ID	69. Emissions Unit IDs	70. Expiration Date						
NA								

	PART N: Unpermitted Emissions Un	its (if applicable)						
Complete this se	ction only if the source has emission units that are not	listed in any perm	it issued by IDEM,	OAQ.				
73. Actual Dates								
71. Emissions Unit ID	72. Type of Emissions Unit	Began Construction	Completed Construction	Began Operation				
NA								

			PART O: New or Modified Emissions	<b>Units</b> (if applicabl	e)	
Complete this se	ction	only	if the source is proposing to add new emissi	on units or modify	existing emission	units.
	3	۵	A CONTROL OF THE CONT	78. Estima	ted Dates	
74. Emissions Unit ID	75. NE	76. MOD	77. Type of Emissions Unit	Begin Construction	Complete Construction	Begin Operation
CEG No. 1 - 234	Υ		Diesel powered emergency generators (critical emergency gens)			
HG No. 1 - 9	Υ		Diesel powered emergency generators (house gens)			

Indiana Department of Environmental Management Office of Air Quality State Form 50640 (R5 / 1-10) Air Permit Application FORM GSD-01 Page 6 of 6

State I UIII 30040 (I	(37 1-10)		age o or o
WTP Gens No. 1 & 2	Y	Diesel powered emergency generators (gen for water treatment system)	
CAB Gen No. 1,			
LCB Gen		Diesel powered emergency	
No.1, &		generators (ancillary gens for Admin	
ACB Gen	1	Building, Logistics Building, and	
No. 1	Υ	Security Building)	
		Diesel fuel storage, including 248	
	1	belly tanks in various sizes for the	
Diesel fuel		generators and nine (9)	
storage		aboveaground central fuel storage	
tanks	Y	tanks.	



# OAQ GENERAL SOURCE DATA APPLICATION GSD-02: Plant Layout Diagram

State Form 51605 (R3 / 1-10)
INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

IDEM - Office of Air Quality - Permits Branch 100 N. Senate Avenue, MC 61-53 Room 1003 Indianapolis, IN 46204-2251 Telephone: (317) 233-0178 or Toll Free: 1-800-451-6027 x30178 (within Indiana) Facsimile Number: (317) 232-6749 www.IN.gov/idem

- The purpose of GSD-02 is to provide a diagram of the entire plant site. This form and a Plant Layout diagram are required for all air permit applications. If you do not provide the necessary information, applicable to your source, the application process may be stopped.
- IDEM, OAQ has provided detailed instructions for this form and an example of a basic plant layout diagram on the Air Permit Application Forms website.
- All information submitted to IDEM will be made available to the public unless it is submitted under a claim of confidentiality.
   Claims of confidentiality must be made at the time the information is submitted to IDEM, and must follow the requirements set out in 326 IAC 17.1-4-1. Failure to follow these requirements exactly will result in your information becoming a public record, available for public inspection.

	Part A: Basic Plant Layout
around the plant site. Please use this table	riate information about all buildings and access-limiting features in and eas a checklist. You must provide scaled drawings, with the actual scale early indicated with a brief explanation of what is being shown. Include the in in feet.):
1. Building Location and Dimensions	
2. Property Lines and Access-Limiting I	Features
3. Surrounding Building Location and D	Dimensions
4. Distances to Property Lines and Acc	ess-Limiting Features
5. X UTM Location Coordinates	6. ⊠ Compass (pointing North) 7. ⊠ Scale
Processing and William representative and the reference from the regions of the processing on the special stage and the region of the special stage of the special stage and the special stage of the	
	Part B: Stack Information
vents at the plant site. Please use this table points and include all relevant stack and emit identify each of these emission points under following (All measurements should be in fee 8.   Exhaust Stacks	riate information about all stacks, roof monitors, control devices, and process e as a checklist. You must show the location of all applicable emission ssions unit identification numbers for each. In addition, you will need to "Stack Identification" on form GSD-04, Stack/Vent Information. Include the et.):
9. Process Vents  10 Roof Monitors No Roof Mar	
No reconstruction	
11.  Control Devices  No Control D	
12. ☐ Interior Vents ☐ No Interior V	ents ☐ Doors and Windows (for processes vented inside a building)
STATE OF THE STATE OF	Part C: Roadway Information
	riate information about the roadways in and around the plant site. Please ollowing (All measurements should be in feet.):
<b>13</b> . ⊠ Adjacent Roadways ⊠ Interior	Roadways
14. 🛚 Roadway Surface Description (grave	el, dirt, paved, etc.)
15. 🛮 Number of Lanes	

#### Part D: Source Building Information This table provides detailed information about each building at the plant site that is part of the source. If additional space is needed, you may make a copy of this table. (All measurements should be given in feet.) 17. Building 18. Building Dimensions 19. Distance & direction to the nearest property 16. Building 20. Distance & direction to ID Description line or access limiting feature the nearest residence Length Width Height (feet & compass coordinate) (feet & compass coordinate) (feet) (feet) (feet) Data Center Bldg A 1005.00 222.00 35.00 138.00 North 3800.00 East Α В Data Center Bldg B 1005.00 222.00 35.00 138.00 North 3400.00 East C Data Center Bldg C 1005.00 222.00 35.00 117.00 North 5100.00 South D Data Center Bldg D 1005.00 222.00 35.00 117.00 North 4800.00 South E Data Center Bldg E 1005.00 222.00 35.00 117.00 North 4500.00 South Data Center Bldg F 1005.00 222.00 35.00 117.00 North South 4200.00 G Data Center Bldg G 1005.00 222.00 35.00 138.00 North 3000.00 East H Data Center Bldg H 1005.00 222.00 35.00 138.00 North 2255.00 East Data Center Bldg I 1005.00 222.00 35.00 179.00 East 2262.00 East WTR TRMT Water Treatment 25.00 483.00 189.00 570.00 NW 4000.00 South Building 200.00 100.00 25.00 CAB Admin Building 350.00 West 4100.00 East 200.00 100.00 CLB Logistics Building 25.00 350.00 West 4000.00 East ACB Security Building 40.00 35.00 12 120.00 West 4500.00 East

			Part E: Su	rrounding Bu	ilding / Residence Inform	ation			
This table provides d table. (All measuren				residence sur	rounding the plant site. If a	dditional space is needed	d, you may mak	ce a copy of this	
21. Surrounding Building /	22. Surrounding Building / Residence Property Dimensions			nearest	e & direction to the property line or access	24. Building ID of nearest building	the nea	25. Distance & direction to the nearest building on	
Residence Description	Lenan vylum ( sielum		1	limiting (feet &	feature compass coordinate)	on the plant site	the plant site (feet & compass coordinate)		
Residence Bldg 1	75.00	50.00	25.00	1800.00	South of the plant site	Data Center Bldg I	2700.00	South	
Residence Bldg 2	85.00	67.00	25.00	1900.00	East of the plant site	Data Center Bldg I	2400.00	East	
Residence Bldg 3	60.00	45.00	25.00	1900.00	East of the plant site	Data Center Bldg H	2400.00	East	
R+L Carriers Bldg 1	720.00	120.00	35.00	900.00 Sout	h of the plant site	Data Center Bldg I	2000.00	South	
R+L Carriers Bldg 2	175.00	115.00	35.00	875.00 Sout	h of the plant site	Data Center Bldg I	2250.00	South	
Master Roller Maf. Bldg	280.00	270.00	35.00	573.00 East		ACB Bldg	700.00 East	Andrew Manager Manager Manager Anna Manager Ma	
Clffs Tek New Carlisle Water Treatment Building	438.00	70.00	35.00	110.00 Nort	h	CAB Bldg	600.00 North	1	
I/N Tek Building	215.00	164.00	35.00	880.00 Nort	h	Data Center Bldg G	1020.00	North	
Tek & Kote Parking Bldg	216.00	160.00	35.00	794.00 NE		Data Center Bldg H	1230.00	NE	
Edcoat	920.00	325.00	35.00	977.00 East		Data Center Bldg H	1160.00	East	
		-	-						

Continued on Next Page

Indiana Department Of Environmental Management Office Of Air Quality State Form 51605 (R3 / 1-10) Air Permit Application FORM GSD-02 Page 4 of 4

Part F: Plant Layout Diagram
This space provides a place for a hand drawn plant layout diagram. It is <b>optional</b> to use this space to create your plant layout, but you must include the diagram with your application. If you choose to submit the plant layout in a different format, state "plant layout attached" in the space provided, and submit the information with your completed application. IDEM, OAQ has provided an example of a basic plant layout diagram on the Air Permit Applications Forms website.
See Figure 2



# OAQ GENERAL SOURCE DATA APPLICATION GSD-03: Process Flow Diagram

State Form 51599 (R3 / 1-10)
INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

IDEM – Office of Air Quality – Permits Branch 100 N. Senate Avenue, MC 61-53 Room 1003 Indianapolis, IN 46204-2251 Telephone: (317) 233-0178 or Toll Free: 1-800-451-6027 x30178 (within Indiana) Facsimile Number: (317) 232-6749 www.IN.qov/idem

- The purpose of GSD-03 is to provide a checklist for identifying the information to be included on each Process Flow diagram.
- Complete this form and submit a process flow diagram for each process included in your air permit application.
- IDEM, OAQ has provided detailed instructions for this form and an example of a basic process flow diagram on the Air Permit Application Forms website.
- All information submitted to IDEM will be made available to the public unless it is submitted under a claim of confidentiality. Claims
  of confidentiality must be made at the time the information is submitted to IDEM, and must follow the requirements set out in 326
  IAC 17.1-4-1. Failure to follow these requirements exactly will result in your information becoming a public record, available for
  public inspection.

			Part A: Process Flow	v Diagr	am					
indi	t A provides basic information t cate that you have included the unds per hour.):									
1.	.   Process Description: Diesel-powered emergency generators									
2.		3.		4.	□ Process Three     □ Process Three	roughput				
5.	Additions Deletions		Modifications							
and	e the space below to briefly exp l/or the reason for the proposed armation and indicate in the spa	l modi	fication. (If additional spa	ce is ne	eded, please atta					
Par	t B indicates the actual (or estin			for the	process.					
6.	□ Process Operation Sched	ule	Hours per Day	Day	ys per Week	Weeks Per Year				
7		(If ad at add ated f	lditional space is needed, ditional information is attac or emergency situations o	please a ched.) nly whe	attach a separate in the local electr					
tab	t C provides information about le as a checklist to indicate that build be given in pounds per hou Stack / Vent Information	you h		ant emi	ssions to the atm					
10.	☐ Air Pollution Control	····								
				مردس كمناسس بسيد						

Indiana Department Of Environmental Management Office Of Air Quality State Form 51599 (R3 / 1-10) Air Permit Application FORM GSD-03 Page 2 of 2

Part D: Process Flow Diagram
This space provides a place for a hand drawn process flow diagram. It is <b>optional</b> to use this space to create your process flow diagram, but you must include the diagram with your application. If you choose to submit the process flow diagram in a different format, state "process flow diagram attached" in the space provided, and submit the information with your completed application. IDEM, OAQ has provided an example of a basic <b>process</b> flow diagram on the Air Permit Applications Forms website.
See Figure 3



IDEM - Office of Air Quality - Permits Branch 100 N. Senate Avenue, MC 61-53 Room 1003

Indianapolis, IN 46204-2251 Telephone: (317) 233-0178 or Toll Free: 1-800-451-6027 x30178 (within Indiana) Facsimile Number: (317) 232-6749

www.tN.gov/idem

- The purpose of this form is to provide basic information about each stack or vent that has the potential to emit air pollutants. If you do not provide enough information to adequately describe each process vent and/or stack, the application process may be stopped. This form is required for all air permit applications.
- Detailed instructions for this form are available online on the Air Permit Application Forms website.
- All information submitted to IDEM will be made available to the public unless it is submitted under a claim of confidentiality. Claims of confidentiality must be made at the time the information is submitted to IDEM, and must follow the requirements set out in 326 IAC 17.1-4-1. Failure to follow these requirements exactly will result in your information becoming a public record, available for public inspection.

		AND BURGAN	Stack	/ Vent Informa	tion	Land State of the Control of the Con	
					ants could be released inte		an air stream is vented
1. Stack / Vent ID	2. Type (V H W O)	3. Shape (C R O)	4. Outlet Dimensions (feet)	5. Height (feet)	6. Maximum Outlet Flow Rate (acfm)	7. Outlet Gas Temperature (Degrees F)	8. Related Stacks / Vents (B P O)
S -1 thru S-234 for CEG No. 1- 234	V	С	1.83	36.00	22052.00	896.0	Р
S-WTP-1 & 2 for WTP Gens 1 & 2	V	С	1.50	36.00	11406.40	757.0	Р
S-HG-1 thru 9 for HG 1 - 9	V	С	0.83	9.00	6028.00	847.0	Р
S-CAB-1 for CAB Gen No. 1	V	С	0.50	8.00	3629.10	909.0	Р
S-LCB-1 for LCB Gen No. 1	V	С	0.50	8.00	3629.10	909.0	Р
S-ACB-1 for ACB Gen No. 1	V	С	0.42	8.00	2245.60	852.0	Р
V-TK-1 thru 9 for nine 12,000-gal Central Diesel Fuel Tanks	V	С	0.25	12.00	Negligible	Ambient	Р
L	<u> </u>	<u> </u>	<u> </u>	<u> </u>			



# OAQ GENERAL SOURCE DATA APPLICATION GSD-05: Emissions Unit Information

State Form 51610 (R3 / 1-10)
INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

IDEM – Office of Air Quality – Permits Branch 100 N. Senate Avenue, MC 61-53 Room 1003 Indianapolis, IN 46204-2251 Telephone: (317) 233-0178 or Toll Free: 1-800-451-6027 x30178 (within Indiana) Facsimile Number: (317) 232-6749

Facsimile Number: (317) 232-674 www.IN.gov/idem

### NOTES:

- The purpose of this form is to provide basic information about each emissions unit that has the potential to emit air pollutants. This form is required for all air permit applications.
- . Detailed instructions for this form are available online on the Air Permit Application Forms website.
- All information submitted to IDEM will be made available to the public unless it is submitted under a claim of confidentiality. Claims of confidentiality must be made at the time the information is submitted to IDEM, and must follow the requirements set out in 326 IAC 17.1-4-1. Failure to follow these requirements exactly will result in your information becoming a public record, available for public inspection.

# Emissions Unit Information

This table provides detailed information about each emissions unit that has the potential to emit air pollutants to the atmosphere. Accurate information is needed to determine the total potential to emit. If you do not provide enough information to adequately describe each emissions unit, the application process may be stopped. If additional space is needed, you may make a copy of this form.

1. Unit ID	2. Model Number	3. Serial Number	4. Description	5. Manufacturer	6. Installation Date	7. Maximum Capacity	8. Stack / Vent ID
CEG No. 1 - 234	TBD		234 critical emergency generators, powered by Tier 2 certified diesel engines, with control to meet Tier 4 equivalent emission standards.	TBD	Est. September, 2024	2750.00 kW, each	S-1 thru S- 234
WTP Gens No. 1 & 2	3512C		Two (2) ancillary emergency generators for water treatment system, Tier 2 certified engines, no control.	Caterpillar	Est. September, 2024	1500.00 kW, each	S-WTP-1 & S-WTP-2
HG No. 1 - 9	TBD		Nine (9) house gens (one for each data center building), powered by Tier 2 certified diesel engines, no control.	TBD	Est. September, 2024	750.00 kW, each	S-HG-1 thru S-HG-9
CAB Gen No. 1	C15		One (1) ancillary emergency generator for CAB (Admin Building)	Caterpillar	Est. September, 2024	400.00 kW	S-CAB-1
CLB Gen No. 1	C15		One (1) ancillary emergency generator for CLB (Logistics Building)	Caterpillar	Est. September, 2024	400.00 kW	S-CLB-1
ACB Gen No. 1	C9		One (1) ancillary emergency generator for ACB (Security Building)	Caterpillar	Est. September, 2024	400.00 kW	S-ACB-1
TK No. 1 - 9	TBD		Nine (9) 12,000-gallon aboveground storage tanks for storage of diesel fuel	TBD	Est. September, 2024	12000.00 gallons each	V-TK-1 thru V-TK-9



IDEM – Office of Air Quality – Permits Branch 100 N. Senate Avenue, MC 61-53 Room 1003 Indianapolis, IN 46204-2251 Telephone: (317) 233-0178 or Toll Free: 1-800-451-6027 x30178 (within Indiana) Facsimile Number: (317) 232-6749 www.IN.gov/fdem

- The purpose of this form is to provide basic information about each source of particulate emissions. This form is required for all air permit applications.
- Detailed instructions for this form are available on the Air Permit Application Forms website.
- All information submitted to IDEM will be made available to the public unless it is submitted under a claim of confidentiality. Claims of confidentiality must be made at the time the
  information is submitted to IDEM, and must follow the requirements set out in 326 IAC 17.1-4-1. Failure to follow these requirements exactly will result in your information
  becoming a public record, available for public inspection.

the appli	Administrative Code, Article 6, Particulate cation process may be stopped. If additi ssions Point			u may make a c	opy of this ta		ach source of particu	late emissions,
			T	T				T
1. ID	2. Description See Appendix B	3. PM	4. PM-10	5. PM-2.5	6. TSP	7. Fugitive Dust	8. Fugitive PM	9. HAPPM
							<u> </u>	
							<u> </u>	
				<b></b>				
		<u> </u>					-	
		<b> </b>		<del> </del>				

Indiana Department Of Environmental Management Office Of Air Quality State Form 51612 (R3 / 1-10)

	<b>三国的2015年1月1日的89年6月1日</b>	Part B: Control of Particulate Emissions	
		ulate emissions is controlled. If you do not provide enough information to adequat	
		cation process may be stopped. If additional space is needed, you may make a co	
10. Emissions Point ID CEG No. 1 - 234	11. Control Measure	Control Measure Description     Each of the critical emergency generators will be equipped with a control	13. Control Plan
020110.1 201	No Control	system, which is a combined after-treatment system that integrates selective	Yes No
	Dust Suppression	catalytic reduction (SCR), diesel oxidation catalyst (DOC), and DPF (diesel	Date Submitted:
	Other: Control System	particulate filter) to meet EPA Tier 4 equivalent emission standards.	
WTP Gens No. 1 & 2	No Control	·	Yes No
	Dust Suppression		Date Submitted:
	Other:		
HG No. 1 - 9	No Control		Yes No
	Dust Suppression		Date Submitted:
	Other:		
CAB Gen No. 1	No Control		Yes No
	Dust Suppression		Date Submitted:
	Other:		arramanin'i managamanin'i Princis
CLB Gen No. 1	No Control		Yes No
	Dust Suppression		Date Submitted:
	Other:		
ACB Gen No. 1	No Control		Yes No
	Dust Suppression	•	Date Submitted:
	Other:		
	☐ No Control		Yes No
	Dust Suppression		Date Submitted:
	Other:		
	☐ No Control		Yes No
	Dust Suppression		Date Submitted:
	Other:		<u> </u>

Indiana Department Of Environmental Management Office Of Air Quality State Form 51612 (R3 / 1-10)

Air Permitting Rules 326 IAC 6-4 and 326 IAC 6-5 require fugitive dust to be controlled as needed to prevent dust from visibly crossing property lines. Parts C and D summarize sources of fugitive particulate emissions from process operations and unpaved roads.

			PART C: Fug	itive Dust (if applica	able)		
Part C identifies n	neasures implemented for cor	ntrolling fugiti	ive particulate e	emissions from proce	ess operations and unpaved	roads.	
14. Dust Contro	Plans: Check all that apply.			15. Control Meas	ures:		
☐ Conveying	:	□Wet	☐ Dry				
Stock Piles	S:	Open	☐ Covered				
Unpaved F	Roads: Watered?	Yes	□No				
Other (spec	eify):						
Other (spec	eify):						
Other (spec	cify):						
				ic on Unpaved Roa	SO THE SOLE SOLES		
traffic. Two one-valine is the one-wa	ormation on vehicular traffic p way trips equal one round trip. y trip distance. Content of Unpaved	patterns when For externa	n the site contai al traffic (vehicle	ns unpaved roads. A sentering and leaving	All data should be provided a ng the property lines), the dis	assuming peak t stance from the	nours of vehicular plant to the property
Roads:							
17. Vehicle Description	18. Max. No. round trips at peak hours (trips/hr)	19. Dista way 1 (miles/		20. Max. vehicle speed (mph)	21. Max. gross vehicle weight (fully loaded) (tons)	22. Tare weight (tons)	23. No. of wheels on vehicle (wheels)
· L							
		-					
	<u></u>			<del></del>	<u> </u>		



# OAQ GENERAL SOURCE DATA APPLICATION GSD-07: Criteria Pollutant Emissions Summary State Form 51602 (R3 / 1-10) INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

IDEM – Office of Air Quality – Permits Branch 100 N. Senate Avenue, MC 61-53 Room 1003 Indianapolis, IN 46204-2251

Telephone: (317) 233-0178 or Toll Free: 1-800-451-6027 x30178 (within Indiana) Facsimile Number: (317) 232-6749 www.IN.goy/idem

- The purpose of this form is to provide the actual and potential emissions of each criteria pollutant emitted from the source. This form is required for all air permit applications.
- Detailed instructions for this form are available on the Air Permit Application Forms website.
- All information submitted to IDEM will be made available to the public unless it is submitted under a claim of confidentiality. Claims of confidentiality must be made at the time the
  information is submitted to IDEM, and must follow the requirements set out in 326 IAC 17.1-4-1. Failure to follow these requirements exactly will result in your information
  becoming a public record, available for public inspection.

			A: Unit Emissions Summa				
adequately c	des the actual and potel describe the emissions t	ntial emissions of each criteria po from each emissions unit, the app	llutant emitted from each en dication process may be sto	nissions unit. If you pped,	do not provide enough infor	mation to	
1. Unit ID	2. Stack / Vent ID	3. Criteria Pollutant	4. Actual Emi	issions	5. Potential To Emit		
			Standard Units	Tons Per Year	Standard Units	Tons Per Year	
	See Appendix B						
······································							
				1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1			
		A111					

Indiana Department Of Environmental Management Office Of Air Quality State Form 51602 (R3 / 1-10)

Pan(B)	Pollutant Emissions Sumn	iary		CONTRACTOR STATE	
Part B provides the total actual and potential emissions of each criter the source). If you do not provide enough information to adequately					
6. Criteria Pollutant	7. Actual Emi	ssions	8. Potential To Emit		
	Standard Units	Tons Per Year	Standard Units	Tons Per Year	
Carbon Monoxide (CO)	See Appendix B				
Lead (Pb)					
Nitrogen Oxides (NOx)					
Particulate Matter (PM)					
Particulate Matter less than 10μm (PM <sub>10</sub> )					
Particulate Matter less than 2.5μm (PM <sub>2.5</sub> )					
Sulfur Dioxide (SO <sub>2</sub> )					
Volatile Organic Compounds (VOC)					
Other (specify):					

## Part C: Fugitive VOC Emissions (if applicable) Part C summarizes the sources of fugitive VOC emissions at the source and estimates VOC emissions from these emission points. Complete this table if you are required to provide fugitive emissions data pursuant to 326 IAC 2-2 or 326 IAC 2-3. 9. Fugitive Emissions Source 10. Emission Factor 11. Number 12. Uncontrolled Potential To Emit Leaking (lb/hr) **Pounds Per Hour** Tons Per Year NA Compressor Seals Flanges Open-Ended Lines Pressure Relief Seals Pump Seals Sampling Connections Valves Other (specify):



# **OAQ GENERAL SOURCE DATA APPLICATION** GSD-08: Hazardous Air Pollutant Emissions Summary State Form 51604 (R3 / 1-10) INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

IDEM - Office of Air Quality - Permits Branch 100 N. Senate Avenue, MC 61-53 Room 1003 Tou N. Senate Avenue, Mc. 61-53 Room 1003 Indianapolis, IN 46204-2251 Telephone: (317) 233-0178 or Toll Free: 1-800-451-6027 x30178 (within Indiana) Facsimile Number: (317) 232-6749

www.IN.gov/idem

- The purpose of this form is to provide the actual and potential emissions of each hazardous air pollutant emitted from the source. This form is required for all air permit
- Detailed instructions for this form are available on the Air Permit Application Forms website.
- All information submitted to IDEM will be made available to the public unless it is submitted under a claim of confidentiality. Claims of confidentiality must be made at the time the information is submitted to IDEM, and must follow the requirements set out in 326 IAC 17.1-4-1. Failure to follow these requirements exactly will result in your information becoming a public record, available for public inspection.

			Part /	A: Unit Emissions Summa	ary		
				s air pollutant emitted from plication process may be st		If you do not provide enou	gh information to
1. Unit ID	2. Stack /	3. Hazardous Air	4. CAS	5. Actual En	nissions	6. Potential T	o Emit
	Vent ID	Pollutant	Number	Standard Units	Tons Per Year	Standard Units	Tons Per Year
See Append	lix B						
· · · · · · · · · · · · · · · · · · ·							

# Part B provides the total actual and potential emissions of each hazardous air pollutant emitted from the source (including all emissions units and fugitive emissions at the source). If you do not provide enough information to adequately describe the total source emissions, the application process may be stopped. 7. Hazardous Air Pollutant 8. CAS Number 8. CAS Number 9. Actual Emissions 10. Potential To Emit Tons Per Year Standard Units Tons Per Year Standard Units Tons Per Year Part C: Fugitive HAP Emissions (If applicable) Part C: summarizes the sources of fugitive HAP emissions at the source and estimates HAP emissions from these emission points. Complete this table if you are

### required to provide fugitive emissions data pursuant to 326 IAC 2-2 or 326 IAC 2-3. 12. Hazardous Air 11. Fugitive Emissions Source 13. Emission Factor 14. Number 15. Uncontrolled Potential To Emit **Pollutant** (lb/hr) Leaking Tons Per Year **Pounds Per Hour** NA Compressor Seals Flanges Open-Ended Lines Pressure Relief Seals Pump Seals Sampling Connections Valves Other (specify):



# OAQ GENERAL SOURCE DATA APPLICATION GSD-10: Insignificant Activities

State Form 51596 (R4 / 1-10)
INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

JDEM - Office of Air Quality - Permits Branch 100 N. Senate Avenue, MC 61-53 Room 1003 Indianapolis, IN 46204-2251 Telephone: (317) 233-0178 or Toll Free: 1-800-451-6027 x30178 (within Indiana) Facsimile Number: (317) 232-6749

www.IN.gov/idem

- The purpose of this form is to identify all trivial and insignificant activities in operation at the source. This form is required for all air permit applications.
- Detailed instructions for this form are available on the Air Permit Application Forms website.
- All information submitted to IDEM will be made available to the public unless it is submitted under a claim of confidentiality. Claims
  of confidentiality must be made at the time the information is submitted to IDEM, and must follow the requirements set out in 326 IAC
  17.1-4-1. Failure to follow these requirements exactly will result in your information becoming a public record, available for public
  inspection.

	Part A: Trivial Activities (Optional)						
checklis	entifies all trivial activities in operation at the source as defined in 326 IAC 2-7-1(40). Please use this to the Check each item and sub-item that applies. If applicable, provide the Emissions Unit Identification nonds to the Plant Layout and Process Flow diagrams.						
Unit ID	Description of Trivial Activity	Citation (326 IAC)					
	1. Any activity or emission unit:	2-7-1(40)(A)					
All the diesel fuel storage tanks, includi	not regulated by a NESHAP, with potential uncontrolled emissions are equal to or less than of pound per day on an emission unit basis for any single HAP or combination of HAPs; and	one (1)					
TK No. 1 - 9 and all the be	for which the potential uncontrolled emissions meet the exemption levels specified in the follo	owing:					
tanks for the emergency generators,	For lead and lead compounds measured as elemental lead (Pb), potential uncontrolled emissions equal to or less than one (1) pound per day	that are					
	For carbon monoxide (CO), potential uncontrolled emissions that are equal to or less than one (1) day	pound per					
	For sulfur dioxide (SO <sub>2</sub> ), potential uncontrolled emissions that are equal to or less than one (1) pour	and per day					
	☑ For volatile organic compounds (VOC), potential uncontrolled emissions that are equal to or less than one (1) pound per day						
	For nitrogen oxides (NOx), potential uncontrolled emissions that are equal to or less than one (1) pound per day						
	For particulate matter with an aerodynamic diameter less than or equal to ten (10) micrometers (Pl potential uncontrolled emissions that are equal to or less than one (1) pound per day	M <sub>10</sub> ),					
	2. Water related activities including:	2-7-1(40)(B)					
	Production of hot water for on-site personal use not related to any industrial or production process						
	Water treatment activities used to provide potable and process water for the plant, excluding any activities associated with wastewater treatment						
	Steam traps, vents, leaks and safety relief valves						
	☐ Cooling ponds						
	Laundry operations using only water solutions of bleach or detergents						
	Demineralized water tanks and demineralizer vents						
	Boiler water treatment operations, not including cooling towers						
	Oxygen scavenging (de-aeration) of water						
	☐ Steam cleaning operations and steam sterilizers						
	☐ Pressure washing of equipment						
	☐ Water jet cutting operations						

	Part A: Trivial Activities (continued)	
checklis	entifies all trivial activities in operation at the source as defined in 326 IAC 2-7-1(40). Please use this ta t. Check each item and sub-item that applies. If applicable, provide the Emissions Unit Identification nunds to the Plant Layout and Process Flow diagrams.	
Unit ID	Description of Trivial Activity	Citation (326 IAC)
	Combustion activities including the following:	2-7-1(40)(C)
	Portable electrical generators that can be moved by hand from one location to another. "Moved by hand that it can be moved without the assistance of any motorized or non-motorized vehicle, conveyance, or	
	☐ Combustion emissions from propulsion of mobile sources	
	☐ Fuel use related to food preparation for on-site consumption	·
	☐ Tobacco smoking rooms and areas	
	☐ Blacksmith forges	
	☐ Indoor and outdoor kerosene heaters	<del></del>
	4. Activities related to ventilation, venting equipment and refrigeration, including the following:	2-7-1(40)(D)
	Ventilation exhaust, central chiller water systems, refrigeration and air conditioning equipment related to any industrial or production process, including natural draft hoods or ventilating system do not remove air pollutants	
	Stack and vents from plumbing traps used to prevent the discharge of sewer gases, handling sewage only, excluding those at wastewater treatment plants or those handling any industrial	
	☐ Vents from continuous emissions monitors and other analyzers	
	☐ Natural gas pressure regulator vents, excluding venting at oil and gas production facilities	
	☐ Air vents from air compressors	
	☐ Vents for air cooling of electric motors provided the air does not commingle with regulated air	pollutants
	☐ Vents from equipment used to air blow water from cooled plastics strands or sheets	
	Activities related to routine fabrication, maintenance and repair of buildings, structures, equipment or vehicles at the source where air emissions from those activities would not be associated with any commercial production process including the following:	2-7-1(40)(E)
	<ul> <li>Activities associated with the repair and maintenance of paved and unpaved roads, including sealing, or both, of parking lots and roadways</li> </ul>	paving or
	Painting, including interior and exterior painting of buildings, and solvent use, excluding degree operations utilizing halogenated organic solvents	easing
	☐ Brazing, soldering, or welding operations and associated equipment	
	Portable blast-cleaning equipment with enclosures	
	☐ Blast-cleaning equipment using water as the suspension agent and associated equipment	
	☐ Batteries and battery charging stations, except at battery manufacturing plants	
	Lubrication, including hand-held spray can lubrication, dipping metal parts into lubricating oil, manual or automated addition of cutting oil in machining operations	and
	☐ Non-asbestos insulation installation or removal	
	☐ Tarring, retarring and repair of building roofs	
	☐ Bead blasting of heater tubes	
	☐ Instrument air dryer and filter maintenance	
	☐ Manual tank gauging	
	Open tumblers associated with deburring operations in maintenance shops	

table as	a che	ded to identify all trivial activitience cklist. Check each item and someonesponds to the Plant Layout	sub-item that applies.	ource as defined in 32 If applicable, provide t	6 IAC 2-7-1(40). Pleas	
Unit ID	Des	cription of Trivial Activity				Citation (326 IAC)
	6.	Activities performed using har	nd-held equipment incl	uding the following:		2-7-1(40)(F)
		☐ Application of hot melt adhesives	s with no VOC in the adhesiv	e formulation		
		☐ Cutting, excluding cutting torches	s 🔲 Buffing	☐ Grinding	☐ Sanding	
		☐ Machining wood, metal, or plastic	c	☐ Polishing	☐ Sawing	
		☐ Turning wood, metal, or plastic	☐ Drilling	Routing	☐ Surface grind	
	7.	Housekeeping and janitorial a	activities and supplies i	ncluding the following:		2-7-1(40)(G)
		☐ Vacuum cleaning systems	s used exclusively for h	ousekeeping or custo	dial activities, or both	
		☐ Steam cleaning activities	The state of the s	TO ALL TO THE SECOND SE		
		Rest rooms and associate	ed cleanup operations	and supplies		
		☐ Alkaline or phosphate clea	aners and associated e	equipment		
		☐ Mobile floor sweepers and	d floor scrubbers			
		Pest control fumigation				
	8.	Office related activities includ	ling the following:			2-7-1(40)(H)
		Office supplies and equip				
		☐ Photocopying equipment		es		
		☐ Paper shredding	arra documento dappina			
		☐ Blueprint machines, photo	ographic equipment ar	nd associated supplies		
	9.	Lawn care and landscape ma	nintenance activities an	d equipment, including		2-7-1(40)(I)
		spraying or application of inse		d herbicides		
	10.	Storage equipment and activit	ties including:			2-7-1(40)(J)
		Pressurized storage tanks	s and associated piping	for the following:		
		☐ Acetylene	☐ Inorganic compounds		☐ Natural gas	
		☐ Anhydrous ammonia	Liquid petroleum gas		☐ Nitrogen dioxide	
		☐ Carbon Monoxide ☐ Chlorine	Liquid natural gas (LI	NG) (propane)	☐ Sulfur dioxide	
		Storage tanks, vessels, ar contain any VOC or HAP	nd containers holding o	or storing liquid substa	nces that do not	
		Storage tanks, reservoirs, soap, wax, vegetable oil, provided appropriate lids	grease, animal fat, and	I nonvolatile aqueous		·
		Storage of drums containi	ing maintenance raw m	naterials		
		Storage of the following:				
		☐ Castings				
		☐ Lance rods				
		☐ Any non-HAP containing m	naterial in solid form stored in	a sealed or covered contain	ner	
		Portable containers used container capacity is equa container is closed except	al to or less than forty-s	six hundredths (0.46) o		

table as	a che	Part A: Trivial Activities (continued) es to identify all trivial activities in operation at the source as defined in 326 IAC 2-7-1(40). Please ecklist. Check each item and sub-item that applies. If applicable, provide the Emissions Unit Iden brresponds to the Plant Layout and Process Flow diagrams.	
Unit ID	Des	cription of Trivial Activity	Citation (326 IAC)
	11.	Emergency and standby equipment including:	2-7-1(40)(K)
		Emergency (backup) electrical generators at residential locations, such as dormitories, prisons and hospitals.	
		Safety and emergency equipment, except engine driven fire pumps, including fire suppression systems and emergency road flares.	
		Process safety relief devices installed solely for the purpose of minimizing injury to persons or damage to equipment which could result from abnormal process operating conditions, including the following:	
		☐ Explosion relief vents, diaphragms or panels ☐ Rupture discs ☐ Safety relief valves	
		<ul> <li>Activities and equipment associated with on-site medical care not otherwise specifically regulated</li> </ul>	
		☐ Vacuum producing devices for the purpose of removing potential accidental releases	
	12.	Sampling and testing equipment and activities including the following:	2-7-1(40)(L)
		Equipment used for quality control/assurance or inspection purposes, including sampling equipment used to withdraw materials for analysis	
		Hydraulic and hydrostatic testing equipment	
		Ground water monitoring wells and associated sample collection equipment	
		☐ Environmental chambers not using hazardous air pollutant (HAP) gases	
		☐ Shock chambers	
		☐ Humidity chambers	
		☐ Solar simulators	
		☐ Sampling activities including	
		☐ Sampling of waste ☐ Glove box sampling, charging, and packaging	
		☐ Instrument air dryers and distribution	
	13.	Use of consumer products and equipment where the product or equipment is used at a source in the same manner as normal consumer use and is not associated with any production process	2-7-1(40)(M)
	14.	Equipment and activities related to the handling, treating, and processing of animals including:	2-7-1(40)(N)
		Equipment used exclusively to slaughter animals, but not including the following: Rendering cookers, Boilers, Heating plants, Incinerators, and/or Electrical power generating equipment	
		☐ Veterinary operating rooms	
	15.	Activities generating limited amounts of fugitive dust including:	2-7-1(40)(O)
		☐ Fugitive emissions related to movement of passenger vehicles, provided the emissions are not counted for applicability purposes under 326 IAC 2-7-1(22)(B), and any required fugitive dust control plan or its equivalent is submitted	
		☐ Soil boring	
		☐ Road salting and sanding	

checklis	Part A: Frivial Activities (continued) entifies all trivial activities in operation at the source as defined in 326 IAC 2-7-1(40). Please use this t. Check each item and sub-item that applies. If applicable, provide the Emissions Unit Identification nds to the Plant Layout and Process Flow diagrams.	table as a
Unit ID	Description of Trivial Activity	Citation (326 IAC)
	16. Activities associated with production including the following:	2-7-1(40)(P)
	<ul> <li>Closed, non-vented, tumblers used for cleaning or deburring metal products without abrasive blasting</li> </ul>	
	☐ Electrical resistance welding	
	CO <sub>2</sub> lasers, used only on metals and other materials which do not emit HAPs in the process	
	<ul> <li>Laser trimmers which do not produce fugitive emissions and are equipped with dust collection devices such as bag filter, cyclone, or equivalent device</li> </ul>	1
	Application equipment for hot melt adhesives with no VOC in the adhesive formulation	-
	☐ Drop hammers or hydraulic presses for forging or metalworking	
	☐ Air compressors and pneumatically operated equipment, including hand tools	
	Compressor or pump lubrication and seal oil systems	
	<ul> <li>Equipment used to mix and package soaps, vegetable oil, grease, animal fat, and nonvolatile aqueous salt solutions, provided appropriate lids and covers are utilized</li> </ul>	
	<ul> <li>Equipment for washing or drying fabricated glass or metal products, if no VOCs or HAPs are used in the process, and no gas, oil or solid fuel is burned</li> </ul>	
	<ul> <li>Handling of solid steel, including coils and slabs, excluding scrap burning, scarfing, and charging into steel making furnaces and vessels</li> </ul>	:
	17. Miscellaneous equipment, but not emissions associated with the process for which the equipment is used, and activities including the following:	2-7-1(40)(Q)
	<ul> <li>Equipment used for surface coating, painting, dipping or spraying operation, except those that will emit VOCs or HAPs</li> </ul>	
	Condensate drains for natural gas and landfill gas	
	<ul> <li>Electric or steam heated drying ovens and autoclaves, including only the heating emissions and not any associated process emissions</li> </ul>	
	<ul> <li>Salt baths using nonvolatile salts including caustic solutions that do not result in emissions of any regulated air pollutants</li> </ul>	
	Ozone generators	
	Portable dust collectors	
	Scrubber systems circulating water based solutions of inorganic salts or bases which are installed to be available for response to emergency situations	
	☐ Soil borrow pits	
	☐ Manual loading and unloading operations	
	<ul> <li>Purging of refrigeration devices using a combination of nitrogen and CFC-22 (R-22) as pressure test media</li> </ul>	
	Construction and demolition operations	
	☐ Mechanical equipment gear boxes and vents which are isolated from process materials	
	☐ Non-volatile mold release waxes and agents	

	Pan B: Insignificant Activities			
table as	entifies all insignificant activities in operation at the source as defined in 326 IAC 2-7-1(21)(G). Pleas a checklist. Indicate which activities are present by checking the appropriate box. If applicable, provide Unit Identification number that corresponds to the Plant Layout and Process Flow diagrams.			
Unit ID	t ID Description of Insignificant Activity			
	18. Combustion related activities, including the following:			
	Space heaters, process heaters, or boilers using the following fuels			
	Propane or liquified petroleum gas, or butane-fired combustion sources with heat input equal to or less than six million (6,000,000) Btu per hour			
	Fuel oil-fired combustion sources with heat input equal to or less than two million (2,000,000) Btu per hour and firing fuel containing less than five-tenths percent (0.5%) sulfur by weight			
	☐ Wood-fired combustion sources with heat input equal to or less than one million (1,000,000) Btu per hour and not burning wood refuse, treated wood or chemically contaminated wood			
	Equipment powered by diesel fuel fired or natural gas fired internal combustion engines of capacity equal to or less than five hundred thousand (500,000) Btu/hour, except where total capacity of equipment operated by one stationary source exceeds two million (2,000,000) Btu/hour			
	Combustion source flame safety purging on startup			
	19. Fuel dispensing activities, including the following:	2-7-1(21)(G)(ii)		
	A gasoline fuel transfer dispensing operation handling less than or equal to one thousand three hundred (1,300) gallons per day and filling storage tanks having a capacity equal to or less than ten thousand five hundred (10,500) gallons. Such storage tanks may be in a fixed location or on mobile equipment			
	A petroleum fuel, other than gasoline, dispensing facility, having a storage tank capacity less than or equal to ten thousand five hundred (10,500) gallons, and dispensing three thousand five hundred (3,500) gallons per day or less			
·	20. The following VOC and HAP storage containers:	2-7-1(21)(G)(iii)		
	Storage tanks with capacity less than or equal to one thousand (1,000) gallons and annual throughputs less than twelve thousand (12,000) gallons			
	☐ Vessels storing the following:			
	☐ Hydraulic oils ☐ Lubricating oils ☐ Machining oils ☐ Machining fluids			
	21. Refractory storage not requiring air pollution control equipment			
	22. Equipment used exclusively for the following	2-7-1(21)(G)(v)		
	☐ Packaging the following: ☐ Greases ☐ Lubricants			
	☐ Filling drums, pails or other packaging containers with the following:			
	☐ Greases ☐ Lubricating oils ☐ Waxes			

Part B: Insignificant Activities (continued)				
table as	entifies all insignificant activities in operation at the source as defined in 326 IAC 2-7-1(21)(G). Please a checklist. Indicate which activities are present by checking the appropriate box. If applicable, present Identification number that corresponds to the Plant Layout and Process Flow diagrams.			
Unit ID	Description of Insignificant Activity	Citation (326 IAC)		
	23. Production related activities, including the following:	2-7-1(21)(G)(vi)		
	☐ Application of the following as temporary protective coatings:			
	☐ Greases ☐ Lubricants ☐ Nonvolatile materials ☐ Oils			
	Machining where an aqueous cutting coolant continuously floods the machining interface			
	Degreasing operations that do not exceed one hundred forty-five (145) gallons per twelve (12) months, except if subject to 326 IAC 20-6	-		
	Cleaners and solvents characterized as follows where the use of which, for all cleaners and solvents combined, does not exceed one hundred forty-five (145) gallons per twelve (12) months			
	<ul> <li>Having a vapor pressure equal to or less than two kilo Pascals (2.0 kPa) (fifteen millimeters of mercury (15 mm Hg) or three-tenths pound per square inch (0.3 psi)) measured at thirty-eight degrees Centigrade (38°C) (one hundred degrees Fahrenheit (100°F))</li> </ul>			
	Having a vapor pressure equal to or less than seven-tenths kilo Pascals (0.7 kPa) (five millimeters of mercury (5 mm Hg) or one-tenth pound per square inch (0.1 psi)) measured at twenty degrees Centigrade (20°C) (sixty-eight degrees Fahrenheit (68°F))			
	The following equipment related to manufacturing activities not resulting in the emission of HAPs:			
	☐ Brazing equipment ☐ Cutting torches ☐ Soldering equipment ☐ Weld	ing equipment		
	☐ Closed loop heating and cooling systems			
	☐ Infared cure equipment			
	<ul> <li>Exposure chambers (towers or columns) for curing of ultraviolet inks and ultra-violet coatings where heat is the intended discharge</li> </ul>			
	Any of the following structural steel and bridge fabrication activities:			
	Cutting two hundred thousand (200,000) linear feet or less of one (1) inch plate or equivalent			
	Using eighty (80) tons or less of welding consumables			
	24. Activities associated with the following recovery systems:	2-7-1(21)(G)(vii)		
	Rolling oil recovery systems			
	☐ Groundwater oil recovery wells			
	25. Solvent recycling systems with batch capacity less than or equal to one hundred (100)	2-7-1(21)(G)(viii)		

# 1 # # 1 5 F	Part B: Insignificant Activities (continued)			
use this	intended to identify all insignificant activities in operation at the source as defined in 326 IAC 2-7-1( table as a checklist. Indicate which activities are present by checking the appropriate box. If apparions Unit Identification number that corresponds to the Plant Layout and Process Flow diagrams.			
Unit ID	Description of Insignificant Activity	Citation (326 IAC)		
	26. Water-based activities, including the following:	2-7-1(21)(G)(ix)		
	Activities associated with the treatment of wastewater streams with an oil and grease content less than or equal to one percent (1%) by volume			
	☐ Water runoff ponds for petroleum coke-cutting and coke storage piles			
	Activities associated with the transportation and treatment of sanitary sewage, provided discharge to the treatment plant is under the control of the owner/operator, that is, an onsite sewage treatment facility			
	Any operation using aqueous solutions containing less than one percent (1%) by weight of VOCs excluding HAPs			
	☐ Water based adhesives that are less than or equal to five percent (5%) by volume of VOCs excluding HAPs			
	☐ Noncontact cooling tower systems with either of the following:			
	☐ Natural draft cooling towers not regulated under a NESHAP			
	☐ Forced and induced draft cooling tower systems not regulated under a NESHAP			
	Quenching operations used with heat treating processes			
	27. Repair activities, including the following:	2-7-1(21)(G)(x)		
	Replacement or repair of electrostatic precipitators, bags in baghouses and filters in other air filtration equipment			
	☐ Heat exchanger cleaning and repair			
	☐ Process vessel degassing and cleaning to prepare for internal repairs			
	28. Trimmers that do not produce fugitive emissions and that are equipped with a dust collection or trim material recovery device, such as a bag filter or cyclone	2-7-1(21)(G)(xi)		
	29. Stockpiled soils from soil remediation activities that are covered and waiting transport for disposal	2-7-1(21)(G)(xii)		
	30. Paved and unpaved roads and parking lots with public access	2-7-1(21)(G)(xiii)		
	31. Conveyors as follows:	2-7-1(21)(G)(xiv)		
	Covered conveyors for solid raw material, including the following:			
	☐ Coal or coke conveying of less than or equal to three hundred sixty (360) tons per day			
	Limestone conveying of less than or equal to seven thousand two hundred (7,200) tons per day for sources other than mineral processing plants constructed after August 31, 1983			
	Uncovered coal or coke conveying of less than or equal to one hundred twenty (120) tons per day			
	☐ Underground conveyors			
	☐ Enclosed systems for conveying plastic raw materials and plastic finished goods			
	32. Coal bunker and coal scale exhausts and associated dust collector vents	2-7-1(21)(G)(xv)		
	33. Asbestos abatement projects regulated by 326 IAC 14-10	2-7-1(21)(G)(xvi)		

### Part B: Insignificant Activities (continued) Part B is intended to identify all insignificant activities in operation at the source as defined in 326 IAC 2-7-1(21)(G). Please use this table as a checklist. Indicate which activities are present by checking the appropriate box. If applicable, provide the Emissions Unit Identification number that corresponds to the Plant Layout and Process Flow diagrams. Citation **Description of Insignificant Activity** Unit ID (326 IAC) 2-7-1(21)(G)(xvii) 34. Routine maintenance and repair of buildings, structures, or vehicles at the source where air emissions from those activities would not be associated with any production process, including the following: ☐ Purging of vessels ☐ Purging of gas lines 35. Flue gas conditioning systems and associated chemicals such as the following: 2-7-1(21)(G)(xviii) Sodium sulfate Ammonia Sulfur trioxide. 36. Equipment used to collect any material that might be released during a malfunction, 2-7-1(21)(G)(xix) process upset, or spill cleanup, including the following: Temporary liquid separators ☐ Catch tanks ☐ Tanks Fluid handling equipment 2-7-1(21)(G)(xx) 37. Blowdown for the following: ☐ Sight glass Boiler Compressors Pumps Cooling tower 2-7-1(21)(G)(xxi) 38. Furnaces used for melting metals other than beryllium with a brim full capacity of less than or equal to four hundred fifty (450) cubic inches by volume 2-7-1(21)(G)(xxii) Activities associated with emergencies, including the following: On-site fire training approved by the IDEM Emergency generators as follows: Gasoline generators not exceeding one hundred ten (110) horsepower HG No. 1 - 9 CAB Gen No. 1 Diesel generators not exceeding one thousand six hundred (1,600) horsepower CLB Gen No. ACB Gen No. 1 Natural gas turbines or reciprocating engines not exceeding sixteen thousand (16,000) horsepower Stationary fire pump engines 2-7-1(21)(G)(xxiii) 40. Grinding and machining operations controlled with fabric filters, scrubbers, mist collectors, wet collectors and electrostatic precipitators with a design grain loading of less than or equal to three one-hundredths grains per actual cubic foot (0.03 gr/acf) and a gas flow rate less than or equal to four thousand actual cubic feet per minute (4,000 acf/min), including the following: Deburring Polishing ☐ Pneumatic conveying Buffing Abrasive blasting ☐ Woodworking operations 41. Purge double block and bleed valves 2-7-1(21)(G)(xxiv) 42. Filter or coalescer media changeout 2-7-1(21)(G)(xxv) 43. Vents from ash transport systems not operated at positive pressure 2-7-1(21)(G)(xxvi) 2-7-1(21)(G)(xxvii) Mold release agents using low volatile products (vapor pressure less than or equal to two kilo Pascals (2kPa) measured at thirty-eight degrees Centigrade (38°C) 2-7-1(21)(G)(xviii) 45. Farm operations

Part B: Insignificant Activities (continued)						
Part B identifies all insignificant activities in operation at the source as defined in 326 IAC 2-7-1(21)(G). Please use this table as a checklist. Indicate which activities are present by checking the appropriate box. If applicable, provide the Emissions Unit Identification number that corresponds to the Plant Layout and Process Flow diagrams.						
Unit ID	Cital Description of Insignificant Activity (326					
	46. Woodworking equipment controlled by a baghouse provided that the following criteria are met:	2-7-1(21)(G)(xxix)				
	☐ The baghouse does not exhaust to the atmosphere greater than one hundred twenty-five (125,000) cubic feet per minute	thousand				
	☐ The baghouse does not emit particulate matter with a diameter less than ten (10) micronsthree-thousandths grains per dry standard cubic feet (0.003 gr/dscf) of outlet air	s in excess of				
	Opacity from the baghouse does not exceed ten percent (10%)					
	☐ The baghouse is in operation at all times the woodworking equipment is in use					
. `	☐ Visible emissions from the baghouse are observed daily using procedures in accordance with 40 CFR 60, Appendix A, Method 22 and normal or abnormal emissions are recorded. In the event abnormal emissions are observed for greater than six (6) minutes in duration, the following shall occur:					
	☐ The baghouse shall be inspected					
	☐ Corrective actions, such as replacing or reseating bags, are initiated, when necessary					
	☐ The baghouse is inspected quarterly when vented to the atmosphere					
	☐ The owner or operator keeps the following records:					
	Records documenting the date when the baghouse redirected indoors or to the atmosphere					
	Quarterly inspection reports, when vented to the atmosphere					
	☐ Visible observation reports					
	Records of corrective actions					
	47. Woodworking equipment controlled by a baghouse provided that the following criteria are met:	2-7-1(21)(G)(xxx)				
	The baghouse does not exhaust to the atmosphere greater than forty thousand (40,000) minute	cubic feet per				
	The baghouse does not emit particulate matter with a diameter less than ten (10) micron one-hundredth grains per dry standard cubic feet (0.01 gr/dscf) of outlet air	s in excess of				
	Opacity from the baghouse does not exceed ten percent (10%)					
	☐ The baghouse is in operation at all times the woodworking equipment is in use					
	☐ Visible emissions from the baghouse are observed daily using procedures in accordance 60, Appendix A, Method 22 and normal or abnormal emissions are recorded. In the ever emissions are observed for greater than six (6) minutes in duration, the following shall on	nt abnormal				
	☐ The baghouse shall be inspected					
	Corrective actions, such as replacing or reseating bags, are initiated, when necessary					
	☐ The baghouse is inspected quarterly when vented to the atmosphere					
	☐ The owner or operator keeps the following records:					
	Records documenting the date when the baghouse redirected indoors or to the atmosphere					
	Quarterly inspection reports, when vented to the atmosphere					
	☐ Visible observation reports					
	Records of corrective actions					

Part C: Insignificant Laboratory, Research, and Educational Activities			
Part C identifies insignificant activities in operation at the source as defined in 326 IAC 2-7-1(21), paragraph (D), (E), or (F).  Please use this table as a checklist. Indicate which activities are present by checking the appropriate box. If applicable, provide the Emissions Unit Identification number that corresponds to the Plant Layout and Process Flow diagrams.			
Unit ID I	Description of Insignificant Acti	ivity	
	8. Emissions from a laborat	tory as defined in 2-7-1(21)(D).	
	9.   Emissions from research	and development activities as defined in 2-7-1(21)(E).	
Ę	0. Emissions from educatio	nal and teaching activities as defined in 2-7-1(21)(F).	
	Villa de la P	art D: Other Insignificant Activities	
and (B) as not identifie	tifies all other insignificant activiti those activities with potential unc	ies in operation at the source (as defined in 326 IAC 2-7-1(21), paragraphs (A) controlled emissions equal to or less than the thresholds listed below) that are oplicable, provide the Emissions Unit Identification number that corresponds to	
Carbon M	onoxide (CO) ≤ 25 lb/day	Particulate Matter with aerodynamic diameter ≤ 10μm (PM₁₀) ≤ 5 lbs/hr or 25 lb/day	
Lead (Pb)	≤ 0.6 ton/yr or 3.29 lb/day	Sulfur Dioxide (SO₂) ≤ 5 lbs/hr or 25 lb/day	
Nitrogen C	Oxides (NO <sub>x</sub> ) ≤ 5 lbs/hr or 25 lb/day	Volatile Organic Compounds (VOC) ≤ 3 lbs/hr or 15 lb/day	
51. Other	nsignificant Activities: Identify	any "other activities", and provide a brief description.	
Unit ID	Description of Other Activity		

# Part E: Insignificant Activities with HAP Emissions

Part D identifies all insignificant activities in operation at the source (as defined in 326 IAC 2-7-1(21)(C)) that have the potential to emit hazardous air pollutants (HAP). These activities may or may not be identified above in Parts A, B, or D. **Activities listed in Part C above, need not be listed in this section.** Indicate which type of "Insignificant HAP Activities" are present by checking the appropriate box, and provide a brief description.

are present by ch		box, and provide a brief description	
52. <b>Individual HA</b> Identify any e per day or 1 to		ated by a NESHAP, emitting greate HAP.	er than 1 pound per day but less than 5 pounds
Emissions Unit	HAP	Brief Description	Applicable Requirements
•			
Annual Control of Cont			
Identify any e	HAP Emissions: missions unit, not regul ay or 2.5 ton per year o	ated by a NESHAP, emitting greate f a combination of HAPs.	er than 1 pound per day but less than 12.5
Emissions Unit	HAPs	Brief Description	Applicable Requirements
***************************************			

Air Permit Application FORM GSD-10 Page 13 of 13

# Part E: Specifically Regulated Insignificant Activities

Part E identifies all specifically regulated insignificant activities. Examples of specifically regulated activities that may have insignificant emissions include boilers, process heaters, any activity regulated under a federal rule such as MACT or BACT, etc. If you are not sure if an emissions unit would be considered a specifically regulated insignificant activity, contact the Air Permit Reviewer of the Day for additional guidance.

54. Unit ID	55. Stack /	56. Pollutant	57. Actual Emissions		58. Potential to Emit		59. Citation
	Vent ID	56. Pollutant	Standard Units	Tons Per Year	Standard Units	Tons Per Year	
· · · · · · · · · · · · · · · · · · ·							
		77					



# OAQ GENERAL SOURCE DATA APPLICATION GSD-13: Affidavit of Applicability

State Form 51603 (R2 / 1-10)
INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

IDEM – Office of Air Quality – Permits Branch 100 N. Senate Avenue, MC 61-53 Room 1003 Indianapolis, IN 46204-2251 Telephone: (317) 233-0178 or Toll Free: 1-800-451-6027 x30178 (within Indiana) Facsimile Number: (317) 232-6749

www.IN.gov/idem

- The purpose of GSD-13 is to certify that the requirement to notify adjacent landowners and occupants is applicable to the source of air pollutant emissions.
- Detailed instructions for this form are available on the Air Permit Application Forms website.
- All information submitted to IDEM will be made available to the public unless it is submitted under a claim of confidentiality. Claims
  of confidentiality must be made at the time the information is submitted to IDEM, and must follow the requirements set out in 326 IAC
  17.1-4-1. Failure to follow these requirements exactly will result in your information becoming a public record, available for public
  inspection.

44.4	PART A: Affida	avit Of Applicability			
	Complete this form to certify that the requirement to notify adjacent landowners and occupants pursuant to Indiana Code (IC) 13-15-8 is applicable to the source of air pollutant emissions. This form must be notarized by a public notary.				
	Pamela A. Gregorski	, being first duly sworn upon oath, deposes and says:			
1.	I live in New Castle County, State of Delaware, and being of sound mind and over twenty-one (21) years of age, I am competent to give this affidavit.				
2.	I hold the position of President for Razor5 L	LC - SBN100 Site (permit applicant's or facility's name).			
3.	By virtue of my position withRazor5 LLC to make the representation contained in this affidavit on	(permit applicant's name), I am authorized behalf of the facility.			
4.	I understand that the notice requirements of Ind. Code § permit applicant's or facility's name) for purposes of the	§13-15-8 applies to Razor5 LLC - SBN100 Site accompanying permit application.			
5.	5. As required by Indiana Code § 13-15-8, the permit applicant will send written notice to adjacent landowners not more than ten (10) days after submission of the accompanying application for construction and operation of a data center facility in New Carlisle, St. Joseph County, Indiana (briefly describe type of permit application) filed on behalf of (permit applicant's or facility's name).				
6.	Further Affiant Saith Not.				
X	I affirm under the penalty for perjury that the representations contained in this affidavit are true, to the best of my information and belief.				
	Pamela A. Gregorski President				
	nature (typed)	Title  4   11   24  Date			
STA	ATE OF Delaware	COUNTY OF New Castle			

PART B: Notarization
This section must be completed by a Public Notary.
Before me a notary Public in and for said County and State, personally appeared Pamela A. Gregorski, and being first
duly sworn by me upon oath, says that the fact stated in the foregoing instrument are true. Signed and sealed this
of April 2024 Surann F. Jakeye
Printed: OUZanne F. Laberge My Commission Expires: 1921 194
Residence of Wilmington, Delaware County New Castle
DEC. 21, 2024  DEC. 21, 2024  OF DELANTING



# OAQ GENERAL SOURCE DATA APPLICATION GSD-14: Owners and Occupants Notified

State Form 51609 (R2 / 1-10)
INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

IDEM - Office of Air Quality - Permits Branch 100 N. Senate Avenue, MC 61-53 Room 1003 Indianapolis, IN 46204-2251 Telephone: (317) 233-0178 or Toll Free: 1-800-451-6027 x30178 (within Indiana) Facsimile Number: (317) 232-6749 www.IN.gov/idem

- The purpose of GSD-14 is to identify adjacent landowners and occupants that are to be notified that an air permit application has been submitted.
- Detailed instructions for this form are available on the Air Permit Application Forms website.
- All information submitted to IDEM will be made available to the public unless it is submitted under a claim of confidentiality. Claims of confidentiality must be made at the time the information is submitted to IDEM, and must follow the requirements set out in 326 IAC 17.1-4-1. Failure to follow these requirements exactly will result in your information becoming a public record, available for public inspection.

Owners And Occ	cupants Notified			
Use this table to identify adjacent landowners and occupants that you have notified of your intent to construct pursuant to Indiana Code (IC) 13-15-8. If you need additional space, you may make copies of this form.				
1. Owner / Occupant Name: I/N Tek		2. Date Notified:		
3. Address: 30755 Edison Rd				
City: New Carlisle	State: IN	ZIP Code: 46552 –		
4. Electronic Mail:	5. Telephone Numb	er: ( ) -		
6. Method of Notification:   Telephone  Electronic	ic Mail 🛛 Standard M	lail Other (specify):		
Owner / Occupant Name: Town of New Carlisle / Cliffs Tek N Treatment Plant	New Carlisle Water	Date Notified:		
Address: 31061 Edison Rd				
City: New Carlisle	State: IN	ZIP Code: 46552 –		
Electronic Mail:	Telephone Number: (	)		
Method of Notification:   Telephone  Electronic	Mail 🛛 Standard Mai	il Dother (specify):		
Owner / Occupant Name: Master Roll Manufacturing		Date Notified:		
Address: 31140 Edison Rd				
City: New Carlisle	City: New Carlisle State: IN ZIP Code: 46552 –			
Electronic Mail:	Telephone Number: (	) ~		
Method of Notification:   Telephone  Electronic	Mail 🛛 Standard Mai	il Dother (specify):		
Owner / Occupant Name: Greenwood Motorlines DBA R&L 0	Carriers	Date Notified:		
Address: 30923 Fillmore Rd				
City: New Carlisle	State: IN	<b>ZIP Code</b> : 46552 –		
Electronic Mail:	Telephone Number: (	) -		
Method of Notification:	Mail 🛛 Standard Mai	il Other (specify):		
Owner / Occupant Name: Board of County Commissioners of	of St. Joseph County	Date Notified:		
Address: County-City Building 227 West Jefferson Blvd, Suite 722				
City: South Bend	State: IN ZIP Code: -			
Electronic Mail:	) -			
Method of Notification: ☐ Telephone ☐ Electronic Mail ☐ Standard Mail ☐ Other (specify):				



# OAQ GENERAL SOURCE DATA APPLICATION GSD-14: Owners and Occupants Notified

State Form 51609 (R2 / 1-10)
INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

IDEM - Office of Air Quality - Permits Branch

100 N. Senate Avenue, MC 61-53 Room 1003 Indianapolis, IN 46204-2251 Telephone: (317) 233-0178 or Toll Free: 1-800-451-6027 x30178 (within Indiana) Facsimile Number: (317) 232-6749

www.IN.gov/idem

- The purpose of GSD-14 is to identify adjacent landowners and occupants that are to be notified that an air permit application has been submitted.
- Detailed instructions for this form are available on the Air Permit Application Forms website.
- All information submitted to IDEM will be made available to the public unless it is submitted under a claim of confidentiality.
   Claims of confidentiality must be made at the time the information is submitted to IDEM, and must follow the requirements set out in 326 IAC 17.1-4-1. Failure to follow these requirements exactly will result in your information becoming a public record, available for public inspection.

Owners And Occ	cupants Notified			
Use this table to identify adjacent landowners and occupants that you have notified of your intent to construct pursuant to Indiana Code (IC) 13-15-8. If you need additional space, you may make copies of this form.				
<ol> <li>Owner / Occupant Name: John E Critzer (owner of the property on the east side of the proposed data center site)</li> <li>Date Notified:</li> </ol>				
3. Address: 854 Olive Branch Rd (owner's mailing address)				
City: Galien	State: MI	ZIP Code: 49113 –		
4. Electronic Mail:	5. Telephone Numb	er: ( ) -		
6. Method of Notification: 🗌 Telephone 📗 Electroni	ic Mail 🛮 🖂 Standard M	Mail Other (specify):		
Owner / Occupant Name:		Date Notified:		
Address:				
City:	State:	ZIP Code: –		
Electronic Mail:	Telephone Number: (	) -		
Method of Notification:   Telephone  Electronic	Mail 🔲 Standard Ma	il Other (specify):		
Owner / Occupant Name:		Date Notified:		
Address:				
City:	State:	ZIP Code: -		
Electronic Mail: Telephone Number: ( ) -				
Method of Notification:   Telephone  Electronic	Mail   Standard Mai	il Other (specify):		
Owner / Occupant Name:		Date Notified:		
Address:				
City:	State:	ZIP Code: –		
Electronic Mail: Telephone Number: ( ) -				
Method of Notification:   Telephone  Electronic	Mail 🔲 Standard Ma	il Other (specify):		
Owner / Occupant Name: Date Notified:				
Address:				
City:	State:	ZIP Code: –		
Electronic Mail: Telephone Number: ( ) -				
Method of Notification:   Telephone  Electronic Mail  Standard Mail  Other (specify):				



# OAQ GENERAL SOURCE DATA APPLICATION GSD-15: Government Officials Notified

State Form 51608 (R3 / 1-10)
INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

IDEM – Office of Air Quality – Permits Branch 100 N. Senate Avenue, MC 61-53 Room 1003 Indianapolis, IN 46204-2251 Telephone: (317) 233-0178 or Toll Free: 1-800-451-6027 x30178 (within Indiana)

Facsimile Number: (317) 232-6749 www.IN.gov/idem

- The purpose of GSD-15 is to identify local government officials that are to be notified that an air permit application has been submitted.
- Detailed instructions for this form are available on the Air Permit Application Forms website.
- All information submitted to IDEM will be made available to the public unless it is submitted under a claim of confidentiality.
   Claims of confidentiality must be made at the time the information is submitted to IDEM, and must follow the requirements set out in 326 IAC 17.1-4-1. Failure to follow these requirements exactly will result in your information becoming a public record, available for public inspection.

Government Officials Notified					
Use this table to identify local government officials that should be notified pursuant to Indiana Code (IC) 13-15-3-1 that an air permit application has been submitted. If you need additional space, you may make copies of this form.					
1. Name: Carl H. Baxmeyer		2. Date Notified:			
3. Title: St. Joseph County, Board of Commissioners, Preside	ent				
4. Address: 227 W Jefferson Boulevard					
City: South Bend	State: IN	<b>ZIP Code</b> : 46601 –			
5. Electronic Mail: sjccom@sjcindiana.com	6. Telephone Number	: (574) 235 - 9534			
7. Method of Notification:  Telephone  Electronic	c Mail 🔲 Standard Mai	I Other (specify):			
Name: Marcy Kauffman	ar kalegupa di Salamin migangan nakimbagi ayasan di Sangaran mini indik sa cakaki milipan masa di Kalifa ka adi bila	Date Notified:			
Title: New Carlisle Town Council, President					
Address: 124 E. Michigan Street					
City: New Carlisle	State: IN	<b>ZIP Code</b> : 46552 –			
Electronic Mail: Telephone Number: (574) 654 - 3733					
Method of Notification:					
Name: Date Notified:					
Title:					
Address:					
City:	State:	ZIP Code: –			
Electronic Mail:	Telephone Number: (	) -			
Method of Notification:					
Name:  Date Notified:					
Title:					
Address:					
City:	State:	ZIP Code: –			
Electronic Mail:	Telephone Number: ( ) -				
Method of Notification: Telephone Electronic M		Other (specify):			



### OAQ PROCESS INFORMATION APPLICATION PI-02A: Combustion Unit Summary

State Form 52535 (R2 / 1-10)
INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

IDEM - Office of Air Quality - Permits Branch

100 N. Senate Avenue, MC 61-53 Room 1003 Indianapolis, IN 46204-2251 Telephone: (317) 233-0178 or Toll Free: 1-800-451-6027 x30178 (within Indiana)

Facsimile Number: (317) 232-6749 www.IN.gov/idem

NOTES:

- · The purpose of this form is to summarize all of the combustion process units.
- Detailed instructions for this form are available on the Air Permit Application Forms website.
- All information submitted to IDEM will be made available to the public unless it is submitted under a claim of confidentiality. Claims
  of confidentiality must be made at the time the information is submitted to IDEM, and must follow the requirements set out in 326
  IAC 17.1-4-1. Failure to follow these requirements exactly will result in your information becoming a public record, available for
  anyone to inspect and photocopy.

Form ID	Form Title	Guidance on when to submit the form			
PI-02A	Combustion Unit Summary	Unit Summary Complete once for each application.			
PI-02B	Boilers & Process Heaters	Complete once for each boiler or process heater.			
PI-02C	Turbines & Internal Combustion	Complete once for each turbine or internal combustion			
	Engines	engine.			
PI-02D	Incinerators & Combustors	Complete once for each incinerator or combustor.			
PI-02E	Kilns	Complete once for each kiln.			
PI-02F	Fuel Use	Complete once for each emissions unit that burns fuel			
		other than natural gas.			
PI-02G	Emission Factors	Complete once for each emissions unit.			
PI-02H	Federal Rule Applicability	Complete once for each emissions unit.			

#### **Summary of Combustion Units** This table summarizes all the combustion units at the source. If there are multiple combustion units that are identical in nature, capacity, and use, you may use one row to summarize the identical units. 1. Combustion 2. Number of 3. Unit 4. Date of Installation 5. Heat Input Rate 6. Emergency / ID(s) **Unit Type Identical Units** or Modification of each unit Back-Up (MMBtu/hr) (actual or anticipated) Unit? Internal CEG No. 234 9.38 X Yes combustion □No 1 - 234engines **WTP** Internal 2 5.12 Gens No. ⊠ Yes combustion No engines 1 & 2 Internal HG No. 1 9 2.56 ☐ No combustion - 9 engines CAB Gen Internal No. 1 2 1.36 combustion and CLB ☐ No engines Gen No. 1 Internal ACB Gen 0.85 1 combustion ☐ No No. 1 engines ☐ Yes □ No ☐ Yes ☐ No Yes ☐ No



State Form 52537 (R2 / 1-10)
INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

IDEM – Office of Air Quality – Permits Branch 100 N. Senate Avenue, MC 61-53 Room 1003 Indianapolis, IN 46204-2251 Telephone: (317) 233-0178 or Toll Free: 1-800-451-6027 x30178 (within Indiana) Facsimile Number: (317) 232-6749 www.IN.gov/idem

NOTES:

- · The purpose of this form is to specify details that pertain only to turbines and internal combustion engines.
- Complete one PI-02C form for each emissions unit. If there are multiple emission units that are identical in nature, capacity, and use, you may use one PI-02C form to summarize the units.
- Detailed instructions for this form are available on the Air Permit Application Forms website.
- All information submitted to IDEM will be made available to the public unless it is submitted under a claim of confidentiality.
   Claims of confidentiality must be made at the time the information is submitted to IDEM, and must follow the requirements set out in 326 IAC 17.1-4-1. Failure to follow these requirements exactly will result in your information becoming a public record, available for anyone to inspect and photocopy.

PART A: Process Unit Details					
Part A specifies operating information that is unique to turbines and reciprocating internal combustion engines.  Definitions and additional explanation of terminology are included in the instructions for this form.					
1. Unit ID: CEG No. 1 - 2	1. Unit ID: CEG No. 1 - 234 (2,750 kW each)				
2. Type of Combustion Unit					
	☐ Simple Cycle				
C Table	Regenerative Cycle				
☐ Turbine:	☐ Cogeneration				
	Combined Cycle				
	2-stroke lean-burn				
Reciprocating Internal Combustion Engine:					
Compaction Engine.	4-stroke rich-burn				
3. Combustion Process:	☐ Diffusion Flame Combustion				
3. Combustion Process:	Lean-Premix Staged Combustion				
	☐ Spark				
4. Ignition Type:					
	horsepower (hp)				
5. Power Output:	2.75 each megawatts (MW)				
6. Duty Cycle:	hours per year (hr/yr)				
	☐ Natural Gas Only				
7. Fuel Used:	Other — Attach completed PI-02F.				
8. Does this combustion unit supply power to an emergency generator?					

PART B: Emission Controls and Limitations						
Part B identifies control technology, control techniques or other process limitations that impact air emissions.						
9. Add-On Control Technology: Identify all control technologies used for this process. Attach completed CE-01 (unless "none").						
□ None						
☐ Catalytic Oxidation — Attach CE-06 ☐ NO <sub>X</sub> Reduction — Attach CE-09						
Other (specify): A combined after-treatment system that in						
oxidation catalyst (DOC), and diesel particulate filter (DPF) to m	HOLE 12 - 12 - 12 - 12 - 12 - 12 - 12 - 12					
10. Control Techniques: Identify all control techniques used for	or this process.					
☐ None (explain):	Cartant Ingrana					
☐ Air-To-Fuel Ratio Adjustments	☐ Aromatic Content Increase					
☐ Boiling Point adjusted to 10% and 90%	Cetane Number					
Charge Cooling	Combustion Chamber Modifications					
☐ Derating	☐ Electronic Timing & Metering					
Exhaust Gas Recirculation	☐ Fuel Additives					
Fuel Injection Pressure	☐ Injection Rate Control					
☐ Injection Timing Retard	☐ Injector Nozzle Geometry					
☐ Cil Consumption Control	□ Low Sulfur Content Fuel     □ Bro ignition Chamber Combustion					
Oil Consumption Control	☐ Pre-ignition Chamber Combustion					
Rapid Spill Nozzles	☐ Turbocharging					
Two Stage Lean / Lean Combustion	☐ Two Stage Rich / Lean Combustion					
☐ Water/Fuel Emulsions	☐ Water / Steam Injection					
Other (specify):	— Attach completed GSD-09.					
11. Process Limitations / Additional Information: Identify an information if necessary.	ny acceptable process limitations. Attach additional					
The applicant requests to limit the facility wide NOX emission and limit the HAP emissions below 9 tpy for any single HAP becoming a major source of HAPs.						



State Form 52537 (R2 / 1-10)
INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

IDEM – Office of Air Quality – Permits Branch 100 N. Senate Avenue, MC 61-53 Room 1003 Indianapolis, !N 46204-2251 Telephone: (317) 233-0178 or Toll Free: 1-800-451-6027 x30178 (within Indiana) Facsimile Number: (317) 232-6749 www.lN.gov/idem

NOTES:

- The purpose of this form is to specify details that pertain only to turbines and internal combustion engines.
- Complete one PI-02C form for each emissions unit. If there are multiple emission units that are identical in nature, capacity, and use, you may use one PI-02C form to summarize the units.
- Detailed instructions for this form are available on the Air Permit Application Forms website.
- All information submitted to IDEM will be made available to the public unless it is submitted under a claim of confidentiality.
   Claims of confidentiality must be made at the time the information is submitted to IDEM, and must follow the requirements set out in 326 IAC 17.1-4-1. Failure to follow these requirements exactly will result in your information becoming a public record, available for anyone to inspect and photocopy.

PART A: Process Unit Details					
Part A specifies operating information that is unique to turbines and reciprocating internal combustion engines.  Definitions and additional explanation of terminology are included in the instructions for this form.					
1. Unit ID: WTP Gens No	. Unit ID: WTP Gens No. 1 & 2 (1,500 kW each)				
2. Type of Combustion Unit					
	☐ Simple Cycle				
	Regenerative Cycle				
Turbine:	☐ Cogeneration				
	Combined Cycle				
	2-stroke lean-burn				
Reciprocating Internal Combustion Engine:	⊠ 4-stroke lean-burn				
Combustion Engine.	4-stroke rich-burn				
	☐ Diffusion Flame Combustion				
3. Combustion Process:	Lean-Premix Staged Combustion				
	☐ Spark				
4. Ignition Type:	⊠ Compression				
의 발표 제상의 설계기를 모르는 것이다. (프랑크 및 의 기원들의 유리하는 보기 스	horsepower (hp)				
5. Power Output:	1.5 each megawatts (MW)				
6. Duty Cycle:	hours per year (hr/yr)				
	☐ Natural Gas Only				
7. Fuel Used:	Other – Attach completed PI-02F.				
8. Does this combustion unit supply power to an emergency generator? 🔀 Yes 🔲 No					

Process Information - Combustion FORM PI-02C Page 2 of 2

PART B: Emission Controls and Limitations						
Part B identifies control technology, control techniques or other process limitations that impact air emissions.						
9. Add-On Control Technology: Identify all control technologies used for this process. Attach completed CE-01 (unless "none").						
⊠ None	None     Non					
☐ Catalytic Oxidation – Attach CE-06	☐ NO <sub>x</sub> Reduction – Attach CE-09					
Other (specify):	— Attach CE-10.					
10. Control Techniques: Identify all control techniques used	for this process.					
⊠ None (explain):						
☐ Air-To-Fuel Ratio Adjustments	Aromatic Content Increase					
☐ Boiling Point adjusted to 10% and 90%	Cetane Number					
☐ Charge Cooling	Combustion Chamber Modifications					
☐ Derating	☐ Electronic Timing & Metering					
☐ Exhaust Gas Recirculation	Fuel Additives					
☐ Fuel Injection Pressure	☐ Injection Rate Control					
☐ Injection Timing Retard	☐ Injector Nozzle Geometry					
∠ Lean Combustion						
☐ Oil Consumption Control	☐ Pre-ignition Chamber Combustion					
Rapid Spill Nozzles	☐ Turbocharging					
☐ Two Stage Lean / Lean Combustion	☐ Two Stage Rich / Lean Combustion					
☐ Water/Fuel Emulsions	☐ Water / Steam Injection					
Other (specify):	- Attach completed GSD-09.					



State Form 52537 (R2 / 1-10)
INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

IDEM - Office of Air Quality - Permits Branch 100 N. Senate Avenue, MC 61-53 Room 1003 Indianapolis, IN 46204-2251 Telephone: (317) 233-0178 or Toll Free: 1-800-451-6027 x30178 (within Indiana) Facsimile Number: (317) 232-6749 www.IN.gov/idem

NOTES:

- The purpose of this form is to specify details that pertain only to turbines and internal combustion engines.
- Complete one PI-02C form for each emissions unit. If there are multiple emission units that are identical in nature, capacity, and use, you may use one PI-02C form to summarize the units.
- Detailed instructions for this form are available on the Air Permit Application Forms website.
- All information submitted to IDEM will be made available to the public unless it is submitted under a claim of confidentiality.
   Claims of confidentiality must be made at the time the information is submitted to IDEM, and must follow the requirements set out in 326 IAC 17.1-4-1. Failure to follow these requirements exactly will result in your information becoming a public record, available for anyone to inspect and photocopy.

PART A: Process Unit Details					
	Part A specifies operating information that is unique to turbines and reciprocating internal combustion engines.  Definitions and additional explanation of terminology are included in the instructions for this form.				
1.	1. Unit ID: House Gens No. 1 - 9 (750 kW each)				
2.	. Type of Combustion Unit				
		☐ Simple Cycle			
		Regenerative Cycle			
	Turbine:	☐ Cogeneration			
		Combined Cycle			
		2-stroke lean-burn			
	Reciprocating Internal Combustion Engine:				
	Combustion Engine.	4-stroke rich-burn			
	Combustion Process:	☐ Diffusion Flame Combustion			
3.		Lean-Premix Staged Combustion			
4	당시 (2012년 1일) 1일	☐ Spark			
4.	Ignition Type	□ Compression			
	Power Output:	horsepower (hp)			
5.		0.75 megawatts (MW)			
6.	Duty Cycle:	hours per year (hr/yr)			
		☐ Natural Gas Only			
7.	Fuel Used.	Other — Attach completed PI-02F.			
8.	8. Does this combustion unit supply power to an emergency generator?				

PART B: Emission Controls and Limitations						
Part B identifies control technology, control techniques or other process limitations that impact air emissions.						
9. Add-On Control Technology: Identify all control technologies used for this process. Attach completed CE-01 (unless "none").						
⊠ None						
☐ Catalytic Oxidation — Attach CE-06	NO <sub>X</sub> Reduction – Attach CE-09					
Other (specify): — Attach CE-10.						
10. Control Techniques: Identify all control techniques used f	or this process.					
⊠ None (explain):						
☐ Air-To-Fuel Ratio Adjustments	Aromatic Content Increase					
☐ Boiling Point adjusted to 10% and 90%	Cetane Number					
☐ Charge Cooling	Combustion Chamber Modifications					
☐ Derating	☐ Electronic Timing & Metering					
☐ Exhaust Gas Recirculation	☐ Fuel Additives					
☐ Fuel Injection Pressure	☐ Injection Rate Control					
☐ Injection Timing Retard	☐ Injector Nozzle Geometry					
☐ Oil Consumption Control	☐ Pre-ignition Chamber Combustion					
☐ Rapid Spill Nozzles	☐ Turbocharging					
☐ Two Stage Lean / Lean Combustion	☐ Two Stage Rich / Lean Combustion					
☐ Water/Fuel Emulsions	☐ Water / Steam Injection					
Other (specify):	— Attach completed GSD-09.					
11. Process Limitations / Additional Information: Identify a information if necessary.	2001년 22년 일본 22년 학생의 신부를 하고 말라면 있다면 된다.					
The applicant requests to limit the facility wide NOX emissi and limit the HAP emissions below 9 tpy for any single HAF becoming a major source of HAPs.						



State Form 52537 (R2 / 1-10)
INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

IDEM – Office of Air Quality – Permits Branch 100 N. Senate Avenue, MC 61-53 Room 1003 Indianapolis, IN 46204-2251 Telephone: (317) 233-0178 or Toll Free: 1-800-451-6027 x30178 (within Indiana) Facsimile Number: (317) 232-6749 www.IN.gov/idem

NOTES:

- The purpose of this form is to specify details that pertain only to turbines and internal combustion engines.
- Complete one PI-02C form for each emissions unit. If there are multiple emission units that are identical in nature, capacity, and
  use, you may use one PI-02C form to summarize the units.
- Detailed instructions for this form are available on the Air Permit Application Forms website.
- All information submitted to IDEM will be made available to the public unless it is submitted under a claim of confidentiality.
   Claims of confidentiality must be made at the time the information is submitted to IDEM, and must follow the requirements set out in 326 IAC 17.1-4-1. Failure to follow these requirements exactly will result in your information becoming a public record, available for anyone to inspect and photocopy.

	PART A: Process Unit Details				
	Part A specifies operating information that is unique to turbines and reciprocating internal combustion engines.  Definitions and additional explanation of terminology are included in the instructions for this form.				
1.	1. Unit ID: CAB Gen No. 1 and CLB Gen No. 1 (400 kW each)				
2.	2. Type of Combustion Unit				
☐ Simple Cycle					
	The transfer of	Regenerative Cycle			
	Turbine:	☐ Cogeneration			
		☐ Combined Cycle			
		2-stroke lean-burn			
	Reciprocating Internal Combustion Engine:	☑ 4-stroke lean-burn			
	Compaction Engine.	4-stroke rich-burn			
3.		☐ Diffusion Flame Combustion			
٥.	Combustion Process:	Lean-Premix Staged Combustion			
		☐ Spark			
4.	Ignition Type:				
١,	Power Output:	horsepower (hp)			
5.		0.4 each megawatts (MW)			
6.	Duty Cycle:	hours per year (hr/yr)			
١,	Fuel Used:	☐ Natural Gas Only			
7.		Other — Attach completed PI-02F.			
8.	8. Does this combustion unit supply power to an emergency generator?				

PART B: Emission Controls and Limitations							
Part B identifies control technology, control techniques or other process limitations that impact air emissions.							
9. Add-On Control Technology: Identify all control technology	ogies used for this process. Attach completed CE-01 (unless "none").						
⊠ None							
☐ Catalytic Oxidation – Attach CE-06	☐ NO <sub>X</sub> Reduction — Attach CE-09						
Other (specify):	— Attach CE-10.						
10. Control Techniques: Identify all control techniques us	ed for this process.						
⊠ None (explain):							
☐ Air-To-Fuel Ratio Adjustments	Aromatic Content Increase						
☐ Boiling Point adjusted to 10% and 90%	Cetane Number						
☐ Charge Cooling	Combustion Chamber Modifications						
☐ Derating	☐ Electronic Timing & Metering						
☐ Exhaust Gas Recirculation	Fuel Additives						
☐ Fuel Injection Pressure	☐ Injection Rate Control						
☐ Injection Timing Retard	☐ Injector Nozzle Geometry						
☐ Oil Consumption Control	☐ Pre-ignition Chamber Combustion						
☐ Rapid Spill Nozzles	☐ Turbocharging						
☐ Two Stage Lean / Lean Combustion	☐ Two Stage Rich / Lean Combustion						
☐ Water/Fuel Emulsions	☐ Water / Steam Injection						
Other (specify):	Attach completed GSD-09.						
Process Limitations / Additional Information: Identi information if necessary.  The applicant requests to limit the facility wide NOX em	fy any acceptable process limitations. Attach additional issions below 249 tpy to avoid becoming a PSD major source						
and limit the HAP emissions below 9 tpy for any single becoming a major source of HAPs.							
	· ·						
<b>i</b>							



State Form 52537 (R2 / 1-10)
INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

IDEM -- Office of Air Quality -- Permits Branch 100 N. Senate Avenue, MC 61-53 Room 1003 Indianapolis, IN 46204-2251 Telephone: (317) 233-0178 or Toll Free: 1-800-451-6027 x30178 (within Indiana) Facsimile Number: (317) 232-6749 www.IN.qov/idem

NOTES:

- The purpose of this form is to specify details that pertain only to turbines and internal combustion engines.
- Complete one PI-02C form for each emissions unit. If there are multiple emission units that are identical in nature, capacity, and use, you may use one PI-02C form to summarize the units.
- Detailed instructions for this form are available on the Air Permit Application Forms website.
- All information submitted to IDEM will be made available to the public unless it is submitted under a claim of confidentiality.
   Claims of confidentiality must be made at the time the information is submitted to IDEM, and must follow the requirements set out in 326 IAC 17.1-4-1. Failure to follow these requirements exactly will result in your information becoming a public record, available for anyone to inspect and photocopy.

PART A: Process Unit Details					
		mation that is unique to turbines and reciprocating internal combustion engines.  Ination of terminology are included in the instructions for this form.			
1.	Unit ID: ACB Gen No.	1 (250 kW)			
2.	2. Type of Combustion Unit				
		☐ Simple Cycle			
gwestan.		Regenerative Cycle			
	Turbine:	☐ Cogeneration			
		☐ Combined Cycle			
	,	2-stroke lean-burn			
	Reciprocating Internal Combustion Engine:				
	Compustion Engine.	4-stroke rich-burn			
		☐ Diffusion Flame Combustion			
3.	Combustion Process:	☐ Lean-Premix Staged Combustion			
		☐ Spark			
4.	Ignition Type:	⊠ Compression			
	Power Output:	horsepower (hp)			
5.		0.25 megawatts (MW)			
6.					
		☐ Natural Gas Only			
7.	Fuel Used:	☑ Other — Attach completed PI-02F.			
8.	8. Does this combustion unit supply power to an emergency generator?				

PART B: Emission Controls and Limitations				
Part B identifies control technology, control techniques or other process limitations that impact air emissions.				
Add-On Control Technology: Identify all control technologies used for this process. Attach completed CE-01 (unless "none").				
None     Non				
Catalytic Oxidation – Attach CE-06	NO <sub>X</sub> Reduction — Attach CE-09			
Other (specify):	Attach CE-10.			
10. Control Techniques: Identify all control techniques us	sed for this process.			
⊠ None (explain):				
☐ Air-To-Fuel Ratio Adjustments	☐ Aromatic Content Increase			
☐ Boiling Point adjusted to 10% and 90%	Cetane Number			
☐ Charge Cooling	Combustion Chamber Modifications			
☐ Derating	☐ Electronic Timing & Metering			
☐ Exhaust Gas Recirculation	☐ Fuel Additives			
☐ Fuel Injection Pressure	☐ Injection Rate Control			
☐ Injection Timing Retard	☐ Injector Nozzle Geometry			
☐ Oil Consumption Control	☐ Pre-ignition Chamber Combustion			
Rapid Spill Nozzles	☐ Turbocharging			
☐ Two Stage Lean / Lean Combustion	☐ Two Stage Rich / Lean Combustion			
☐ Water/Fuel Emulsions	☐ Water / Steam Injection			
Other (specify):	— Attach completed GSD-09.			
□ Other (specify): — Attach completed GSD-09.  11. Process Limitations / Additional Information: Identify any acceptable process limitations. Attach additional information if necessary.  The applicant requests to limit the facility wide NOX emissions below 249 tpy to avoid becoming a PSD major source and limit the HAP emissions below 9 tpy for any single HAP and 24 tpy for any combination of HAPs to avoid becoming a major source of HAPs.				



#### OAQ PROCESS INFORMATION APPLICATION

PI-02F: Combustion - Fuel Use
State Form 52540 (R2 / 1-10)
INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

IDEM – Office of Air Quality – Permits Branch 100 N. Senate Avenue, MC 61-53 Room 1003 Indianapolis, IN 46204-2251 Telephone: (317) 233-0178 or Toll Free: 1-800-451-6027 x30178 (within Indiana) Facsimile Number: (317) 232-6749 www.IN.gov/idem

NOTES:

- The purpose of this form is to identify each fuel that will be used in the combustion unit. Definitions and additional explanation of terminology are included in the instructions for this form
- Complete one form PI-02F for each combustion unit. If the unit has any capability of using a fuel, even if on a backup or intermittent basis, complete the applicable section. Using a
  fuel that is not specified in the permit is a violation of the permit.
- · Detailed instructions for this form are available on the Air Permit Application Forms website.
- All information submitted to IDEM will be made available to the public unless it is submitted under a claim of confidentiality. Claims of confidentiality must be made at the time the
  information is submitted to IDEM, and must follow the requirements set out in 326 IAC 17.1-4-1. Failure to follow these requirements exactly will result in your information becoming
  a public record, available for anyone to inspect and photocopy.

# PART A: Process Unit Identification 1. Unit ID: All the proposed emergency gens (CEG No. 1 - 234, WTP Gens No. 1 & 2, HG No. 1 - 9, CAB Gen No. 1, CLB Gen No. 1, and ACB Gen No. 1) PART B: Gaseous Fuels Part B identifies the gaseous fuels that will be used in the combustion unit.

Part B identifies the gaseous fuels that will be used in the combustion unit.					
2. Fuel Type:	3. Percent of Fuel Use (by volume)	4. Primary or S	Secondary Fuel?	5. Component Percentages:	6. Heating Value:
☐ Natural Gas		☐ Primary	Secondary	Sulfur:	(Btu/ft³)
☐ Liquefied Petroleum Gas ☐ Commercial- Propane ☐ Engine Fuel Propane (HD-5) ☐ Commercial- Butane		☐ Primary	☐ Secondary	Sulfur: Butane: Propane:	(Btu/ft³)
☐ Process Gas *		☐ Primary	Secondary	Sulfur:	(Btu/ft³)
☐ Landfill Gas *		☐ Primary	Secondary	Sulfur:	(Btu/ft³)
☐ Other (specify):		☐ Primary	Secondary	: :	(Btu/ft³)
* Indicate the source of the process or landfill gas:					

Indiana Department Of Environmental Management Office Of Air Quality State Form 52540 (R2 / 1-10) Process Information - Combustion FORM PI-02F Page 2 of 4

		PART C: Liquid Fu	els		
Part C identifies the liquid fuels th	nat will be used in the combu	stion unit.			
7. Fuel Type:	8. Percent of Fuel Use (by volume)	9. Primary or Secondary Fuel?	10. Component Percentages:	11. Heating Value:	12. Percent Heat:
Residual Fuel Oil					
☐ No. 5 Heavy		☐ Primary	Codform	(Dt., (1)	
☐ No. 5 – Light		Secondary	Sulfur:	(Btu/gal)	
☐ No. 6 (Bunker C)					
☐ No. 1		□ Primary	0.45	137030.00	4000/
⊠ No. 2 (Diesel)	100.00%	Secondary	Sulfur: 0.0015%	(Btu/gal)	100%
☐ No. 4					
		Primary			
Gasoline		Secondary	Sulfur:	(Btu/gal)	
	A 8 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4		Sulfur:		
		☐ Primary	Ash:		
☐ Waste Oil		Secondary	Lead	(Btu/gal)	
			Chlorine:		
,		Primary	Sulfur:		
☐ Liquid Waste *			Fluorine:	(Btu/gal)	
		Secondary	Chlorine:		
Cother ( )()		☐ Primary	:	(Ptu/201)	
Other (specify):		Secondary	:	(Btu/gal)	
* RCRA alpha-numeric c	codes for Special or Hazardo	ous Waste to be Burned:			

This space was intentionally left blank.

Indiana Department Of Environmental Management Office Of Air Quality State Form 52540 (R2 / 1-10) Process Information - Combustion FORM PI-02F Page 3 of 4

		PART D1: Solid Fuels	- Coal		
Part D1 identifies all variations of coal that will be used in the combustion unit.					
13. Fuel Type:	14. Percent of Fuel Use (by volume)	15. Primary or Secondary Fuel?	16. Component Percentages:	17. Heating Value:	18. Basis:
☐ Anthracite Coal ☐ Anthracite ☐ Culm		☐ Primary ☐ Secondary	Sulfur: Ash: Moisture:	(Btu/lb)	☐ Dry ☐ Moist
☐ Bituminous Coal		☐ Primary ☐ Secondary	Sulfur: Ash: Moisture:	(Btu/lb)	☐ Dry ☐ Moist
Sub-bituminous Coal		☐ Primary ☐ Secondary	Sulfur: Ash: Moisture:	(Btu/lb)	☐ Dry ☐ Moist
☐ Lignite Coal		☐ Primary ☐ Secondary	Sulfur: Ash: Moisture:	(Btu/lb)	☐ Dry ☐ Moist
☐ Coke		☐ Primary ☐ Secondary	Sulfur: Ash: Moisture:	(Btu/lb)	☐ Dry ☐ Moist
Other Coal (specify):		☐ Primary ☐ Secondary	Sulfur: Ash: Moisture:	(Btu/gal)	☐ Dry ☐ Moist

This space was intentionally left blank.

Indiana Department Of Environmental Management Office Of Air Quality State Form 52540 (R2 / 1-10)

Process Information - Combustion FORM PI-02F Page 4 of 4

19. Fuel Type:	20. Percent of Fuel Use (by volume)	21. Primary or Secondary Fuel?	22. Component Percentages:	23. Heating Value:	24. Percent Heat:
☐ Wood or Wood Waste ☐ Wood Only ☐ Wood Residue Only ☐ Wood and Wood Residue		☐ Primary ☐ Secondary	Moisture:	(Btu/ton)	
☐ Tires or Tire Derived Fuel ☐ Whole Tires ☐ Tire Derived Fuel		☐ Primary ☐ Secondary	Sulfur: Chromium: Chlorine:	(Btu/lb)	
Bagasse		☐ Primary ☐ Secondary	Ash: Moisture:	(Btu/lb)	
☐ Solid Waste *		☐ Primary ☐ Secondary	:	(Btu/lb)	
Other (specify):		☐ Primary ☐ Secondary	:	(Btu/lb)	
*RCRA alpha-numeric	codes for Special or Hazardo				
Use the space provided to specif	PAR fy any fuel consumption limita	RT E: Fuel Consumption	The state of the s		

for any single HAP and 24 tpy for any combination of HAPs to avoid becoming a major source of HAPs.

The applicant requests not to set fuel usage as permit limits. The site will comply with emissions limits by tracking actual emissions based on the lbs/gal emission factors and actual fuel usage of each engine type. See the proposed compliance method in the narrative description, Section 3.3.1.



### OAQ PROCESS INFORMATION APPLICATION PI-02G: Combustion – Emission Factors

State Form 52541 (R2 / 1-10)
INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

IDEM - Office of Air Quality - Permits Branch 100 N. Senate Avenue, MC 61-53 Room 1003 Indianapolis, IN 46204-2251 Telepnone: (317) 233-0178 or Toll Free: 1-800-451-6027 x30178 (within Indiana) Facsimile Number: (317) 232-6749 www.IN.gov/idem

NOTES:

- . The purpose of this form is to specify the emission factors used to calculate potential to emit from the combustion unit.
- Complete one PI-02G form for each emissions unit. If there are multiple emission units that are identical in nature, capacity, and use, you may use one PI-02G form to summarize the units.
- Detailed instructions for this form are available on the Air Permit Application Forms website.
- All information submitted to IDEM will be made available to the public unless it is submitted under a claim of confidentiality.
   Claims of confidentiality must be made at the time the information is submitted to IDEM, and must follow the requirements set out in 326 IAC 17.1-4-1. Failure to follow these requirements exactly will result in your information becoming a public record, available for anyone to inspect and photocopy.

Emis	sion Factors	5 <u></u>		-parks.	je P
This table identifies all emission factors used to calculate	This table identifies all emission factors used to calculate air emissions from the combustion unit.				
1. Unit ID:	All the proposed emergency generators (CEG No. 1-234, WTP Gens No. 1 & 2, HG No. 1-9, CAB Gen No. 1, CLB Gen No. 1, and ACB Gen No. 1) See emission calculations in Appendix B				
2. Air Pollutant:	3. Emissi	ion Factor		of Emission F g AP-42, include o	
Carbon Monoxide (CO)			☐ AP-42		□ N/A
Lead (Pb)			☐ AP-42	Other	☐ N/A
Hazardous Air Pollutant (HAP) (specify):				☐ Other	□ N/A
Nitrogen Oxides (NO <sub>x</sub> )			☐ AP-42	Other	□ N/A
Mercury (Hg)			☐ AP-42	☐ Other	□ N/A
Particulate Matter (PM)			☐ AP-42	Other	□ N/A
Particulate Matter less than 10μm (PM <sub>10</sub> )			☐ AP-42	Other	□ N/A
Particulate Matter less than 2.5μm (PM <sub>2.5</sub> )			☐ AP-42	Other	□ N/A
Sulfur Dioxide (SO <sub>2</sub> )			⊠ AP-42	Other	□ N/A
Volatile Organic Compounds (VOC)			☐ AP-42	Other	☐ N/A
Other (specify):			☐ AP-42	☐ Other	□ N/A
Other (specify):			☐ AP-42	☐ Other	□ N/A
Other (specify):			☐ AP-42	☐ Other	□ N/A



#### **AEF-01 – ALTERNATE EMISSION FACTOR REQUEST**

State Form 51860 (R / 1-10)

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

IDEM – Office of Air Quality – Permits Branch 100 N. Senate Avenue, MC 61-53 Room 1003 Indianapolis, IN 46204-2251 Telephone: (317) 233-0178 or Toll Free: 1-800-451-6027 x30178 (within Indiana) Facsimile Number: (317) 232-6749

www.IN.gov/idem

- The purpose of this application is to request to use an alternate emission factor for permitting determinations, estimating source emissions for billing, or for development of emission inventories for use in air quality planning. This is required form.
- Detailed instructions for this form are available on the Air Permit Application Forms website.
- All information submitted to IDEM will be made available to the public unless
  it is submitted under a claim of confidentiality. Claims of confidentiality must
  be made at the time the information is submitted to IDEM, and must follow
  the requirements set out in 326 IAC 17.1-4-1. Failure to follow these
  requirements exactly will result in your information becoming a public record,
  available for any one to inspect and photocopy.

	EOE C	EEICE	USE O	NI V	
DEDMIT	NUMBE				
PERMIT	NUMBE				

	PART A: Process Iden	
Part A is intended to identify the	process at the source for which the	alternate emission factor is requested.
1. Process Description: Emer	gency Generators	
2. Affected Emissions Units:	3. Affected Control Devices:	Raw Materials Impacting Emissions:
CEG No. 1 - 234	CE 1 - 234	Ultra-low sulfur diesel
WTP Gens No. 1 & 2	None	Ultra-low sulfur diesel
HG No. 1 - 9	None	Ultra-low sulfur diesel
CAB Gen No. 1	None	Ultra-low sulfur diesel
CLB Gen No. 1	None	Ultra-low sulfur diesel
ACB Gen No. 1	None	Ultra-low sulfur diesel

PART B: Standard Calculation Method
Part B is intended to identify the standard emission calculation method and to identify why the method is not adequate.
5. Standard Emission Calculation Method: AP-42
6. Rationale: Briefly explain why the published emission factor does not appropriately represent the process, operation, or pollution control equipment efficiently.
Manufacturer provided specific emission factors for NOx, CO, VOC, and filterable PM per engine model.

PART C: Proposed Alternate Emission Factor
Part C is intended to identify the proposed alternate emission factor (AEF) and to sufficiently describe the AEF such that IDEM staff can understand the process used to develop the AEF.
7. Proposed AEF: Briefly describe the proposed alternate emission factor.
Manufacturer provided specific emission factors for NOx, CO, VOC, and filterable PM per engine model.
8. AEF Development Method: What approach was, or will be used to develop the alternate emission factor?
Continuous Emissions Monitoring System (CEMS)
A. Is the CEM certified by IDEM?
B. Is the CEM operated and maintained in accordance with the applicable regulations?  Yes No
Source Testing
A. Was testing conducted by a trade association or industry group?
Identify the trade association or industry group:
B. Was testing published and validated through peer review?
C. Was testing approved by IDEM?
Development of Material Balance Equations
Emission Modeling
Engineering Estimates
Other – Please Specify: Manufacturer provided performance and emission data (see Appendix C)
9. Supporting Data: Have you attached the data supporting the development of your alternate    ☐ Yes ☐ Note that the data supporting the development of your alternate   ☐ Yes ☐ Note that the data supporting the development of your alternate   ☐ Yes ☐ Note that the data supporting the development of your alternate   ☐ Yes ☐ Note that the data supporting the development of your alternate   ☐ Yes ☐ Note that the data supporting the development of your alternate   ☐ Yes ☐ Note that the data supporting the development of your alternate   ☐ Yes ☐ Note that the data supporting the development of your alternate   ☐ Yes ☐ Note that the data supporting the development of your alternate   ☐ Yes ☐ Note that the data support   ☐ Yes ☐ Note that the data support   ☐ Yes
10. RM/TP Submittal: Have you submitted the appropriate reference method or test ☐ Yes ☐ No ☒ N/ protocol to IDEM?
11. Modeling Analysis: Was any modeling conducted?
<b>12. Modeling Summary:</b> Briefly describe any modeling that was conducted. Attach additional information using <u>form</u> <u>GSD-05, Summary of Additional Information</u> , as needed.



### OAQ PROCESS INFORMATION APPLICATION PI-02H: Combustion – Federal Rule Applicability

State Form 52542 (R2 / 1-10)
INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

IDEM – Office of Air Quality – Permits Branch 100 N. Senate Avenue, MC 61-53 Room 1003 Indianapolis, IN 46204-2251 Telephone: (317) 233-0178 or Toll Free: 1-800-451-6027 x30178 (within Indiana) Facsimile Number: (317) 232-6749 www.IN.gov/idem

- . The purpose of this form is to identify any federal rules that apply to the emission unit.
- Complete one PI-02H form for each emissions unit. If there are multiple emission units that are identical in nature, capacity, and use, you may use one PI-02H form to summarize the units.
- Detailed instructions for this form are available on the Air Permit Application Forms website.
- All information submitted to IDEM will be made available to the public unless it is submitted under a claim of confidentiality.
   Claims of confidentiality must be made at the time the information is submitted to IDEM, and must follow the requirements set out in 326 IAC 17.1-4-1. Failure to follow these requirements exactly will result in your information becoming a public record, available for anyone to inspect and photocopy.

Part of the second of the second of	ederal Rule Applicability			
This table identifies any federal rules that apply to the process.				
Is a New Source Performance Standard (     If yes, attach a completed FED-01 for each rule		2. Unit IDs		
☐ 40 CFR Part 60, Subpart Cb	Large Municipal Waste Combustors (constructed before 9/20/1994)			
☐ 40 CFR Part 60, Subpart Ce	Hospital/Medical/Infectious Waste Incinerators			
☐ 40 CFR Part 60, Subpart D	Fossil-Fuel-Fired Steam Generators (constructed after 8/17/1971)			
☐ 40 CFR Part 60, Subpart Da	Electric Utility Steam Generating Units (constructed after 9/18/1978)			
☐ 40 CFR Part 60, Subpart Db	Industrial-Commercial-Institutional Generating Units			
☐ 40 CFR Part 60, Subpart Dc	Small Industrial-Commercial-Institutional Generating Units			
☐ 40 CFR Part 60, Subpart E	Incinerators			
☐ 40 CFR Part 60, Subpart Ea	Municipal Waste Combustors (constructed after 12/20/1989 and before 9/20/1994)			
☐ 40 CFR Part 60, Subpart Eb	Large Municipal Waste Combustors (constructed after 9/20/1994 or modified / reconstructed after 6/19/1996)			
☐ 40 CFR Part 60, Subpart Ec	Hospital/Medical/Infectious Waste Incinerators (constructed after 6/20/1996)			
☐ 40 CFR Part 60, Subpart O	Sewage Treatment Plants (sludge burners)			
☐ 40 CFR Part 60, Subpart Y	Coal Preparation Plants			
☐ 40 CFR Part 60, Subpart GG	Stationary Gas Turbines			
☐ 40 CFR Part 60, Subpart AAA	New Residential Wood Heaters			
☐ 40 CFR Part 60, Subpart AAAA	Small Municipal Waste Combustion Units (constructed after 8/30/1999 or modified / reconstructed after 6/6/2001)			
☐ 40 CFR Part 60, Subpart BBBB	Small Municipal Waste Combustion Units (constructed on or before 8/30/1999)			
☐ 40 CFR Part 60, Subpart CCCC	Commercial and Industrial Solid Waste Incineration Units (constructed after 11/30/1999 or modified / reconstructed after 6/1/2001)			
☐ 40 CFR Part 60, Subpart DDDD	Commercial and Industrial Solid Waste Incineration Units (constructed on or before 11/30/1999)			
☐ 40 CFR Part 60, Subpart KKKK	Stationary Combustion Turbines			

Federa	al Rule Applicability (continued)		
This table identifies any federal rules that apply	to the process.		
3. Is a National Emission Standard for Hazardous Air Pollutants (NESHAP) applicable to this source?			4. Unit IDs
☐ 40 CFR Part 63, Subpart MM	Combustion Sources at Kraft, Soda, and Paper Mills	d Sulfite Pulp &	
☐ 40 CFR Part 63, Subpart EEE	Hazardous Waste Combustion		
☐ 40 CFR Part 63, Subpart YYYY	Stationary Combustion Turbines		
⊠ 40 CFR Part 63, Subpart ZZZZ	Reciprocating Internal Combustion Engi	nes (RICE)	All the proposed emergency generators
☐ 40 CFR Part 63, Subpart DDDDD	Industrial, Commercial, and Institutional Process Heaters	Boilers and	
5. Non-Applicability Determination: Provide the rule title or the source category), but the		rs subject to a ru	ile (based on



# OAQ PROCESS INFORMATION APPLICATION PI-14: Volatile Organic Liquid Compound Storage State Form 52554 (R2/1-10)

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

IDEM - Office of Air Quality - Permits Branch 100 N. Senate Avenue, MC 61-53 Room 1003 Indianapolis, IN 46204-2251 Telephone: (317) 233-0178 or Toll Free: 1-800-451-6027 x30178 (within Indiana) Facsimile Number: (317) 232-6749 www.IN.gov/idem

- The purpose of this form is to obtain detailed information about all tanks larger than 250 gallons that are used to store volatile organic liquid compounds. Duplicate this form as necessary.
- Detailed instructions for this form are available on the Air Permit Application Forms website.
- All information submitted to IDEM will be made available to the public unless it is submitted under a claim of confidentiality.
   Claims of confidentiality must be made at the time the information is submitted to IDEM, and must follow the requirements set out in 326 IAC 17.1-4-1. Failure to follow these requirements exactly will result in your information becoming a public record, available for anyone to inspect and photocopy.

Part /		어린다 회사를 하는 것을 다른 경기가 하는 것이 없는 어느 있는데 그 사람	
	erender verstellte der kommen er det er det det er det Dit verstellt in de stellt de en det er de e	e tank. Duplicate this form as necessary to incl	<u> 18 martin - Landon Dennis, de la Barracción de la Persona de la Persona de la Persona de la Persona de la Pe</u> rsona de la Persona de la Perso
	Tank/Unit ID:	Nine (9) 12,000-Gal Central Diesel Fuel S	Storage Tanks / TK No. 1 - 9
	nstallation Date: actual or anticipated)		
3. T	Гank Location:	One for the each data center building	
4. T	Tank Type		
	☐ Fixed Roof, Cone	External Floating Roof, Domed	☐ Internal Floating Roof
	Fixed Roof, Dome	☐ External Floating Roof, Not Domed	☐ Variable Vapor Space
Σ	Other (specify): Horizonta	al tanks	☐ Pressure Tank
5. ls	s the tank <b>Above Ground</b> ?	⊠ Yes □ No	
6. T	Tank Orientation:	⊠ Horizontal ☐ Vertical	
7. T	Tank Color:	White	
8. N	Materials Stored (include MSD)	os) Diesel fuel	
9. T	True Vapor Pressure (PVA):	: 0.04 pounds per square inch (psi at 20°	'c)
10. V	Vapor Molecular Weight (My	v): ~ 200 gallons ( <i>b/lbmole</i> )	
11. A	Annual Throughput:	5.28MMgallons per year (gal/yr) for all nine t	tanks combined
12. V	Venting Method:	Tank vent	
13. F	Filling Method:	⊠ Submerged □ Not Submerged	Other (specify):
		PART B: Emission Controls and Limitation	ons
Part I	B identifies control technolog	gy, control techniques or other process limitation	ns that impact air emissions.
14. <i>f</i>	Add-On Control Technolog	y: Identify all control technologies used for this unit, a	and attach completed CE-01 (unless "none
Σ	⊠ None [	Other (specify):	— Attach CE-10.
15. C	Control Techniques: Identify	y all control techniques used for this process.	
_ [>	⊠ None	☐ Flare ☐ Vapor Recov	very System
[	Other (specify):	- Attach GSD-09.	

PART C: Information Specific to Tank Type			
Part C identifies the physical properties of the tank.			
17. Tank Diameter (D): 8.00 feet (ff)			
18. Tank Height (Hs): Length 32 feet (#)			
19. Tank Volume / Capacity (V): 12000.00 ga	allons (gal) cubic feet (#³)		
20. Maximum Liquid Height (Hlx): 7.5 feet (ft)			
21. External Floating Roof: Complete only if applicable.			
a. Average Liquid Density (WI): pounds pe	er gallon ( <i>lb/gal</i> )		
b. Roof Type:	ng Roof		
c. Tank Construction:   Welded	Riveted		
d. Primary Rim Seal:	d		
e. Secondary Rim Seal:   Weather Shield	d ☐ Rim Mounted ☐ None		
22. Internal Floating Roof: Complete only if applicable.			
a. Average Liquid Density (WI):	pounds per gallon ( <i>lb/gal</i> )		
b. Roof Type	☐ Double Deck Floating Roof ☐ Other: (specify)		
c. Self-supported fixed roof	☐ Yes ☐ No		
d. Number of columns supporting the fixed roof			
e. Deck Construction:	☐ Welded ☐ Riveted ☐ Bolted		
f. Primary Rim Seal:	☐ Vapor Mounted ☐ Liquid Mounted		
g. Is there a Secondary Rim Seal?	☐ Yes ☐ No		
23. Variable Vapor Space: Complete only if applicable.			
a. Volume of liquid pumped into the system (V1):	gallons per year ( <i>gal/yr</i> )		
b. Volume expansion capacity of system (V2):	gallons ( <i>gal</i> )		
c. Number of Transfers Into the System (N2)	per year (/yr)		
	· · · · · · · · · · · · · · · · · · ·		
PART D' En	mission Factors		
Part D identifies all emission factors used to calculate air e			
	25. Emission Factor 26. Source of Emission Factor (if not using AP-42, include calculations)		
Hazardous Air Pollutant (HAP): (specify):	☐ AP-42 ☐ Other ☐ N/A		
Volatile Organic Compounds (VOC)	✓ AP-42 ☐ Other ☐ N/A		
Other (specify):	☐ AP-42 ☐ Other		
Other (specify):	☐ AP-42 ☐ Other		

PAR	E: Federal Rule Applicability	
Part E identifies any federal rules that apply to	he process.	
27. Is a New Source Performance Standard If yes, attach a completed FED-01 for each rule	(NSPS) applicable to this source? ☐ Yes ☒ No that applies.	28. Unit ID:
☐ 40 CFR Part 60, Subpart K	Petroleum Liquid Storage Vessels (constructed after 6/11/1973 and before 5/19/1978)	
☐ 40 CFR Part 60, Subpart Ka	Petroleum Liquid Storage Vessels (constructed after 5/18/1978 and before 7/23/1984)	
☐ 40 CFR Part 60, Subpart Kb	Volatile Organic Liquid Storage Vessels, Including Petroleum Liquid Storage (constructed after 7/23/1984)	
☐ 40 CFR Part 60, Subpart VV	Equipment Leaks of VOC in the Synthetic Organic Chemicals Manufacturing Industry	
☐ 40 CFR Part 60, Subpart GGG	Equipment Leaks of VOC in Petroleum Refineries	
☐ 40 CFR Part 60, Subpart KKK	Equipment Leaks of VOC from On-Shore Natural Gas Processing Plants	
29. Is a National Emission Standard for Haza applicable to this source? If yes, attach a con		30. Unit ID:
☐ 40 CFR Part 61, Subpart J	Equipment Leaks (Fugitive Emission Sources) of Benzene	
☐ 40 CFR Part 61, Subpart V	Equipment Leaks (Fugitive Emission Sources)	
☐ 40 CFR Part 61, Subpart Y	Benzene Emissions from Benzene Storage Vessels	
☐ 40 CFR Part 63, Subpart R	Gasoline Distribution (Bulk Gasoline Terminals and Pipeline Breakout Stations)	·
☐ 40 CFR Part 63, Subpart CC	Petroleum Refineries	
☐ 40 CFR Part 63, Subpart HHH	Natural Gas Transmission and Storage	
☐ 40 CFR Part 63, Subpart EEEE	Organic Liquids Distribution (non-gasoline)	
31. Non-Applicability Determination: Provide the rule title or the source category), but the	e an explanation if the process unit appears subject to a rue rule will not apply.	ule (based on
TK No. 1 - 9 are not subject to 40 CFR 60 S (approximately 19,813 gallons).	Subpart Kb because the tank size is less than 75 cubic me	eters



### OAQ PROCESS INFORMATION APPLICATION PI-14: Volatile Organic Liquid Compound Storage

State Form 52554 (R2 / 1-10)
INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

IDEM – Office of Air Quality – Permits Branch 100 N. Senate Avenue, MC 61-53 Room 1003 Indianapolis, IN 46204-2251 Telephone: (317) 233-0178 or Toll Free: 1-800-451-6027 x30178 (within Indiana) Facsimile Number: (317) 232-6749 www.IN.gov/idem

- The purpose of this form is to obtain detailed information about all tanks larger than 250 gallons that are used to store volatile organic liquid compounds. Duplicate this form as necessary.
- Detailed instructions for this form are available on the Air Permit Application Forms website.
- All information submitted to IDEM will be made available to the public unless it is submitted under a claim of confidentiality.
   Claims of confidentiality must be made at the time the information is submitted to IDEM, and must follow the requirements set out in 326 IAC 17.1-4-1. Failure to follow these requirements exactly will result in your information becoming a public record, available for anyone to inspect and photocopy.

		ik ldentilication		
Part A identifies and describes the tar	Part A identifies and describes the tank. Duplicate this form as necessary to include all applicable tanks.			
1. Tank/Unit ID:	6,300-Gal Belly Ta - 234	nks BT No. 1 - 234 for	critical emergency engines CEG No. 1	
2. Installation Date: (actual or anticipated)				
3. Tank Location:	Under each critical	emergency engine		
4. Tank Type				
☐ Fixed Roof, Cone	☐ External Floatin	g Roof, Domed	☐ Internal Floating Roof	
☐ Fixed Roof, Dome	☐ External Floatin	g Roof, Not Domed	☐ Variable Vapor Space	
Other (specify): Horizontal red	ctangle tanks		☐ Pressure Tank	
5. Is the tank Above Ground?	⊠ Yes □	] No		
6. Tank Orientation:		] Vertical		
7. Tank Color:	White			
8. Materials Stored: (include MSDS)	Diesel fuel			
9. True Vapor Pressure (PVA):	0.04 pounds pe	r square inch (psi at 20°0	5)	
10. Vapor Molecular Weight (Mv): ~ 200 gallons (b/lbmole)				
11. Annual Throughput:	5.20MMgallons per	year ( <i>gal/yr</i> ) for all 234 be	elly tanks combined	
12. Venting Method:	Tank vent			
13. Filling Method:	Submerged	Not Submerged	Other (specify):	
	PART B: Emission C	ontrols and Limitatio	ins	
Part B identifies control technology, co	ontrol techniques or c	other process limitation	s that impact air emissions.	
14. Add-On Control Technology: Id.	entify all control technol	ogies used for this unit, a	and attach completed CE-01 (unless "none").	
⊠ None □ O	her (specify):		– Attach CE-10.	
15. Control Techniques: Identify all	control techniques us	ed for this process.		
⊠ None ☐ FI	are	☐ Vapor Recov	ery System	
Other (specify):		- Attach GSD-09.		
16. Process Limitations / Additiona information if necessary.	l Information: Ident	ify any acceptable prod	cess limitations. Attach additional	
Belly tanks for storage of diesel fu	el for emergency ger	nerators		

PART C: Informatio	n Specific to Tank Type		
Part C identifies the physical properties of the tank.	[발표] [생태] 내내 그는 그는 말이 되는 말이 되었다.		
17. Tank <del>Diameter (D):</del> Length (L) & Width (W) feet (ft)	36.1 ft (L) x 14.0 ft (W)		
18. Tank Height (Hs): 1.70 feet (#)			
<b>19. Tank Volume / Capacity</b> (V): 6300.00 ga	allons (gal) each cubic feet (ft³)		
20. Maximum Liquid Height (Hlx): 1.5 feet (ft)			
21. External Floating Roof: Complete only if applicable.			
a. Average Liquid Density (WI): pounds pe	er gallon ( <i>lb/gal</i> )		
b. Roof Type: ☐ Pontoon Floatin	ng Roof Double Deck Floating Roof		
c. Tank Construction:	Riveted		
d. Primary Rim Seal:	Liquid Mounted		
e. Secondary Rim Seal:	Rim Mounted None		
22. Internal Floating Roof: Complete only if applicable.			
a. Average Liquid Density (WI):	pounds per gallon ( <i>lb/gal</i> )		
<b>b.</b> Roof Type	☐ Double Deck Floating Roof ☐ Other: (specify)		
c. Self-supported fixed roof	☐ Yes ☐ No		
d. Number of columns supporting the fixed roof			
e. Deck Construction:	☐ Welded ☐ Riveted ☐ Bolted		
f. Primary Rim Seal:	☐ Vapor Mounted ☐ Liquid Mounted		
g. Is there a Secondary Rim Seal?	☐ Yes ☐ No		
23. Variable Vapor Space: Complete only if applicable.			
a. Volume of liquid pumped into the system (V1):	gallons per year (gal/yr)		
b. Volume expansion capacity of system (V2):	gallons ( <i>gal</i> )		
c. Number of Transfers Into the System (N2)  per year (/yr)			
PART D: Er	nission Factors		
Part D identifies all emission factors used to calculate air e			
	25. Emission Factor 26. Source of Emission Factor (if not using AP-42, include calculations)		
A DESCRIPTION OF THE PROPERTY	value units		
Hazardous Air Pollutant (HAP): (specify):	☐ AP-42 ☐ Other ☐ N/A		
Volatile Organic Compounds (VOC)			
Other (specify):  Other (specify):	AP-42 Other		
Other (specify).	│		

PART	E: Federal Rule Applicability		
Part E identifies any federal rules that apply to t	he process.		
27. Is a New Source Performance Standard ( If yes, attach a completed FED-01 for each rule to		28. Unit ID:	
☐ 40 CFR Part 60, Subpart K	Petroleum Liquid Storage Vessels (constructed after 6/11/1973 and before 5/19/1978)		
☐ 40 CFR Part 60, Subpart Ka	Petroleum Liquid Storage Vessels (constructed after 5/18/1978 and before 7/23/1984)		
☐ 40 CFR Part 60, Subpart Kb	Volatile Organic Liquid Storage Vessels, Including Petroleum Liquid Storage (constructed after 7/23/1984)		
☐ 40 CFR Part 60, Subpart VV	Equipment Leaks of VOC in the Synthetic Organic Chemicals Manufacturing Industry		
☐ 40 CFR Part 60, Subpart GGG	Equipment Leaks of VOC in Petroleum Refineries		
☐ 40 CFR Part 60, Subpart KKK	Equipment Leaks of VOC from On-Shore Natural Gas Processing Plants		
29. Is a National Emission Standard for Haza applicable to this source? If yes, attach a con		30. Unit ID:	
☐ 40 CFR Part 61, Subpart J	Equipment Leaks (Fugitive Emission Sources) of Benzene		
☐ 40 CFR Part 61, Subpart V	Equipment Leaks (Fugitive Emission Sources)		
☐ 40 CFR Part 61, Subpart Y	Benzene Emissions from Benzene Storage Vessels		
☐ 40 CFR Part 63, Subpart R	Gasoline Distribution (Bulk Gasoline Terminals and Pipeline Breakout Stations)		
☐ 40 CFR Part 63, Subpart CC	Petroleum Refineries		
☐ 40 CFR Part 63, Subpart HHH	Natural Gas Transmission and Storage		
☐ 40 CFR Part 63, Subpart EEEE	Organic Liquids Distribution (non-gasoline)		
31. Non-Applicability Determination: Provide an explanation if the process unit appears subject to a rule (based on the rule title or the source category), but the rule will not apply.			
These belly tanks are not subject to 40 CFF meters (approximately 19,813 gallons).	R 60 Subpart Kb because the tank size is less than 75 cul	pic	



### OAQ PROCESS INFORMATION APPLICATION PI-14: Volatile Organic Liquid Compound Storage

State Form 52554 (R2 / 1-10)
INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

IDEM – Office of Air Quality – Permits Branch 100 N. Senate Avenue, MC 61-53 Room 1003 Indianapolis, IN 46204-2251 Telephone: (317) 233-0178 or Toll Free: 1-800-451-6027 x30178 (within Indiana) Facsimile Number: (317) 232-6749 www.IN.gov/idem

- The purpose of this form is to obtain detailed information about all tanks larger than 250 gallons that are used to store volatile organic liquid compounds. Duplicate this form as necessary.
- Detailed instructions for this form are available on the Air Permit Application Forms website.
- All information submitted to IDEM will be made available to the public unless it is submitted under a claim of confidentiality.
   Claims of confidentiality must be made at the time the information is submitted to IDEM, and must follow the requirements set out in 326 IAC 17.1-4-1. Failure to follow these requirements exactly will result in your information becoming a public record, available for anyone to inspect and photocopy.

	PART A: Tank Identification			
Part A identifies and describes	the tank. Duplicate this form as necessary to incl	ude all applicable tanks.		
1. Tank/Unit ID:	Two (2) 5,000-Gal Belly Tanks for the tw	o WTP gens / BT-WTP No. 1 & 2		
Installation Date:     (actual or anticipated)				
3. Tank Location:	Under each emergency engine			
4. Tank Type				
☐ Fixed Roof, Cone	☐ External Floating Roof, Domed	☐ Internal Floating Roof		
Fixed Roof, Dome	External Floating Roof, Not Domed	☐ Variable Vapor Space		
Other (specify): Horizo	ontal rectangle tanks	☐ Pressure Tank		
5. Is the tank Above Ground	l? ⊠ Yes ☐ No			
6. Tank Orientation:	⊠ Horizontal ☐ Vertical			
7. Tank Color:	White			
8. Materials Stored:(include M	SDS) Diesel fuel			
9. True Vapor Pressure (PV	A): 0.04 pounds per square inch (psi at 20	°C)		
10. Vapor Molecular Weight (Mv): ~ 200 gallons (b/lbmole)				
11. Annual Throughput: 77050.00 gallons per year (gal/yr) for all the ancillary gens' belly tanks combined.				
12. Venting Method:	Tank vent			
13. Filling Method:	☐ Submerged ☐ Not Submerged	Other (specify):		
	PART B: Emission Controls and Limitati	ons		
Part B identifies control techno	logy, control techniques or other process limitation	ns that impact air emissions.		
14. Add-On Control Technol	ogy: Identify all control technologies used for this unit,	and attach completed CE-01 (unless "none").		
None     Non	Other (specify):	— Attach CE-10.		
15. Control Techniques: Identify all control techniques used for this process.				
None     Non	☐ Flare ☐ Vapor Reco	very System		
Other (specify):	- Attach GSD-09.			
information if necessary.	ditional Information: Identify any acceptable pro iesel fuel for emergency generators	cess limitations. Attach additional		

PART C: Informa	ition Specific to Tank Ty	ρ <b>e</b>	
Part C identifies the physical properties of the tank.			
17. Tank <del>Diameter (D):</del> Length (L) x Width (W) feet (ft)	31 ft (L) x 11 ft (W)		
<b>18. Tank Height</b> (Hs): 2.00 feet (#)			
19. Tank Volume / Capacity (V): 5000.00	gallons (gal) each	cubic feet (ff³)	
20. Maximum Liquid Height (Hlx): 1.80 feet (ft)			
21. External Floating Roof: Complete only if applicab	le.		
a. Average Liquid Density (WI): pounds	s per gallon (Ib/gal)		
b. Roof Type: Pontoon Flo	oating Roof	eck Floating I	Roof
c. Tank Construction:	Riveted		
d. Primary Rim Seal:	nted	ounted	☐ Mechañical Shoe
e. Secondary Rim Seal:	ield Rim Mou	nted	None
22. Internal Floating Roof: Complete only if applicable	e.		
a. Average Liquid Density (WI):	pounds per gal	lon ( <i>lb/gal</i> )	
b. Roof Type	Double Deck Floatin	ng Roof [	Other: (specify)
c. Self-supported fixed roof	Yes No		
d. Number of columns supporting the fixed roof			
e. Deck Construction:	☐ Welded ☐ Riv	veted [	Bolted
f. Primary Rim Seal:	☐ Vapor Mounted		Liquid Mounted
g. Is there a Secondary Rim Seal?	☐ Yes ☐ No	)	
23. Variable Vapor Space: Complete only if applicable	9.		
a. Volume of liquid pumped into the system (V1):	gallons per yea	ar ( <i>gal/yr</i> )	
<b>b.</b> Volume expansion capacity of system (V2):	gallons (gal)		
c. Number of Transfers Into the System (N2)	per year (/yr)		
PART D  Part D identifies all emission factors used to calculate a	: Emission Factors		
24. Air Pollutant:	25. Emission Factor  value units		of Emission Factor g AP-42, include calculations)
Hazardous Air Pollutant (HAP): (specify):		☐ AP-42	Other N/A
Volatile Organic Compounds (VOC)		⊠ AP-42	Other N/A
Other (specify):		☐ AP-42	Other
Other (specify):		☐ AP-42	Other

P	ART E: Federal Rule Applicability	
Part E identifies any federal rules that apply	to the process.	
27. Is a New Source Performance Standa If yes, attach a completed FED-01 for each		28. Unit ID:
☐ 40 CFR Part 60, Subpart K	Petroleum Liquid Storage Vessels (constructed after 6/11/1973 and before 5/19/1978)	
☐ 40 CFR Part 60, Subpart Ka	Petroleum Liquid Storage Vessels (constructed after 5/18/1978 and before 7/23/1984)	
☐ 40 CFR Part 60, Subpart Kb	Volatile Organic Liquid Storage Vessels, Including Petroleum Liquid Storage (constructed after 7/23/1984)	
☐ 40 CFR Part 60, Subpart VV	Equipment Leaks of VOC in the Synthetic Organic Chemicals Manufacturing Industry	
☐ 40 CFR Part 60, Subpart GGG	Equipment Leaks of VOC in Petroleum Refineries	
☐ 40 CFR Part 60, Subpart KKK	Equipment Leaks of VOC from On-Shore Natural Gas Processing Plants	
29. Is a National Emission Standard for I applicable to this source? If yes, attach a	Hazardous Air Pollutants (NESHAP) a completed FED-01 for each rule that applies. ☐ Yes ☒ No	30. Unit ID:
☐ 40 CFR Part 61, Subpart J	Equipment Leaks (Fugitive Emission Sources) of Benzene	
☐ 40 CFR Part 61, Subpart V	Equipment Leaks (Fugitive Emission Sources)	
☐ 40 CFR Part 61, Subpart Y	Benzene Emissions from Benzene Storage Vessels	
☐ 40 CFR Part 63, Subpart R	Gasoline Distribution (Bulk Gasoline Terminals and Pipeline Breakout Stations)	
☐ 40 CFR Part 63, Subpart CC	Petroleum Refineries	
☐ 40 CFR Part 63, Subpart HHH	Natural Gas Transmission and Storage	
☐ 40 CFR Part 63, Subpart EEEE	Organic Liquids Distribution (non-gasoline)	
31. Non-Applicability Determination: Pro the rule title or the source category), bu	vide an explanation if the process unit appears subject to a ru t the rule will not apply.	ule (based on
The emergency generator belly tanks a cubic meters (approximately 19,813 gal	re not subject to 40 CFR 60 Subpart Kb because the tank sizellons).	e is less than 75



# OAQ PROCESS INFORMATION APPLICATION PI-14: Volatile Organic Liquid Compound Storage State Form 52554 (R2 / 1-10)

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

IDEM - Office of Air Quality - Permits Branch 100 N. Senate Avenue, MC 61-53 Room 1003 Indianapolis, IN 46204-2251 Telephone: (317) 233-0178 or Toll Free: 1-800-451-6027 x30178 (within Indiana) Facsimile Number: (317) 232-6749 www.IN.gov/idem

NOTES:

- The purpose of this form is to obtain detailed information about all tanks larger than 250 gallons that are used to store volatile organic liquid compounds. Duplicate this form as necessary.
- Detailed instructions for this form are available on the Air Permit Application Forms website.
- All information submitted to IDEM will be made available to the public unless it is submitted under a claim of confidentiality.
   Claims of confidentiality must be made at the time the information is submitted to IDEM, and must follow the requirements set out in 326 IAC 17.1-4-1. Failure to follow these requirements exactly will result in your information becoming a public record, available for anyone to inspect and photocopy.

	PART A: Tank Identification		
Part A identifies and describes the ta	nk. Duplicate this form as necessary to incl	ude all applicable tanks.	
1. Tank/Unit ID:	Nine (9) up to 1,500-Gal Belly Tanks for	the nine house gens / BT-HG No. 1-9	
Installation Date:     (actual or anticipated)			
3. Tank Location:	Under each emergency engine		
4. Tank Type			
Fixed Roof, Cone	☐ External Floating Roof, Domed	☐ Internal Floating Roof	
☐ Fixed Roof, Dome	☐ External Floating Roof, Not Domed	☐ Variable Vapor Space	
Other (specify): Horizontal re	ectangle tanks	☐ Pressure Tank	
5. Is the tank Above Ground?	⊠ Yes □ No		
6. Tank Orientation:	☐ Horizontal ☐ Vertical		
7. Tank Color:	White		
8. Materials Stored:(include MSDS)	Diesel fuel		
9. True Vapor Pressure (PVA):	0.04 pounds per square inch (psi at 20°	°C)	
10. Vapor Molecular Weight (Mv):	~ 200 gallons-(b/lbmole)		
11. Annual Throughput: 77050.00 gallons per year (gal/yr) for all ancillary gens' belly tanks combined.			
12. Venting Method:	Tank vent		
13. Filling Method:	☐ Submerged ☐ Not Submerged	Other (specify):	
PART B: Emission Controls and Limitations			
Part B identifies control technology, control techniques or other process limitations that impact air emissions.			
14. Add-On Control Technology: Identify all control technologies used for this unit, and attach completed CE-01 (unless "none").			
⊠ None □ C	Other (specify):	— Attach CE-10.	
15. Control Techniques: Identify all control techniques used for this process.			
⊠ None □ F	lare	very System	
Other (specify):	– Attach GSD-09.		
16. Process Limitations / Additional Information: Identify any acceptable process limitations. Attach additional information if necessary.  Belly tanks for storage of diesel fuel for emergency generators			

PART C: Information Specific to Tank Type			
Part C identifies the physical properties of the tank			
17. Tank Diameter (D): Length (L) x Width (W) feet (ft) 15 ft (L) x 6.4 ft (W)			
18. Tank Height (Hs): 2.10 feet (ft)			
19. Tank Volume / Capacity (V): Up to 1,500 gallons (gal) each cubic feet (ft³)			
20. Maximum Liquid Height (HIx): 1.80 feet (ft)			
21. External Floating Roof: Complete only if applicable.			
a. Average Liquid Density (WI): pounds per gallon (Ib/gal)			
b. Roof Type: ☐ Pontoon Floating Roof ☐ Double Deck Floating Roof			
c. Tank Construction: Welded Riveted			
d. Primary Rim Seal: Vapor Mounted Liquid Mounted Mechanical Sho	эе		
e. Secondary Rim Seal:			
22. Internal Floating Roof: Complete only if applicable.			
a. Average Liquid Density (WI): pounds per gallon (/b/gal)			
b. Roof Type Double Deck Floating Roof Other: (specify)			
c. Self-supported fixed roof Yes No			
d. Number of columns supporting the fixed roof			
e. Deck Construction:			
f. Primary Rim Seal: ☐ Vapor Mounted ☐ Liquid Mounted			
g. Is there a Secondary Rim Seal?			
23. Variable Vapor Space: Complete only if applicable.			
a. Volume of liquid pumped into the system (V1): gallons per year (gallyr)			
b. Volume expansion capacity of system (V2): gallons (gal)			
c. Number of Transfers Into the System (N2)  per year (/yr)	-		
	·		
PART D: Emission Factors			
Part D identifies all emission factors used to calculate air emissions from the storage tank.			
24. Air Pollutant: 25. Emission Factor 26. Source of Emission Facto	r		
value units (if not using AP-42, include calcula			
Hazardous Air Pollutant (HAP): (specify):	N/A		
Volatile Organic Compounds (VOC)	N/A		
Other (specify):			
Other (specify):			

Part E identifies any federal rules that apply to the process.  27. Is a New Source Performance Standard (NSPS) applicable to this source?	PART	E: Federal Rule Applicability	
17 yes, attach a completed FED-01 for each rule that applies.   18 Stand   20. Unit ID:   19 Stand   19 Stand   20. Unit ID:   19 Stand   20. Unit ID:   19 Stand   20. Unit ID:   20. U	Part E identifies any federal rules that apply to t	he process.	
6/11/1973 and before 5/19/1978    40 CFR Part 60, Subpart Ka   Petroleum Liquid Storage Vessels (constructed after 5/18/1978 and before 7/23/1984)   40 CFR Part 60, Subpart Kb   Volatile Organic Liquid Storage Vessels, Including Petroleum Liquid Storage (constructed after 7/23/1984)   40 CFR Part 60, Subpart VV   Equipment Leaks of VOC in the Synthetic Organic Chemicals Manufacturing Industry   40 CFR Part 60, Subpart GGG   Equipment Leaks of VOC in Petroleum Refineries   40 CFR Part 60, Subpart KKK   Equipment Leaks of VOC from On-Shore Natural Gas Processing Plants   29. Is a National Emission Standard for Hazardous Air Pollutants (NESHAP) applicable to this source? If yes, attach a completed FED-01 for each rule that applies.   Yes   No 30. Unit ID:   40 CFR Part 61, Subpart J   Equipment Leaks (Fugitive Emission Sources) of Benzene   40 CFR Part 61, Subpart V   Equipment Leaks (Fugitive Emission Sources)     40 CFR Part 63, Subpart R   Gasoline Distribution (Bulk Gasoline Terminals and Pipeline Breakout Stations)     40 CFR Part 63, Subpart CC   Petroleum Refineries     40 CFR Part 63, Subpart HHH   Natural Gas Transmission and Storage     40 CFR Part 63, Subpart EEEE   Organic Liquids Distribution (non-gasoline)     31. Non-Applicability Determination: Provide an explanation if the process unit appears subject to a rule (based on the rule title or the source category), but the rule will not apply.   The emergency generator belly tanks are not subject to 40 CFR 60 Subpart Kb because the tank size is less than 75			28. Unit ID:
S/18/1978 and before 7/23/1984    40 CFR Part 60, Subpart Kb   Volatile Organic Liquid Storage Vessels, Including Peteroleum Liquid Storage (constructed after 7/23/1984)   40 CFR Part 60, Subpart VV   Equipment Leaks of VOC in the Synthetic Organic Chemicals Manufacturing Industry     40 CFR Part 60, Subpart GGG   Equipment Leaks of VOC in Petroleum Refineries     40 CFR Part 60, Subpart KKK   Equipment Leaks of VOC from On-Shore Natural Gas Processing Plants     40 CFR Part 60, Subpart KKK   Equipment Leaks of VOC from On-Shore Natural Gas Processing Plants     40 CFR Part 60, Subpart KKK   Equipment Leaks (NESHAP)   Yes No applicable to this source? If yes, attach a completed FED-01 for each rule that applies.   Yes No applicable to this source? If yes, attach a completed FED-01 for each rule that applies.     40 CFR Part 61, Subpart J   Equipment Leaks (Fugitive Emission Sources) of Benzene     40 CFR Part 61, Subpart V   Equipment Leaks (Fugitive Emission Sources)     40 CFR Part 63, Subpart R   Gasoline Distribution (Bulk Gasoline Terminals and Pipeline Breakout Stations)     40 CFR Part 63, Subpart CC   Petroleum Refineries     40 CFR Part 63, Subpart EEEE   Organic Liquids Distribution (non-gasoline)     40 CFR Part 63, Subpart EEEE   Organic Liquids Distribution (non-gasoline)     40 CFR Part 63, Subpart EEEE   Organic Liquids Distribution (non-gasoline)     40 CFR Part 63, Subpart EEEE   Organic Liquids Distribution (non-gasoline)     40 CFR Part 63, Subpart EEEE   Organic Liquids Distribution (non-gasoline)     40 CFR Part 63, Subpart EEEE   Organic Liquids Distribution (non-gasoline)     40 CFR Part 63, Subpart EEEE   Organic Liquids Distribution (non-gasoline)	☐ 40 CFR Part 60, Subpart K		
Petroleum Liquid Storage (constructed after 7/23/1984)    40 CFR Part 60, Subpart VV	☐ 40 CFR Part 60, Subpart Ka		
Chemicals Manufacturing Industry    40 CFR Part 60, Subpart GGG   Equipment Leaks of VOC in Petroleum Refineries     40 CFR Part 60, Subpart KKK   Equipment Leaks of VOC from On-Shore Natural Gas Processing Plants     29. Is a National Emission Standard for Hazardous Air Pollutants (NESHAP)   Yes No applicable to this source? If yes, attach a completed FED-01 for each rule that applies.   Yes No applicable to this source? If yes, attach a completed FED-01 for each rule that applies.   Yes No applicable to this source? If yes, attach a completed FED-01 for each rule that applies.   Yes No applicable to this source? If yes, attach a completed FED-01 for each rule that applies.   Yes No applicable to this sources?   Yes No applicable to this source? If yes, attach a completed FED-01 for each rule that applies.   Yes No applicable to this source?   Yes No applicable to this sources?   Yes No applicable to this source?   Yes No applicable to the source entry of the process unit appears subject to a rule (based on the rule title or the source category), but the rule will not apply.   The emergency generator belly tanks are not subject to 40 CFR 60 Subpart Kb because the tank size is less than 75	☐ 40 CFR Part 60, Subpart Kb	Petroleum Liquid Storage (constructed after	
□ 40 CFR Part 60, Subpart KKK  Equipment Leaks of VOC from On-Shore Natural Gas Processing Plants  29. Is a National Emission Standard for Hazardous Air Pollutants (NESHAP) applicable to this source? If yes, attach a completed FED-01 for each rule that applies.  □ 40 CFR Part 61, Subpart J  Equipment Leaks (Fugitive Emission Sources) of Benzene  □ 40 CFR Part 61, Subpart V  Equipment Leaks (Fugitive Emission Sources)  □ 40 CFR Part 61, Subpart Y  Benzene Emissions from Benzene Storage Vessels  □ 40 CFR Part 63, Subpart R  Gasoline Distribution (Bulk Gasoline Terminals and Pipeline Breakout Stations)  □ 40 CFR Part 63, Subpart CC  Petroleum Refineries  □ 40 CFR Part 63, Subpart HHH  Natural Gas Transmission and Storage  □ 40 CFR Part 63, Subpart EEEE  Organic Liquids Distribution (non-gasoline)  31. Non-Applicability Determination: Provide an explanation if the process unit appears subject to a rule (based on the rule title or the source category), but the rule will not apply.  The emergency generator belly tanks are not subject to 40 CFR 60 Subpart Kb because the tank size is less than 75	☐ 40 CFR Part 60, Subpart VV		
Processing Plants  29. Is a National Emission Standard for Hazardous Air Pollutants (NESHAP) applicable to this source? If yes, attach a completed FED-01 for each rule that applies.  40 CFR Part 61, Subpart J Equipment Leaks (Fugitive Emission Sources) of Benzene 40 CFR Part 61, Subpart V Equipment Leaks (Fugitive Emission Sources)  40 CFR Part 61, Subpart Y Benzene Emissions from Benzene Storage Vessels  40 CFR Part 63, Subpart R Gasoline Distribution (Bulk Gasoline Terminals and Pipeline Breakout Stations)  40 CFR Part 63, Subpart CC Petroleum Refineries  40 CFR Part 63, Subpart HHH Natural Gas Transmission and Storage  40 CFR Part 63, Subpart EEEE Organic Liquids Distribution (non-gasoline)  31. Non-Applicability Determination: Provide an explanation if the process unit appears subject to a rule (based on the rule title or the source category), but the rule will not apply.  The emergency generator belly tanks are not subject to 40 CFR 60 Subpart Kb because the tank size is less than 75	□ 40 CFR Part 60, Subpart GGG	Equipment Leaks of VOC in Petroleum Refineries	
applicable to this source? If yes, attach a completed FED-01 for each rule that applies.  40 CFR Part 61, Subpart J  Equipment Leaks (Fugitive Emission Sources) of Benzene  40 CFR Part 61, Subpart V  Equipment Leaks (Fugitive Emission Sources)  40 CFR Part 61, Subpart Y  Benzene Emissions from Benzene Storage Vessels  40 CFR Part 63, Subpart R  Gasoline Distribution (Bulk Gasoline Terminals and Pipeline Breakout Stations)  40 CFR Part 63, Subpart CC  Petroleum Refineries  40 CFR Part 63, Subpart HHH  Natural Gas Transmission and Storage  40 CFR Part 63, Subpart EEEE  Organic Liquids Distribution (non-gasoline)  31. Non-Applicability Determination: Provide an explanation if the process unit appears subject to a rule (based on the rule title or the source category), but the rule will not apply.  The emergency generator belly tanks are not subject to 40 CFR 60 Subpart Kb because the tank size is less than 75	☐ 40 CFR Part 60, Subpart KKK		
Benzene  40 CFR Part 61, Subpart V Equipment Leaks (Fugitive Emission Sources)  40 CFR Part 61, Subpart Y Benzene Emissions from Benzene Storage Vessels  40 CFR Part 63, Subpart R Gasoline Distribution (Bulk Gasoline Terminals and Pipeline Breakout Stations)  40 CFR Part 63, Subpart CC Petroleum Refineries  40 CFR Part 63, Subpart HHH Natural Gas Transmission and Storage  40 CFR Part 63, Subpart EEEE Organic Liquids Distribution (non-gasoline)  31. Non-Applicability Determination: Provide an explanation if the process unit appears subject to a rule (based on the rule title or the source category), but the rule will not apply.  The emergency generator belly tanks are not subject to 40 CFR 60 Subpart Kb because the tank size is less than 75			30. Unit ID:
<ul> <li>☐ 40 CFR Part 61, Subpart Y</li> <li>☐ 40 CFR Part 63, Subpart R</li> <li>☐ Gasoline Distribution (Bulk Gasoline Terminals and Pipeline Breakout Stations)</li> <li>☐ 40 CFR Part 63, Subpart CC</li> <li>☐ 40 CFR Part 63, Subpart HHH</li> <li>☐ Natural Gas Transmission and Storage</li> <li>☐ 40 CFR Part 63, Subpart EEEE</li> <li>☐ Organic Liquids Distribution (non-gasoline)</li> <li>31. Non-Applicability Determination: Provide an explanation if the process unit appears subject to a rule (based on the rule title or the source category), but the rule will not apply.</li> <li>The emergency generator belly tanks are not subject to 40 CFR 60 Subpart Kb because the tank size is less than 75</li> </ul>	☐ 40 CFR Part 61, Subpart J		
<ul> <li>☐ 40 CFR Part 63, Subpart R</li> <li>☐ 40 CFR Part 63, Subpart CC</li> <li>☐ 40 CFR Part 63, Subpart CC</li> <li>☐ 40 CFR Part 63, Subpart HHH</li> <li>☐ Natural Gas Transmission and Storage</li> <li>☐ 40 CFR Part 63, Subpart EEEE</li> <li>☐ Organic Liquids Distribution (non-gasoline)</li> <li>31. Non-Applicability Determination: Provide an explanation if the process unit appears subject to a rule (based on the rule title or the source category), but the rule will not apply.</li> <li>The emergency generator belly tanks are not subject to 40 CFR 60 Subpart Kb because the tank size is less than 75</li> </ul>	☐ 40 CFR Part 61, Subpart V	Equipment Leaks (Fugitive Emission Sources)	
Pipeline Breakout Stations)  40 CFR Part 63, Subpart CC Petroleum Refineries  40 CFR Part 63, Subpart HHH Natural Gas Transmission and Storage  40 CFR Part 63, Subpart EEEE Organic Liquids Distribution (non-gasoline)  31. Non-Applicability Determination: Provide an explanation if the process unit appears subject to a rule (based on the rule title or the source category), but the rule will not apply.  The emergency generator belly tanks are not subject to 40 CFR 60 Subpart Kb because the tank size is less than 75	☐ 40 CFR Part 61, Subpart Y	Benzene Emissions from Benzene Storage Vessels	
<ul> <li>☐ 40 CFR Part 63, Subpart HHH Natural Gas Transmission and Storage</li> <li>☐ 40 CFR Part 63, Subpart EEEE Organic Liquids Distribution (non-gasoline)</li> <li>31. Non-Applicability Determination: Provide an explanation if the process unit appears subject to a rule (based on the rule title or the source category), but the rule will not apply.</li> <li>The emergency generator belly tanks are not subject to 40 CFR 60 Subpart Kb because the tank size is less than 75</li> </ul>	☐ 40 CFR Part 63, Subpart R		
☐ 40 CFR Part 63, Subpart EEEE Organic Liquids Distribution (non-gasoline)  31. Non-Applicability Determination: Provide an explanation if the process unit appears subject to a rule (based on the rule title or the source category), but the rule will not apply.  The emergency generator belly tanks are not subject to 40 CFR 60 Subpart Kb because the tank size is less than 75	☐ 40 CFR Part 63, Subpart CC	Petroleum Refineries	
31. Non-Applicability Determination: Provide an explanation if the process unit appears subject to a rule (based on the rule title or the source category), but the rule will not apply.  The emergency generator belly tanks are not subject to 40 CFR 60 Subpart Kb because the tank size is less than 75	☐ 40 CFR Part 63, Subpart HHH	Natural Gas Transmission and Storage	
the rule title or the source category), but the rule will not apply.  The emergency generator belly tanks are not subject to 40 CFR 60 Subpart Kb because the tank size is less than 75	☐ 40 CFR Part 63, Subpart EEEE	Organic Liquids Distribution (non-gasoline)	
			ıle (based on
			e is less than 75



# OAQ PROCESS INFORMATION APPLICATION PI-14: Volatile Organic Liquid Compound Storage State Form 52554 (R2 / 1-10)

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

IDEM – Office of Air Quality – Permits Branch 100 N. Senate Avenue, MC 61-53 Room 1003 Indianapolis, IN 46204-2251 Telephone: (317) 233-0178 or Toll Free: 1-800-451-6027 x30178 (within Indiana) Facsimile Number: (317) 232-6749

www.IN.gov/idem

- The purpose of this form is to obtain detailed information about all tanks larger than 250 gallons that are used to store volatile organic liquid compounds. Duplicate this form as necessary.
- Detailed instructions for this form are available on the Air Permit Application Forms website.
- All information submitted to IDEM will be made available to the public unless it is submitted under a claim of confidentiality.
   Claims of confidentiality must be made at the time the information is submitted to IDEM, and must follow the requirements set out in 326 IAC 17.1-4-1. Failure to follow these requirements exactly will result in your information becoming a public record, available for anyone to inspect and photocopy.

PART A: Tank Identification			
Part A identifies and desc	ribes the tank. Duplicate this form as necessary to include all applicable tanks.		
1. Tank/Unit ID:	Three (3) up to 1,000-Gal Belly Tanks for the ancillary CAB, CLB, and ACB emergency generators		
2. Installation Date: (actual or anticipated)	시 (1 등 2 명) - 1일 위에 보고 있다. - 1일 이 전 (1 ) 등 1 등 1 등 1 등 1 등 1 등 1 등 1 등 1 등 1		
3. Tank Location:	Under each emergency engine		
4. Tank Type	그래요 생생은 일반이 그리고 물론하면 가셨다면 하는데 보고 있다면 하는데 하는데 되었다.		
☐ Fixed Roof, Cone	External Floating Roof, Domed Internal Floating Roof		
☐ Fixed Roof, Dome	External Floating Roof, Not Domed Variable Vapor Space		
Other (specify): H	orizontal rectangle tanks Pressure Tank		
5. Is the tank Above Gro	ound? 🗵 Yes 🗌 No		
6. Tank Orientation:	⊠ Horizontal □ Vertical		
7. Tank Color:	White		
8. Materials Stored:(incl.	ude MSDS) Diesel fuel		
9. True Vapor Pressure	(PVA): 0.04 pounds per square inch (psi at 20°C)		
10. Vapor Molecular Weight (Mv): ~ 200 gallons (b/lbmole)			
11. Annual Throughput:	77050.00 gallons per year (gal/yr) for all ancillary gens' belly tanks combined		
12. Venting Method:	Tank vent		
13. Filling Method:	☐ Submerged ☐ Not Submerged ☐ Other (specify):		
	PART B: Emission Controls and Limitations		
Part B identifies control te	chnology, control techniques or other process limitations that impact air emissions.		
14. Add-On Control Technology: Identify all control technologies used for this unit, and attach completed CE-01 (unless "none").			
None     Non	Other (specify): — Attach CE-10.		
15. Control Techniques: Identify all control techniques used for this process.			
None     Non	☐ Flare ☐ Vapor Recovery System		
Other (specify):	- Attach GSD-09.		
information if necessa	Additional Information: Identify any acceptable process limitations. Attach additional ry. of diesel fuel for emergency generators		

PART C: Informati	on Specific to Tank Typ	ge '''
Part C identifies the physical properties of the tank.		
17. Tank <del>Diameter (D)</del> : Length (L) x Width (W) feet (ft)	12.8 ft (L) x 5 ft (W)	
18. Tank Height (Hs): 2.10 feet (#)		
19. Tank Volume / Capacity (V): Up to 1,000 gallons (g	gal) each cubic fee	et (#³)
20. Maximum Liquid Height (Hlx): 1.80 feet (ft)		amaining admining account factor and faller as and consequence of the
21. External Floating Roof: Complete only if applicable.		
a. Average Liquid Density (WI): pounds p	oer gallon ( <i>lb/gal</i> )	
b. Roof Type: Pontoon Float	ing Roof 🔲 Double D	Deck Floating Roof
c. Tank Construction:	Riveted	
d. Primary Rim Seal:	ed 🔲 Liquid Mo	ounted
e. Secondary Rim Seal:	ld Rim Mou	inted None
22. Internal Floating Roof: Complete only if applicable.		
a. Average Liquid Density (WI):	pounds per gall	lon ( <i>lb/gal</i> )
b. Roof Type	☐ Double Deck Floatin	ng Roof Other: (specify)
c. Self-supported fixed roof	☐ Yes ☐ No	)
d. Number of columns supporting the fixed roof		
e. Deck Construction:	☐ Welded ☐ Riv	veted
f. Primary Rim Seal:	☐ Vapor Mounted	Liquid Mounted
g. Is there a Secondary Rim Seal?	Yes No	
23. Variable Vapor Space: Complete only if applicable.		
a. Volume of liquid pumped into the system (V1):	gallons per yea	ar (gal/yr)
b. Volume expansion capacity of system (V2):	gallons (gal)	
c. Number of Transfers Into the System (N2)	per year (/yr)	
PART D: E	Emission Factors	
Part D identifies all emission factors used to calculate air		age tank.
24. Air Pollutant:	25. Emission Factor	26. Source of Emission Factor
1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1. 1	value units	(if not using AP-42, include calculations)
Hazardous Air Pollutant (HAP): (specify):		☐ AP-42 ☐ Other ☐ N/A
Volatile Organic Compounds (VOC)		□ AP-42 □ Other □ N/A
Other (specify):		☐ AP-42 ☐ Other
Other (specify):		☐ AP-42 ☐ Other

PAI	RT E: Federal Rule Applicability			
Part E identifies any federal rules that apply to	the process.			
27. Is a New Source Performance Standard If yes, attach a completed FED-01 for each rule		28. Unit ID:		
☐ 40 CFR Part 60, Subpart K	Petroleum Liquid Storage Vessels (constructed after 6/11/1973 and before 5/19/1978)			
☐ 40 CFR Part 60, Subpart Ka	Petroleum Liquid Storage Vessels (constructed after 5/18/1978 and before 7/23/1984)			
☐ 40 CFR Part 60, Subpart Kb	Volatile Organic Liquid Storage Vessels, Including Petroleum Liquid Storage (constructed after 7/23/1984)			
☐ 40 CFR Part 60, Subpart VV	Equipment Leaks of VOC in the Synthetic Organic Chemicals Manufacturing Industry			
☐ 40 CFR Part 60, Subpart GGG	Equipment Leaks of VOC in Petroleum Refineries			
☐ 40 CFR Part 60, Subpart KKK	Equipment Leaks of VOC from On-Shore Natural Gas Processing Plants			
29. Is a National Emission Standard for Ha applicable to this source? If yes, attach a co		30. Unit ID:		
☐ 40 CFR Part 61, Subpart J	Equipment Leaks (Fugitive Emission Sources) of Benzene			
☐ 40 CFR Part 61, Subpart V	Equipment Leaks (Fugitive Emission Sources)			
☐ 40 CFR Part 61, Subpart Y	Benzene Emissions from Benzene Storage Vessels			
☐ 40 CFR Part 63, Subpart R	Gasoline Distribution (Bulk Gasoline Terminals and Pipeline Breakout Stations)			
☐ 40 CFR Part 63, Subpart CC	Petroleum Refineries			
☐ 40 CFR Part 63, Subpart HHH	Natural Gas Transmission and Storage			
☐ 40 CFR Part 63, Subpart EEEE	Organic Liquids Distribution (non-gasoline)			
31. Non-Applicability Determination: Provide the rule title or the source category), but the	de an explanation if the process unit appears subject to a nother rule will not apply.	ule (based on		
The emergency generator belly tanks are cubic meters (approximately 19,813 gallor	not subject to 40 CFR 60 Subpart Kb because the tank sizns).	e is less than 75		



#### OAQ CONTROL EQUIPMENT APPLICATION

CE-01: Control Equipment Summary State Form 51904 (R3 / 1-10)

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

IDEM – Office of Air Quality – Permits Branch 100 N. Senate Avenue, MC 61-53 Room 1003 Indianapolis, IN 46204-2251 Telephone: (317) 233-0178 or Toll Free: 1-800-451-6027 x30178 (within Indiana) Facsimile Number: (317) 232-6749 www.IN.gov/idem

NOTES:

- . The purpose of CE-01 is to summarize all of the equipment used to control emissions. This is a required form.
- · Detailed instructions for this form are available on the Air Permit Application Forms website.
- All information submitted to IDEM will be made available to the public unless it is submitted under a claim of confidentiality. Claims
  of confidentiality must be made at the time the information is submitted to IDEM, and must follow the requirements set out in 326
  IAC 17.1-4-1. Failure to follow these requirements exactly will result in your information becoming a public record, available for
  any one to inspect and photocopy.

#### Summary of Control Equipment

This table summarizes all of the equipment used to control air pollutant emissions. The identification numbers listed on this form should correspond to the emissions unit identified on the Plant Layout diagram and Process Flow diagram.

Control     Equipment ID	Control Equipment     Description	3. Pollutant Controlled	4. Emission Unit ID	5. Stack / Vent ID	6. Applicable Rule
CE 1 - 234	Each of the critical emergency generators CEG No. 1 – 234 (2750 kW each) will be equipped with an emission control system, which is a combined after-treatment system that integrates selective catalytic reduction (SCR), diesel oxidation catalyst (DOC), and diesel particulate filter (DPF) to meet the Tier 4 equivalent emission limits	NOx, CO, VOC, and PM	CEG No. 1 - 234	S-1 thru S-234	Tier 2 certified engines with voluntary emission control to achieve EPA Tier 4 emission standards
to salaring and a salaring and the salar					



# OAQ CONTROL EQUIPMENT APPLICATION CE-10: Miscellaneous Control Equipment

State Form 52436 (R2 / 1-10)
INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

IDEM - Office of Air Quality - Perinits Branch 100 N. Senate Avenue, MC 61-53 Room 1003 Indianapolis, IN 46204-2251

Telepnone: (317) 233-0178 or
Toll Free: 1-800-451-6027 x30178 (within Indiana)
Facsimile Number: (317) 232-6749
www.lN.gov/idem

#### NOTES:

- The purpose of CE-10 is to identify all the parameters that describe the control device.
- Complete this form once for each control device not covered by CE-02 through CE-09.
- Detailed instructions for this form are available online on the Air Permit Application Forms website.
- All information submitted to IDEM will be made available to the public unless it is submitted under a claim of confidentiality. Claims
  of confidentiality must be made at the time the information is submitted to IDEM, and must follow the requirements set out in 326
  IAC 17.1-4-1. Failure to follow these requirements exactly will result in your information becoming a public record, available for
  any one to inspect and photocopy.

PART'A: lo	dentification and Description of Control Equipment describes its physical properties.
Control Equipment ID:     Installation Date:	CE 1 - 234 for critical emergency generators CEG No. 1 - 234
3. Description of Control Device:	Each critical emergency generator will be equipped with a combined after-treatment system that integrates selective catalytic reduction (SCR), diesel oxidation catalyst (DOC), and diesel particulate filter (DPF). All these components work together to achieve the control efficiencies provided in the manufacturer specifications (attached in Appendix B).

PART B: Operational Part B provides the operational parameters of the control devices	AND DESCRIPTION OF THE PERSON NAMED IN COLUMN TWO IS NOT THE OWNER.	The second secon	gas stream. <i>i</i>	Appropriate units
must be included if the standard units are not used.	A. Units	B. Inlet	C. Outlet	D. Differential
4. Gas Stream Flow Rate				
5. Gas Stream Temperature	°F			
6. Gas Stream Pressure	inches of water			to
7. Moisture Content	%			
8. Particle Size Range	micrometers			to
9. Other (specify):				

Part C provides the pollutant concentrations of the	<b>C: Pollutant C</b> pollutant lade		S			
	10. Units	11. Inlet	12. Outlet	13. Efficiency	· (%):	
				Capture	Control	
a. Carbon Monoxide (CO)	# # # # # # # # # # # # # # # # # # #			100.00%	70.00%	
b. Lead (Pb)						
c. Hazardous Air Pollutant (HAP) (specify):  Volatile organic HAPs from diesel fuel combustion				100.00%	45.00%	
d. Nitrogen Oxides (NO <sub>X</sub> )				100.00%	91.70%	
e. Mercury (Hg)						
f. Particulate Matter (PM)				100.00%	68.60%	
g. Particulate Matter less than 10µm (PM <sub>10</sub> )				100.00%	68.60%	
h. Particulate Matter less than 2.5μm (PM <sub>2.5</sub> )	# # !			100.00%	68.60%	

Indiana Department of Environmental Management Office of Air Quality State Form 52436 (R2 / 1-10) Miscellaneous Control Device FORM CE-10 Page 2 of 3

i. Sulfur Dioxide (SO <sub>2</sub> )		17 Common 17 Com
j. Volatile Organic Compounds (VOC)	100.00%	45.00%
k. Other Pollutant (specify):		

PART D Part D identifies any existing or prop		rd Keeping, & Testing Proce ord keeping, & testing proced		d to be included
in the permit.				
14. Item(s) Monitored:	Catalyst bed temperature	Differential pressure across the control system		
15. Monitoring Frequency:	At least once every 15 miutes during generator operation	Per equipment supplier's recommendation		
16. Item(s) Recorded:	Catalyst bed temperature	Differential pressure across the control system		
17. Record Keeping Frequency:	At least once every 15 miutes during generator operation	Per equipment supplier's recommendation		
18. Pollutant(s) Tested:	NA			
19. Test Method(s):	NA			
20. Testing Frequency:	NA			
Part E verifies that a complete Preve applicable. Use this table as a check 21. Do you have a Preventive Mair	dist to ensure that th	e PMP is complete.		
21. Do you have a Preventive Mair	ntenance Plan (PMF	?)?		
	es – the following it	ems are identified on the PMP	: \$20   10   10   10   10   10   10   10	
and the state of t	ridual(s) responsible for in	specting, maintaining and repairing e	mission control device	<b>S</b> .
B. Description of the items	or conditions that will be i	nspected.		
C. Schedule for inspection	of items or conditions des	cribed above.	1 k 1 . k 2 l . k 2 l . k 2 l . k K 1 . k 3 l . k 1 k 1 k 3 l . k 3 l . k	
		t parts that will be maintained in inver	ntory for quick replace	ment
quant			y galok repideel	
Part F provides explanation to determ		nation of Integral Control ntrol device should be conside	red integral to the	process.
22. Has IDEM already made an interpretation of "Yes", provide the following:	egral control deterr	nination for this device?	⊠ No	☐ Yes
Permit Number:	Issuance Date:	Determination	ı: 🔲 Integral	☐ Not Integral
23. Is this device integral to the proof of "Yes", provide the reason(s) we		nral. ⊠ No [	] Yes	



# OAQ FEDERAL RULE INCORPORATION APPLICATION FED-01: Summary of Federal Requirements – NSPS & NESHAP

State Form 53512 (R / 1-10)

#### INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

IDEM - Office of Air Quality - Permits Branch 100 N. Senate Avenue, MC 61-53, Room 1003 Indianapolis, IN 46204-2251 Telephone: (317) 233-0178 or Toll Free: 1-800-451-6027 x30178 (within Indiana)

Facsimile Number: (317) 232-6749 www.in.gov/idem

#### NOTES:

- The purpose of this form is to provide a standardized way for sources to identify the NSPS or NESHAP requirements that are applicable to the regulated source. Complete one (1) form for each federal rule that applies to the source. This is a required form.
- Detailed instructions for this form are available on the Air Permit Application Forms website.
- All information submitted to IDEM will be made available to the public unless it is submitted under a claim of confidentiality. Claims
  of confidentiality must be made at the time the information is submitted to IDEM, and must follow the requirements set out in 326 IAC
  17.1-4-1. Failure to follow these requirements exactly will result in your information becoming a public record.

	Pa	rt A: Identification of A	pplicable Standard	
Ра	rt A identifies the applicable standard	and affected source.		
1.	Type of Standard:	☐ Part 60 NSPS	Part 61 NESHAP	☑ Part 63 NESHAP (MACT)
2.	Subpart Letter:	Part 50 NSPS Subpart	t IIII and Part 63 NESHA	AP Subpart ZZZZ
	Source Category Name:	Emergency generators		
4.	Affected Source (Include all applicable emission unit IDs):	CEG No. 1 - 234, WTP CLB Gen No. 1, and AC		o. 1 - 9, CAB Gen No. 1,

	Part B: Applicable Requirements	
Part B specifies the specific requiremen	ts of the federal rule that are applicable to	the process or emission unit.
level. For example, if all of 40 CFR	y the section of the federal standard that is 63.342(c) is applicable, "40 CFR 63.342(c applicable, then the appropriate citation is	)" is the appropriate citation. If only
<ul> <li>40 CFR 60.4200(a)(2) and</li> </ul>	• 40 CFR 63.6580	•
(4), (c)	• 40 CFR 63.6585	•
• 40 CFR 60.4205(b)	• 40 CFR 63.6590(a)(2)(iii) and	•
• 40 CFR 60.4206	(c)(1)	•
• 40 CFR 60.4207(b)	<ul> <li>40 CFR 63.6595(a)(7)</li> </ul>	•
<ul> <li>40 CFR 60.4208</li> </ul>	• 40 CFR 63.6670	
• 40 CFR 60.4209	• 40 CFR 63.6675	
<ul> <li>40 CFR 60.4211(a), (c), (f), and (g)</li> </ul>	•	•
<ul> <li>40 CFR 60.4212</li> </ul>		•
• 40 CFR 60.4214(b)		•
• 40 CFR 60.4218	•	•
• 40 CFR 60.4219	•	•
Table 8 to NSPS Subpart IIII	•	

Part C identifies the performance testing require		Requirements
la filitaria. El colò como la compania de la compa	ments that are applic	cable to the process or emission unit.
6. Performance Testing:	No testing required	by NSPS or NESHAP
7. Date of Initial Performance Test:	·	
8. Test Methods:		
Was the initial performance test approved by IDEM?	Yes: Date appr	roved: No
10. Did the initial performance test show compliance with the rule?	☐ Yes ☐	No: Date of next performance test:
	Part D: Important D	Dates 🔭 📆 💮
Part D identifies specific dates associated with t	he federal standard t	that are applicable to the process or emission unit.
11. Date Initial Notification was Submitted:	Proposed units no	t yet installed
12. Initial Compliance Date:	Startup:	Other:
경기를 통해 이 시간 하시는 동안 통해 모든데 있다. 그 이 시간 (1) 사용하는 이 등에 있는 아무슨 사람들이 만들어 되었다. (2)	Description:	
13. Other Dates	Description:	
방향되다 당시 경기 전체 바닷가 하루 하시다.	Description:	Date:



# OAQ COMPLIANCE DETERMINATION APPLICATION CD-01: Emissions Unit Compliance Status

State Form 51861 (R / 1-10)
INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

IDENI - Office of Air Quality - Permits Branch 100 N. Senate Avenue, MC 61-53 Room 1003 Indianapolis, IN 46204-2251 Telephone: (317) 233-0178 or Toll Free: 1-800-451-6027 x30178 (within Indiana) Facsimile Number: (317) 232-6749 www.IN.qov/idem

#### NOTES:

- The purpose of CD-01 is to identify the requirements that apply to each emissions unit at the permitted source and to determine the
  compliance status of these emissions units.
- · This is required form for each initial Title V permit application as well as each modification and every renewal.
- · Detailed instructions for this form are available on the Air Permit Application Forms website.
- All information submitted to IDEM will be made available to the public unless it is submitted under a claim of confidentiality. Claims
  of confidentiality must be made at the time the information is submitted to IDEM, and must follow the requirements set out in 326
  IAC 17.1-4-1. Failure to follow these requirements exactly will result in your information becoming a public record, available for any
  one to inspect and photocopy.

Part A identification of Source and Emission Part A identifies the source and the emissions unit. For the purposes of this form site as a whole and NOT to individual emissions units.	
1. Source Name: Razor5 LLC	2. Source ID: –
3. Emissions Unit Description: All the proposed emergency generators	4. Unit ID: CEG No. 1-234, WTP Gens 1 & 2, H

#### PART B: Regulatory Compliance Status

Part B identifies the regulatory requirements that apply to the emissions unit and to determine the compliance status of the emissions unit. These "regulatory requirements" are those required by federal, state, or local law.

5. Rule Cite	6. Description	7. State / Local Only	8. Limitation	9. Test Method	10. In Compliance (y/n)
40 CFR 60 Subpart IIII	NSPS for Stationary Compression Ignition Internal Combustion Engines		Tier 2 or Tier 3 emission standards, depending on the engine power capacity	Purchasing certified engines	у
40 CFRR 63 Subpart ZZZZ	NESHAP for Stationary Reciprocating Internal Combustion Engines		Comply with this subpart by meeting the requirements of 40 CFR 60 Subpart IIII	NA	У
326 IAC-5- 2-1	Opacity limits	Х	See Narrative Description, Section 4.2.1	Visible emission obervations	У
326 IAC 6.5- 1-2	PM limitations	X	See Narrative Description, Section 4.2.5	Purchasing certified engines	У

#### PART C: Compliance Status - Other Requirements

Part C identifies any other requirements that apply to the emissions unit and to determine the compliance status of the emissions unit. These "other requirements" would not be required by federal, state, or local law.

11. Other Requirements

12. State / Local Only

13. In Compliance (y/n)

Office Of Air Quality State Form 51861 (R / 3-06)				FORM CD-01 Page 2 of 2		
			į			



#### OAQ COMPLIANCE DETERMINATION APPLICATION CD-02: Compliance Plan Requirements Per Applicable Requirement

State Form 51862 (R2 / 1-10)
INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

IDEM - Office of Air Quality - Permits Branch 100 N. Senate Avenue, MC 61-53 Room 1003 Indianapolis, IN 46204-2251 Telephone: (317) 233-0178 or Toll Free: 1-800-451-6027 x30178 (within Indiana) Facsimile Number: (317) 232-6749 www.IN.gov/idem

#### NOTES:

- The purpose of CD-02 is to identify existing compliance monitoring activities (monitoring, testing, record keeping and/or reporting)
  required in an applicable requirement or to provide compliance monitoring activities for applicable requirements where there is no or
  inadequate compliance monitoring requirements.
- CD-02 focuses on generally applicable requirements that apply to many or all emission units at the source.
- This is required form for each initial Title V permit application as well as each modification and every renewal.
- Detailed instructions for this form are available on the Air Permit Application Forms website.
- All information submitted to IDEM will be made available to the public unless it is submitted under a claim of confidentiality. Claims
  of confidentiality must be made at the time the information is submitted to IDEM, and must follow the requirements set out in 326 IAC
  17.1-4-1. Failure to follow these requirements exactly will result in your information becoming a public record, available for any one
  to inspect and photocopy.

## PART A: Identification of Source and Applicable Requirement

Part A identifies the source and the applicable requirement. Use one form for each applicable requirement. For the purposes of this form, the term "source" refers to the plant site as a whole and NOT to individual emissions units.

1. Source Name: Razor5 LLC 2. Source ID:

3. Applicable Requirement: 40 CFR 60 Subpart IIII - NSPS for Stationary Compression Ignition Internal Combustion Engines

4. Rule Cite: 40 CFR 60.4205(b) and 60.4211(f)

5. Limitations: List each operational and/or emission limit specified in the applicable requirement.

Emission limits: meet applicable Tier 2 or Tier 3 emission standards based on the power capacity of each engine.

Operational limits: Runtime restrictions for emergency engines:

- (1) No time limit in emergency situations.
- (2) Runtime for maintenance checks and rediness testing shall not exceed 100 hrs/yr.
- (3) Runtime in non-emergency situations shall not exceed 50 hrs/yr, which are counted as part of the 100 hrs/yr for maintenance checks and readiness testing.
- 6. Reporting Schedule: Provide a description of the reporting schedule to be used. The schedule should include what will be reported and how often the reports will be submitted.

No initial notification or routine reporting required for emergency engines under 40 CFR 60. The owner or operator must keep records of the operation of the engine in emergency and non-emergency service that are recorded through the non-resettable hour meter. The owner must record the time of operation of the engine and the reason the engine was in operation during that time.

Indiana Department Of Environmental Management Office Of Air Quality State Form 51862 (R2 / 1-10)

7. Unit	8. Stack /	9. Control	10. Parameters	11. Monitoring	12, Item	13. Record	14. Pollutants	15. Test	16. Testing
ID.	Vent ID	Equipment	Monitored	Frequency	Recorded	Keeping Frequency	tested	Method	Frequency
All the emerge ncy gens		NA	Operation of each engine in emergency and non-emergency service: time of operation and the reason of run.	Each engine run event	Time of operation and the reason of run.	Each engine run event	NA	NA	NA
A									

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT OFFICE OF AIR QUALITY State Form XXXXX (8-04) Compliance Plan Requirements FORM CD-02

- 4	1				1	I	1
	I	1				i	
- 7	1	ì	- 1	1		}	
- 4	1	ł	:			ì	1
- 4.	 		 	 			
- 2	1		1				3
- 7	1				1	I	1
- 5				1		i	
- 1	i	ł.		1		i	
٠.	 		 	 			
- 1		1	1				
- 2	1	1	1		1		
2	1					I	i
3	1	i				i	



#### OAQ COMPLIANCE DETERMINATION APPLICATION CD-03: Compliance Plan Requirements Per Emissions Unit

State Form 51863 (R2 / 1-10)
INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

JDEM - Office of Air Quality - Permits Branch 100 N. Senate Avenue, MC 61-53 Room 1003 Indianapolis, IN 46204-2251 Telephone: (317) 233-0178 or Toll Free: 1-800-451-6027 x30178 (within Indiana) Facsimile Number: (317) 232-6749 www.IN.gov/idem

#### NOTES:

- The purpose of CD-03 is to identify existing compliance monitoring activities (monitoring, testing, record keeping and/or reporting)
  required in an applicable requirement or to provide compliance monitoring activities for applicable requirements where there is no
  or inadequate compliance monitoring requirements.
- CD-03 focuses on specific applicable requirements that may apply to a single emission unit or group of emission units.
- · This is required form for each initial Title V permit application as well as each modification and every renewal.
- Detailed instructions for this form are available on the Air Permit Application Forms website.
- All information submitted to IDEM will be made available to the public unless it is submitted under a claim of confidentiality. Claims
  of confidentiality must be made at the time the information is submitted to IDEM, and must follow the requirements set out in 326
  IAC 17.1-4-1. Failure to follow these requirements exactly will result in your information becoming a public record, available for any
  one to inspect and photocopy.

form, the term "source" refers to the plant site as a whole and NOT to indiv	viduai emissions units.
1. Source Name: Razor5 LLC	2. Source ID: —
3. Emissions Unit Description: Emergency Gens < 460 kW each	CAB Gen No. 1, CLB 4. Unit ID: Gen No. 1, & ACB Gen No. 1

5. Limitations: List each operational and/or emission limit for this emissions unit.

Meet EPA Tier 3 emission standards (will comply by purchasing certified engines).

Operational limits: Runtime restrictions for emergency engines:

- (1) No time limit in emergency situations.
- (2) Runtime for maintenance checks and rediness testing shall not exceed 100 hrs/yr.
- (3) Runtime in non-emergency situations shall not exceed 50 hrs/yr, which are counted as part of the 100 hrs/yr for maintenance checks and readiness testing.
- **6. Reporting Schedule:** Provide a description of the reporting schedule to be used. The schedule should include what will be reported and how often the reports will be submitted.

No initial notification or routine reporting required for emergency engines under 40 CFR 60. The owner or operator must keep records of the operation of the engine in emergency and non-emergency service that are recorded through the non-resettable hour meter. The owner must record the time of operation of the engine and the reason the engine was in operation during that time.

					lan Components			
Part B ider	tifies the main cor	nponents of each re	equired compliance	e plan.				
7. Rule Cite	8. Control Equipment	9. Parameters Monitored	10. Monitoring Frequency	11. Item Recorded	12. Record Keeping Frequency	13. Pollutants tested	14. Test Method	15. Testing Frequency
40 CFR 60.4211(f ) & 4214 (b)	NA	Operation of each engine in emergency and non-emergency service: time of operation and the reason of run.	Each engine run event	Time of operation and the reason of run.	Each engine run event	NA	NA	NA
							ļ	
				ļ				
				ļ				
		-						
							ļ	
				ļ				
				ļ				
							ļ <u></u>	
				ļ		ļ		-
		1						

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR QUALITY
State Form XXXXX (6-04)

Compliance Plan Requirements
FORM CD-02



### OAQ COMPLIANCE DETERMINATION APPLICATION

CD-04: Compliance Schedule and Certification State Form 51864 (R2 / 1-10)

State Form 51864 (R2 / 1-10)
INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

IDEM – Office of Air Quality – Permits Branch 100 N. Senate Avenue, MC 61-53 Room 1003 Indianapolis. IN 46204-2251 Telephone: (317) 233-0178 or Toll Free: 1-800-451-6027 x30178 (within Indiana) Facsimile Number: (317) 232-6749 www.lN.gov/idem

#### NOTES:

- The purpose of CD-04 is to provide a schedule of for compliance certification submittals, a certification of the source's compliance status with all applicable requirements, and a compliance schedule that details the measures a source will use to address non-compliance.
- Complete this form once per application (not once for each emissions unit) with respect to all applicable requirements at the source.
- . This is required form for each initial Title V permit application as well as each modification and every renewal.
- Detailed instructions for this form are available on the Air Permit Application Forms website.
- All information submitted to IDEM will be made available to the public unless it is submitted under a claim of confidentiality.
   Claims of confidentiality must be made at the time the information is submitted to IDEM, and must follow the requirements set out in 326 IAC 17.1-4-1. Failure to follow these requirements exactly will result in your information becoming a public record, available for any one to inspect and photocopy.

PART A: Source Identification and Compliance Schedule

1. Source Name: Razor5 LLC	2.	Source ID: —
3. Permit Term Compliance Certification Schedule		
Date of first certification submittal:	Frequency of fut	ure submittals: Annual
DACT Ri Biol/ Mayo		
Part B indicates whether sources subject to section 112(r), Accid		vention, are complying with the
<ol> <li>Statement of Applicability / Non-Applicability: Indicate where requirement to submit and RMP.</li> </ol>	nether the source is	s subject to Section 112(r) and the
Source is subject to Section 112(r) and a Risk Manageme	ent Plan (RMP) is re	equired.
3. Permit Term Compliance Certification Schedule  Date of first certification submittal:  PART B: Risk Management Plan  Part B indicates whether sources subject to section 112(r), Accidental Release Prevention, are complying with the requirement to submit a Risk Management Plan (RMP).  4. Statement of Applicability / Non-Applicability: Indicate whether the source is subject to Section 112(r) and the requirement to submit and RMP.  Source is subject to Section 112(r) and a Risk Management Plan (RMP) is required.  Source is not subject to Section 112(r) and a Risk Management Plan (RMP) is not required.  RMP Submittal Information: Indicate when the RMP was submitted to each of the following agencies. If the RMP has not yet been submitted to any of the listed agencies, indicate the date when the RMP will be mailed to that agency. If the RMP for IDEM is attached to this application, please write "attached" in the Date Submitted column.		
Source is not subject to Section 112(r) and a Risk Manage	ement Plan (RMP)	is not required.
RMP Submittal Information: Indicate when the RMP was subm not yet been submitted to any of the listed agencies, indicate the	itted to each of the date when the RM	following agencies. If the RMP has P will be mailed to that agency. If the
RMP Submittal Information: Indicate when the RMP was subm not yet been submitted to any of the listed agencies, indicate the RMP for IDEM is attached to this application, please write "attach	itted to each of the date when the RM ned" in the Date Su	following agencies. If the RMP has P will be mailed to that agency. If the bmitted column.
RMP Submittal Information: Indicate when the RMP was subm not yet been submitted to any of the listed agencies, indicate the RMP for IDEM is attached to this application, please write "attach 5. Agency Name	itted to each of the date when the RM ned" in the Date Su	following agencies. If the RMP has P will be mailed to that agency. If the bmitted column.
RMP Submittal Information: Indicate when the RMP was subminot yet been submitted to any of the listed agencies, indicate the RMP for IDEM is attached to this application, please write "attached."  5. Agency Name  Chemical Safety and Hazard Investigation Board (CSHIB)	itted to each of the date when the RM ned" in the Date Su	following agencies. If the RMP has P will be mailed to that agency. If the bmitted column.
RMP Submittal Information: Indicate when the RMP was subminot yet been submitted to any of the listed agencies, indicate the RMP for IDEM is attached to this application, please write "attached."  5. Agency Name  Chemical Safety and Hazard Investigation Board (CSHIB)  United States Environmental Protection Agency (U.S. EPA)	itted to each of the date when the RM ned" in the Date Su	following agencies. If the RMP has P will be mailed to that agency. If the bmitted column.
RMP Submittal Information: Indicate when the RMP was submined yet been submitted to any of the listed agencies, indicate the RMP for IDEM is attached to this application, please write "attached."  5. Agency Name  Chemical Safety and Hazard Investigation Board (CSHIB)  United States Environmental Protection Agency (U.S. EPA)  Indiana Department of Environmental Management (IDEM)	itted to each of the date when the RM ned" in the Date Su	following agencies. If the RMP has P will be mailed to that agency. If the bmitted column.

	PART C: Co	ertification of Source Co	impliance Statu	g .				
	whether the source is or is not in taken in cases of noncompliance		applicable require	ements and to ide	entify corrective			
	he Most Accurate Statement.							
	source described in this air pollut irements and will continue to com			npliance with all a	applicable			
FOR	M CD-01 includes new requirement. The source will meet such rec	ents that apply or will app	ly to the emissio	ns unit during the	term of the			
requ	source described in this air pollut irements, except for the emission dule identified below.	ion control permit applica as unit(s) listed below. Co	tion is fully in cor impliance will be	npliance with all a achieved accordi	applicable ng to the			
10. Unit ID	11. Applicable Requirement	12. Corrective Action	13. Deadline	14. Progress Reports				
				Start Date	Frequency			
		7000						
					- 100 100 100 100 100 100 100 100 100 10			
,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,								
			,					
15. Signatu	re of Responsible Official							
	rtify that, based on informat information presented are t			ble inquiry, the	e statements			
	mela A. Gregorski	accurate and ool	President					
Name (typed		 Title	i icalaciit					
. tamo (typou	/	Title						
			4/8/2024					
Signature		Date						

		ertification of Source Co	ACCRECATION ACCRECATION AND A SECURITION OF THE PROPERTY OF TH	The first development of the state of the st	
	whether the source is or is not it taken in cases of noncompliance		applicable require	ements and to ide	ntify corrective
9. Check th	ne Most Accurate Statement.				
	source described in this air pollut			npliance with all a	pplicable
	rements and will continue to com				
	M CD-01 includes new requirement. The source will meet such rec			ns unit during the	erm of the
	source described in this air pollut			npliance with all a	pplicable
	rements, except for the emission	is unit(s) listed below. Co	mpliance will be	achieved according	ng to the
	dule identified below.				
10. Unit ID	11. Applicable Requirement	12. Corrective Action	13. Deadline	14. Progress R	eports
				Start Date	Frequency
;					
					The state of the s
15. Signatur	re of Responsible Official				
☐ I cer	tify that, based on informat	ion and helief formed	after reasons	hle inquiny the	statements
	information presented are			bie inquiry, tile	SIGICITICITIS
	nela A. Gregorski		President		
Name (typed		 Title			
Λ	. 1. A (11	7. (			
- KM	May Sugger	$\mathcal{W}_{\underline{}}$	4/11/2024		
Signature	, , , , , , , , , , , , , , , , , , ,	Date		пост <del>або пота примен МО менено по Разлема по претаваний на</del> песана п	nn Magalak (1880) Nagazak san yimbayaza (Aron Mada sanan Malayay indapak menganak

APPENDIX B
POTENTIAL EMISSION CALCULATIONS

Facility Wide Potential Emissions Summary

Facility:

Address:

55001 Larrison Blvd., New Cartisle, IN 46552

Table B.1 - Summary of Facility V	Wide Potential Emissi	ons									
Projection United	Ineighticant Activity	Edition out 15, Up.	Tuniber of Brits	No <u>u</u> (py)	es (tuy)	en e	VOC GPO	964 (UV	Mar. Single HAP (QV)	Total Haire (Fre)	00 (g (g)7)
Critical Emergency Generators (Tier 4 Equivalent - 2,750 kW ea.)	Significant EUs	CEG No. 1 - 234	234	236.80	90.41	10.52	38.44	0.54	0.17	0.35	58,291.86
Ancillary Emergency Generators for Water Treatment System (Tier 2 - 1,500 kW ea.)	Significant EUs	WTP Gens No. 1 & 2	2								
House Emergency Generators (Tier 2 - 750kW ea.)	Insignificant per 326 IAC 2-7-1 (21)(xxii)(bb)	HG No. 1 ~ 9	9								
Ancillary Emergency Generator for CAB (Tier 3 - 400 kW)	Insignificant per 326 IAC 2-7-1 (21)(xxii)(bb)	CAB Gen No. 1	1	12.05	19.19	1.33	7.75	1.53	0.004	0.01	863.73
Ancillary Emergency Generator for LCB (Tier 3 - 400 kW)	Insignificant per 326 IAC 2-7-1 (21)(xxii)(bb)	LCB Gen No. 1	1								
Ancillary Emergency Generator for ACB (Tier 3 - 250kW)	Insignificant per 326 IAC 2-7-1 (21)(xxii)(bb)	ACB Gen No. 1	1								
Central Diesel Fuel Storage Tanks - Nine (9) 12,000-Gal Fuel Tanks	Insignificant per 326 IAC 2-7-1(21)(E)(iv) or Trivial per 2-7-1 (42)(C)(t)&(ii)(DD)	TK No. 1 - 9	9				0.056		Neg.	Neg.	
Diesel Fuel Belly Tanks for Tier 4 Gens, 6,300-gal each	Insignificant per 326 IAC 2-7-1(21)(E)(iv) or Trivial per 2-7-1 (42)(C)(i)&(ii)(DD)	BT No, 1 - 234	234				0.150		Neg.	Neg.	
Diesel Fuel Belly Tanks in various sizes for Ancillary Gens	Insignificant per 326 IAC 2-7-1(21)(E)(iv) or Trivial per 2-7-1 (42)(C)(i)&(ii)(DD)	BT WTP No. 1 & 2 BT HG No. 1 - 9 BT CAB No. 1 BT LCB No. 1 BT ACB No. 1	13				0.002		Neg.	Neg.	
Total				248.85	109.60	11.85	46,40	2.08	0.18	0.36	59,155.59
Proposed Emission Limits				< 249		See I	lote 1		< 9	< 24	-
	<b>~</b>										
Major Title V Threshold				100	100	100	100	100	10	25	
Title V Triggered?	L			Yes	Yes	No	No	No	No	No	~

Major Title V Threshold		100	100	100	100	100	10	25	-
Title V Triggered?		Yes	Yes	No	No	No	No	No	-
PSD Threshold		250	250	250	250	250			-
PSD Triggered?		No	No	No	No	No			-

Note:

1. NO<sub>X</sub> is the pollutant with the highest emission rate. Therefore, when NO<sub>X</sub> emissions are limited to be no more than 249 tpy, potential emissions of other criteria pollutants are inherently below 249 tpy.

Emission Factors per Engine Type
Facility: SBN100
Address: 55001 Larrison Blvd., New Carlisle, IN 46552

Engine Information

anging distormined				
	Attimber of Sens	Rower Capacity	Thur known	Steph)
Number and Three of	234	2,750 kW ea.	Tier 2 Certified, with control to achieve Tier 4 Equivalent	Model TBD (CAT 3516e or Cummins DQLF)
Gallerator/Singles-Sate	2	1,500 kW ea.	Tier 2 Certified	3512C Gens
	9	750 kW ea.	Tier 2 Certified	Model TBD (C18 Gens or Cummins DQFAA)
	2	400 kW ea.	Tier 3 Certified	C15 Gens, 400 kW ea.
	1	250 kW ea.	Tier 3 Certified	C9 Gen, 250 kW

0.853

Engine Specifications

Table B.3 - Engine Power Output by Load

		P(0)	as Omgons e (	(diap)		l
Engine Type	10%-Egad	25% Lyad	50% 6636	F580 Legid	Full Chandity	1
2.750 kW Tier 4 Equivalent	507	1,086	2,052	3,017	4,021	Cummins
2,730 KW Hei 4 Equivalent	549	1,131	2,102	3,072	4,043	CAT
1,500 kW Tier 2 Certified	312	632	1,144	1,662	2,206	
750 kW Tier 2 Certified	130	287	549	811	1,073	Cummins
750 KW Her 2 Certified	155	315	575	840	1,112	CAT
400 kW Tier 3 Certified	92	179	319	467	619	l
250 kW Tier 3 Certified	69	124	211	302	398	1

Table B.4 - Engine Fuel C	onsumption	and Heat Inp	ut by Load	e esta de la companya			iar at tai	antie ekstekte	the comp		1
Engine Bose	Adding though	245% Long	509-10 <b>9</b> 6	340.00.34	Foll Stangally	1896 Lead	350 Logic	50204700	Seen Lords	Fall 25 and by	
2.750 kW Tier 4 Equivalent	38.0	61.0	106.0	147.0	187.0	5.21	8.36	14.53	20.14	25.62	Curnmins
2,750 kW (lef 4 Equivalent	36.1	62,9	107.5	147.3	192.2	4.95	8.62	14.73	20,18	26.34	CAT
1,500 kW Tier 2 Certified	19.5	33.5	57.3	81.0	103.2	2.67	4.59	7.85	11.10	14.14	1
750 kW Tier 2 Certified	9,0	16.0	27.0	39.0	51.0	1.23	2.19	3.70	5.34	6.99	Cummins
750 KW Her 2 Cerdiled	9,5	16.6	28.4	42.8	53.6	1.30	2.27	3.89	5.86	7.34	CAT
400 kW Tier 3 Certified	6.5	10.7	18.7	25.4	31.3	0.89	1.47	2.56	3.48	4.29	1
250 kW Tier 3 Certified	4.3	7.2	11.4	15.3	19.1	0.59	0.99	1.56	2.10	2.62	1

Notes:

1. Per the manufacturer specification sheets and performance data for each engine model.

2. Diesel fuel consumption was converted to heat input based on the diesel high heating value from the USEPA's AP-42, Section 3.4, Large Stationary Diesel and All Stationary Dual-fuel Engines, Table 3.4-1, footnote a (October 1996):

Diesel HHV = 0.137 MMBtu/gal

137030

 $\mathsf{NO}_{\mathsf{X}\mathsf{f}}$  CO, VOC, and Filterable PM Emission Factors

Table 8.5.a - 2,750 kW Uncontrolled Emission Factors in g/bhp-hr

	2,750 kg	Hourly Unco	ptrolled Eng	slon Factors	(a/lehe-hi)	Cupuplics	2,750	av Floorly Un	controlled E	nisylon (taylo	s (g/blue br	- CAT
Polistant	16% Bond	25% Load	U0% Loaf	759 (Bosit)	Full Standby	Modifiero	10% Load	25% (and	50% Load	750 a torid	Fell Standse	Maximum
Criteria Pollutants												
NO <sub>X</sub>	8.81	4.78	4,41	5.80	8.51	8.81	8.51	3.73	3.65	4.83	6.00	8.51
со	2.30	0.88	0.38	0.50	1.25	2.30	3.43	1.68	0.57	0.56	1.16	3.43
voc	1.00	0.56	0.29	0.18	0.13	1.00	0.46	0.29	0.17	0.12	0.10	0.46
Filt, PM	0.29	0.16	0.09	0.10	0.13	0.29	0.21	0.15	0.07	0.05	0.07	0.21

Table B.5.b - 1,500 kW Uncontrolled Emission Factors in g/bhp-hr

	1,500 kW Hourly Uncontrolled Emission Pactors (g/php-hr)										
Pollutant	10% Load	25% Lond	50% Load	75% tead	Full Standby	Maximum					
Criteria Pollutants		A CONTRACTOR OF THE PARTY OF TH									
NO <sub>X</sub>	8.87	5.68	4.14	4.28	6.38	8.87					
co	5.95	3.04	1.42	0.69	0.84	5.95					
voc	1.03	0,44	0.31	0.22	0.16	1.03					
Filt. PM	0.35	0.28	0.13	0.06	0.04	0.35					

Table B.5.c - 750 kW Uncontrolled Emission Factors in g/bhp-h

	750 KW	Hearly Uncon	trailed Envirs	ion Factors (c	y/bhp-hc) *-	750 A	W Hobely Uni	antrolled Em	ission Factor	s (g/khip-lir)	- CAT	
Pollutant	10% Load	25% knad	50% Load	75% Lead	Full Standby	Maxidium	10% Load	25% Load	50% Lead	759a Logil	Full Standby	Mestiman
Criteria Pollutants	1											
NO <sub>X</sub>	8.39	7.32	5.77	4.94	5.02	8.39	5.42	4.62	3,88	4.05	5.85	5.85
co	4.60	2.60	1.00	0.80	1.00	4.60	13.85	1.85	0.25	0.52	0.41	13.85
voc	0.58	0.34	0.19	0.17	0.15	0.58	5.59	0.33	0.16	0.15	0.11	5.59
Filt. PM	0.22	0.30	0.26	0.22	0.20	0.30	0.93	0.16	0.07	0.08	0.06	0.93

Table B.5.d - 400 kW Uncontrolled Emission Factors in g/bhp-hr

	40	400 kW Hourly Uncontrolled Emission Factors (g/blip-br) 1											
Pollutant	10% Load	25% Load	50% Load	75% Load	Full Standby	Maximum							
Criteria Pollutants													
NO <sub>X</sub>	5.39	4,40	2.46	2.75	4,22	5.39							
CO	5.70	3.37	5.08	2.91	0.67	5.70							
VOC	1.23	0.37	0.28	0.15	0.08	1.23							
Filt, PM	0.39	0,22	0.18	0.09	0.07	0.39							

# Emission Factors per Engine Type Facility: SBN100 Address: 55001 Larrison Blvd., New Carlisle, IN 46552

Table 8.5.4 - 250 kW Uncontrolled Emission Factors in a /hhn-hr

	ontrolled Emission Factors in gypnp-nr											
Polintant	4000 1000	75 % Logic	Spon Lain	75 versions	101	Bosimum						
Criteria Pollutants												
NO <sub>4</sub>	3.22	2.27	2.16	2.38	3.14	3.22						
со	3.89	2.30	1.01	0.90	0.68	3.89						
voc	1.03	0.57	0.44	0.29	0.17	1.03						
Filt. PM	0.49	0.40	0.23	0.22	0.16	0.49						

#### Notes:

3. Emission factors are from the manufacturer specification sheets and performance data for each engine model. The performance data sheets provide nominal emission data and potential site variation data. For a conservative estimate of the potential emissions, the potential site variation data are used in the emission calculations.

#### $\mathrm{SO}_2$ , Condensable PM, and HAPs Emission Factors

Table B.6.a - AP-42 Emission Factors *											
Pellutant	Emiasio) Pactor for Large Gens										
	(16/ Materia)	(17/MB(370)									
SO <sub>2</sub> <sup>5</sup>	1.52E-03	0.29									
Condensable PM	7.70E-03	Same as left									
Benzene	7.76E-04	9.33E-04									
Toluene	2.81E-04	4.09E-04									
Xylene	1.93E-04	2.85E-04									
Formaldehyde	7.89E-05	1.18E-03									
Acetaldehyde	2,52E-05	7.67E-04									
Acrolein	7.88E-06	9.25E-05									
Total PAH 6	2.12E-04	1.68E-04									

#### Table B.6.b - GHG Emission Factors




Table B.6.c - GHG Global Warming Factors

Table B.O.C -	Gild Global V
Politakasi	Global Warming Potopolal
CO,	1
CH <sub>4</sub>	25
N <sub>2</sub> O	298

- 4. Emission factors were taken from AP-42, Chapter 3.4, Tables 3.4-1, 3.4-3 & 3.4-4 for engines > 600 kW and Chapter 3.3, Table 3.3-1 & 3.3-2 for engines < 600 kW.

  5. The SO<sub>2</sub> emission factor for engines > 600 kW was calculated based on the maximum allowable diesel fuel sulfur content under NSPS Subpart IIII: Diesel Sulfur Content = 0.0015 wt.% Sulfur
- 7. Per 40 CFR 98, Subpart C, Tables C-1 and C-2 for No. 2 fuel oil combustion, The emission factors were converted from kg/MMBtu to lb/MMBtu.
- 8. The CO2e emission factor was calculated as the sum of each GHG pollutant multiplied by its global warming potential, per 40 CFR 98, Subpart A, Table A-1.

#### Hourly Emission Rates

#### Emission Factors in lbs/gal of Fuel Input

Table B.7.a - 2,750 kW H	ourly Uncont	rolled Emissi	on Rates in Ib	/hr/gen		Table B.8.a - 2,750 kW Uncontrolled Emission Factor in lbs/gal/gen						
	2,750	kW Hourly U	ncontrolled E	mission fact	ors (lb/fo/ga	9)	7,77,72,750	this Hourly t	aeanteniled E	mis Glan Petel	ara (di maiya	er)
Poflutant	10% Load	75% Load	50% Load	75% Load	Full Standby	Maximum	1894 Load	25%-Load	50% Epad	75% Lord.	Full Standby	Maximus
Criteria Pollutants												
NO <sub>x</sub> - Cummins	9.85	11.44	19.95	38,58	75.44	75,44	0.259	0.188	0.188	0.262	0.403	0.403
NO <sub>X</sub> - CAT	10.30	9.30	16.91	32.71	53.48	53.48	0,285	0.148	0.157	0.222	0.278	0.285
CO - Cummins	2.57	2.11	1.72	3.33	11.08	11.08	0,068	0.035	0.016	0.023	0.059	0,068
CO - CAT	4.15	4.19	2.64	3.79	10.34	10.34	0.115	0.067	0.025	0.026	0.054	0.115
VOC - Cummins	1.12	1.34	1.31	1.20	1.15	1,34	0.029	0.022	0.012	0.008	0.006	0.029
VOC - CAT	0.56	0.72	0.79	0.81	0.89	0.89	0.015	0.011	0.007	0.006	0.005	0.015
Filt. PM - Curnmins	0.32	0.38	0.41	0.67	1.11	1.11	0.009	0.006	0.004	0.005	0.006	0.009
Filt. PM - CAT	0.25	0.37	0.32	0.34	0.62	0.62	0.007	0.006	0.003	0.002	0.003	0.007
PM/PM <sub>10</sub> /PM <sub>2.5</sub> <sup>12</sup> - Cummins	0.36	0.45	0.52	0.82	1.31	1.31	0.010	0.007	0.005	0.006	0.007	0.010
PM/PM <sub>10</sub> /PM <sub>2.5</sub> <sup>12</sup> - CAT	0.29	0.44	0.44	0.49	0.83	0.83	0.008	0.007	0.004	0.003	0.004	0.008
SO₂	0.008	0.013	0.022	0.031	0.040	0.04	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002
Hazardous Air Pollutants (Sa	ame for Cumm	ins and CAT)									-	
Benzene	4.04E-03	6.69E-03	1.14E-02	1.57E-02	2.04E-02	2.04E-02	1.06E-04	1.06E-04	1.06E-04	1.06E-04	1.06E-04	1.06E-04
Toluene	1.46E-03	2.42E-03	4.14E-03	5.67E-03	7.40E-03	7.40E-03	3.85E-05	3.85E-05	3.85E-05	3.85E-05	3.85E-05	3.85E-05
Xylenes	1.00E-03	1.66E-03	2.84E-03	3.90E-03	5.08E-03	5.08E-03	2.64E-05	2.64E-05	2.64E-05	2.64E-05	2,64E-05	2.64E-05
Formaldehyde	4.11E-04	6.80E-04	1.16E-03	1.59E-03	2.08E-03	2,08E-03	1.08E-05	1.08E-05	1.08E-05	1.08E-05	1.08E-05	1.08E-05
Acetaldehyde	1.31E-04	2.17E-04	3.71E-04	5.09E-04	6.64E-04	6,64E-04	3.45E-06	3.45E-06	3.45E-06	3.45E-06	3.45E-06	3.45E-06
Acrolein	4.10E-05	6.79E-05	1.16E-04	1.59E-04	2.08E-04	2.08E-04	1.08E-06	1.08E-06	1.08E-06	1.08E-06	1.08E-06	1.08E-06
Total PAH	1.10E-03	1.83E-03	3.12E-03	4.28E-03	5.58E-03	5,58E-03	2.91E-05	2.91E-05	2.91E-05	2.91E-05	2.91E-05	2.91E-05
Total HAP	8.20E-03	1.36E-02	2.32E-02	3.18E-02	4.15E-02	4,15E-02	2.16E-04	2.16E-04	2.16E-04	2.16E-04	2,16E-04	2.16E-04
Greenhouse Gases (Same fo	or Cummins an	d CAT)										
CO <sub>2</sub>	849.04	1405.39	2401.90	3291.16	4294.38	4294.38	22.34	22.34	22.34	22.34	22.34	22.34
CH.	0.03	0.06	0.10	0.13	0.17	0.17	9.06E-04	9.06E-04	9.06E-04	9.06E-04	9.06E-04	9.06E-04
N₂O	0,01	0.01	0.02	0.03	0.03	0.03	1.81E-04	1.81E-04	1.81E-04	1.81E-04	1.81E-04	1.81E-04
CO₂e	851.96	1410,21	2410.14	3302.46	4309.11	4309.11	22.42	22.42	22.42	22.42	22,42	22.42

Emission Factors per Engine Type
Facility: SBN 100
Address: 55001 Larrison Blvd., New Carlisle, IN 46552

Table B.7.b - 2,750 kW Hourly Controlled Emission Rates in lb/hr/gen

Table B.8.b - 2,750 kW Controlled Emission Factor in lbs/gal/gen

Table 8.7.5 - 2,750 kW H	e B.7.b - 2,750 kW Hourly Controlled Emission Rates in lb/hr/gen								Table B.8.b - 2,750 kW Controlled Emission Factor in lbs/gal/gen					
	5.7	er in the House	Controlled E	nasana Papis	ni (le nijeni	0 11	2.3	n ka armi	free claury controlled Since		ra (lb/get/ge	0)		
Palistoni	LIVA Lead	25% cond	50% Land	760 hand	Full: Standing		com cons	45%   ned	50% toos	35% total	est Stantiby	Maximum		
Criteria Pollutants														
NO <sub>x</sub> - Cummins	9.85	0.95	1.66	3.20	6.26	6.26	0.259	0.016	0.016	0.022	0.033	0.033		
NO <sub>x</sub> - CAT	10.30	0.77	1.40	2.72	4.44	4.44	0.285	0.012	0.013	0.018	0.023	0.023		
CO - Cummins	2.57	0.63	0.52	1.00	3.32	3.32	0.068	0 010	0,005	0.007	0.018	0.018		
CO - CAT	4.15	1.26	0.79	1.14	3.10	3.10	0.115	0.020	0.007	0.008	0.016	0.020		
VOC - Cummins	1.12	0.74	0.72	0.66	0.63	0.74	0.029	0.012	0.007	0.004	0.003	0.012		
VOC - CAT	0.56	0.40	0.43	0.45	0.49	0.49	0.015	0.006	0.004	0.003	0.003	0.006		
Filt. PM - Cummins	0.32	0.12	0.13	0.21	0.35	0.35	0.009	0.002	0.001	0.001	0.002	0.0020		
Filt, PM - CAT	0.25	0.12	0.10	0.11	0.20	0.20	0.007	0.002	0.001	0.001	0.001	0.0019		
PM/PM <sub>10</sub> /PM <sub>2.S</sub> <sup>12</sup> - Cummins	0.36	0.18	0.24	0.36	0.55	0.55	0.010	0.003	0.002	0.002	0.003	0.0030		
PM/PM <sub>10</sub> /PM <sub>2 5</sub> 12 - CAT	0.29	0.18	0.22	0.26	0.40	0.40	0.008	0.003	0.002	0.002	0.002	0.0029		
SO <sub>2</sub> - Same for Cummins & CAT	0.008	0.013	0.022	0.031	0.039	0.039	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002		
Hazardous Air Pollutants (S.	ame for Cumm	ins and CAT)					I							
Benzene	4.04E-03	3.68E-03	6.29E-03	8.61E-03	1.12E-02	1.12E-02	1.06E-04	5.85E-05	5.85E-05	5.85E-05	5.858-05	5.85E-05		
Toluene	1.46E-03	1.33E-03	2.28E-03	3.12E-03	4.07E-03	4.07E-03	3.85E-05	2.12E-05	2.12E-05	2.12E-05	2.12E-05	2.12E-05		
Xylenes	1.00E-03	9.15E-04	1.56E-03	2.14E-03	2.80E-03	2.80E-03	2.64E-05	1.45E-05	1.45E-05	1.45E-05	1.45E-05	1.45E-05		
Formaldehyde	4.11E-04	3,74E-04	6.39E-04	8.76E-04	1.14E-03	1.14E-03	1.08E-05	5.95E-06	5.95E-06	5.95E-06	5.95E-06	5.95E-06		
Acetaldehyde	1.31E-04	1.19E-04	2.04E-04	2.80E-04	3.65E-04	3.65E-04	3.45E-06	1.90E-06	1.90E-06	1.90E-06	1.90E-06	1.90E-06		
Acrolein	4.10E-05	3.74E-05	6.38E-05	8.75E-05	1.14E-04	1.14E-04	1.08E-06	5.94E-07	5.94E-07	5.94E-07	5.94E-07	5.94E-07		
Total PAH	1.10E-03	1.00E-03	1.72E-03	2.35E-03	3.07E-03	3.07E-03	2.91E-05	1.60E-05	1.60E-05	1.60E-05	1.60E-05	1.60E-05		
Total HAP	8.20E-03	7.46E-03	1.28E-02	1.75E-02	2.28E-02	2.28E-02	2.16E-04	1.19E-04	1.19E-04	1.19E-04	1.19E-04	1.19E-04		
Greenhouse Gases (Same f	or Cummins ar	id CAT)												
CO <sub>2</sub>	849.04	1362.94	2368.39	3284.46	4178.19	4178.19	22.34	22.34	22.34	22.34	22.34	22.34		
CH₄	0.03	0.06	0.10	0.13	0.17	0.17	9.06E-04	9.06E-04	9.06E-04	9.06E-04	9.06E-04	9,06E-04		
N <sub>2</sub> O	0.01	0.01	0.02	0.03	0.03	0.03	1.81E-04	1.81E-04	1.81E-04	1.81E-04	1.81E-04	1.81E-04		
CO₂e	851.96	1367,62	2376.51	3295.73	4192.53	4192.53	22.42	22.42	22.42	22.42	22.42	22.42		

Table B.7.c - 1,500 kW Hourly Uncontrolled Emission Rates in lb/hr/gen

Table B.8.c - 1,500 kW Uncontrolled Emission Factor in Ibs/gal/gen

	1,410	) bulk Houriy t	hcontrolled E	mission Fact	de entratario	n) *****	1,500	HW Noorly t	neon) rolled l	mismoli fict	es (disarriva	en,
Pallutant	10% bead	25% (cond	9000 Lond	75% Load	Full Standby	Maximum	10% Load	29% Lond	Strik Load	75% Load:	Full Standby	Maximum
Criteria Pollutants	T											
NOx	6.10	7.91	10.44	15.68	31.03	31.03	0.31	0.24	0.18	0.19	0.30	0,313
co	4.09	4.24	3.58	2.53	4.09	4.24	0.21	0.13	0.06	0.03	0.04	0.210
voc	0.71	0.61	0.78	0.81	0.78	0.81	0.036	0.018	0.014	0,010	0.008	0.036
Filt. PM	0.24	0.39	0,33	0.22	0.19	0.39	0.012	0.012	0,006	0.003	0.002	0.012
PM/PM <sub>10</sub> /PM <sub>2.5</sub> 12	0.26	0.43	0.39	0.31	0.30	0.43	0.013	0.013	0.007	0.004	0.003	0.013
SO <sub>2</sub>	0.0019	0.0033	0,0056	0.0081	0.0106	0.01	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001
Hazardous Air Pollutants	T											
Benzene	2.07E-03	3.56E-03	6.09E-03	8.61E-03	1.10E-02	1.10E-02	1.06E-04	1.06E-04	1.06E-04	1.06E-04	1.06E-04	1.06E-04
Toluene	7.51E-04	1.29E-03	2.21E-03	3.12E-03	3.97E-03	3.97E-03	3.85E-05	3.85E-05	3.85E-05	3.85E-05	3.85E-05	3.85E-05
Xylenes	5,16E-04	8.86E-04	1.52E-03	2.14E-03	2.73E-03	2.73E-03	2,64E-05	2.64E-05	2.64E-05	2.64E-05	2.64E-05	2.64E-05
Formaldehyde	2.11E-04	3.62E-04	6.20E-04	8.76E-04	1.12E-03	1.12E-03	1.08E-05	1.08E-05	1.08E-05	1.08E-05	1.08E-05	1.08E-05
Acetaldehyde	6.73E-05	1.16E-04	1.98E-04	2.80E-04	3.56E-04	3.56E-04	3.45E-06	3.45E-06	3.45E-06	3.45E-06	3,45E-06	3.45E-06
Acrolein	2.11E-05	3.62E-05	6.19E-05	8.75E-05	1.11E-04	1.11E-04	1.08E-06	1.08E-06	1.08E-06	1.08E-06	1.08E-06	1.08E-06
Total PAH	5.66E-04	9.73E-04	1.66E-03	2.35E-03	3.00E-03	3,00E-03	2.91E-05	2.91E-05	2.91E-05	2.91E-05	2.91E-05	2.91E-05
Total HAP	4.21E-03	7.23E-03	1.24E-02	1.75E-02	2.23E-02	2.23E-02	2.16E-04	2.16E-04	2.16E-04	2.16E-04	2.16E-04	2.16E-04
Greenhouse Gases												
CO <sub>2</sub>	435.69	748.50	1280.27	1809.81	2305.83	2305.83	22.34	22.34	22.34	22.34	22.34	22.34
CH₄	0.02	0.03	0.05	0.07	0.09	0.09	9.06E-04	9.06E-04	9.06E-04	9.06E-04	9.06E-04	9.06E-04
N₂O	0.00	0.01	0.01	0.01	0.02	0.02	1.81E-04	1.81E-04	1.81E-04	1.81E-04	1.81E-04	1.81E-04
CO₂e	437.19	751,07	1284.66	1816.02	2313.74	2313.74	22.42	22.42	22.42	22.42	22.42	22.42

# Emission Factors per Engine Type Facility: 5BN100 Address: 55001 Larrison Blvd., New Carlisle, IN 46552

Table 8.7.d - 750 kW Hourly Uncontrolled Emission Rates in lb/hr/gen

Table B.8.d - 750 kW Uncontrolled Emission Factor in lbs/gal/gen

Table 8.7.4 - 730 KW HOL	8.7.d - 750 kW Hourly Uncontrolled Emission Rates in lb/hr/gen 750 kW Hourst Uncontrolled Staleston Facebres (Kyrir Ignas)								Table B.8.d - 750 kW Uncontrolled Emission Factor in lbs/gal/gen					
	2/50	at double to			3 (17)		100	10.00	controlled fo	nggan salan	se disposition	DP4		
Permant	10% Load	75% Energ	50% baad	75% Load	Full Starretter	Madionic	40001.200	25.90 Load	Strong and	FFFE Load	Fall Standby	Maximum		
<u>Criteria Pollutants</u>														
NO <sub>x</sub> - Cummins	2.40	4.63	6.98	8.83	11.88	11.88	0.27	0.29	0.26	0.23	0.23	0.289		
NO <sub>x</sub> - CAT	1.85	3.21	4.92	7.50	14.34	14.34	0.19	0.19	0.17	0.18	0.27	0.268		
CO - Cummins	1.32	1.65	1.21	1.43	2.37	2.37	0.15	0.10	0.04	0.04	0.05	0.146		
CO - CAT	4.73	1.28	0.32	0.96	1.01	4.73	0.50	0.08	0.01	0.02	0.02	0.498		
VOC - Cummins	0.17	0.22	0.23	0.30	0.35	0.35	0.018	0.013	0.009	0.008	0.007	0.018		
VOC - CAT	1.91	0.23	0.20	0.28	0.27	1.91	0.201	0.014	0.007	0.006	0.005	0.201		
Filt. PM - Cummins	0.06	0.19	0.31	0.39	0.47	0.47	0.007	0.012	0.012	0.010	0.009	0.012		
Filt, PM - CAT	0.32	0.11	0.09	0.15	0.15	0.32	0.033	0.007	0.003	0.003	0.003	0.033		
PM/PM <sub>19</sub> /PM <sub>2 5</sub> <sup>12</sup> - Cummins	0.07	0.21	0.34	0.43	0.53	0.53	0.008	0.013	0.013	0.011	0.010	0.013		
PM/PM <sub>10</sub> /PM <sub>2.5</sub> <sup>12</sup> - CAT	0.33	0.13	0.12	0.19	0.20	0,33	0.035	0.008	0.004	0.005	0.004	0.035		
SO <sub>2</sub> - Same for Cummins & CAT	0.002	0.003	0.006	0.008	0.011	0.01	0.0002	0.0002	0.0002	0.0002	0.0002	0.0002		
Hazardous Air Pollutants (Sa	ame for Cumm	ins and CAT)												
Benzene	1.01E-03	1.77E-03	3.02E-03	4.55E-03	5.70E-03	5.70E-03	1.06E-04	1.06E-04	1.06E-04	1.06E-04	1.06E-04	1.06E-04		
Toluene	3.66E-04	6.39E-04	1.09E-03	1.65E-03	2.06E-03	2.06E-03	3.85E-05	3.85E-05	3.85E-05	3.85E-05	3.85E-05	3.85E-05		
Xylenes	2.51E-04	4.39E-04	7.51E-04	1.13E-03	1.42E-03	1.42E-03	2.64E-05	2.64E-05	2.64E-05	2.64E-05	2.64E-05	2.64E-05		
Formaldehyde	1.03E-04	1.79E-04	3.07E-04	4.63E-04	5.80E-04	5.80E-04	1.08E-05	1.08E-05	1.08E-05	1.08E-05	1.08E-05	1.08E-05		
Acetaldehyde	3.28E-05	5.73E-05	9.81E-05	1.48E-04	1.85E-04	1.85E-04	3.45E-06	3.45E-06	3.45E-06	3.45E-06	3.45E-06	3.45E-06		
Acrolein	1.03E-05	1.79E-05	3.07E-05	4.62E-05	5.79E-05	5.79E-05	1.08E-06	1.08E-06	1.08E-06	1.08E-06	1.08E-06	1.08E-06		
Total PAH	2.76E-04	4.82E-04	8.25E-04	1.24E-03	1.56E-03	1.56E-03	2.91E-05	2.91E-05	2.91E-05	2.91E-05	2.91E-05	2.91E-05		
Total HAP	2.05E-03	3.58E-03	6.13E-03	9.23E-03	1.16E-02	1.16E-02	2.16E-04	2.16E-04	2.16E-04	2.16E-04	2.16E-04	2.16E-04		
Greenhouse Gases (Same fo	or Cummins an	d CAT)												
CO <sup>5</sup>	212.26	370.90	634.55	956.29	1197.60	1197.60	22,34	22.34	22.34	22.34	22.34	22.34		
CH₄	0.01	0.02	0.03	0.04	0.05	0.05	9.06E-04	9.06E-04	9.06E-04	9.06E-04	9.06E-04	9.06E-04		
N₂O	0.00	0.00	0.01	0.01	0.01	0.01	1.81E-04	1.81E-04	1.81E-04	1.81E-04	1.81E-04	1.81E-04		
CO <sub>z</sub> e	212.99	372.17	636,73	959.57	1201.71	1201.71	22.42	22.42	22.42	22.42	22.42	22.42		

Table B.7.e - 400 kW Hourly Uncontrolled Emission Rates in lb/hr/gen Table B.8.e - 400 kW Uncontrolled Emission Factor in lbs/gal/gen

	400	400 kW Henriy Uncontrolled Emission Factors (Us/In/gea) <sup>9,10</sup>							490 kW Hourly Uncontrolled Emission Factors (lb/gal/gen) 14					
Polistant	10% Load	25% Load	50% Load	75% Lucid	Full Standing	Maximum	T6% Load	25% Lead	50% Load	75% Local	Full Standing	Nexion		
Criteria Pollutants														
NO <sub>X</sub>	1.10	1.74	1.73	2.83	5.76	5.76	0.17	0.16	0.09	0.11	0.18	0.184		
co	1.16	1.33	3.57	3.00	0.91	3.57	0.18	0.12	0.19	0.12	0.03	0.191		
voc	0,25	0.15	0.20	0.15	0.11	0.25	3.85E-02	1.36E-02	1.05E-02	6.08E-03	3.49E-03	0.038		
Filt. PM	0.08	0.09	0.13	0.09	0.10	0.13	1.22E-02	8.11E-03	6.77E-03	3.65E-03	3.05E-03	1.22E-02		
PM/PM <sub>10</sub> /PM <sub>2.5</sub> 12	8.61E-02	9.81E-02	1.46E-01	1.19E-01	1.29E-01	0.15	1.33E-02	9.17E-03	7.82E-03	4.70E-03	4.11E-03	1,33E-02		
SO <sub>2</sub>	2.58E-01	4.25E-01	7.43E-01	1.01E+00	1.24E+00	1.24	3.97E-02	3.97E-02	3.97E-02	3.97E-02	3.97E-02	3.97E-02		
Hazardous Air Pollutants														
Benzene	8.31E-04	1.37E-03	2.39E-03	3,25E-03	4.00E-03	4.00E-03	1.06E-04	1.06E-04	1.06E-04	1.06E-04	1.06E-04	1.06E-04		
Toluene	3.64E-04	6.00E-04	1.05E-03	1.42E-03	1.75E-03	1.75E-03	3.85E-05	3.85E-05	3.85E-05	3.85E-05	3.85E-05	3,85E-05		
Xylenes	2.54E-04	4.18E-04	7.30E-04	9.92E-04	1.22E-03	1.22E-03	2.64E-05	2.64E-05	2.64E-05	2.64E-05	2.64E-05	2.64E-05		
Formaldehyde	1.05E-03	1.73E-03	3.02E-03	4.11E-03	5.06E-03	5.06E-03	1.08E-05	1.08E-05	1.08E-05	1.08E-05	1.08E-05	1.08E-05		
Acetaldehyde	6.83E-04	1.12E-03	1.97E-03	2.67E-03	3.29E-03	3.29E-03	3.45E-06	3.45E-06	3.45E-06	3.45E-06	3.45E-06	3.45E-06		
Acrolein	8.24E-05	1,36E-04	2.37E-04	3.22E-04	3.97E-04	3.97E-04	1.08E-06	1.08E-06	1.08E-06	1.08E-06	1.08E-06	1.08E-06		
Total PAH	1.50E-04	2.46E-04	4.30E-04	5.85E-04	7.21E-04	7.21E-04	2.91E-05	2.91E-05	2.91E-05	2.91E-05	2.91E-05	2.91E-05		
Total HAP	3.42E-03	5.62E-03	9.83E-03	1.33E-02	1.64E-02	1.64E-02	2.16E-04	2.16E-04	2.16E-04	2.16E-04	2.16E-04	2.16E-04		
Greenhouse Gases														
CO <sub>2</sub>	145.23	239.07	417.82	567.52	699.34	699.34	22,34	22.34	22.34	22.34	22.34	22.34		
CH₄	0.01	0.01	0.02	0.02	0.03	0.03	9.06E-04	9.06E-04	9.06E-04	9.06E-04	9.06E-04	9.06E-04		
N <sub>2</sub> O	0.00	0.00	0.00	0.00	0.01	0.01	1.81E-04	1.81E-04	1.81E-04	1.81E-04	1.81E-04	1.81E-04		
CO₂e	145.73	239.89	419.25	569.47	701.74	701.74	22.42	22.42	22.42	22.42	22.42	22.42		

Emission Factors per Engine Type

Facility:

Address:

55001 Larrison Blvd., New Carlisle, IN 46552

Table B.7.f - 250 kW Hourly Uncontrolled Emission Rates in lb/hr/gen

Table B.8.f - 250 kW Uncontrolled Emission Factor in lbs/gal/gen

	kw nounty oncomercined cantesion races in to/m/gen							Table 3.3.7 250 KW Officiality and Climation ( tector in 103) gain gen					
	2,57	HAV House to	tern er dakeler	erpeten Paraki	re (1071) / gran		250	NW Renew V	(augistolina) la	alission Facto		10 5	
Politicant	20% thend	zeste exemple:	50% to su.	Mary Longie	Full Strandby	Masumum	3.00% Coart	25% Loan	5000 Local	Pinkstand	Stendby	Sections	
Criteria Poilutants			Literatura de la composición dela composición de la composición de la composición dela composición dela composición dela composición de la composición dela composición de la composición dela composición	Anny any annual and a residue								Daniel Company	
NO <sub>X</sub>	0.49	0.62	1.00	1.58	2.76	2.76	0.11	0.09	0.09	0.10	0.14	0.144	
со	0.59	0.63	0.47	0.60	0.60	0.63	0.14	0.09	0.04	0.04	0.03	0.137	
voc	0.16	0.16	0.20	0.19	0.15	0.20	3 64E-02	2.16E-02	1.80E-02	1.26E-02	7.81E-03	0.036	
Filt. PM	0.07	0.11	0.11	0.15	0.14	0.15	1.73E-02	1.52E-02	9.39E-03	9.57E-03	7,35E-03	1.73E-02	
PM/PM <sub>10</sub> /PM <sub>2.5</sub> <sup>12</sup>	7.90E-02	1.17E-01	1.19E-01	1,63E-01	1.61E-01	0.16	1.84E-02	1.62E-02	1.04E-02	1.06E-02	8.41E-03	1.84E-02	
SO <sub>2</sub>	1.71E-01	2.86E-01	4.53E-01	6.08E-01	7.59E-01	7.59E-01	3.97E-02	3.97E-02	3.97E-02	3.97E-02	3.97E-02	3.97E-02	
Hazardous Air Pollutants							I						
Benzene	5.50E-04	9.21E-04	1.46E-03	1.96E-03	2.44E-03	2.44E-03	1.06E-04	1.06E-04	1.06E-04	1.06E-04	1.06E-04	1.06E-04	
Toluene	2.41E-04	4.04E-04	6.39E-04	8,57E-04	1.07E-03	1.07E-03	3.85E-05	3.85E-05	3.85E-05	3.85E-05	3,85E-05	3.85E-05	
Xylenes	1.68E-04	2.81E-04	4.45E-04	5.98E-04	7.46E-04	7.46E-04	2.64E-05	2.64E-05	2.64E-05	2.64E-05	2,64E-05	2.64E-05	
Formaldehyde	6.95E-04	1.16E-03	1.84E-03	2.47E-03	3.09E-03	3.09E-03	1.08E-05	1.08E-05	1.08E-05	1.08E-05	1.08E-05	1.08E-05	
Acetaldehyde	4.52E-04	7.57E-04	1.20E-03	1.61E-03	2.01E-03	2.01E-03	3.45E-06	3.45E-06	3.45E-06	3.45E-06	3.45E-06	3.45E-06	
Acrolein	5.45E-05	9.13E-05	1.44E-04	1,94E-04	2.42E-04	2.42E-04	1.08E-06	1.08E-06	1.08E-06	1.08E-06	1.08E-06	1.08E-06	
Total PAH	9.90E-05	1.66E-04	2.62E-04	3.52E-04	4.40E-04	4.40E-04	2.91E-05	2.91E-05	2.91E-05	2.91E-05	2.91E-05	2.91E-05	
Total HAP	2,26E-03	3.78E-03	5.99E-03	8.04E-03	1.00E-02	1.00E-02	2.16E-04	2.16E-04	2.16E-04	2.16E-04	2.16E-04	2.16E-04	
Greenhouse Gases													
CO <sub>2</sub>	96,08	160.87	254.71	341.85	426.76	426.76	22.34	22.34	22.34	22.34	22.34	22.34	
CH₄	0.00	0.01	0.01	0.01	0.02	0.02	9.06E-04	9.06E-04	9.06E-04	9.06E-04	9.06E-04	9.06E-04	
N <sub>2</sub> O	0.00	0.00	0.00	0.00	0.00	0.00	1.81E-04	1.81E-04	1.81E-04	1.81E-04	1.81E-04	1.81E-04	
CO <sub>2</sub> e	96.41	161.42	255.59	343.03	428.22	428.22	22.42	22.42	22.42	22,42	22.42	22.42	

#### Notes:

9. For engine-specific emission factors:
Hourly Emissions at Load X (lb/hr/gen) = Emission Factor at Load X (g/hp-hr) x Engine Power at Load X (bhp/gen) / (453.6 g/lb)

10. For AP-42 & GHG emission factors:
Hourly Emissions at Load X (lb/hr/gen) = Emission Factor (lb/MMBtu) x Heat Input at Load X (MMBtu/hr/gen)

11. Fuel Emission Factors at Load X in In/gal/gen: X = Hourly Emissions at Load X (ligh/r/gen) / Fuel Usage at Load X (gal/hr) For NOx, CO, VOC, and PM: In/gal/gen at Load X = Hourly Emissions at Load X (ligh/r/gen) / Fuel Usage at Load X (gal/hr) For AP-42 & GHG: It/gal/gen = Emission Factor (In/Mmbtu) x Diesel HVV (0.137 MMBtu/gal) 12. Total PM/PM<sub>10</sub>/FM<sub>1,5</sub> is the sum of filterable PM/PM<sub>10</sub>/FM<sub>2,5</sub> and condensable PM.

13. Two sets of control systems, manufactured by Miratech and Safety Power, respectively, have been chosen for the critical gens. It has not been determined which brand will be used for final installation. Based on the manufacturer provided specification sheets, the Miratech control system has lower control efficiencies than Safety Power's. For a conservative estimate of the post-controlled emissions from CEG 1 - 234, the Tier 4 level controls (SCR, DOC, DPF) are assumed based on the Miratech's control efficiencies, as listed below:

CO 70.0% VOC 45.0% Filterable PM 68.6%

14. SCR (control) does not function when engines run at 10% load. Therefore, emergency runs at 10% load are counted towards uncontrolled run times.

#### Estimated Fuel Usage and Potential Emissions - Tier 4 Generators

Facility:

SBN100

Address:

55001 Larrison Blvd., New Carlisle, IN 46552

Number of Critical (Tier 4) Emergency Engines

Gene	Number of Tier 4
	Esologe 
CEG No. 1 - 234	234

#### Fuel Consumption by Load (taken from Table B.4)

Gens			Diesel Ruel Consumption (gal/tir/engine)	H Vide	
	10% Load	25% Load	50% Board	75% Load	Full Standby
CEG No. 1 - 234 Cummins	. 38.0	61.0	106.0	147.0	187.0
CEG No. 1 - 234 CAT	36,1	62.9	107.5	147.3	192.2
Maximum	38.0	62.9	107.5	147.3	192.2

#### Notes:

Table 8.9 - Estimated Annual Total Fuel Usage by Tier 4 Gens 2, 3, 4

Limit	Value	Unite
Estimated Uncontrolled Diesel Fuel Usage by Tier 4 Gens	809,546	gal/yr (all Tier 4 gens)
Estimated Controlled Diesel Fuel Usage by Tier 4 Gens	4,390,454	gal/yr (all Tier 4 gens)
Estimated Total Diesel Fuel Usage by Tier 4 Gens [All Purposes]	5,200,000	gal/yr (all Tier 4 gens)

Note: These fuel usage values are estimated for calculating potential emissions. However, the Site is not requesting to set these estimated fuel usage values as permit limits. The site will comply with emissions limits by tracking generator operation and calculating 12-month rolling emissions.

Table B.10 - PTE of All Tier 4 Gens

	Time A Chine See	actor Fartage	Potential Emissions - All Fier 4 Gens Combined 2			
Pollutant	Tier 4 Gens Emission Factors <sup>‡</sup> (lb/ggl)		(49)			
	Uncontrolled Maximum	Centrolled Maximum	Uncontrolled	Controlled	Total	
Criteria Pollutants						
NO <sub>X</sub>	0.403	0.033	163.293	73.504	236.80	
со	0.115	0.020	46.548	43.859	90.41	
voc	0.029	0.012	11.906	26.538	38.44	
Filt. PM	0.009	0.002	3.453	4.329	7.78	
PM/PM <sub>10</sub> /PM <sub>2,5</sub>	0.010	0.003	3.880	6.645	10.52	
SO₂	0.00022	0.00021	0.088	0.456	0.54	
Hazardous Air Pollutants						
Benzene	1.06E-04	5.85E-05	0.043	0.128	0.171	
Toluene	3.85E-05	2.12E-05	0.016	0.046	0.062	
Xylenes	2.64E-05	1.45E-05	0.011	0.032	0.043	
Formaldehyde	1.08E-05	5.95E-06	0.004	0.013	0.017	
Acetaldehyde	3.45E-06	1.90E-06	0.001	0.004	0.006	
Acrolein	1.08E-06	5.94E-07	0.000	0.001	0.002	
Total PAH	2.91E-05	1.60E-05	0.012	0.035	0.047	
Total HAP	2.16E-04	1.19E-04	0.087	0.260	0.348	
Greenhouse Gases						
CO <sub>2</sub>	22.34	22.34	9,043.959	49,048.555	58,092.514	
CH <sub>4</sub>	9.06E-04	9.06E-04	0.367	1.990	2.356	
N₂O	1.81E-04	1.81E-04	0.073	0.398	0.471	
CO <sub>2</sub> e	22.42	22.42	9,074.994	49,216.869	58,291.863	

#### Notes:

- 2. SCR (control) does not function when engines run at 10% load. Therefore, emergency generator runs between 0% and 10% load are captured under uncontrolled runtime and fuel usage.
- 3. Commissioning is not included in emergency runtime calculations.
- 4. The estimated fuel consumptions, uncontrolled and controlled, are based on the maximum fuel consumption rate (gal/gen/hr) at full standby load for a conservative estimate.
- 5. See Tables B.8.a and B.8.b for uncontrolled and controlled Tier 4 gens emission factors in lbs/gal. For each pollutant, the higher emission factor in lbs/gal between Cummins and CAT is selected for the conservative estimate of the PTE.
- 6. Uncontrolled Emissions (tpy) = Uncontrolled Emission Factor (lbs/gal) x Total Uncontrolled Diesel Fuel Usage (gal/yr)

  Controlled Emissions (tpy) = Controlled Emission Factor (lbs/gal) x Total Controlled Diesel Fuel Usage (gal/yr)

  Total Emissions (tpy) = Uncontrolled Emissions (tpy) + Controlled Emissions (tpy)

 $<sup>\</sup>textbf{1. Per the manufacturer specification sheets and performance data for Cummins DQLF and CAT 3516E, respectively.}\\$ 

#### Estimated Fuel Usage and Potential Emissions - All Support Generators

Facility:

SBN100

Address:

55001 Larrison Blvd., New Carlisle, IN 46552

Fuel Consumption by Load (taken from Table 8.4)

Diesel Fuel Consumption (gal/hr/gen) Num						
engine rase	18% Koad	25% total	Selva Cond	75% Lond	Fill Standay	Gerts
1,500 kW Tier 2 Certified	19.5	33.5	57.3	81.0	103.2	2
750 kW Tier 2 Certified	9.5	16.6	28.4	42.8	53.6	9
400 kW Tier 3 Certified	6.5	10.7	18.7	25.4	31.3	2
250 kW Tier 3 Certified	4.3	7.2	11.4	15.3	19.1	1

Estimated Total Fuel Usage for All Support Gens =

77,050

gal/yr for all support gens

Table 8.11 - Maximum Emission Factors in ths/gal per Engine Type (taken from Tables 8.3.c - f)

Engline Type	NO <sub>y</sub> Emission Factor (lb/gal)	CO Emission Factor (lb/gal)		PM/PM <sub>in</sub> /PM <sub>is</sub> Emission Eactor (lb/gat)	
1,500 kW Tier 2 Certified	0.31	0.21	0.0363	0.0134	0.00010
750 kW Tier 2 Certified <sup>1</sup>	0.29	0.50	0.2011	0.0345	0.00021
400 kW Tier 3 Certified	0.18	0.19	0.0385	0.0133	0.03974
250 kW Tier 3 Certified	0.14	0.14	0.0364	0.0184	0.03974

#### Note:

Table B.12 - Criteria Pollutants PTE (assuming 93,782 gal/yr of fuel is all consumed by each engine type)

Engine Type	NO <sub>x</sub> Emissions (tpy)	CO Emissions (Lpv)	VOC Emissions (tpv)	PM/PM <sub>10</sub> /PM <sub>25</sub> Emissions (194)	SG, Emissions (tpy)
1,500 kW Tier 2 Certified	12.05	8.09	1.40	0.52	0.00
750 kW Tier 2 Certified	11.15	19.19	7.75	1.33	0.01
400 kW Tier 3 Certified	7.09	7.36	1.48	0.51	1.53
250 kW Tier 3 Certified	5.56	5.29	1.40	0.71	1.53
Maximum	12.05	19.19	7.75	1.33	1.53

Table B.13 - HAPs and GHG PTE

Pollutant	Maximum Emission Factor (lbs/gal/gen)	Potential Emissions (tpy)
Hazardous Air Pollutants		
Benzene	1.06E-04	4.10E-03
Toluene	3.85E-05	1.48E-03
Xylenes	2.64E-05	1.02E-03
Formaldehyde	1.08E-05	4.17E-04
Acetaldehyde	3.45E-06	1.33E-04
Acrolein	1.08E-06	4.16E-05
Total PAH	2.91E-05	1.12E-03
Total HAP	2.16E-04	8.31E-03
Greenhouse Gases		
CO <sub>2</sub>	22.34	860.77
CH₄	9.06E-04	3.49E-02
N <sub>2</sub> O	1.81E-04	6.98E-03
CO₂e	22.42	863.73

<sup>1.</sup> For each pollutant emitted from the 750 kW Gens, the higher emission factor in lbs/gal between Cummins and CAT is selected for a conservative estimate of the PTE.

Potential Emissions - Diesel Fuel Storage Tanks
Facility: SBN100
Address: 55001 Larrison Blvd., New Carlisle, IN 46552

Table B.14 - VOC Emission Calculations for Diesel Fuel Storage Tanks

Table B.14 - VOC Emission Calculation	ons for Dieser Fael Storage Taliks						
Parameter Description (1)	Source/Equation	Belly Tanks for CEG No. 5 - 234	Belly fanks for WIP Supe No. 1 (C.2)	aelly Topkis House Sens HG That II D	Boffy Tanks for CAB and CLB Gens	Setty James for ACB Gdis	i a ode Gai Storage Fadic
		Potential	Privatelis	Partertial	: Setopikal	Potential	Potentini
		6,300-gal	\$ 000 gal	1,500-gai	1,000 491	Louis-get	12 (104-ga)
Material Stored	Facility Information	Diesel Fuel	Diesel Fuel	Diesel Fuel	Diesel Fuel	Diesel Fuel	Diesel Fuel
Location	Facility Information	Indoors	Indoors	Indoors	Indoors	Indoors	Outdoors
Tank Type	Facility Information	Horizontal	Horizontal	Horizontal	Horizontal	Horizontal	Horizontal
Roof Type	Facility Information	Fixed	Fixed	Fixed	Fixed	Fixed	Fixed
Bottom Type	Facility Information	Flat	Flat	Flat	Flat	Flat	Flat
Tank Color	Facility Information	Grey - Med	Grey - Med	Grey - Med	Grey - Med	Grey - Med	White
Roof Color	Facility Information	Grey - Med	Grey - Med .	Grey - Med	Grey - Med	Grey - Med	White
Paint Condition	Facility Information	Average	Average	Average	Average	Average	Average
Heated	Facility Information	No.	No	No	No	No	No
Tank Diameter (D), ft	Facility Information	N/A	N/A	N/A	N/A	N/A	8.00
Bottom Height (H <sub>c</sub> ), ft	Facility Information	N/A	N/A	N/A	N/A	N/A	N/A
Tank Width (W), ft	Facility Information	14.00	11.00	6.42	5.00	5.00	N/A
Tank Length (L), ft	Facility Information	36.10	31.04	15.00	12.83	12.83	31.92
	$R_5 = D/2$						
Tank Shell Radius (R <sub>s</sub> ), ft	Rectangular Tank: N/A	Not needed for	Not needed for	Not needed for	Not needed for	Not needed for	4
Effective Diameter ( $D_E$ ), ft	Horizontal tank: $D_E = (LD/(n/4))^{1/2}$	rectangular tank	rectangular tank	rectangular tank	rectangular tank	rectangular tank	18.03
Tank Dome Roof Radius (R <sub>R</sub> ), ft	Flat Roof: N/A				l		N/A
Tank Shell Height (H <sub>S</sub> ), ft	Facility Information	1.67	1.96	2.08	2.08	2.08	N/A
Effective Height (H <sub>E</sub> ), ft	Rectangular tank: $H_S = H_E$ Horizontal tank: $H_E = (n/4)D$	1.67	1.96	2.08	2.08	2.08	6.28
Tank Volume (V), ft <sup>3</sup>	Horizontal tank: $V = nR_S^2L$ Rectangular tank: $V = WLH_S$	842	669	201	134	134	1604
Tank Volume (V), gal	$V = ft^3 * 7.48 gal/ft^3$	6,300	5,002	1,500	1,000	1,000	12,000
Liquid Height (H <sub>L</sub> ), ft	Horizontal & rectangular tank: Assumed H <sub>L</sub> = 0.5H <sub>S</sub>	0.83	0.98	1.04	1.04	1.04	3.14
Tank Cone Roof Slope (S <sub>R</sub> ), ft/ft	Flat Roof: S <sub>R</sub> = 0	0	0	0	0	0	0
Tank Roof Height (H <sub>R</sub> ), ft	Flat Roof: H <sub>R</sub> = S <sub>R</sub> R <sub>S</sub>	0	0	0	0	0	0
Roof Outage (H <sub>RO</sub> ), ft	Flat Roof: H <sub>RO</sub> = 0	0	1	0	0	0	0
Vapor Space Outage (H <sub>vo</sub> ), ft	Horizontal tank: H <sub>VO</sub> = 1/2H <sub>E</sub>	0.83	0.98	1.04	1.04	1.04	3.14
Vapor Space Volume (V <sub>v</sub> ), ft <sup>3</sup>	Horizontal tank: $V_V = n/4(D_E^2 H_{VO})$ Rectangular tank: $H_{VO}WL$	421.13	334.34	100.26	66.84	66.84	802.15
Ideal Gas Constant (R), psia ft³/lb-mole R	Constant	10.731	10.731	10.731	10.731	10.731	10.731
Daily Maximum Ambient Temperature (T <sub>AX</sub> ), R	AP-42, Table 7.1-7 (Jackson, MS)	535.0	535.0	535.0	535.0	535.0	535,0
Daily Minimum Ambient Temperature (T <sub>AN</sub> ), R	AP-42, Table 7.1-7 (Jackson, MS)	514.0	514.0	514.0	514.0	514.0	514.0
Daily Average Ambient Temperature $(T_{AA})$ , R	$T_{AA} = (T_{AX} + T_{AN})/2$	524.5	524.5	524.5	524.5	524.5	524.5
Liquid Bulk Temperature ( $T_{\text{B}}$ ), R	$T_B = T_{AA} + 0.003 \alpha_s I$ Generator Belly Tanks: Assumed $T_B$ = $T_{AA}$ since tank shell solar absorptance $\alpha_s$ will be zero	524.5	524.5	524.5	524.5	524.5	525.5 (Note 2)
Daily Average Liquid Surface Temperature (T <sub>IA</sub> ), R	$T_{LA} = 0.4T_{AA} + 0.6T_B + 0.005 \alpha I$ Generator Belly Tanks: Assume shell solar absorptance is zero	524.5	524.5	524.5	524.5	524.5	526.9 (Note 2)
Vapor Molecular Weight (M <sub>V</sub> ), lb/lb- mole	AP-42, Table 7.1-2, No 2 Fuel Oil	130	130	130	130	130	130
Vapor Pressure Constant, A	AP-42, Table 7.1-2, No 2 Fuel Oil	12.101	12.101	12.101	12.101	12.101	12.101
Vapor Pressure Constant, B	AP-42, Table 7.1-2, No 2 Fuel Oil	8907	8907	8907	8907	8907	8907
Vapor Pressure at T <sub>IA</sub> (P <sub>VA</sub> ), psia	$P_{VA} = \exp[A - (B/T_{UA})]$	0.008	0.008	0.008	0.008	0.008	0.008
Avg Vapor Temperature T <sub>V</sub> , R	$T_V = 0.7T_{AA} + 0.3T_B + 0.009 \alpha I$ Generator Belly Tanks: Assume shell solar absorptance is zero	524.5	524.5	524.5	524.5	524.5	528.0 (Note 2)
Vapor Density (W <sub>v</sub> ), lb/ft <sup>3</sup>	$W_V = M_V P_{VA} / R T_V$	0.00018	0.00018	0.00018	0.00018	0.00018	0.00019
Daily Ambient Temperature Range $(\Delta T_A)$ , R	$\Delta T_A = T_{AX} - T_{AN}$	21.0	21.0	21.0	21.0	21.0	21.0
Daily Vapor Temperature Range ( $\Delta T_{v}$ ), R	$\Delta T_V = 0.7 \Delta T_A + 0.02 \alpha I$ Generator Belly Tanks: Assume shell solar absorptance is zero	14.7	14.7	14.7	14.7	14.7	14.7
Vapor Pressure at T <sub>AN</sub> (P <sub>VN</sub> ), psia	$P_{VN} = \exp[A - (B/T_{AR})]$	0.005	0.005	0.005	0.005	0.005	0.005
Vapor Pressure at T <sub>AX</sub> (P <sub>VX</sub> ), psia	$P_{VX} = \exp[A - (B/T_{AX})]$	0.011	0.011	0.011	0.011	0.011	0.011
Daily Vapor Pressure Range (ΔP <sub>V</sub> ), psia	$\Delta P_{V} = P_{VX} - P_{VN}$	0.005	0.005	0.005	0.005	0.005	0.005
Breather Vent Pressure Setting Range ( $\Delta P_B$ ), psig	$\Delta P_{B} = P_{BP} - P_{BV} \text{ (Assumed = 0.06)}$	0.06	0.06	0.06	0.06	0.06	0.06
Atmospheric Pressure (P <sub>A</sub> ), psia	Constant	14.7	14.7	14.7	14.7	14.7	14.7
, terrospriene i reasure (rg), psia	Constant	14./	17./				0.02
Vapor Space Expansion Factor (K <sub>E</sub> ), dimensionless	Outdoor Tanks: $K_E = \Delta T_V/T_{IA} + (\Delta P_V)$ $-\Delta P_B/(P_A - P_{VA})$ Indoor Tanks: 0	0.02	0.02	0.02	0.02	0.02	0.02
dimensionless  Vented Vapor Saturation Factor $(K_S)$ ,		1.0	1.0	1.0	1.0	1.0	1.0
dimensionless	- AP <sub>B</sub> )/(P <sub>A</sub> - P <sub>VA</sub> ) Indoor Tanks: 0						

Potential Emissions - Diesel Fuel Storage Tanks

Facility: Address: SBN100 55001 Larrison Blvd., New Carlisle, IN 46552

Table B.14 - VOC Emission Calculations for Diesel Fuel Storage Tanks

		and the same of the same of the same of					
Parameter Description (4)	Scarce/Equation	Builty Yanks (o) Cere No. 2 - 22 s	Folky Tarries for WTP Gens -Ng. 1 & 2	Bally Tableside Ballys General No. 1 - F	Selly Tenke for CAR Sell CLS Cents	adig tank for Adiograp	12 900 Gal Swrage Tard
		Pokspäist	Peterntial	Powerfal.	Websards1	Potential	Palenta.
30		6,300-gai	5/000-gal	1,500-gal	1,000-4-0	1,0001-061	12,000 gal
Maximum Throughput (Q), gal 2,3	Facility Information	26,667	46,230 (Note 4)	10,273 (Note 4)	46,230 (Note 4)	92,460 (Note 4)	703,607
Maximum Throughput ( $V_Q$ ), ft	Conversion	3,564.8	6,180.1	1,373.3	6,180.1	12,360.1	94,058.5
Tank Maximum Liquid Volume (V <sub>IX</sub> ), ft	Horizontal tank: Assumed V <sub>LX</sub> = 0.9V	758.0	601.8	180.5	120 3	120.3	1443.9
Turnovers (N), dimensionless	$N = V_Q/V_{LX}$	4.7	10.3	7.6	51.4	102.7	65.1
Turnover Factor (K <sub>#</sub> ), dimensionless	For N $\leq$ 36 K <sub>N</sub> = 1, For N > 36 KN = (180 + N)/6N	1.0	1.0	1.0	0.8	0.5	0.5
Working Loss Factor (K <sub>P</sub> ), dimensionless	For Organic Liquids, K <sub>P</sub> = 1	1.0	1.0	1.0	1.0	1.0	1.0
Vent setting correction factor, K <sub>B</sub>	For vent setting range $\pm$ 0.03 psig, $K_B=1$	1.0	1.0	1.0	1.0	1.0	1.0
Working Losses (L <sub>w</sub> ), lb/year/tank	$L_W = V_Q K_N K_P W_V K_B$	0.62	1.08	0.24	0.81	0.99	11.10
Total Uncontrolled Losses (L <sub>T</sub> ), lb/year/tank	$L_T = L_S + L_W$	1.28	1.60	0.40	0.92	1.10	12.43
Total Uncontrolled Losses $(L_1)$ , $lb/hr/tank$	Calculated assuming 8,760 hr/yr	1.46E-04	1,83E-04	4.52E-05	1 05E-04	1.25E-04	1.42E-03
Total Uncontrolled Losses (L <sub>T</sub> ), ton/year/tank	2,000 lb/ton	6.39E-04	8.01E-04	1.98E-04	4.58£-04	5.48E-04	6.22E-03
Number of Tanks	Facility Information	234	2	9	2	1	9
Total Uncontrolled Losses (L <sub>T</sub> ), ib/hr (all tanks)	L <sub>T</sub> = lb/hr/tank * # tanks	3.41E-02	3.66E-04	4.07E-04	2.09E-04	1.25E-04	1.28E-02
Total Uncontrolled Losses (L <sub>T</sub> ), ton/year (all tanks)	L <sub>T</sub> = ton/year/tank * # tanks	1.50E-01	1.60E-03	1.78E-03	9.16E-04	5.48E-04	5.59E-02

- 1. Emissions calculated according to the methodology presented in AP-42, Section 7.1 for fixed-roof tanks.
- 2. For the 12,000-gal horizontal tanks, the tank surface solar absorptance (a, dimensionless) was taken from AP-42, Section 7.1, Table 7.1-6 (average 0.25 for white color), and the average daily total insolation factor (I, Btu/( $\mathrm{ft}^2$  day)) was taken from Table 7.1-7 (1434 for Jackson, MS).
- 3. An additional 20% safety factor is applied to each maximum annual throughput for a conservative estimate of tank emissions.
- 4. For the support gens' belly tanks, the potential VOC emissions were calculated assuming a total of 93,130 gal/yr diesel fuel will be consumed by each type of gens, and the maximum annual emissions were selected as the PTE from the belly tanks for support gens.

APPENDIX C
GENERATOR SPECIFICATION SHEETS:

CEG NO. 1 – 234 (2,750 KW GENERATOR): CATERPILLER 3516E CUMMINS DQLF MIRATECH CONTROL SYSTEM SAFETY POWER CONTROL SYSTEM

WTP GENS NO. 1 & 2 (1,500 KW GENERATOR): CATERPILLER 3512C

HOUSE GENS NO. 1 - 9 (750 KW GENERATOR): CATERPILLER C18

CAB AND CLB GENS (400 KW GENERATOR): CATERPILLER C15


ACB GEN (250 KW GENERATOR): CATERPILLER C9 250 KW GENERATOR Razor5 LLC - Application for New Source Minor PSD Construction Approval and Title V Operating Permit

CTERPILLER 3516E 2,750 KW GENERATOR

# Cat® 3516E

### **Diesel Generator Sets**





Bore – mm (in)	170 (6.69)
Stroke – mm (in)	215 (8.46)
Displacement – L (in³)	78.1 (4766)
Compression Ratio	14.7:1
Aspiration	TA
Fuel System	EUI
Governor Type	ADEM™ A5

Image shown may not reflect actual configuration

Standby 60 Hz ekW (kVA)	Mission Critical 60 Hz ekW (kVA)	Prime 60 Hz ekW (kVA)	Emissions Performance
2750 (3438)	2750 (3438)	2500 (3125)	U.S. EPA Certified for Emergency Stationary Applications (Tier 2)

#### **Features**

#### Cat<sup>®</sup> Diesel Engine

- Meets U.S. EPA Stationary Emergency Use Only (Tier 2) emission standards
- Reliable performance proven in thousands of applications worldwide
- Certified alternative fuels including Hydrotreated Vegetable Oil (HVO), Renewable Diesel (RD) and Hydrotreated Renewable Diesel (HRD) which meet EN 15940 or ASTM D975 can be used or blended with EN 590 diesel

#### **Generator Set Package**

- Accepts 100% block load in one step
- Meets NFPA 110 loading requirements
- Conforms to ISO 8528-5 G3 load acceptance requirements
- Reliability verified through torsional vibration, fuel consumption, oil consumption, transient performance, and endurance testing

#### **Alternators**

- Superior motor starting capability minimizes need for oversizing generator
- Designed to match performance and output characteristics of Cat diesel engines

#### **Cooling System**

- Cooling systems available to operate in ambient temperatures up to 50°C (122°F)
- · Tested to ensure proper generator set cooling

#### Cat Energy Control System (ECS)

- · User-friendly interface and navigation
- Scalable system to meet a wide range of installation requirements
- Expansion modules and site specific programming for specific customer requirements
- · Graphical touchscreen display
- · Easily upgradeable

#### Warranty

- 24 months/1000-hour warranty for standby and mission critical ratings
- 12 months/unlimited hour warranty for prime and continuous ratings
- Extended service protection is available to provide extended coverage options

#### **Worldwide Product Support**

- Cat dealers have over 1,800 dealer branch stores operating in 200 countries
- Your local Cat dealer provides extensive post-sale support, including maintenance and repair agreements

#### Financing

- Caterpillar offers an array of financial products to help you succeed through financial service excellence
- Options include loans, finance lease, operating lease, working capital, and revolving line of credit
- Contact your local Cat dealer for availability in your region



## Package Performance


Performance	Sta	ndby	Missio	n Critical	P	rime
Frequency	60	) Hz	60	) Hz	60	) Hz
Gen set power rating with fan	2750	) ekW	275	0 ekW	250	0 ekW
Gen set power rating with fan @ 0.8 power factor	343	8 kVA	343	8 kVA	3125 kVA	
Emissions	EPA ES	E (TIER 2)	EPA ES	E (TIER 2)	EPA ES	E (TIER 2)
Performance number	EM5	400-00	EM5	402-00	EM5	404-00
Fuel Consumption						
100% load with fan – L/hr (gal/hr)	716.3	(189.2)	716.3	(189.2)	645.8	(170.6)
75% load with fan L/hr (gal/hr)	547.0	(144.5)	547.0	(144.5)	505.8	(133.6)
50% load with fan - L/hr (gal/hr)	399.0	(105.4)	399.0	(105.4)	370.6	(97.9)
25% load with fan - L/hr (gal/hr)	233.5	(61.7)	233.5	(61.7)	218.7	(57.8)
Cooling System	1.2					
Radiator air flow restriction (system) – kPa (in. water)	0.12	(0.48)	0.12	(0.48)	0.12	(0.48)
Radiator air flow – m³/min (cfm)	3026	(106862)	3026	(106862)	3026	(106862)
Engine coolant capacity – L (gal)	233.0	(61.6)	233.0	(61.6)	233.0	(61.6)
Radiator coolant capacity – L (gal)	202.0	(53.3)	202.0	(53.3)	202.0	(53.3)
Total coolant capacity – L (gal)	435.0	(114.9)	435.0	(114.9)	435.0	(114.9)
Inlet Air						
Combustion air inlet flow rate – m³/min (cfm)	236.0	(8332.4)	236.0	(8332.4)	223.7	(7898.4)
Exhaust System						
Exhaust stack gas temperature – °C (°F)	480.0	(896.1)	480.0	(896.1)	459.3	(858.7)
Exhaust gas flow rate – m³/min (cfm)	624.5	(22051.6)	624.5	(22051.6)	574.2	(20277.1)
Exhaust system backpressure (maximum allowable) – kPa (in. water)	6.7	(27.0)	6.7	(27.0)	6.7	(27.0)
Heat Rejection						
Heat rejection to jacket water – kW (Btu/min)	894	(50827)	894	(50827)	827	(47027)
Heat rejection to exhaust (total) – kW (Btu/min)	2849	(162025)	2849	(162025)	2514	(142941)
Heat rejection to aftercooler – kW (Btu/min)	941	(53492)	941	(53492)	844	(47998)
Heat rejection to atmosphere from engine – kW (Btu/min)	160	(9124)	160	(9124)	147	(8364)
Heat rejection from alternator – kW (Btu/min)	126	(7172)	126	(7172)	112	(6386)
Emissions* (Nominal)						
NOx mg/Nm³ (g/hp-h)	2319.2	(5.00)	2319.2	(5.00)	2275.1	(4.82)
CO mg/Nm³ (g/hp-h)	321.4	(0.69)	321.4	(0.69)	183.8	(0.39)
HC mg/Nm³ (g/hp-h)	30.7	(0.08)	30.7	(0.08)	33.1	(80.0)
PM mg/Nm³ (g/hp-h)	20.0	(0.05)	20.0	(0.05)	14.6	(0.04)
Emissions* (Potential Site Variation)						
NOx mg/Nm³ (g/hp-h)	2783.0	(6.00)	2783.0	(6.00)	2730.1	(5.79)
CO mg/Nm³ (g/hp-h)	536.7	(1.16)	536.7	(1.16)	307.0	(0.65)
HC mg/Nm³ (g/hp-h)	40.8	(0.10)	40.8	(0.10)	44.1	(0.11)

<sup>\*</sup>mg/Nm³ levels are corrected to 5% O<sub>2</sub>. Contact your local Cat dealer for further information.

LEHE1351-10 Page 3 of 4



#### Weights and Dimensions



Dim "A" mm (in)	Dim "B" mm (in)	Dim "C" mm (in)	Dry Weight kg (lb)	
7922 (311.9)	2640 (104.0)	3342 (131.6)	18 480 (40,750)	

Note: For reference only. Do not use for installation design. Contact your local Cat dealer for precise weights and dimensions.

#### **Ratings Definitions**

#### Standby

Output available with varying load for the duration of the interruption of the normal source power. Average power output is 70% of the standby rated ekW. Typical operation is 200 hours per year, with maximum expected usage of 500 hours per year.

#### **Mission Critical**

Output available with varying load for the duration of the interruption of the normal source power. Average power output is 85% of the mission critical rated ekW. Typical peak demand up to 100% of rated ekW for up to 5% of the operating time. Typical operation is 200 hours per year, with maximum expected usage of 500 hours per year.

#### Prime

Output available with varying load for an unlimited time. Average power output is 70% of the prime rated ekW. Typical peak demand is 100% of prime rated ekW with 10% overload capability for emergency use for a maximum of 1 hour in 12. Overload operation cannot exceed 25 hours per year.

#### **Applicable Codes and Standards**

AS 1359, ULC 2200 3rd edition, UL 489, UL 869A, IBC, IEC 60034-1, ISO 3046, ISO 8528, NEMA MG1-22, NEMA MG1-33, 2014/35/EU, 2006/42/EC, 2014/30/EU and facilitates compliance to NFPA 37, NFPA 70, NFPA 99, NFPA 110.

**Note:** Codes may not be available in all model configurations. Please consult your local Cat dealer for availability.

#### Data Center Applications

- All ratings Tier III/Tier IV compliant per Uptime Institute requirements.
- All ratings ANSI/TIA-942 compliant for Rated-1 through Rated-4 data centers.

#### **Fuel Rates**

Fuel consumption reported in accordance with ISO 3046-1, based on fuel oil of 35° API [16°C (60°F)] gravity having an LHV of 42,780 kJ/kg (18,390 Btu/lb) when used at 15°C (59°F) and weighing 850 g/liter (7.0936 lbs/U.S. gal.) All fuel consumption values refer to rated engine power.

www.cat.com/electricpower ©2023 Caterpillar All rights reserved.

Materials and specifications are subject to change without notice. The International System of Units (SI) is used in this publication. Performance Number: EM5402 Change Level: 00

DIRECT INJECTION SALES MODEL: 3516E COMBUSTION: ENGINE SPEED (RPM): BRAND: CAT 1,800 MACHINE SALES MODEL: HERTZ: 60 FAN POWER (HP): 160,9 ENGINE POWER (BHP): 4 043 GEN POWER WITH FAN (EKW): ASPIRATION: 2,750.0 TA COMPRESSION RATIO: AFTERCOOLER TYPE: ATAAC RATING LEVEL: MISSION CRITICAL STANDBY AFTERCOOLER CIRCUIT TYPE: JW+OC, ATAAC PUMP QUANTITY: INLET MANIFOLD AIR TEMP (F): 122 FUEL TYPE: DIESEL JACKET WATER TEMP (F): 219.2 MANIFOLD TYPE: PARALLEL DRY TURBO CONFIGURATION: TURBO QUANTITY: GOVERNOR TYPE: ADEM5 TURBOCHARGER MODEL: GTB6051N-44T-1.25 **ELECTRONICS TYPE:** ADEM5 IGNITION TYPE: CERTIFICATION YEAR: CI 2017 INJECTOR TYPE: EUI CRANKCASE BLOWBY RATE (FT3/HR): 4,039.5 FUEL INJECTOR: 3920221 FUEL RATE (RATED RPM) NO LOAD (GAL/HR): 15.6 UNIT INJECTOR TIMING (IN): 64.34 PISTON SPD @ RATED ENG SPD (FT/MIN): 2,539.4 REF EXH STACK DIAMETER (IN): 12 MAX OPERATING ALTITUDE (FT): 2,461

INDUSTRY	SUBINDUSTRY	APPLICATION
ELECTRIC POWER	STANDARD	PACKAGED GENSET

#### General Performance Data

THE INLET MANIFOLD AIR TEMP LISTED IN THE HEADER, AND IN THE GENERAL PERFORMANCE DATA, IS THE AVERAGE INLET MANIFOLD TEMP FRONT TO REAR ON THE ENGINE.

THIS STANDBY RATING IS FOR A STANDBY ONLY ENGINE ARRANGEMENT. RERATING THE ENGINE TO A STANDARD PRIME OR CONTINUOUS RATING IS NOT PERMITTED.

GENSET POWER WITH FAN	PERCENT LOAD	ENGINE POWER	BRAKE MEAN EFF PRES (BMEP)	BRAKE SPEC FUEL CONSUMPTN (BSFC)	ISO BRAKE SPEC FUEL CONSUMPTN (BSFC)	VOL FUEL CONSUMPTN (VFC)	ISO VOL FUEL CONSUMPTN (VFC)	ELEC SPEC FUEL CONSUMPTN (ESFC)	ISO ELEC SPEC FUEL CONSUMPTN (ESFC)
EKW	%	BHP	PSI	L8/BHP-HR	LB/BHP-HR	GAL/HR	GAL/HR	LB/EKW-HR	LB/EKW-HR
2,750.0	100	4,043	373	0.338	0,332	192.9	189.2	0.498	0.488
2,475.0	90	3,655	337	0.334	0.328	172.3	169.0	0.494	0.484
2,200.0	80	3,266	302	0.338	0.331	155.6	152.6	0.502	0.492
2,062.5	75	3,072	284	0.340	0.334	147.3	144.5	0.507	0.497
1,925.0	70	2,878	266	0.343	0,336	139.1	136.5	0.513	0.503
1,650.0	60	2,490	230	0.351	0.344	123.2	120.9	0.530	0.520
1,375.0	50	2,102	194	0.363	0.356	107.5	105.4	0.554	0.544
1,100.0	40	1,714	158	0.373	0.366	90.1	88.4	0.581	0.570
825.0	30	1,325	122	0.384	0.377	71.8	70.5	0.618	0.606
687.5	25	1,131	104	0.394	0.387	62.9	61.7	0.649	0.636
550.0	20	937	87	0.409	0.402	54.1	53.1	0.698	0.684
275.0	10	549	51	0.467	0.458	36.1	35.4	0.932	0.914

GENSET POWER WITH FAN	PERCENT LOAD	ENGINE POWER	INLET MFLD PRES	INLET MFLD TEMP	EXH MFLD TEMP	EXH MFLD PRES	ENGINE OUTLET	COMPRESSOR OUTLET PRES	COMPRESSOR OUTLET TEMP
EKW	%	BHP	IN-HG	DEG F	DEG F	IN-HG	DEG F	IN-HG	DEG F
2,750.0	100	4,043	89.7	120.9	1,247.2	69.7	896.1	96	465.2
2,475.0	90	3,655	79.9	102.0	1,177.6	61.5	857.1	86	428.6
2,200.0	80	3,266	71.9	98.5	1,145.5	54.8	848.2	77	401.0
2,062.5	75	3,072	67.8	97.4	1,131.8	51.5	846.4	73	387.5
1,925.0	70	2,878	63.6	96.2	1,118.6	48.2	844.6	69	374.0
1,650,0	60	2,490	55.3	93.9	1,093.3	42.0	841.3	60	346.7
1,375.0	50	2,102	46.9	91.1	1,067.7	36.0	838.3	51	316.6
1,100.0	40	1,714	36.6	89.9	1,032.0	28.7	832.3	40	275.0
825.0	30	1,325	25.4	88.2	974.3	21.2	811.3	28	227.7
687.5	25	1,131	20.4	87.3	934.9	17.9	791.9	23	205.6
550.0	20	937	16.0	86.6	884.2	15.0	762,1	18	185.1
275.0	10	549	8.0	84,6	714.9	9.7	636.4	10	144.3

#### **General Performance Data (Continued)**

## PERFORMANCE DATA[EM5402]

WITH FAN			FLOW RATE	WET EXH GAS V	OL MASS FLOW RATE	MASS FLOW RATE		FLOW RATE (32
				FLOW RATE			DEG F AND 29,98 IN HG)	DEG F AND 29.98 IN HG)
EKW	%	BHP	CFM	CFM	LB/HR	L8/HR	FT3/MIN	FT3/MIN
2,750.0	100	4,043	8,332.4	22,051.6	36,608.0	37,975.1	7,997.3	7,319.2
2,475.0	90	3,655	7,853,4	20,133.0	34,488.6	35,710.8	7,517.4	6,906.2
2,200.0	80	3,266	7,346.5	18,607.4	32,131.3	33,232.9	6,995.3	6,441.4
2,062.5	75	3,072	7,067.4	17,824.4	30,845.3	31,888.9	6,710.2	6,183.4
1,925.0	70	2,878	6,782.6	17,045.8	29,542.6	30,529.2	6,425.6	5,925.8
1,650.0	60	2,490	6,233.4	15,564.7	27,073.1	27,946.5	5,882.4	5,438.9
1,375.0	50	2,102	5,678.9	14,065.9	24,551.5	25,313.7	5,328.0	4,936.7
1,100.0	40	1,714	4,977.5	12,157.1	21,327.5	21,966.5	4,626.4	4,295.6
825.0	30	1,325	4,151.9	9,893.9	17,669.9	18,179.6	3,827.4	3,562.6
687.5	25	1,131	3,769.2	8,812.6	16,008.2	16,454.6	3,462.1	3,227.8
550.0	20	937	3,431.9	7,819.9	14,554.5	14,938.7	3,146.9	2,941.1
275.0	10	549	2,823,3	5,742.8	11,937.6	12,194.1	2,576.0	2,431.3

### **Heat Rejection Data**

GENSET POWER WITH	PERCENT LOAD	ENGINE POWER	REJECTION TO JACKET	REJECTION TO	REJECTION TO EXH	EXHAUST RECOVERY	FROM OIL COOLER	FROM AFTERCOOLER	WORK RENERGY	LOW HEAT VALUE	HIGH HEAT VALUE
FAN			WATER	ATMOSPHERE		TO 350F				ENERGY	ENERGY
EKW	%	BHP	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN
2,750.0	100	4,043	50,827	9,124	162,025	87,978	22,342	53,492	171,445	419,468	446,839
2,475.0	90	3,655	46,700	8,321	141,538	76,477	19,956	47,423	154,983	374,677	399,125
2,200.0	80	3,266	43,252	7,985	129,537	69,793	18,018	40,903	138,521	338,278	360,350
2,062.5	75	3,072	41,519	7,846	123,724	66,690	17,061	37,707	130,290	320,314	341,215

### **Emissions Data**

#### DIESEL

#### RATED SPEED NOMINAL DATA: 1800 RPM

GENSET POWER WITH		EKW	2,750.0	2,062.5	1,375.0	687.5	275.0
PERCENT LOAD		%	100	75	50	25	102
ENGINE POWER		BHP	4,043	3,072	2,102	1,131	549
TOTAL NOX (AS NO2)		G/HR	20,001	12,263	6,348	3,506	3,883
TOTAL CO		G/HR	2,776	1,017	711	1,134	1,123
TOTAL HC		G/HR	305	285	264	243	189
TOTAL CO2		KG/HR	1,954	1,489	1,082	626	359
PART MATTER		G/HR	206.9	114.2	111.5	119.5	82.4
TOTAL NOX (AS NO2)	(CORR 5% O2)	MG/NM3	2,319.2	1,872.1	1,335.4	1,271.3	2,728.6
TOTAL CO	(CORR 5% O2)	MG/NM3	321.4	155.3	149.5	421.2	689,5
TOTAL HC	(CORR 5% O2)	MG/NM3	30.7	37.7	48.2	77.4	97.9
PART MATTER	(CORR 5% O2)	MG/NM3	20.0	14.8	20.1	37.3	44.3
TOTAL NOX (AS NO2)	(CORR 15% O2)	MG/NM3	860.6	694.7	495.5	471.7	1,012.5
TOTAL CO	(CORR 15% O2)	MG/NM3	119.3	57.6	55.5	156.3	255.9
TOTAL HC	(CORR 15% O2)	MG/NM3	11.4	14.0	17.9	28.7	36.3
PART MATTER	(CORR 15% O2)	MG/NM3	7.4	5.5	7.5	13.8	16.4
TOTAL NOX (AS NO2)	(CORR 5% O2)	PPM	1,130	912	650	619	1,329
TOTAL CO	(CORR 5% O2)	PPM	257	124	120	337	552
TOTAL HC	(CORR 5% O2)	PPM	57	70	90	144	183
TOTAL NOX (AS NO2)	(CORR 15% O2)	PPM	419	338	241	230	493
TOTAL CO	(CORR 15% O2)	PPM	95	46	44	125	205
TOTAL HC	(CORR 15% O2)	PPM	21	26	33	54	68
TOTAL NOX (AS NO2)		G/HP-HR	5.00	4.03	3.04	3.11	7.09
TOTAL CO		G/HP-HR	0.69	0,33	0.34	1.01	2.05
TOTAL HC		G/HP-HR	0,08	0.09	0.13	0.22	0.34
PART MATTER		G/HP-HR	0.05	0.04	0.05	0.11	0.15
TOTAL NOX (AS NO2)		G/KW-HR	6.80	5.47	4.13_	4.23	9.65
TOTAL CO		G/KW-HR	0.94	0,45	0.46	1,37	2.79
TOTAL HC		G/KW-HR	0.10	0.13	0.17	0.29	0.47

### PERFORMANCE DATA[EM5402]

PART MATTER	G/KW-HR	0.07	0.05	ი ა7	0.14	0,20	
FOTAL NOX (AS NO2)	LB/HR	44.09	27.03	13,99	7.73	8,56	
TOTAL CO	LB/HR	6.12	2.24	1.57	2.50	2,48	
TOTAL HC	LB/HR	0.67	0.63	0.58	0.54	0.42	
TOTAL CO2	LB/HR	4,307	3,282	2,386	1,381	792	
PART MATTER	LB/HR	0.46	0.25	0.25	0.26	0.18	
OXYGEN IN EXH	%	9.7	10.7	11.5	12.4	14.4	
DRY SMOKE OPACITY	%	2.7	1.8	2.1	3.0	2.3	
BOSCH SMOKE		0.98	0.58	0.70	1.07	0.75	
NUMBER							

#### RATED SPEED POTENTIAL SITE VARIATION: 1800 RPM

GENSET POWER WITH		EKW	2,750.0	2,062.5	1,375.0	687.5	275.0
PERCENT LOAD		%	100	75	50	25	10
ENGINE POWER		ВНР	4,043	3,072	2,102	1,131	549
TOTAL NOX (AS NO2)		G/HR	24,002	14,715	7,618	4,207	4,659
TOTAL CO		G/HR	4,637	1,698	1,187	1,894	1,876
TOTAL HC		G/HR	405	379	352	324	251
PART MATTER		G/HR	289.7	159.8	156.1	167.3	115.3
TOTAL NOX (AS NO2)	(CORR 5% O2)	MG/NM3	2,783.0	2,246.6	1,602.5	1,525.6	3,274.4
TOTAL CO	(CORR 5% O2)	MG/NM3	536.7	259.4	249.6	703.4	1,151.5
TOTAL HC	(CORR 5% O2)	MG/NM3	40.8	50.1	64.1	102.9	130,2
PART MATTER	(CORR 5% O2)	MG/NM3	28.1	20.7	28.2	52.2	62,0
TOTAL NOX (AS NO2)	(CORR 15% O2)	MG/NM3	1,032.7	833.6	594.6	566.1	1,215,0
TOTAL CO	(CORR 15% O2)	MG/NM3	199.2	96.3	92.6	261.0	427.3
TOTAL HC	(CORR 15% O2)	MG/NM3	15.1	18.6	23.8	38.2	48.3
PART MATTER	(CORR 15% O2)	MG/NM3	10,4	7.7	10.5	19.4	23.0
TOTAL NOX (AS NO2)	(CORR 5% O2)	PPM	1,356	1,094	781	743	1,595
TOTAL CO	(CORR 5% O2)	PPM	429	208	200	563	921
TOTAL HC	(CORR 5% O2)	PPM	76	94	120	192	243
TOTAL NOX (AS NO2)	(CORR 15% O2)	PPM	503	406	290	276	592
TOTAL CO	(CORR 15% O2)	PPM	159	77	74	209	342
TOTAL HC	(CORR 15% O2)	PPM	28	35	44	71	90
TOTAL NOX (AS NO2)		G/HP-HR	6.00	4.83	3.65	3.73	8.51
TOTAL CO		G/HP-HR	1.16	0.56	0,57	1.68	3,43
TOTAL HC		G/HP-HR	0.10	0.12	0.17	0,29	0,46
PART MATTER		G/HP-HR	0.07	0.05	0.07	0.15	0.21
TOTAL NOX (AS NO2)		G/KW-HR	8,16	6.57	4.96	5.08	11.57
TOTAL CO		G/KW-HR	1.58	0.76	0.77	2.28	4.66
TOTAL HC		G/KW-HR	0.14	0.17	0.23	0.39	0,62
PART MATTER		G/KW-HR	0.10	0.07	0.10	0.20	0.29
TOTAL NOX (AS NO2)		LB/HR	52.91	32.44	16.79	9.27	10.27
TOTAL CO		LB/HR	10.22	3.74	2.62	4.17	4.13
TOTAL HC		LB/HR	0.89	0.84	0.78	0.71	0,55
PART MATTER		LB/HR	0.64	0.35	0.34	0.37	0,25

### Regulatory Information

EPA EMERGENCY STATION	NARY	201		
GASEOUS EMISSIONS DAT	A MEASUREMENTS PROVIDED	TO THE EPA ARE CONSISTENT WITH THO	SE DESCRIBED IN EPA 40 CFR PART 60 SU	BPART IIII AND ISO 8178 FOR MEASURING HC,
CO, PM, AND NOX. THE "MA	AX LIMITS" SHOWN BELOW ARE	WEIGHTED CYCLE AVERAGES AND ARE I	N COMPLIANCE WITH THE EMERGENCY ST	ATIONARY REGULATIONS.
Locality	Agency	Regulation	Tier/Stage	Max Limits - G/BKW - HR
U.S. (INCL CALIF)	EPA	STATIONARY	EMERGENCY STATIONARY	CO: 3.5 NOx + HC: 6.4 PM: 0.20

#### Altitude Derate Data

THE TEMPERATURES LISTED IN THE CHART ARE AMBIENT TEMPERATURES. THE FOLLOWING DERATE CHART WAS CALCULATED ASSUMING A 5 DEGIC RISE IN AIR TEMPERATURE BETWEEN AMBIENT AND THE TURBOCHARGER INLET.

#### STANDARD

#### PERFORMANCE DATA[EM5402]

AMBIENT OPERATING	30	40	50	60	70	80	90	100	110	120	130	140	NORMAL
TEMP (F)													
ALTITUDE (FT)													
0	4,043	4,043	4,043	4,043	4,043	4,043	4,043	4,043	4,043	4,043	4,043	3,991	4,043
1,000	4,043	4,043	4,043	4,043	4,043	4,043	4,043	4,043	4,043	4,043	4,016	3,914	4,043
2,000	4,043	4,043	4,043	4,043	4,043	4,043	4,043	4,043	4,043	3,988	3,874	3,729	4,043
3,000	3,907	3,906	3,905	3,904	3,904	3,901	3,809	3,675	3,532	3,458	3,456	3,453	3,904
4,000	3,786	3,784	3,783	3,781	3,780	3,742	3,629	3,483	3,375	3,346	3,343	3,340	3,781
5,000	3,679	3,678	3,675	3,673	3,671	3,628	3,511	3,386	3,276	3,251	3,249	3,246	3,673
6,000	3,572	3,570	3,568	3,566	3,564	3,515	3,415	3,289	3,164	3,135	3,131	3,128	3,567
7,000	3,451	3,449	3,447	3,445	3,443	3,398	3,295	3,141	2,983	2,960	2,957	2,954	3,446
8,000	3,333	3,331	3,329	3,327	3,325	3,275	3,140	2,951	2,795	2,780	2,777	2,774	3,329
9,000	3,201	3,199	3,197	3,195	3,193	3,115	2,957	2,770	2,630	2,622	2,620	2,617	3,198
10,000	3,051	3,049	3,047	3,045	3,043	2,957	2,798	2,623	2,486	2,483	2,481	2,478	3,048
11,000	2,943	2,941	2,939	2,937	2,935	2,842	2,693	2,514	2,399	2,397	2,395	2,392	2,941
12,000	2,839	2,837	2,835	2,834	2,832	2,741	2,589	2,417	2,347	2,346	2,344	2,342	2,838
13,000	2,748	2,747	2,746	2,744	2,742	2,643	2,486	2,363	2,293	2,292	2,290	2,289	2,748
14,000	2,634	2,634	2,632	2,631	2,630	2,523	2,398	2,289	2,217	2,216	2,216	2,214	2,635
15,000	2,485	2,484	2,483	2,482	2,481	2,408	2,306	2,182	2,091	2,090	2,090	2,089	2,485

#### **Cross Reference**

Test Spec	Setting	Engine Arrangem	ent Engineering M	lodel Engineering M Version	lodel Start Effective Serial Number	End Effective Serial Number
5644208	LL2333	5898066	PG266	-	JD700379	

#### Performance Parameter Reference

Parameters Reference: DM9600-14
PERFORMANCE DEFINITIONS

PERFORMANCE DEFINITIONS DM9600

APPLICATION:

Engine performance tolerance values below are representative of a typical production engine tested in a calibrated dynamometer test cell at SAE J1995 standard reference conditions. Caterpillar maintains ISO9001:2000 certified quality management systems for engine test Facilities to assure accurate calibration of test equipment. Engine test data is corrected in accordance with SAE J1995. Additional reference material SAE J1228, J1349, ISO 8665, 3046-1:2002E, 3046-3:1989, 1585, 2534, 2288, and 9249 may apply in part or are similar to SAE J1995. Special engine rating request (SERR) test data shall be noted.

PERFORMANCE PARAMETER TOLERANCE FACTORS:

Power +/- 3%

Torque +/- 3%

Exhaust stack temperature +/- 8%

Inlet airflow +/- 5%

Intake manifold pressure-gage +/- 10%

Exhaust flow +/- 6%

Specific fuel consumption +/- 3%

Fuel rate +/- 5%

Specific DEF consumption +/- 3%

DEF rate +/- 5%

Heat rejection +/- 5%

Heat rejection exhaust only +/- 10%

Heat rejection CEM only +/- 10%

Heat Rejection values based on using treated water.

Torque is included for truck and industrial applications, do not

use for Gen Set or steady state applications.

On C7 - C18 engines, at speeds of 1100 RPM and under these values are provided for reference only, and may not meet the tolerance listed

On 3500 and C175 engines, at speeds below Peak Torque these values are provided for reference only, and may not meet the tolerance listed.

These values do not apply to C280/3600. For these models, see the tolerances listed below.

C280/3600 HEAT REJECTION TOLERANCE FACTORS:

Heat rejection +/- 10%

Heat rejection to Atmosphere +/- 50%

Heat rejection to Lube Oil +/- 20%

#### PERFORMANCE DATAJEM54027

Heat rejection to Aftercooler +/- 5% TEST CELL TRANSDUCER TOLERANCE FACTORS: Torque +/- 0.5% Speed +/- 0.2% Fuel flow +/- 1.0%

Temperature +/- 2.0 C degrees

Intake manifold pressure +/- 0.1 kPa

OBSERVED ENGINE PERFORMANCE IS CORRECTED TO SAE J1995 REFERENCE

AIR AND FUEL CONDITIONS.

REFERENCE ATMOSPHERIC INLET AIR

FOR 3500 ENGINES AND SMALLER

SAE J1228 AUG2002 for marine engines, and J1995 JAN2014 for other engines, reference atmospheric pressure is 100 KPA (29.61 in hg),

and standard temperature is 25deg C (77 deg F) at 30% relative

humidity at the stated aftercooler water temp, or inlet manifold

temp.

FOR 3600 ENGINES

Engine rating obtained and presented in accordance with ISO 3046/1 and SAE J1995 JANJAN2014 reference atmospheric pressure is 100 KPA (29.61 in hg), and standard temperature is 25deg C (77 deg F) at 30% relative humidity and 150M altitude at the stated aftercooler water temperature.

MEASUREMENT LOCATION FOR INLET AIR TEMPERATURE Location for air temperature measurement air cleaner inlet at stabilized operating conditions.

REFERENCE EXHAUST STACK DIAMETER

The Reference Exhaust Stack Diameter published with this dataset is only used for the calculation of Smoke Opacity values displayed in this dataset. This value does not necessarily represent the actual stack diameter of the engine due to the variety of exhaust stack adapter options available. Consult the price list, engine order or general dimension drawings for the actual stack diameter size ordered or options available.

REFERENCE FUEL

DIESEL

Reference fuel is #2 distillate diesel with a 35API gravity; A lower heating value is 42,780 KJ/KG (18,390 BTU/LB) when used at 15 deg C (59 deg F), where the density is

850 G/Liter (7.0936 Lbs/Gal).

Reference natural gas fuel has a lower heating value of 33.74 KJ/L (905 BTU/CU Ft). Low BTU ratings are based on 18.64 KJ/L (500 BTU/CU FT) lower heating value gas, Propane ratings are based on 87.56 KJL (2350 BTU/CU Ft) lower heating value gas. ENGINE POWER (NET) IS THE CORRECTED FLYWHEEL POWER (GROSS) LESS EXTERNAL AUXILIARY LOAD

Engine corrected gross output includes the power required to drive standard equipment; lube oil, scavenge lube oil, fuel transfer, common rail fuel, separate circuit aftercooler and jacket water pumps. Engine net power available for the external (flywheel) load is calculated by subtracting the sum of auxiliary load from the corrected gross flywheel out put power. Typical auxiliary loads are radiator cooling fans, hydraulic pumps, air compressors and battery charging alternators. For Tier 4 ratings additional Parasitic losses would also include Intake, and Exhaust

ALTITUDE CAPABILITY

Altitude capability is the maximum altitude above sea level at standard temperature and standard pressure at which the engine could develop full rated output power on the current performance data set

Standard temperature values versus altitude could be seen on TM2001.

When viewing the altitude capability chart the ambient temperature is the inlet air temp at the compressor inlet.

Engines with ADEM MEUI and HEUI fuel systems operating at conditions above the defined altitude capability derate for atmospheric pressure and temperature conditions outside the values defined see TM2001

Mechanical governor controlled unit injector engines require a setting change for operation at conditions above the altitude defined on the engine performance sheet. See your Caterpillar technical representative for non standard ratings. REGULATIONS AND PRODUCT COMPLIANCE

TMI Emissions information is presented at 'nominal' and 'Potential Site Variation' values for standard ratings. No tolerances are applied to the emissions data. These values are subject to change at any time. The controlling federal and local emission requirements need to be verified by your Caterpillar technical representative,

Customer's may have special emission site requirements that need to be verified by the Caterpillar Product Group engineer. EMISSION CYCLE LIMITS:

Cycle emissions Max Limits apply to cycle-weighted averages only. Emissions at individual load points may exceed the cycle-weighted

WET & DRY EXHAUST/EMISSIONS DESCRIPTION: Wet - Total exhaust flow or concentration of total exhaust flow

#### PERFORMANCE DATA[EM5402]

Dry - Total exhaust flow minus water vapor or concentration of exhaust flow with water vapor excluded

EMISSIONS DEFINITIONS:

Emissions : DM1176

EMISSION CYCLE DEFINITIONS

 For constant-speed marine engines for ship main propulsion, including, diesel-electric drive, test cycle E2 shall be applied,

for controllable-pitch propeller sets test cycle E2 shall be applied.

2. For propeller-law-operated main and propeller-law-operated auxiliary engines the test cycle E3 shall be applied.

3. For constant-speed auxiliary engines test cycle D2 shall be applied. 4. For variable-speed, variable-load auxiliary engines, not

included above, test cycle C1 shall be applied.

HEAT REJECTION DEFINITIONS: Diesel Circuit Type and HHV Balance : DM9500

HIGH DISPLACEMENT (HD) DEFINITIONS: 3500; EM1500 RATING DEFINITIONS: Agriculture : TM6008 Fire Pump : TM6009 Generator Set: TM6035 Generator (Gas): TM6041 Industrial Diesel: TM6010 Industrial (Gas): TM6040

Irrigation : TM5749 Locomotive : TM6037 Marine Auxiliary : TM6036 Marine Prop (Except 3600) : TM5747

Marine Prop (3600 only): TM5748

MSHA: TM6042 Oil Field (Petroleum): TM6011 Off-Highway Truck: TM6039
On-Highway Truck: TM6038
SOUND DEFINITIONS:
Sound Power: DM8702 Sound Pressure: TM7080

Date Released: 10/27/21


Razor5 LLC - Application for New Source Minor PSD Construction Approval and Title V Operating Permit

CUMMINS DQLF 2,750KW GENERATOR



# Diesel generator set QS□78 series engine

EPA emissions 2000 kW - 2750 kW 60 Hz



#### Description

Cummins® commercial generator sets are fully integrated power generation systems providing optimum performance, reliability and versatility for stationary Standby, Prime Power and Continuous duty power applications.

#### **Features**

Cummins heavy-duty engine - Rugged 4cycle, industrial diesel delivers reliable power, low emissions and fast response to load changes.

Alternator - Several alternator sizes offer selectable motor starting capability with low reactance 2/3 pitch windings, low waveform distortion with non-linear loads and fault clearing short-circuit capability.

**Permanent Magnet Generator (PMG)** - Offers enhanced motor starting and fault clearing short circuit capability.

Control system - The PowerCommand® electronic control is standard equipment and provides total genset system integration including automatic remote starting/stopping, precise frequency and voltage regulation, alarm and status message display, AmpSentry™ protection, output metering, auto-shutdown at fault detection and NFPA 110 Level 1 compliance.

Cooling system - Standard and enhanced integral set-mounted radiator systems, designed and tested for rated ambient temperatures to simplify the facility design requirements for rejected heat.

Warranty and service - Backed by a comprehensive warranty and worldwide distributor network.

**NFPA** - The generator set accepts full rated load in a single step in accordance with NFPA 110 Level 1 systems.

	Standby rating	Prime rating	Continuous rating	Data sheets
Model	60 H□ kW (k□A)	60 H□ kW (k□A)	60 H□ kW (k□A)	60 H□
DQLE	2500 (3125)	2275 (2844)	2000 (2500)	D-3507
DQLF	2750 (3438)	2500 (3125)	2100 (2625)	D-3518

Generator set	specifications
---------------	----------------

Performance class	Genset models have been tested in accordance with ISO 8528-5. Consult factory for transient performance information.
Steady state voltage regulation, no load to full load	± 1.0%
Random voltage variation	± 1.0%
Frequency regulation	Isochronous
Steady state frequency band	± 0.5%
Radio frequency emissions compliance	BS EN61000-6-4:2001 emissions-industrial
Electromagnet Compatibility Performance	Emissions to EN 61000-6-2:2005 Immunity to EN 61000-6-4:2007+A1:2011

#### Engine specifications

Bore	170.0 mm (6.69 in)
Stroke	190.0 mm (7.48 in)
Displacement	77.6 litres (4735 in³)
Configuration	Cast iron, V 18 cylinder
Battery capacity	2200 amps minimum at ambient temperature of -18 °C to 0 °C (0 °F to 32 °F)
Battery charging alternator	55 amps
Starting voltage	24 volt, negative ground
Fuel system	Direct injection: number 2 diesel fi.el, fuel filter, automatic electric fuel shutoff
Fuel filter	Triple element, 10 micron filtration, spin-on fuel filter with water separator
Air cleaner type	Dry replaceable element standard; heavy duty optional
Lube oil filter type(s)	Six spin-on, combination full flow filter and bypass filters; Eliminator™ option available
Standard cooling system	High ambient cooling system

#### Alternator specifications

Design	Brushless, 4 pole, drip proof, revolving field
Stator	2/3 pitch
Rotor	Two bearing, flexible coupling
Insulation system	Class H on low voltage and medium, Class F on high voltage
Standard temperature rise	125 °C Standby at 40 °C ambient
Exciter type	Permanent Magnet Generator (PMG)
Phase rotation	A (U), B (V), C (W)
Alternator cooling	Direct drive centrifugal blower fan
AC waveform Total Harmonic Distortion (THDV)	< 5% no load to full linear load, < 3% for any single harmonic

## Available voltages

#### 60 H□Line-Neutral/Line-Line

• 380	• 480	• 4160	• 13200	
• 440	• 600	• 12470	• 13800	

Note: Consult factory for other voltages.

## Generator set options and accessories

#### Engine

- 208/240/480 V coolant heater for ambient above 4.5 °C (40 °F) -10,000 W max.
- 208/240/480 V coolant heater for ambient below 4.5 °C (40 °F) -12,840 W max.

### Cooling system

- Remote radiator
- High ambient air temperature (ship loose)
- Enhanced high ambient air temperature (ship loose)

#### Control panel

- Multiple language support
- Right or left facing mounting
- Floor mounted
- 3 phase differential CTs (3x or 6x CTs)
- Masterless load demand
- Warning high bearing temperature

#### Generator set options and accessories (continued)

#### Control panel

- · Alternator temperature monitoring
- Exhaust gas temperature monitoring
- 6x user-configurable relays
- 120/240 V Heater control cabinet
- · Mechanical hour meter
- 2x digital input/output

#### Exhaust system

- · Residential grade exhaust silencer
- · Critical grade exhaust silencer

#### Generator set

- Battery
- Battery rack with hold-down floor standing
- PowerCommand network
- · Remote annunciator panel
- Vibration isolators
- 2 year warranty
- 5 year warranty
- 10 year major components warranty
- IBC and HCAI Certification

#### Alternator

- 80 °C rise
- 105 °C rise
- 125 °C rise
- 150 °C rise
- 120/240 V 300 W anti-condensation heater
- Temperature sensor RTDs, 2/phase
- Temperature sensor alternator bearing RTD
- · Differential current transformers

Note: Some options may not be available on all models - consult factory for availability.

#### PowerCommand 3.3 - control system



The PowerCommand control system is an integrated microprocessor based generator set control system providing voltage regulation, engine protection, alternator protection, operator interface and isochronous governing.

AmpSentry – Includes integral AmpSentry protection, which provides a full range of alternator protection functions that are matched to the alternator provided.

**Power management** – Control function provides battery monitoring and testing features and smart starting control system.

Advanced control methodology – Three phase sensing, full wave rectified voltage regulation, with a PWM output for stable operation with all load types.

**Communications interface** – Control comes standard with PCCNet and Modbus interface.

Service - InPower™ PC-based service tool available for detailed diagnostics, setup, data logging and fault simulation.

**Reliable design** – The control system is designed for reliable operation in harsh environment.

#### Multi-language support

#### Operator panel features

Operator panel features – The operator panel, in addition to the alternator, displays the Utility/AC bus data.

#### Operator/display functions

- 320 x 240 pixels graphic LED backlight LCD
- Auto, manual, start, stop, fault reset and lamp test/panel lamp switches
- Alpha-numeric display with pushbuttons
- LED lamps indicating genset running, remote start, not in auto, common shutdown, common warning, manual run mode, auto mode and stop.

#### Paralleling control functions

- Digital frequency synchronization and voltage matching
- · Isochronous kW and kVar load sharing controls
- Droop kW and kVar control
- · Sync check
- Extended paralleling (peak shave/base load)
- Digital power transfer control (AMF) provides load transfer operation in open or closed transition or soft (ramping) transfer mode

#### Alternator data

- · Line-to-Neutral and Line-to-Line AC volts
- · 3-phase AC current
- Frequency
- kW, kVar, power factor kVA (three phase and total)

#### Engine data

- DC voltage
- · Engine speed
- · Lube oil pressure and temperature
- · Coolant temperature
- · Comprehensive FAE data (where applicable)

#### Other data

- · Genset model data
- · Start attempts, starts, running hours, kW hours
- Load profile (operating hours at % load in 5% increments)
- · Fault history
- Data logging and fault simulation (requires InPower)

#### Standard control functions

#### Digital governing (optional)

- · Integrated digital electronic isochronous governor
- Temperature dynamic governing

#### Digital voltage regulation

- Integrated digital electronic voltage regulator
- · 3-phase, 4-wire Line-to-Line sensing
- Configurable torque matching

#### Standard control functions (continued)

#### AmpSentry AC protection

- AmpSentry protective relay
- · Over current and short circuit shutdown
- Over current warning
- · Single and three phase fault regulation
- · Over and under voltage shutdown
- Over and under frequency shutdown
- · Overload warning with alarm contact
- · Reverse power and reverse Var shutdown
- Field overload

#### Engine protection

- · Battery voltage monitoring, protection and testing
- Overspeed shutdown
- Low oil pressure warning and shutdown
- High coolant temperature warning and shutdown
- . Low coolant level warning or shutdown
- · Low coolant temperature warning
- · Fail to start (overcrank) shutdown
- Fail to crank shutdown

- Cranking lockout
- · Sensor failure indication
- . Low fuel level warning or shutdown
- Fuel-in-rupture-basin warning or shutdown
- Full authority electronic engine protection

#### Control functions

- . Time delay start and cool down
- · Real time clock for fault and event time stamping
- · Exerciser clock and time of day start/stop
- Data logging
- · Cycle cranking
- . Load shed
- · Configurable inputs and outputs (4)
- Remote emergency stop

#### Options

» Auxiliary output relays (2)

#### Ratings definitions

#### Emergency Standby Power (ESP):

Applicable for supplying power continuously to varying electrical loads for the duration of power interruption of a reliable utility source. Emergency Standby Power (ESP) is in accordance with ISO 8528 and ISO 3046-1, obtained and corrected in accordance with ISO 15550).

#### Limited-Time Running Power (LTP):

Applicable for supplying power to a constant electrical load for limited hours. Limited-Time Running Power (LTP) is in accordance with ISO 8528.

#### Prime Power (PRP):

Applicable for supplying power to varying electrical load for unlimited hours. Prime Power (PRP) is in accordance with ISO 8528. Ten percent overload capability is available in accordance with ISO 3046-1. Data shown above represents gross engine performance and capabilities as per ISO 3046-1, obtained and corrected in accordance with ISO 15550.

#### Base Load (Continuous) Power (COP):

Applicable for supplying power continuously to a constant load up to the full output rating for unlimited hours. No sustained overload capability is available for this rating. Consult authorized distributor for rating. (Equivalent to Continuous Power in accordance with ISO 8528 and ISO 3046-1, obtained and corrected in accordance with ISO 15550).

Dim "C

This outline drawing is for reference only. See respective model data sheet for specific model outline drawing number.

#### Do not use for installation design

This rating is not applicable to all generator set models.

Model	Dim "A" mm (in.)			Set weight□ dry kg (lbs)	Set weight□ wet kg (lbs)	
DQLE	7138 (281)	2750 (108.3)	3387 (133.3)	22824 (50318)	23603 (52036)	
DQLF	7138 (281)	2750 (108.3)	3387 (133.3)	22824 (50318)	23603 (52036)	

Notes: \* With standard features and P80X alternator. See outline drawings for other configurations.

#### Codes and standards

Codes or standards compliance may not be available with all model configurations – consult factory for availability.

ISO 9001 ISO 14001 ISO 45001	This product was manufactured in a facility whose quality management system is certified to ISO 9001 and its Health Safety Environmental Management Systems certified to ISO 14001 and ISO 45001.	U.S. EPA	Engine certified to Stationary Emergency U.S. EPA New Source Performance Standards, 40 CFR 60 subpart IIII Tier 2 exhaust emission levels. U.S. applications must be applied per this EPA regulation.
	All genset models are available as CSA certified to CSA C22.2 No.100.	International Building Code	The generator set package is available certified for seismic application in accordance with International Building Code.
UL LISTED	This product is listed to UL 2200, Stationary Engine Generator Assemblies.		The Prototype Test Support (PTS) program verifies the performance integrity of the generator set design. Cummins products bearing the PTS symbol meet the prototype test requirements of NFPA 110 for Level 1 systems.

For more information contact your local Cummins distributor or visit power.cummins.com







March 30th, 2022

#### To Whom It May Concern:

With regards to Cummins Power Systems (CPS) manufactured diesel generator set model DQLF rated for 60 Hz operation and equipped with Cummins QSK78-G12 engine:

When tested under the following conditions:

Table 1	
Fuel Specification:	ASTM D975 No. 2-D S15 diesel fuel with 0.0015% sulfur content (by weight), and 42-48 cetane number.
Air Inlet Temperature:	77 °F
Fuel Inlet Temperature:	104 °F (at fuel pump inlet)
Barometric Pressure:	29.53 in. Hg
Humidity:	NOx measurement corrected to 75 grains H2O/lb. dry air

Based on engine emissions validation testing, the table below represents the nominal performance and exhaust emissions data for the generator set listed above:

		Standby Nominal / NTE (Calc'd)					
PERFORMANCE DATA	10%	25%	50%	75%	100%		
BHP @ 1800 RPM (60 Hz)	507	1086	2052	3017	4021		
Power Output (kWe)	275	688	1375	2063	2750		
Fuel Consumption US Gal/Hr	38	61	106	147	187		
Exhaust Gas Flow CFM	5719	8804	13797	17334	20138		
Exhaust Gas Temperature °F	631	788	847	879	902		
		Nominal / NTE (C					
NMHC (Nonmethane Hydrocarbons)	0.80 / 1.0	0.45 / 0.56	0.23 / 0.29	0.14 / 0.18	0.10 / 0.13		
NOx (Oxides of Nitrogen)	7.05 / 8.81	3.82 / 4.78	3.53 / 4.41	4.64 / 5.8	6.81 / 8.51		
CO (Carbon Monoxide)	1.8 / 2.3	0.7 / 0.88	0.3 / 0.38	0.4 / 0.5	1.0 / 1.25		
PM (Particulate Matter)	0.23 / 0.29	0.13 / 0.16	0.07 / 0.09	0.08 / 0.1	0.10 / 0.125		
All emissions values above are cited as g/bhp-hr							

#### The Exhaust data for 0% load is, 4347 CFM for Exhaust Gas Flow and 478°F for Exhaust Gas Temperature.

Steady-State emissions recorded per ISO8178-1 during operation at rated engine speed (+/-2%) and stated constant load (+/-2%) with engine temperatures, pressures and emission rates stabilized.

The NOx, HC, CO, and PM emission data tabulated here are representative of test data taken from a single engine under the test conditions shown above. Data for the other components are estimated. This data is subject to instrumentation and engine-to-engine variability. Field emissions test data is not guaranteed to these levels. Actual



field test results may vary due to test ambient, site conditions, installation, fuel specification, test procedures, instrumentation and ambient correction factors. Engine operation with excessive air intake or exhaust restriction beyond published maximum limits, or with improper maintenance, may result in elevated emission levels.

The data and information provided in this letter is for informational purposes to assist customers in making purchasing decisions appropriate for their site-specific compliance needs. Owners/operators of compression ignition internal combustion engines are responsible for ensuring compliance with applicable local, state, and federal standards when CI engines are installed at the owner/operator site. The data and information contained herein regarding site variation values in particular should be considered as part of a site-specific compliance evaluation.

This letter does not supersede any of the commercial terms of sale, including, but not limited to, warranty coverage and compliance with law obligations. THE INFORMATION IN THIS LETTER IS PROVIDED "AS IS" AND WITH ALL FAULTS AND DEFECTS. CUMMINS DOES NOT WARRANT THE ACCURACY OF THE INFORMATION PROVIDED AND THIS LETTER SHOULD NOT BE SHARED WITH THIRD PARTIES WITHOUT CUMMINS PRIOR WRITTEN CONSENT. For further questions on this product or application, please contact the local Cummins Sales and Service representative.

Best Regards,

Miguel Araujo

Highlandel

Application Engineer – Strategic Accounts (Data Center)

**Cummins Power Generation** 



# Exhaust emission data sheet 2750DQLF

60 H□Diesel generator set EPA emission

Engine information:

Model:

Cummins Inc. QSK78-G12

Bore:

6.69 in. (170 mm)

Туре:

4 Cycle, 60° V, 18 cylinder diesel

Stroke:

7.48 in. (190 mm)

Aspiration:

Turbocharged and low temperature after-cooled

Displacement:

4735 cu. in. (77.6 liters)

Compression ratio:

15 5:1

Emission control device:

Turbocharger and after-cooled

	1/4	1/2	3/4	<u>Full</u>	<u>Full</u>	<u>Full</u>		
Performance data	Standby	Standby	Standby	Standby	<u>Prime</u>	Continuous		
BHP @ 1800 RPM (60 Hz)	1015	2030	3045	4060	3670	3045		
Fuel consumption (Gal/Hr)	59.7	107.2	145.8	186.9	169.0	145.8		
Exhaust gas flow (CFM)	8409	13364	16965	20134	18784	16965		
Exhaust gas temperature (°F)	761	811	827	879	850	827		
Exhaust emission data								
HC (Total unburned hydrocarbons)	0.43	0.23	0.15	0.12	0.13	0.15		
NOx (Oxides of nitrogen as NO2)	3.35	3.40	4.40	6.40	5.60	4.60		
CO (Carbon monoxide)	0.59	0.45	0.54	1.18	0.93	0.54		
PM (Particular matter)	0.08	0.08	0.09	0.10	0.10	0.09		
SO2 (Sulfur dioxide)	0.13	0.12	0.10	0.10	0.10	0.10		
Smoke (Bosch)	0.28	0.37	0.46	0.59	0.54	0.46		
All values are Grams/HP-Hour, Smoke is Bosch#								

#### Test conditions

Data is representative of steady-state engine speed (± 36 RPM) at designated genset loads. Pressures, temperatures, and emission rates were stabilized.

Fuel specification:

ASTM D975 No. 2-D diesel fuel with 0.03-0.05% sulfur content (by weight), and 40-

60 cetane number.

Fuel temperature

104  $\pm$  9 °F (at fuel pump inlet)

Intake air temperature:

77 ± 9 °F

Barometric pressure:

29.6 ± 1 in. Hg

Humidity:

NOx measurement corrected to 75 grains H2O/lb dry air

Reference standard:

ISO 8178

The NOx, HC, CO and PM emission data tabulated here are representative of test data taken from a single engine under the test conditions shown above. Data for the other components are estimated. These data are subjected to instrumentation and engine-to-engine variability. Field emission test data are not guaranteed to these levels. Actual field test results may vary due to test site conditions, installation, fuel specification, test procedures and instrumentation. Engine operation with excessive air intake or exhaust restriction beyond published maximum limits, or with improper maintenance, may results in elevated emission levels.



## 2023 EPA Tier 2 Exhaust Emission **Compliance Statement** 2750DQLF

## Stationary Emergency

60 H□Diesel Generator Set

#### Compliance Information:

The engine used in this generator set complies with Tier 2 emissions limit of U.S. EPA New Source Performance Standards for stationary emergency engines under the provisions of 40 CFR 60 Subpart IIII when tested per ISO8178

Engine Manufacturer:

Cummins Inc.

EPA Certificate Number:

PCEXL060.AAD-001

Effective Date:

04/13/2022

Date Issued:

04/13/2022

EPA Engine Family (Cummins Emissions Family):

PCEXL060,AAD

Engine Information:

Model:

QSK78-G12

Bore:

6.69 in. (170 mm)

Engine Nameplate HP:

4060

Stroke:

7.48 in. (190 mm)

Type:

4 cycle, 60°V, 18 Cylinder Diesel

Displacement:

4735 cu. in. (77.6 liters)

Aspiration:

Turbocharged and Low Temperature Aftercooled Compression Ratio:

15.5:1

Emission Control Device:

Turbocharged and Low

Exhaust Stack Diameter: Temperature Aftercooled

2 - 14 in.

#### Diesel Fuel Emissions Limits

D2 Cycle Exhaust Emissions		Grams per BHP-hr			Grams per kW <sub>m</sub> -hr		
		<u>NOx∃</u> NMHC	<u>co</u>	<u>PM</u>	<u>NOx</u>	<u>co</u>	<u>PM</u>
	EPA Emissions Limit	4.8	2.6	0.15	6.4	3.5	0.20

Test methods: EPA emissions recorded per 40 CFR Part 60, 89, 1039, 1065 and weighted at load points prescribed in the regulations for constant speed engines.

Diesel fuel specifications: Cetane number: 40-50. Reference: ASTM D975 No. 2-D, 7-15 ppm Sulphur

Reference conditions: Air inlet temperature: 25°C (77°F), Fuel inlet temperature: 40°C (104°F). Barometric pressure: 100 kPa (29.53 in Hg), Humidity: 10.7 g/kg (75 grains H2O/lb) of dry air; required for NOx correction, Restrictions: Intake restriction set to a maximum allowable limit for clean filter; Exhaust back pressure set to a maximum allowable limit.

Tests conducted using alternate test methods, instrumentation, fuel or reference conditions can yield different results. Engine operation with excessive air intake or exhaust restriction beyond published maximum limits, or with improper maintenance, may result in elevated emission levels.

#### Generator Set Data Sheet



Model:

DQLF

Frequency:

60 Hz

Fuel Type:

Diesel

kW Rating:

2750 Standby

2500 Prime

2100 Continuous

Emissions level:

**EPA NSPS Stationary Emergency Tier 2** 

Exhaust emission data sheet:	EDS-1125
Exhaust emission compliance sheet:	EPA-1174
Sound performance data sheet:	MSP-1103
Cooling performance data sheet:	MCP-211
Prototype test summary data sheet:	PTS-299
Remote radiator cooling outline:	A050R323
High ambient cooling system outline (ship loose):	A050R319
Enhanced high ambient cooling system outline (ship loose):	A050R321

	Standby			Prime kW (kVA)				Continuous kW (kVA)	
<b>Fuel Consumption</b>	kW (kVA)								
Ratings	2750 (3438)			2500 (3125)				2100 (2625)	
Load	1/4	1/2	3/4	Full	1/4	1/2	3/4	Full	Full
US gph	63.3	103.4	143.4	183.4	59.7	96.1	132.5	168.9	145.5
L/hr	239	391	542	694	226	364	501	639	551

Engine	Standby rating	Prime rating	Continuous rating			
Engine manufacturer	Cummins Inc.					
Engine model	QSK78-G12					
Configuration	Cast Iron, V 18 cylin	nder				
Aspiration	Turbocharged and	low temperature afte	r-cooled			
Gross engine power output, kWm (bhp)	3028 (4060)	2737 (3670)	2271 (3045)			
BMEP at set rated load, kPa (psi)	2599 (377)	2351 (341)	1951 (283)			
Bore, mm (in.)	170.0 (6.69)					
Stroke, mm (in.)	190.0 (7.48)					
Rated speed, rpm	1800					
Piston speed, m/s (ft/min)	11.4 (2243)					
Compression ratio	15.5:1					
Lube oil capacity, L (qt)	413 (436)					
Overspeed limit, rpm	2100					
Regenerative power, kW	266					

Fuel Flow	Standby rating	Prime rating	Continuous rating				
Maximum fuel flow, L/hr (US gph)	2234 (590)						
Maximum fuel inlet restriction, kPa (in Hg)	17 (5)		100				
Maximum fuel inlet temperature, °C (°F)	71 (160)						
Air							
Combustion air, m³/min (scfm)	239 (8451)	227 (8003)	207 (7302)				
Maximum air cleaner restriction, kPa (in H <sub>2</sub> O)	3.7 (15)						
Alternator cooling air, m³/min (cfm)	270 (9535)						
Exhaust	[ === (a) (a) (b)	1 === (1=== 1)	T (00 (10005)				
Exhaust flow at set rated load, m³/min (cfm)	570 (20134)	532 (18784)	480 (16965)				
Exhaust temperature, °C (°F)	471 (879)	454 (850)	442 (827)				
Maximum back pressure, kPa (in H <sub>2</sub> O)	7 (28)						
High Ambient Cooling System (ship loose	)	,					
Ambient design, °C (°F)	43 (109)	40 (104)	44 (111)				
Fan load, kWm (HP)	90 (121)						
Coolant capacity (with radiator), L (US gal)	738 (195)						
Cooling system air flow, m³/min (scfm)	3060 (108000)						
Total heat rejection, MJ/min (Btu/min)	103.6 (98257)	94.6 (89618)	82.0 (77746)				
Maximum cooling air flow static restriction, kPa (in H <sub>2</sub> O)	0.12 (0.5)						
Enhanced High Ambient Cooling System ( Ambient design, °C (°F)  Fan Inad, kW- (HP)	51 (124)	49 (120)	50 (122)				
Fan load, kW <sub>m</sub> (HP)	107 (144)						
Coolant capacity (with radiator), L (US gal)	1061 (280)						
Cooling system air flow, m³/min (scfm)	4560 (161000)	<b>T</b>	T				
Total heat rejection, MJ/min (Btu/min)	103.6 (98257)	94.6 (89618)	82.0 (77746)				
Maximum cooling air flow static restriction, kPa (in H <sub>2</sub> O)	0.12 (0.5)						
Remote Radiator Cooling at 25C, 110M <sup>1</sup>							
Set coolant capacity, L (US gal)	223 (59)						
Max flow rate at max friction head, jacket water circuit,	2222 (587)	***************************************					
L/min (US gal/min)  Max flow rate at max friction head, aftercooler circuit, L/min	988 (261)						
(US gal/min)  Heat rejected, jacket water circuit, MJ/min (Btu/min)	55.1 (52234)	51.1 (48459)	45.5 (43158)				
Heat rejected, aftercooler circuit, MJ/min (Btu/min)	45.9 (43523)	40.8 (38659)	33.9 (32088)				
Heat rejected, fuel circuit, MJ/min (Btu/min)	2.6 (2500)						
Total heat radiated to room, MJ/min (Btu/min)	23.4 (22179)	21.4 (20341)	18.3 (17400)				
Maximum friction head, jacket water circuit, kPa (psi)	69 (10)						
Maximum friction head, aftercooler circuit, kPa (psi)	48 (7)						
Maximum static head, jacket water circuit, m (ft)	18.3 (60)						
Maximum static head, aftercooler circuit, m (ft)	18.3 (60)						
Maximum jacket water outlet temp. °C (°F)	104 (220)		\ - \ \ - \ - /				
Maximum jacket water outlet temp, °C (°F)  Maximum aftercooler inlet temp at 25 °C (77 °F) ambient, °C (°F)	104 (220) 49 (120)	1.00 (= 1.2)					
Maximum aftercooler inlet temp at 25 °C (77 °F) ambient,		66 (150)					
Maximum aftercooler inlet temp at 25 °C (77 °F) ambient, °C (°F)	49 (120)						

Weights<sup>2</sup>

2	
Unit dry weight kgs (lbs)	23210 (51166)
Unit wet weight kgs (lbs)	24238 (53433)

<sup>&</sup>lt;sup>1</sup> For non-standard remote installations contact your local Cummins representative.

**Derating Factors** 

nelanina i acrois	
Standby	Standard Cooling System: Full genset power available up to 740 m (2428 ft) at ambient temperatures up to 40 °C (104 °F). Above these conditions, derate at 7.8% per 305 m (1000 ft) and 21% per 10 °C (18 °F).  Enhanced Cooling System: Genset is de-rated by 1.3% at sea level (0 m) at ambient
Standby	temperatures up to 50 °C (122 °F). Above these conditions, derate at 7.9% per 305 m (1000 ft) and 21% per 10 °C (18 °F).
	Standard Cooling System: Full genset power available up to 410 m (1345 ft) at ambient temperatures up to 40 °C (104 °F). Above these conditions, derate at 8.6% per 305 m (1000 ft) and 24% per 10 °C (18 °F).
Prime	Enhanced Cooling System: Genset is de-rated by 11.9% at sea level (0 m) at ambient temperatures up to 50 °C (122 °F). Above these conditions, derate at 8.7% per 305 m (1000 ft) and 24% per 10 °C (18 °F).
	Standard Cooling System: Genset is de-rated by 2.0% at sea level (0 m) at ambient temperatures up to 40 °C (104 °F). Above these conditions, derate at 10.2% per 305 m (1000 ft) and 28.8% per 10 °C (18 °F).
Continuous	Enhanced Cooling System: Genset is de-rated by 28.8% at sea level (0 m) at ambient temperatures up to 50 °C (122 °F). Above these conditions, derate at 10.2% per 305 m (1000 ft) and 28.8% per 10 °C (18 °F).

Ratings	Defin	itions
n contract and order	MAN 47 6 X 3 0	7 00 X 000 X X 000

Raunga Deminuona			
Emergency Standby Power (ESP):	Limited-Time Running Power (LTP):	Prime Power (PRP):	Base Load (Continuous) Power (COP):
Applicable for supplying power to varying electrical load for the duration of power interruption of a reliable utility source. Emergency Standby Power (ESP) is in accordance with ISO 8528. Fuel stop power in accordance with ISO 3046, AS 2789, DIN 6271 and BS 5514.	Applicable for supplying power to a constant electrical load for limited hours. Limited-Time Running Power (LTP) is in accordance with ISO 8528.	Applicable for supplying power to varying electrical load for unlimited hours. Prime Power (PRP) is in accordance with ISO 8528. Ten percent overload capability is available in accordance with ISO 3046, AS 2789, DIN 6271 and BS 5514.	Applicable for supplying power continuously to a constant electrical load for unlimited hours. Continuous Power (COP) is in accordance with ISO 8528, ISO 3046, AS 2789, DIN 6271 and BS 5514.

<sup>&</sup>lt;sup>2</sup> Weights represent a set with standard features. See outline drawing for weights of other configurations.

#### Alternator Data

Voltage	Connection <sup>1</sup>	Temp rise degrees C	Duty <sup>2</sup>	Single phase factor <sup>3</sup>	Max surge kVA <sup>4</sup>	Winding No.	Alternator data sheet	Feature code
220/380	Wye	125	S		N/A	13	ADS-531	B407-2
380	Wye	150	S		7944	13	ADS-516	B814-2
440	Wye	150	S/P/C		9719	12	ADS-517	B813-2
380	Wye	125	Р		7944 .	13	ADS-516	B815-2
380	Wye	80	С	3.	N/A	13	ADS-517	B800-2
220/380	Wye	105	С		7944	13	ADS-516	B597-2
380	Wye	105	Р		10049	13	ADS-517	B840-2
440	Wye	125	S/P/C	1745).1	13024	12	ADS-531	B663-2
440	Wye	105	S/P		13024	12	ADS-531	B664-2
480	Wye	150	S		8412	12	ADS-516	B816-2
277/480	Wye	125	Р		8412	12	ADS-516	B718-2
480	Wye	125	S/P/C		9719	12	ADS-517	B801-2
480	Wye	105	S		13024	12	ADS-531	B280-2
480	Wye	80	S		14781	12	ADS-532	B601-2
480	Wye	80	Р		13024	12	ADS-531	B694-2
480	Wye	105	С		7267	12	ADS-515	B583-2
600	Wye	150	S		8189	7	ADS-516	B817-2

#### Notes:

- Single phase power can be taken from three phase generator sets at up to the value listed in the single phase factor column for the generator set nameplate kW rating at unity power factor.
- <sup>2</sup> Standby (S), Prime (P) and Continuous ratings (C).
- <sup>3</sup> Factor for the *single phase output from three phase alternator* formula listed below.
- <sup>4</sup> Maximum rated starting kVA that results in a minimum of 90% of rated sustained voltage during starting.

Alternator Data (continued)

Voltage	Connection <sup>1</sup>	Temp rise degrees C	Duty <sup>2</sup>	Single phase factor <sup>3</sup>	Max surge kVA <sup>4</sup>	Winding No.	Alternator data sheet	Feature code
347/600	Wye	125	Р		8189	7	ADS-516	B720-2
347/600	Wye	80	S		N/A	7	ADS-532	B604-2
600	Wye	80	Р		12426	7	ADS-531	B604-2
347/600	Wye	105	С		7233	7	ADS-515	B582-2
347/600	Wye	105	S		12426	7	ADS-531	B839-2
2400/4160	Wye	105	P/C		7295	51	ADS-519	B571-2
13200- 13800	Wye	125	Р		6800	91 .	ADS-522	B804-2
13200	Wye	105	С		6800	91	ADS-522	B805-2
13200	Wye	125	S/P		11213	91	ADS-533	B819-2
13200	Wye	105	S		11213	91	ADS-533	B501-2
13200	Wye	80	Р		13438	91	ADS-534	B566-2
13200	Wye	80	S		13438	91	ADS-534	B807-2
13200	Wye	80	С		11213	91	ADS-533	B808-2
13800	Wye	125	S		7993	91	ADS-523	B820-2
13800	Wye	105	Р		7993	91	ADS-523	B821-2
13800	Wye	105	С		6800	91	ADS-522	B460-2
13800	Wye	80	S		13438	91	ADS-534	B610-2
13800	Wye	80	Р		11213	91	ADS-533	B809-2
13800	Wye	80	С		6800	91	ADS-522	B565-2
12470	Wye	125	S		11213	91	ADS-533	B822-2
12470	Wye	105	Р		11213	91	ADS-533	B823-2
12470	Wye	105	S		13438	91	ADS-534	B568-2
12470	Wye	80	Р		13438	91	ADS-534	B812-2
12470	Wye	105	С		6800	91	ADS-522	B569-2
12470	Wye	80	С		11213	91	ADS-533	B570-2
13800	Wye	105	S		11213	91	ADS-533	B895-2
2400/4160	Wye	105	S		8752	51	ADS-520	B933-2
2400/4160	Wye	80	S		11185	51	ADS-545	B935-2
2400/4160	Wye	150	S/P/C		7295	51	ADS-519	B938-2
2400/4160	Wye	125	S		7295	51	ADS-519	B940-2
600	Wye	80	С		8189	7	ADS-516	B589-2
2400/4160	Wye	80	Р		8752	51	ADS-520	B939-2

#### Notes:

- 1 Single phase power can be taken from three phase generator sets at up to the value listed in the single phase factor column for the generator set nameplate kW rating at unity power factor.
- 2 Standby (S), Prime (P) and Continuous ratings (C).
- 3 Factor for the single phase output from three phase alternator formula listed below.
- 4 Maximum rated starting kVA that results in a minimum of 90% of rated sustained voltage during starting.

## Formulas for Calculating Full Load Currents:

Three phase output	Single phase output
kW x 1000	kW x SinglePhaseFactor x 1000
Voltage x 1.73 x 0.8	Voltage

Warning: Back feed to a utility system can cause electrocution and/or property damage. Do not connect to any building's electrical system except through an approved device or after building main switch is open.

For more information contact your local Cummins distributor or visit cummins.com



RazorS LLC - Application for New Source Minor PSD Construction Approval and Title V Operating Permit

MIRATECH CONTROL SYSTEM



Proposal Number: SDM-22-005547 Rev(2)

#### **Application & Performance Warranty Data**

**Project Information** 

Site Location:

VA

Project Name:

ADS IAD107ROMP01 - 12

Application:

Standby Power

Number Of Engines:

26

Operating Hours per Year:

100

**Engine Specifications** 

Engine Manufacturer:

Caterpillar

Model Number: Rated Speed:

3516E

Type of Fuel:

1800 RPM

Type of Lube Oil:

Ultra-Low Sulfur Diesel (ULSD)

1 wt% sulfated ash or less

Lube Oil Consumption:

0.1 % Fuel Consumption

Number of Exhaust Manifolds:

#### Engine Cycle Data

Load	Speed	Power	Exhaust Flow	Exhaust Temp.	Fuel Cons.	NOx	co	NMHC	NMNEHC	PM10	O <sub>2</sub>	H <sub>2</sub> O.
%		bhp	acfm (cfm)	.° <i>F</i>	gal/hr	g/bhp-hr	g/bhp-hr	g/bhp-hr	g/bhp-hr	g/bhp-hr	%	%
100	Rated	4,043	22,051.6	897	191.8	6	1.16	0.14	0.1	0.07	9.4	10

#### Emission Data (100% Load)

		aw Engin	e Emissio	ns		Target Outlet Emissions							
Emission	g/bhp- hr	tons/yr	ppmvd @ 15% O2	ppmvd	g/kW-hr	Ib/MW- hr	g/bhp- hr	tons/yr	ppmvd @ 15% O2	ppmvd	g/kW-hr	lb/MW- hr	Calculated Reduction
NO <sub>x</sub> *	6	2.67	496	966	8.046	17.74	0.5	0.22	41	81	0.671	1.48	91.7%
СО	1.16	0.52	157	307	1.556	3.43	0.35	0.16	47	92	0.467	1.03	70%
NMHC**	0.14	0.06	33	65	0.188	0.41	0.07	0.03	17	32	0.094	0.21	50%
PM <sub>10</sub>	0.07	0.03	22	43	0.094	0.21	0.02	0.01	7	14	0.03	0.07	68.6%

<sup>\*</sup> MW referenced as NO<sub>2</sub>

<sup>\*\*</sup> MW referenced as CH4. Propane in the exhaust shall not exceed 15% by volume of the NMHC compounds in the exhaust, excluding aldehydes. The 15% (vol.) shall be established on a wet basis, reported on a methane molecular weight basis. The measurement of exhaust NMHC composition shall be based upon EPA method 320 (FTIR), and shall exclude formaldehyde.

Razor5 LLC - Application for New Source Minor PSD Construction Approval and Title V Operating Permit

SAFETY POWER CONTROL SYSTEM

#### **DESIGN PARAMETERS**

The design of the Safety Power emissions reduction system is based on the following conditions. Note: NOx is calculated as NO<sub>2</sub>.

Table 1 - Engine Data

Engine Type:	CAT 3516E
Application	Stand-by
Engine Power	2,750 ekW
Exhaust Temperature	897 °F
Design Exhaust Flow Rate	21,724 (CFM)
Fuel Type	Diesel

Table 2 - Emissions Data at Full Engine Load

Engine Option	Emissions	Not to Exceed Catalyst Inlet (g/bhp- h)		Catalyst Outlet (g/bhp- hr)	Catalyst Outlet (g/kwh)	Catalyst Outlet (lbs/MW- h)	Catalyst Outlet (ppmvd at 15%O2)	Catalyst Outlet (% reduction)
CAT	NOx	6.0	0.50	0.50	0.67	1.62	40	91.9
3516E	CO *	1.16	2.60	0.23	0.31	0.75	31	80.0
(2,750	VOC *	0.14	0.14	0.06	0.08	0.18	5	60.0
ekW)	PM	0.07	0.022	0.022	0.03	0.07	***	75.6

<sup>\*</sup> Reductions assume an exhaust temp of 662 degF (350 degC) or more.

\*\*\* Particulate matter is a mass quantity and must be determined and reported gravimetrically. As per EPA Method 5 measurement method, PM emissions should not be reported in ppmvd. We would always advise that PM measurements to be taken with front half as this is the most appropriate for this application.

Notes: (1) The EPA does not treat methane and ethane as VOC's. Safety Power can achieve a stated reduction of VOC's based on the EPA definition assuming that the VOC's manifest themselves as propene. (2) all emissions reductions are based on an average at steady state using SCAQMD method 100.1 for NOx and SCAQMD/EPA methods 25.1/25.3 for CO and VOC's or mutually agreed test method approved in writing. (3) if NMHC/VOC data isn't provided 0.6 g/hp-hr is to be assumed (unless otherwise stated).

Table 3 - SCR System Data

Engine Option	CAT 3516E (2,750 ekW)
Max. Ammonia Slip 🗆 15% O2	8 ppm
Urea Consumption - 32.5% solution (□/- 15%)	10.3 USG/hr
System Pressure Loss	19.5" WC
System Inlet/Outlet ANSI Flange Inches	28/28


RazorS LLC - Application for New Source Minor PSD Construction Approval and Title V Operating Permit

CATERPILLER 3512C 1,500 KW GENERATOR

## Cat® 3512C

## **Diesel Generator Sets**





Bore – mm (in)	170 (6.69)
Stroke – mm (in)	190 (7.48)
Displacement – L (in³)	51.8 (3161.03)
Compression Ratio	14.7:1
Aspiration	TA
Fuel System	EUI
Governor Type	ADEM™ A3

Image shown may not reflect actual configuration

Standby 60 Hz ekW (kVA)	Mission Critical 60 Hz ekW (kVA)	Prime 60 Hz ekW (kVA)	Continuous 60 Hz ekW (kVA)	Emissions Performance
1500 (1875)	1500 (1875)	1360 (1700)	1230 (1537)	U.S. EPA Stationary Emergency Use Only. (Tier 2)

#### **Features**

#### Cat® Diesel Engine

- Meets U.S. EPA Stationary Emergency Use Only (Tier 2) emission standards
- Reliable performance proven in thousands of applications worldwide

#### Generator Set Package

- Accepts 100% block load in one step and meets NFPA 110 loading requirements
- Conforms to ISO 8528-5 G3 load acceptance requirements
- Reliability verified through torsional vibration, fuel consumption, oil consumption, transient performance, and endurance testing

#### **Alternators**

- Superior motor starting capability minimizes need for oversizing generator
- Designed to match performance and output characteristics of Cat diesel engines

#### **Cooling System**

- Cooling systems available to operate in ambient temperatures up to 50°C (122°F)
- · Tested to ensure proper generator set cooling

#### **EMCP 4 Control Panels**

- · User-friendly interface and navigation
- Scalable system to meet a wide range of installation requirements
- Expansion modules and site specific programming for specific customer requirements

#### Warranty

- 24 months/1000-hour warranty for standby and mission critical ratings
- 12 months/unlimited hour warranty for prime and continuous ratings
- Extended service protection is available to provide extended coverage options

#### **Worldwide Product Support**

- Cat dealers have over 1,800 dealer branch stores operating in 200 countries
- Your local Cat dealer provides extensive post-sale support, including maintenance and repair agreements

#### Financing

- Caterpillar offers an array of financial products to help you succeed through financial service excellence
- Options include loans, finance lease, operating lease, working capital, and revolving line of credit
- Contact your local Cat dealer for availability in your region

LEHE1248-05 Page 1 of 4

## 3512C Diesel Generator Sets Electric Power



## Standard and Optional Equipment

Engine	Power Termination	Cat Connect
Air Cleaner  ■ Single element □ Dual element □ Heavy duty  Muffler □ Industrial grade (45 dP)	Type ☐ Bus bar ☐ Circuit breaker ☐ 1600A ☐ 2000A ☐ 2500A ☐ 3200A ☐ 3000A	Connectivity  Ethernet Collular  Extended Service Options  Terms
☐ Industrial grade (15 dB)  Starting ☐ Standard batteries ☐ Oversized batteries ☐ Standard electric starter(s) ☐ Dual electric starter(s) ☐ Air starter(s) ☐ Industry water bacter	☐ UL ☐ IEC ☐ 3-pole ☐ 4-pole ☐ Manually operated ☐ Electrically operated  Trip Unit ☐ LSI ☐ LSI-G ☐ LSIG-P	☐ 2 year (prime) ☐ 3 year ☐ 5 year ☐ 10 year  Coverage ☐ Silver
☐ Jacket water heater  Alternator  Output voltage  ☐ 380V ☐ 6600V  ☐ 440V ☐ 6900V  ☐ 480V ☐ 12470V  ☐ 600V ☐ 13200V  ☐ 4160V ☐ 13800V  ☐ 6300V  Temperature Rise (over 40°C ambient)  ☐ 150°C  ☐ 125°C/130°C  ☐ 105°C  ☐ 80°C	Control System  Controller  EMCP 4.2B  EMCP 4.3  EMCP 4.4  Attachments  Local annunciator module  Remote annunciator module  Expansion I/O module  Remote monitoring software  Charging  Battery charger – 10A  Battery charger – 20A	☐ Gold ☐ Platinum ☐ Platinum Plus  Ancillary Equipment ☐ Automatic transfer switch (ATS) ☐ Paralleling switchgear ☐ Paralleling controls  Certifications ☐ UL 2200 Listed ☐ CSA ☐ IBC seismic certification ☐ OSHPD pre-approval
Winding type  ☐ Random wound ☐ Form wound  Excitation ☐ Internal excitation (IE) ☐ Permanent magnet (PM)  Attachments ☐ Anti-condensation heater ☐ Stator and bearing temperature monitoring and protection	□ Battery charger – 35A  Vibration Isolators  □ Spring □ Seismic rated	

Note: Some options may not be available on all models. Certifications may not be available with all model configurations. Consult factory for availabilit.

## 3512C Diesel Generator Sets Electric Power



## Package Performance


Performance	Ste	indby	Missio	n Critical	i e	rime	Cont	inuous
Frequency	60	) Hz	60 Hz		60	O Hz	60	) Hz
Gen set power rating with fan	150	0 ekW	1500 ekW		1360 ekW		123	0 ekW
Gen set power rating with fan @ 0.8 power factor	187	5 kVA	187	5 kVA	1700 kVA		1537 kVA	
Emissions	1	tationary ncy (Tier 2)		tationary ncy (Tier 2)	EPA Stationary Emergency (Tier 2)		EPA Stationary Emergency (Tier 2	
Performance number	EM1	898-01	EM1	899-01	DM8	261-05	DM8	262-05
Fuel Consumption								
100% load with fan - L/hr (gal/hr)	383.3	(101.3)	383.3	(101.3)	352.5	(93.1)	326.2	(86.2)
75% load with fan – L/hr (gal/hr)	300.6	(79.4)	300.6	(79.4)	276.7	(73.1)	253.8	(67.1)
50% load with fan L/hr (gal/hr)	212.7	(56.2)	212.7	(56.2)	195.3	(51.6)	179.1	(47.3)
25% load with fan – L/hr (gal/hr)	124.3	(32.8)	124.3	(32.8)	115.9	(30.6)	108.1	(28.6)
Cooling System					<b>C</b> 4 1 1 1			
Radiator air flow restriction (system) – kPa (in. water)	0.12	(0.48)	0.12	(0.48)	0.12	(0.48)	0.12	(0.48)
Radiator air flow – m³/min (cfm)	2075	(73278)	2075	(73278)	2075	(73278)	2075	(73278)
Engine coolant capacity – L (gal)	156.8	(41.4)	156.8	(41.4)	156.8	(41.4)	156.8	(41.4)
Radiator coolant capacity – L (gal)	234.0	(61.0)	234.0	(61.0)	234.0	(61.0)	234.0	(61.0)
Total coolant capacity – L (gal)	390.8	(102.4)	390.8	(102.4)	390.8	(102.4)	390.8	(102.4)
Inlet Air								
Combustion air inlet flow rate – m³/min (cfm)	135.8	(4794.6)	135.8	(4794.6)	130.9	(4621.6)	125.8	(4441.3)
Exhaust System								
Exhaust stack gas temperature – °C (°F)	402.6	(756.6)	402.6	(756.6)	387.3	(729.2)	380.6	(717.1)
Exhaust gas flow rate – m³/min (cfm)	323.0	(11406.4)	323.0	(11406.4)	303.5	(10715.6)	288.2	(10176.5)
Exhaust system backpressure (maximum allowable – kPa (in. water)	6.7	(27.0)	6.7	(27.0)	6.7	(27.0)	6.7	(27.0)
Heat Rejection								
Heat rejection to jacket water - kW (Btu/min)	499	(28363)	499	(28363)	471	(26784)	447	(25402)
Heat rejection to exhaust (total) - kW (Btu/min)	1431	(81392)	1431	(81392)	1316	(74821)	1231	(69985)
Heat rejection to aftercooler – kW (Btu/min)	504	(28646)	504	(28646)	463	(26343)	425	(24173)
Heat rejection to atmosphere from engine – kW (Btu/min)	125	(7084)	125	(7084)	118	(6701)	113	(6439)
Heat rejection from alternator – kW (Btu/min)	74	(4208)	74	(4208)	64	(3645)	69	(3913)
Emissions* (Nominal)								
NOx mg/Nm³ (g/hp-h)	2303.5	(5.32)	2303.5	(5.32)	1961.1	(4.62)	1641.9	(3.93)
CO mg/Nm³ (g/hp-h)	230.3	(0.47)	230.3	(0.47)	207.3	(0.42)	189.9	(0.40)
HC mg/Nm³ (g/hp-h)	50.3	(0.12)	50.3	(0.12)	59.8	(0.14)	63.0	(0.15)
PM mg/Nm³ (g/hp-h)	12.6	(0.03)	12.6	(0.03)	13.5	(0.03)	14.9	(0.04)
Emissions* (Potential Site Variation)				542 - P				
NOx mg/Nm³ (g/hp-h)	2764.3	(6.38)	2764.3	(6.38)	2353.3	(5.54)	1970.3	(4.71)
CO mg/Nm³ (g/hp-h)	414.5	(0.84)	414.5	(0.84)	373.1	(0.76)	341.7	(0.71)
HC mg/Nm³ (g/hp-h)	66.9	(0.16)	66.9	(0.16)	79.6	(0.19)	83.8	(0.20)
PM mg/Nm³ (g/hp-h)	17.7	(0.04)	17.7	(0.04)	18.9	(0.05)	20.8	(0.05)
	L	<del></del>					L	


 $<sup>^*</sup> mg/Nm^3$  levels are corrected to 5%  $\rm O_2.$  Contact your local Cat dealer for further information.

LEHE1248-05 Page 3 of 4



#### Weights and Dimensions





Dim "A"	Dim "B"	Dim "C"	Dry Weight
mm (in)	mm (in)	mm (in)	kg (lb)
5920 (233.1)	2281 (89.8)	2794 (110.0)	13 970 (30,790)

Note: For reference only. Do not use for installation design. Contact your local Cat dealer for precise weights and dimensions.

#### **Ratings Definitions**

#### Standby

Output available with varying load for the duration of the interruption of the normal source power. Average power output is 70% of the standby rated ekW. Typical operation is 200 hours per year, with maximum expected usage of 500 hours per year.

#### Mission Critical

Output available with varying load for the duration of the interruption of the normal source power. Average power output is 85% of the mission critical rated ekW. Typical peak demand up to 100% of rated ekW for up to 5% of the operating time. Typical operation is 200 hours per year, with maximum expected usage of 500 hours per year.

#### Prime

Output available with varying load for an unlimited time. Average power output is 70% of the prime rated ekW. Typical peak demand is 100% of prime rated ekW with 10% overload capability for emergency use for a maximum of 1 hour in 12. Overload operation cannot exceed 25 hours per year.

#### Continuous

Output available with non-varying load for an unlimited time. Average power output is 70-100% of the continuous rated ekW. Typical peak demand is 100% of continuous rated ekW for 100% of the operating hours.

#### Applicable Codes and Standards

AS 1359, CSA C22.2 No. 100-04, UL 142, UL 489, UL 869, UL 2200, IBC, IEC 60034-1, ISO 3046, ISO 8528, NEMA MG1-22, NEMA MG1-33, 2014/35/EU, 2006/42/EC, 2014/30/EU and facilitates compliance to NFPA 37, NFPA 70, NFPA 99, NFPA 110.

**Note:** Codes may not be available in all model configurations. Please consult your local Cat dealer for availability.

#### **Data Center Applications**

- All ratings Tier III/Tier IV compliant per Uptime Institute requirements.
- All ratings ANSI/TIA-942 compliant for Rated-1 through Rated-4 data centers.

#### **Fuel Rates**

Fuel consumption reported in accordance with ISO 3046-1, based on fuel oil of 35° API [16°C (60°F)] gravity having an LHV of 42,780 kJ/kg (18,390 Btu/lb) when used at 15°C (59°F) and weighing 850 g/liter (7.0936 lbs/U.S. gal.) All fuel consumption values refer to rated engine power.

www.cat.com/electricpower
©2021 Caterpillar
All rights reserved.

Materials and specifications are subject to change without notice. The International System of Units (SI) is used in this publication.

## PERFORMANCE DATA [512DRC5]

MARCH 09, 2022

For Help Desk Phone Numbers Click here

Perf No: EM1899			Change Level:
General Heat Rejection S	ound Emissions Regulatory	Altitude Derate Cross Reference Supplementary D	ata Perf Param Ref
View PDF			
SALES MODEL:	3512C	COMBUSTION:	DIRECT INJECTION
BRAND:	CAT	ENGINE SPEED (RPM):	1,800
MACHINE SALES MODEL:	CAI	HERTZ:	60
ENGINE POWER (BHP):	2,206	FAN POWER (HP):	88.5
GEN POWER WITH FAN (EKW):	1,500.0	ASPIRATION:	TA
COMPRESSION RATIO:	14.7	AFTERCOOLER TYPE:	ATAAC
RATING LEVEL:	MISSION CRITICAL STANDBY	AFTERCOOLER CIRCUIT TYPE:	JW+OC, ATAAC
PUMP QUANTITY:	1	INLET MANIFOLD AIR TEMP (F):	122
FUEL TYPE:	DIESEL	JACKET WATER TEMP (F):	210.2
MANIFOLD TYPE:	DRY	TURBO CONFIGURATION:	PARALLEL
GOVERNOR TYPE:	ADEM3	TURBO QUANTITY:	4
ELECTRONICS TYPE:	ADEM3	TURBOCHARGER MODEL:	GTB4708BN-52T-0.9
CAMSHAFT TYPE:	STANDARD	CERTIFICATION YEAR:	2006
IGNITION TYPE:	CI	CRANKCASE BLOWBY RATE (FT3/HR):	2,203.4
INJECTOR TYPE:	EUI	FUEL RATE (RATED RPM) NO LOAD (GAL/HR):	9.8
FUEL INJECTOR:	3920220	PISTON SPD @ RATED ENG SPD (FT/MIN):	2,244.1
UNIT INJECTOR TIMING (IN):	64.34		
REF EXH STACK DIAMETER (IN):	10		
MAX OPERATING ALTITUDE (FT):	3,937		

## General Performance Data Top

#### Note(s)

INDUSTRY

OIL AND GAS

ELECTRIC POWER

THIS STANDBY RATING IS FOR A STANDBY ONLY ENGINE ARRANGEMENT. RERATING THE ENGINE TO A PRIME OR CONTINUOUS RATING IS NOT PERMITTED.

APPLICATION

PACKAGED GENSET

PACKAGED GENSET

SUB INDUSTRY

LAND PRODUCTION

STANDARD

	Carrier Co.				Appendix on the second				
GENSET POWER WITH FAN	PERCENT LOAD	ENGINE POWER		BRAKE SPEC FUEL CONSUMPTN (BSFC)	ISO BRAKE SPEC FUEL CONSUMPTN (BSFC)	VOL FUEL CONSUMPTN (VFC)	ISO VOL FUEL CONSUMPTN (VFC)	ELEC SPEC FUEL CONSUMPTN (ESFC)	ISO ELEC SPEC FUEL CONSUMPTN (ESFC)
EKW	%	ВНР	PSI	LB/BHP-HR	LB/BHP-HR	GAL/HR	GAL/HR	LB/EKW-HR	LB/EKW-HR
1,500.0	100	2,206	307	0.332	0.326	103.2	101.3	0.488	0.479
1,350.0	90	1,983	276	0.336	0.330	94.0	92.2	0.494	0.484
1,200.0	80	1,768	246	0.343	0.336	85.5	83.8	0.505	0.496
1,125.0	75	1,662	232	0.346	0.339	81.0	79.4	0.510	0.501
1,050.0	70	1,556	217	0.348	0.341	76.4	74.9	0.516	0.506
900.0	60	1,349	188	0.352	0.346	67.0	65.7	0.528	0.518
750.0	50	1,144	159	0.355	0.349	57.3	56.2	0.542	0.532
600.0	40	940	131	0.359	0.352	47.6	46.7	0.563	0.552
450.0	30	736	103	0.368	0.361	38.1	37.4	0.601	0.590
375.0	25	632	88	0.376	0.368	33.5	32.8	0.633	0.621
300.0	20	527	73	0.388	0.380	28.8	28.3	0.681	0.668
150.0	10	312	43	0.443	0.434	19.5	19.1	0.920	0.902

GENSET POW	ER PERCE	NT ENGINE	INLET	INLET	EXH	EXH	ENGÎNE	COMPRESS	OR COMPRESS	OR
WITH FAN	LOAD	POWER	MFLD PR	S MFLD TEMP	MFLD TEMP	MFLD PRES	OUTLET T	EMP OUTLET PR	ES OUTLET TE	4P
EKW	%	BHP	IN-HG	DEG F	DEG F	IN-HG	DEG F	IN-HG	DEG F	

GENSET POWER WITH FAN	PERCENT LOAD	ENGINE POWER	INLET MFLD PRES	INLET MFLD TEMP	EXH MFLD TEMP	EXH MFLD PRES	ENGINE OUTLET TEMP	COMPRESSOR OUTLET PRES	COMPRESSOR OUTLET TEMP
1,500.0	100	2,206	77.5	120.9	1,145.6	74.6	756.6	82	449.8
1,350.0	90	1,983	72.2	116.1	1,102.7	€8.8	727.5	77	428.8
1,200.0	80	1,768	66.9	113.2	1,069.1	63.0	713.4	71	409.0
1,125.0	75	1,662	63.4	111.5	1,052.3	59.5	706.7	68	396.6
1,050.0	70,	1,556	59.7	109.8	1,035.2	55.8	700.0	64	382.6
900.0	60	1,349	51.1	107.1	1,000.5	47.6	687.3	55	350.3
750.0	50	1,144	40.6	107.5	963.6	38.4	696.7	44	309.9
600.0	40	940	30.0	108.4	921.9	29.4	702.2	33	266.6
450.0	30	736	20.9	107.1	856.0	21.9	685.3	23	224.6
375.0	25	632	16.9	106.2	809.5	18.8	664.9	19	204.3
300.0	20	527	13.3	105.2	754.5	16.0	636.4	15	184.2
150.0	10	312	7.3	103.2	609.7	11.4	540.6	9	148.8

GENSET POWER WITH FAN	PERCENT LOAD	ENGINE POWER	WET INLET AIR VOL FLOW RATE	ENGINE OUTLET WET EXH GAS VOL FLOW RATE	WET INLET AIR MASS FLOW RATE	WET EXH GAS MASS FLOW RATE	WET EXH VOL FLOW RATE (32 DEG F AND 29.98 IN HG)	DRY EXH VOL FLOW RATE (32 DEG F AND 29.98 IN HG)
EKW	%	ВНР	CFM	CFM	LB/HR	LB/HR	FT3/MIN	FT3/MIN
1,500.0	100	2,206	4,794.6	11,406.4	21,167.1	21,899.0	4,610.8	4,188.7
1,350.0	90	1,983	4,598.6	10,640.5	20,285.8	20,952.1	4,406.6	4,013.7
1,200.0	80	1,768	4,378.0	9,981.4	19,285.7	19,892.1	4,183.4	3,822.5
1,125.0	75	1,662	4,246.6	9,595.7	18,674.6	19,249.2	4,045.1	3,700.9
1,050.0	70	1,556	4,098.2	9,181.5	17,984.1	18,526.3	3,892.6	3,565.4
900.0	60	1,349	3,753.0	8,273.8	16,379.2	16,854.4	3,546.8	3,254.6
750.0	50	1,144	3,280.4	7,230.6	14,251.7	14,658.2	3,074.4	2,822.7
600.0	40	940	2,787.5	6,155.4	12,057.0	12,394.7	2,604.7	2,394.2
450.0	30	736	2,363.4	5,134.0	10,186.4	10,456.9	2,204.7	2,032.9
375.0	25	632	2,179.8	4,645.2	9,382.2	9,619.6	2,030.9	1,877.5
300.0	20	527	2,011.4	4,165.1	8,648.1	8,852.3	1,868.3	1,733.0
150.0	10	312	1,730.9	3,244.5	7,428.8	7,566.8	1,594.8	1,494.1

## Heat Rejection Data Top

GENSET POWER WITH FAN	PERCENT LOAD	ENGINE POWER	REJECTION TO JACKET WATER	REJECTION TO ATMOSPHERE	REJECTION TO EXH	EXHAUST RECOVERY TO 350F	FROM OIL COOLER	FROM AFTERCOOLER	WORK ENERGY	LOW HEAT VALUE ENERGY	HIGH HEAT VALUE ENERGY
EKW	%	BHP	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN
1,500.0	100	2,206	28,363	7,084	81,392	37,320	11,956	28,646	93,547	224,476	239,123
1,350.0	90	1,983	26,596	6,665	74,128	33,028	10,882	26,053	84,110	204,315	217,647
1,200.0	80	1,768	24,935	6,360	68,257	30,111	9,897	23,350	74,958	185,825	197,950
1,125.0	75	1,662	24,035	6,215	64,979	28,563	9,376	21,735	70,466	176,039	187,526
1,050.0	70	1,556	23,095	6,074	61,624	26,950	8,845	20,016	66,004	166,069	176,905
900.0	60	1,349	21,108	5,797	54,723	23,576	7,759	16,292	57,205	145,683	155,189
750.0	50	1,144	18,963	5,518	47,678	21,085	6,636	11,959	48,509	124,586	132,716
600.0	40	940	16,710	5,240	40,505	18,108	5,512	7,849	39,882	103,489	110,241
450.0	30	736	14,361	4,818	33,056	14,499	4,416	4,829	31,201	82,917	88,327
375.0	25	632	13,131	4,577	29,249	12,494	3,876	3,681	26,809	72,772	77,520
300.0	20	527	11,848	4,331	25,396	10,418	3,336	2,726	22,353	62,628	66,715
150.0	10	312	9,052	3,821	17,619	5,853	2,253	1,342	13,214	42,301	45,061

## Sound Data Top

Note(s)
SOUND PRESSURE DATA FOR THIS RATING CAN BE FOUND IN PERFORMANCE NUMBER - DM8779.

#### DIESEL

#### RATED SPEED NOMINAL DATA: 1800 RPM

GENSET POWER WITH FAN ENGINE POWER		EKW BHP	1,500.0 2,206	1,125.0 1,662	750.0 1,144	375.0 632	150.0 312
PERCENT LOAD		%	100	75	50	25	10
TOTAL NOX (AS NO2)	Table 18 St. Section (1972) Fig. Fresh, Television (1974)	G/HR	11,615	5,877	3,912	2,972	2,290
TOTAL CO		G/HR	1,019	634	898	1,060	1,024
TOTAL HC		G/HR	257	278	262	207	241
TOTAL CO2		KG/HR	1,063	828	584	342	198
PART MATTER		G/HR	67.7	68.8	104.8	127.8	77.9
TOTAL NOX (AS NO2)	(CORR 5% O2)	MG/NM3	2,303.5	1,458.7	1,352.5	1,792.1	2,400.6
TOTAL CO	(CORR 5% O2)	MG/NM3	230.3	181.4	384.5	802.1	1,284.5
TOTAL HC	(CORR 5% O2)	MG/NM3	50.3	69.9	90.2	128.2	263.2
PART MATTER	(CORR 5% O2)	MG/NM3	12.6	16.3	37.9	76.2	80.1
TOTAL NOX (AS NO2)	(CORR 15% O2)	MG/NM3	854.8	541.3	501.9	665.0	890.8
TOTAL CO	(CORR 15% O2)	MG/NM3	85.5	67.3	142.7	297.6	476.6
TOTAL HC	(CORR 15% O2)	MG/NM3	18.7	25.9	33.5	47.6	97.7
PART MATTER	(CORR 15% O2)	MG/NM3	4.7	6.0	14.1	28.3	29.7
TOTAL NOX (AS NO2)	(CORR 5% O2)	PPM	1,122	711	659	873	1,169
TOTAL CO	(CORR 5% O2)	PPM	184	145	308	642	1,028
TOTAL HC	(CORR 5% O2)	PPM	94	130	168	239	491
TOTAL NOX (AS NO2)	(CORR 15% O2)	PPM	416	264	244	324	434
TOTAL CO	(CORR 15% O2)	PPM	68	54	114	238	381
TOTAL HC	(CORR 15% O2)	PPM	35	48	62	89	182
TOTAL NOX (AS NO2)		G/HP-HR	5.32	3.57	3.45	4.73	7.39
TOTAL CO		G/HP-HR	0.47	0.39	0.79	1.69	3.30
TOTAL HC		G/HP-HR	0.12	0.17	0.23	0.33	0.78
PART MATTER		G/HP-HR	0.03	0.04	0.09	0.20	0.25
TOTAL NOX (AS NO2)		G/KW-HR .	7.23	4.85	4.69	6.43	10.05
TOTAL CO		G/KW-HR	0.63	0.52	1.08	2.29	4.49
TOTAL HC	to the other lands of the	G/KW-HR	0.16	0.23	0.31	0.45	1.06
PART MATTER		G/KW-HR	0.04	0.06	0.13	0.28	0.34
TOTAL NOX (AS NO2)		LB/HR	25.61	12.96	8.62	6.55	5.05
TOTAL CO		LB/HR	2.25	1.40	1.98	2.34	2,26
TOTAL HC		LB/HR	0.57	0.61	0.58	0.46	0.53
TOTAL CO2		LB/HR	2,344	1,825	1,289	753	436
PART MATTER		LB/HR	0.15	0.15	0.23	0.28	0.17
OXYGEN IN EXH		%	10.9	12.0	12.7	13.7	15.7
DRY SMOKE OPACITY		%	1.0	1.3	2.9	5.0	3.0
BOSCH SMOKE NUMBER			0.77	0.79	1.02	1.30	1.04
from the print and continuous and a second control of the control of the control of the con-							

#### RATED SPEED POTENTIAL SITE VARIATION: 1800 RPM

GENSET POWER WITH FAN ENGINE POWER		EKW BHP	1,500.0 2,206	1,125.0 1,662	750.0 1,144	375.0 632	150.0 312
PERCENT LOAD		%	100	75	50	25	10
TOTAL NOX (AS NO2)	Congression of Assert Company of the	G/HR	13,938	7,053	4,695	3,567	2,748
TOTAL CO		G/HR	1,834	1,142	1,617	1,908	1,843
TOTAL HC		G/HR	341	370	348	276	320
PART MATTER		G/HR	94.8	96.4	146.7	178.9	109.0
TOTAL NOX (AS NO2)	(CORR 5% O2)	MG/NM3	2,764.3	1,750.5	1,623.0	2,150.5	2,880.8
TOTAL CO	(CORR 5% O2)	MG/NM3	414.5	326.5	692.0	1,443.8	2,312.1
TOTAL HC	(CORR 5% O2)	MG/NM3	66.9	93.0	119.9	170.5	350.1
PART MATTER	(CORR 5% O2)	MG/NM3	17.7	22.8	53.1	106.7	112.2
TOTAL NOX (AS NO2)	(CORR 15% O2)	MG/NM3	1,025.7	649.6	602.2	798.0	1,069.0
TOTAL CO	(CORR 15% O2)	MG/NM3	153.8	121.2	256.8	535.8	857.9
TOTAL HC	(CORR 15% O2)	MG/NM3	24.8	34.5	44.5	63.3	129.9
PART MATTER	(CORR 15% O2)	MG/NM3	6.6	8.5	19.7	39.6	41.6
TOTAL NOX (AS NO2)	(CORR 5% O2)	PPM	1,346	853	791	1,047	1,403
TOTAL CO	(CORR 5% O2)	PPM	332	261	554	1,155	1,850
TOTAL HC	(CORR 5% O2)	PPM	125	174	224	318	654
TOTAL NOX (AS NO2)	(CORR 15% O2)	PPM	500	316	293	389	521
TOTAL CO	(CORR 15% O2)	PPM	123	97	205	429	686
TOTAL HC	(CORR 15% O2)	PPM	46	64	83	118	243
TOTAL NOX (AS NO2)		G/HP-HR	6.38	4.28	4.14	5.68	8.87
TOTAL CO		G/HP-HR	0.84	0.69	1.42	3.04	5.95
TOTAL HC		G/HP-HR	0.16	0.22	0.31	0.44	1.03
PART MATTER		G/HP-HR	0.04	0.06	0.13	0.28	0.35
TOTAL NOX (AS NO2)		G/KW-HR	8.68	5.83	5.62	7.72	12.06
TOTAL CO		G/KW-HR	1.14	0.94	1.94	4.13	8.09
TOTAL HC		G/KW-HR	0.21	0.31	0.42	0.60	1.40
PART MATTER		G/KW-HR	0.06	0.08	0.18	0.39	0.48
TOTAL NOX (AS NO2)		LB/HR	30.73	15.55	10.35	7.86	6.06
TOTAL CO		LB/HR	4.04	2.52	3.56	4.21	4.06
TOTAL HC		LB/HR	0.75	0.82	0.77	0.61	0.71
PART MATTER		LB/HR	0.21	0.21	0.32	0.39	0.24

## Regulatory Information Top

EPA EMERGENCY STATIONARY

2011 - ----

GASEOUS EMISSIONS DATA MEASUREMENTS PROVIDED TO THE EPA ARE CONSISTENT WITH THOSE DESCRIBED IN EPA 40 CFR PART 60 SUBPART HILL AND ISO 8178 FOR MEASURING HC, CO, PM, AND NOX. THE "MAX LIMITS" SHOWN BELOW ARE WEIGHTED CYCLE AVERAGES AND ARE IN COMPLIANCE WITH THE EMERGENCY STATIONARY REGULATIONS.

Locality
U.S. (INCL CALIF)

Agency EPA Regulation STATIONARY Tier/Stage EMERGENCY STATIONARY Max Limits - G/BKW - HR CO: 3.5 NOx + HC: 6.4 PM: 0.20

### Altitude Derate Data Top

#### **STANDARD**

ALTITUDE CORRECTED POWER CAPABILITY (BHP)

AMBIENT OPERATING TEMP (F)	30	40	50	60	70	80	90	100	110	120	130	140	NORMAL
ALTITUDE (FT)													
0 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	2,206	2,206	2,206	2,206	2,206	2,206	2,206	2,206	2,206	2,206	2,206	2,096	2,206
1,000	2,206	2,206	2,206	2,206	2,206	2,206	2,206	2,206	2,206	2,206	2,162	2,074	2,206
2,000	2,206	2,206	2,206	2,206	2,206	2,206	2,206	2,206	2,206	2,176	2,118	2,007	2,206
3,000	2,206	2,206	2,206	2,206	2,206	2,206	2,206	2,173	2,135	2,098	2,052	1,919	2,206
4,000	2,201	2,201	2,201	2,201	2,201	2,171	2,132	2,094	2,057	2,021	1,963	1,831	2,201
5,000	2,129	2,129	2,129	2,129	2,129	2,092	2,054	2,017	1,982	1,947	1,875	1,743	2,129
5,000	2,059	2,059	2,059	2,059	2,053	2,015	1,978	1,943	1,909	1,876	1,765	1,677	2,059
7,000	1,992	1,992	1,992	1,992	1,976	1,940	1,904	1,870	1,838	1,787	1,677	1,588	1,992
8,000	1,927	1,927	1,927	1,927	1,902	1,867	1,833	1,800	1,769	1,699	1,610	1,522	1,927
9,000	1,865	1,865	1,865	1,865	1,831	1,797	1,764	1,733	1,699	1,610	1,522	1,412	1,865
10,000	1,805	1,805	1,805	1,795	1,761	1,729	1,697	1,667	1,610	1,522	1,368	1,279	1,805
11,000	1,522	1,522	1,522	1,522	1,522	1,522	1,522	1,522	1,434	1,324	1,213	1,125	1,522
12,000	1,478	1,478	1,478	1,478	1,478	1,478	1,478	1,390	1,279	1,169	1,081	993	1,478
13,000	1,434	1,434	1,434	1,434	1,434	1,434	1,346	1,235	1,147	1,037	971	882	1,434
14,000	1,390	1,390	1,390	1,390	1,390	1,279	1,191	1,103	1,015	927	860	794	1,390
15,000	1,346	1,346	1,346	1,346	1,235	1,147	1,059	971	882	816	772	728	1,346

#### Cross Reference Top

Test Spec Setting	Engine Arrangement	Engineering Model	Enginee   Model   Version	ering Start Effective End Effective Serial Serial 1 Number Number	
4577180 LL1862	5084278	GS656	LS	CT200463	
4577180 LL1862	5157729	PG242	. 1815. <del>-</del> 11. 51	LYH00001	

## Supplementary Data Top

Type	Classification	Performance Number
SOUND	SOUND PRESSURE	DM8779

#### Performance Parameter Reference Top

Parameters Reference: DM9600 - 14
PERFORMANCE DEFINITIONS

#### PERFORMANCE DEFINITIONS DM9600

APPLICATION: Engine performance tolerance values below are representative of a typical production engine tested in a

#### MAX Performance Data Display

calibrated dynamometer test cell at SAE 11995 standard reference conditions. Caterpillar maintains ISO9001:2000 certified quality management systems for engine test Facilities to assure accurate calibration of test equipment. Engine test data is corrected in accordance with SAE J1995. Additional reference material SAE J1228, J1349, ISO 8665, 3046-1:2002E, 3046-3:1989, 1585, 2534, 2288, and 9249 may apply in part or are similar to SAE J1995. Special engine rating request (SERR) test data shall be noted.

PERFORMANCE PARAMETER TOLERANCE FACTORS: Power +/- 3% Torque +/- 3% Exhaust stack temperature +/- 8% Inlet airflow +/- 5% Intake manifold pressure-gage +/- 10% Exhaust flow +/- 6% Specific fuel consumption +/- 3% Fuel rate +/- 5% Specific DEF consumption +/- 3% DEF rate +/- 5% Heat rejection +/- 5% Heat rejection exhaust only +/- 10% Heat rejection

Heat Rejection values based on using treated water.

Torque is included for truck and industrial applications, do not use for Gen Set or steady state applications. On C7 - C18 engines, at speeds of 1100 RPM and under these values are provided for reference only, and may not meet the tolerance listed.

On 3500 and C175 engines, at speeds below Peak Torque these values are provided for reference only, and may not meet the tolerance listed.

These values do not apply to C280/3600. For these models, see the tolerances listed below.

C280/3600 HEAT REJECTION TOLERANCE FACTORS: Heat rejection +/- 10% Heat rejection to Atmosphere +/- 50% Heat rejection to Lube Oil +/- 20% Heat rejection to Aftercooler +/- 5%

TEST CELL TRANSDUCER TOLERANCE FACTORS: Torque +/- 0.5% Speed +/- 0.2% Fuel flow +/- 1.0% Temperature +/- 2.0 C degrees Intake manifold pressure +/- 0.1 kPa
OBSERVED ENGINE PERFORMANCE IS CORRECTED TO SAE J1995 REFERENCE AIR AND FUEL CONDITIONS.

REFERENCE ATMOSPHERIC INLET AIR FOR 3500 ENGINES AND SMALLER SAE J1228 AUG2002 for marine engines, and J1995 JAN2014 for other engines, reference atmospheric pressure is 100 KPA (29.61 in hg), and standard temperature is 25deg C (77 deg F) at 30% relative humidity at the stated aftercooler water temp, or inlet manifold temp. FOR 3600 ENGINES Engine rating obtained and presented in accordance with ISO 3046/1 and SAE J1995 JANJAN2014 reference atmospheric pressure is 100 KPA (29.61 in hg), and standard temperature is 25deg C (77 deg F) at 30% relative humidity and 150M altitude at the stated aftercooler water temperature.

MEASUREMENT LOCATION FOR INLET AIR TEMPERATURE Location for air temperature measurement air cleaner inlet at stabilized operating conditions.

REFERENCE EXHAUST STACK DIAMETER The Reference Exhaust Stack Diameter published with this dataset is only used for the calculation of Smoke Opacity values displayed in this dataset. This value does not necessarily represent the actual stack diameter of the engine due to the variety of exhaust stack adapter options available. Consult the price list, engine order or general dimension drawings for the actual stack diameter size ordered or options available.

**REFERENCE FUEL** <u>DIESEL</u> Reference fuel is #2 distillate diesel with a 35API gravity; A lower heating value is 42,780 KJ/KG (18,390 BTU/LB) when used at 15 deg C (59 deg F), where the density is 850 G/Liter (7.0936 Lbs/Gal). <u>GAS</u> Reference natural gas fuel has a lower heating value of 33.74 KJ/L (905 BTU/CU Ft). Low BTU ratings are based on 18.64 KJ/L (500 BTU/CU FT) lower heating value gas. Propane ratings are based on 87.56 KJ/L (2350 BTU/CU Ft) lower heating value

ENGINE POWER (NET) IS THE CORRECTED FLYWHEEL POWER (GROSS) LESS EXTERNAL AUXILIARY LOAD Engine corrected gross output includes the power required to drive standard equipment; lube oil, scavenge lube oil, fuel transfer, common rail fuel, separate circuit aftercooler and jacket water pumps. Engine net power available for the external (flywheel) load is calculated by subtracting the sum of auxiliary load from the corrected gross flywheel out put power. Typical auxiliary loads are radiator cooling fans, hydraulic pumps, air compressors and battery charging alternators. For Tier 4 ratings additional Parasitic losses would also include Intake, and Exhaust Restrictions.

**ALTITUDE CAPABILITY** Altitude capability is the maximum altitude above sea level at standard temperature and standard pressure at which the engine could develop full rated output power on the current performance data set. Standard temperature values versus altitude could be seen on TM2001.

When viewing the altitude capability chart the ambient temperature is the inlet air temp at the compressor inlet. Engines with ADEM MEUI and HEUI fuel systems operating at conditions above the defined altitude capability derate for atmospheric pressure and temperature conditions outside the values defined, see TM2001.

Mechanical governor controlled unit injector engines require a setting change for operation at conditions above the altitude defined on the engine performance sheet. See your Caterpillar technical representative for non standard ratings.

REGULATIONS AND PRODUCT COMPLIANCE TMI Emissions information is presented at 'nominal' and 'Potential Site Variation' values for standard ratings. No tolerances are applied to the emissions data. These values are subject to change at any time. The controlling federal and local emission requirements need to be verified by your Caterpillar technical representative. Customer's may have special emission site requirements that need to be verified by the Caterpillar Product Group engineer.

EMISSION CYCLE LIMITS: Cycle emissions Max Limits apply to cycle-weighted averages only. Emissions at individual load points may exceed the cycle-weighted limit.

WET & DRY EXHAUST/EMISSIONS DESCRIPTION: Wet - Total exhaust flow or concentration of total exhaust flow Dry - Total exhaust flow minus water vapor or concentration of exhaust flow with water vapor excluded

EMISSIONS DEFINITIONS: Emissions: DM1176

#### EMISSION CYCLE DEFINITIONS

- 1. For constant-speed marine engines for ship main propulsion, including, diesel-electric drive, test cycle E2 shall be applied, for controllable-pitch propeller sets test cycle E2 shall be applied.
- 2. For propeller-law-operated main and propeller-law-operated auxiliary engines the test cycle E3 shall be applied.
- 3. For constant-speed auxiliary engines test cycle D2 shall be applied.
- 4. For variable-speed, variable-load auxiliary engines, not included above, test cycle C1 shall be applied.

HEAT REJECTION DEFINITIONS: Diesel Circuit Type and HHV Balance: DM9500

HIGH DISPLACEMENT (HD) DEFINITIONS: 3500: EM1500

RATING DEFINITIONS: Agriculture: TM6008

Fire Pump: TM6009 Generator Set: TM6035 Generator (Gas) : TM6041 Industrial Diesel: TM6010 Industrial (Gas) : TM6040 Irrigation : TM5749 Locomotive: TM6037

Marine Auxiliary: TM6036 Marine Prop (Except 3600): FM5747 Marine Prop (3600 only): TM5748 MSHA: TM6042 Oil Field (Petroleum): TM6011 Off-Highway Truck: TM6039 On-Highway Truck: TM6038

SOUND DEFINITIONS: Sound Power: DM8702 Sound Pressure: TM7080

Date Released : 10/27/21

**Systems Data**Reference Number: EM1899

## CATERPILLAR

March 09, 2022 For Help Desk Phone Numbers <u>Click Here</u>

THE INSTALLED SYSTEM MUST COMPLY WITH THE SYSTEM LIMITS BELOW FOR ALL E TO ASSURE REGULATORY COMPLIANCE.	MISSIONS CERTII	FIED ENGINE
MAXIMUM ALLOWABLE INTAKE RESTRICTION WITH CLEAN ELEMENT	15	IN-H20
MAXIMUM ALLOWABLE INTAKE RESTRICTION WITH DIRTY ELEMENT	25	IN-H20
MAXIMUM PRESSURE DROP FROM COMPRESSOR OUTLET TO MANIFOLD INLET (OR MIXER INLET FOR EGR)	4.4	IN-HG
CHARGE AIR FLOW AT RATED SPEED	337.7	LB/MIN
TURBO COMPRESSOR OUTLET TEMPERATURE AT RATED SPEED	451	DEG F
MAXIMUM ALLOWABLE STATIC WEIGHT ON AIR INLET	59.5	LB
MAXIMUM ALLOWABLE STATIC WEIGHT ON AIR INLET (AIR SHUT OFF INCLUDED)	17.6	LB
MAXIMUM ALLOWABLE STATIC BENDING MOMENT ON AIR INLET	9.6	LB-FT
MAXIMUM ALLOWABLE STATIC WEIGHT ON TURBO OUTLET CONNECTION	0	LB
MAXIMUM ALLOWABLE STATIC BENDING MOMENT ON TURBO OUTLET CONNECTION	0	LB-FT
COOLING SYSTEM		
ENGINE ONLY COOLANT CAPACITY	41.4	GAL
MAXIMUM ALLOWABLE JACKET WATER OUTLET TEMPERATURE	210	DEG F
DECULATOR LOCATION FOR THE CUTT		~ <del>-</del>
REGULATOR LOCATION FOR JW (HT) CIRCUIT	OUTLET	747
	OUTLET 5.0	G/MIN
REGULATOR LOCATION FOR JW (HT) CIRCUIT MAXIMUM UNINTERRUPTED FILL RATE ENGINE SPEC SYSTEM	5.0	G/MIN
MAXIMUM UNINTERRUPTED FILL RATE  ENGINE SPEC SYSTEM  CYLINDER ARRANGEMENT	5.0 VEE	G/MIN
MAXIMUM UNINTERRUPTED FILL RATE  ENGINE SPEC SYSTEM  CYLINDER ARRANGEMENT  NUMBER OF CYLINDERS	5.0 VEE 12	
MAXIMUM UNINTERRUPTED FILL RATE  ENGINE SPEC SYSTEM  CYLINDER ARRANGEMENT  NUMBER OF CYLINDERS  CYLINDER BORE DIAMETER	VEE 12 6.7	IN
MAXIMUM UNINTERRUPTED FILL RATE  ENGINE SPEC SYSTEM  CYLINDER ARRANGEMENT  NUMBER OF CYLINDERS  CYLINDER BORE DIAMETER  PISTON STROKE	5.0 VEE 12 6.7 7.5	IN IN
MAXIMUM UNINTERRUPTED FILL RATE  ENGINE SPEC SYSTEM  CYLINDER ARRANGEMENT  NUMBER OF CYLINDERS  CYLINDER BORE DIAMETER  PISTON STROKE  TOTAL CYLINDER DISPLACEMENT	5.0 VEE 12 6.7 7.5 3161	IN
MAXIMUM UNINTERRUPTED FILL RATE  ENGINE SPEC SYSTEM  CYLINDER ARRANGEMENT  NUMBER OF CYLINDERS  CYLINDER BORE DIAMETER  PISTON STROKE	5.0 VEE 12 6.7 7.5	IN IN
MAXIMUM UNINTERRUPTED FILL RATE  ENGINE SPEC SYSTEM  CYLINDER ARRANGEMENT  NUMBER OF CYLINDERS  CYLINDER BORE DIAMETER  PISTON STROKE  TOTAL CYLINDER DISPLACEMENT  STANDARD CRANKSHAFT ROTATION FROM FLYWHEEL END  STANDARD CYLINDER FIRING ORDER	5.0 VEE 12 6.7 7.5 3161 CCW 1-12-9-4-5- 8-11-2-3-	IN IN
MAXIMUM UNINTERRUPTED FILL RATE  ENGINE SPEC SYSTEM  CYLINDER ARRANGEMENT  NUMBER OF CYLINDERS  CYLINDER BORE DIAMETER  PISTON STROKE  TOTAL CYLINDER DISPLACEMENT  STANDARD CRANKSHAFT ROTATION FROM FLYWHEEL END	5.0 VEE 12 6.7 7.5 3161 CCW 1-12-9-4-5- 8-11-2-3- 10-7-6 RIGHT	IN IN
MAXIMUM UNINTERRUPTED FILL RATE  ENGINE SPEC SYSTEM  CYLINDER ARRANGEMENT NUMBER OF CYLINDERS CYLINDER BORE DIAMETER PISTON STROKE TOTAL CYLINDER DISPLACEMENT STANDARD CRANKSHAFT ROTATION FROM FLYWHEEL END  STANDARD CYLINDER FIRING ORDER  NUMBER 1 CYLINDER LOCATION	5.0 VEE 12 6.7 7.5 3161 CCW 1-12-9-4-5- 8-11-2-3- 10-7-6 RIGHT FRONT	IN IN
MAXIMUM UNINTERRUPTED FILL RATE  ENGINE SPEC SYSTEM  CYLINDER ARRANGEMENT NUMBER OF CYLINDERS CYLINDER BORE DIAMETER PISTON STROKE TOTAL CYLINDER DISPLACEMENT STANDARD CRANKSHAFT ROTATION FROM FLYWHEEL END  STANDARD CYLINDER FIRING ORDER  NUMBER 1 CYLINDER LOCATION STROKES/COMBUSTION CYCLE	5.0  VEE  12  6.7  7.5  3161  CCW  1-12-9-4-5- 8-11-2-3- 10-7-6  RIGHT FRONT  4	IN IN CU IN
MAXIMUM UNINTERRUPTED FILL RATE  ENGINE SPEC SYSTEM  CYLINDER ARRANGEMENT  NUMBER OF CYLINDERS  CYLINDER BORE DIAMETER  PISTON STROKE  TOTAL CYLINDER DISPLACEMENT  STANDARD CRANKSHAFT ROTATION FROM FLYWHEEL END  STANDARD CYLINDER FIRING ORDER  NUMBER 1 CYLINDER LOCATION  STROKES/COMBUSTION CYCLE  EXHAUST SYSTEM  THE INSTALLED SYSTEM MUST COMPLY WITH THE SYSTEM LIMITS BELOW FOR ALL E	5.0  VEE  12  6.7  7.5  3161  CCW  1-12-9-4-5- 8-11-2-3- 10-7-6  RIGHT FRONT  4	IN IN CU IN
MAXIMUM UNINTERRUPTED FILL RATE  ENGINE SPEC SYSTEM  CYLINDER ARRANGEMENT  NUMBER OF CYLINDERS  CYLINDER BORE DIAMETER  PISTON STROKE  TOTAL CYLINDER DISPLACEMENT  STANDARD CRANKSHAFT ROTATION FROM FLYWHEEL END  STANDARD CYLINDER FIRING ORDER  NUMBER 1 CYLINDER LOCATION  STROKES/COMBUSTION CYCLE  EXHAUST SYSTEM  THE INSTALLED SYSTEM MUST COMPLY WITH THE SYSTEM LIMITS BELOW FOR ALL E TO ASSURE REGULATORY COMPLIANCE.	5.0   VEE	IN IN CU IN
MAXIMUM UNINTERRUPTED FILL RATE  ENGINE SPEC SYSTEM  CYLINDER ARRANGEMENT  NUMBER OF CYLINDERS  CYLINDER BORE DIAMETER  PISTON STROKE  TOTAL CYLINDER DISPLACEMENT  STANDARD CRANKSHAFT ROTATION FROM FLYWHEEL END  STANDARD CYLINDER FIRING ORDER  NUMBER 1 CYLINDER LOCATION  STROKES/COMBUSTION CYCLE  EXHAUST SYSTEM  THE INSTALLED SYSTEM MUST COMPLY WITH THE SYSTEM LIMITS BELOW FOR ALL E TO ASSURE REGULATORY COMPLIANCE.  MAXIMUM ALLOWABLE SYSTEM BACK PRESSURE	5.0   VEE   12   6.7   7.5   3161   CCW   1-12-9-4-5-   8-11-2-3-   10-7-6   RIGHT   FRONT   4   MISSIONS CERTIN	IN IN CU IN

FUEL SYSTEM		
MAXIMUM FUEL FLOW FROM TRANSFER PUMP TO ENGINE	332.9	G/HR
MAXIMUM ALLOWABLE FUEL SUPPLY LINE RESTRICTION	8.9	IN-HG
MAXIMUM ALLOWABLE FUEL TEMPERATURE AT TRANSFER PUMP INLET	151	DEG F
MAXIMUM FUEL FLOW TO RETURN LINE FROM ENGINE	322.3	G/HR
MAXIMUM ALLOWABLE FUEL RETURN LINE RESTRICTION	8.0	IN-HG
NORMAL FUEL PRESSURE IN A CLEAN SYSTEM	60.2	PSI
FUEL SYSTEM TYPE	EUI	
MAXIMUM TRANSFER PUMP PRIMING LIFT WITHOUT PRIMING PUMP	12.1	FT
MAXIMUM HEAT REJECTION TO FUEL	540	BTU/MIN
LUBE SYSTEM		
CRANKCASE VENTILATION TYPE	TO ATM	
MOUNTING SYSTEM		
CENTER OF GRAVITY LOCATION - X DIMENSION - FROM REAR FACE OF BLOCK - (REFERENCE TM7077)	37.4	IN
CENTER OF GRAVITY LOCATION - Y DIMENSION - FROM CENTERLINE OF CRANKSHAFT - (REFERENCE TM7077)	9.8	IN
CENTER OF GRAVITY LOCATION - Z DIMENSION - FROM CENTERLINE OF CRANKSHAFT - (REFERENCE TM7077)	0.0	IN
MASS MOMENT OF INERTIA - X AXIS	8851	LB IN SEC2
MASS MOMENT OF INERTIA - Y AXIS	61955	LB IN SEC2
MASS MOMENT OF INERTIA - Z AXIS	61955	LB IN SEC2
STARTING SYSTEM		
MINIMUM CRANKING SPEED REQUIRED FOR START	120	RPM


Razor5 LLC - Application for New Source Minor PSD Construction Approval and Title V Operating Permit

CATERPILLER C18 750 KW GENERATOR

## Cat® C18 DIESEL GENERATOR SETS



#### Standby & Prime: 60Hz



Engine Model	Cat® C18 AFAAC™ In-line 6, 4-cycle diesel
Bore x Stroke	145mm x 183mm (5.7in x 7.2in)
Displacement	13.13 L (1106.3 in³)
Compression Ratio	14:1
Aspiration	Turbocharged Air-to-Air Aftercooled
Fuel Injection System	Electronic Unit Injection
Governor	Electronic ADEM™ A4

Model	Standby	Prime	Emission Strategy
C18	750 ekW, 938 kVA	680 ekW, 850 kVA	EPA TIER II

#### PACKAGE PERFORMANCE

Performance	Standby	Prime
Frequency	60	Hz
Genset Power Rating	938 kVA	850 kVA
Genset power rating with fan @ 0.8 power factor	750 ekW	680 ekW
Emissions	EPA T	TER II
Performance Number	EM3842	EM3843
Fuel Consumption		
100% load with fan, L/hr (gal/hr)	205.5 (54.2)	188.5 (49.7)
75% load with fan, L/hr (gal/hr)	164.3 (43.4)	146.3 (38.6)
50% load with fan, L/hr (gal/hr)	108.9 (28.7)	100.3 (26.5)
25% load with fan, L/hr (gal/hr)	63.5 (16.7)	59.4 (15.6)
Cooling System <sup>1</sup>	16-71-16-16-16-16-16-16-16-16-16-16-16-16-16	
Radiator air flow restriction (system), kPa (in. Water)	0.12 (0.48)	0.12 (0.48)
Radiator air flow, m³/min (cfm)	900 (31783)	900 (31783)
Engine coolant capacity, L (gal)	20.8 (5.5)	20.8 (5.5)
Radiator coolant capacity, L (gal)	77 (20.3)	77 (20.3)
Total coolant capacity, L (gal)	97.8 (25.8)	97.8 (25.8)
Inlet Air		
Combustion air inlet flow rate, m³/min (cfm)	67.3 (2376)	65.6 (2316)
Max. Allowable Combustion Air Inlet Temp, °C (°F)	49 (120)	49 (120)
Exhaust System		Gradie de la Sant
Exhaust stack gas temperature, °C (°F)	452.9 (847.2)	432.9 (811.2)
Exhaust gas flow rate, m³/min (cfm)	170.7 (6028)	161 (5686)
Exhaust system backpressure (maximum allowable) kPa (in. water)	10.0 (40.0)	10.0 (40.0)
Heat Rejection		
Heat rejection to jacket water, kW (Btu/min)	225 (12795)	208 (11828)
Heat rejection to exhaust (total) kW (Btu/min)	714 (40604)	664 (37761)
Heat rejection to aftercooler, kW (Btu/min)	272 (15468)	253 (14387)
Heat rejection to atmosphere from engine, kW (Btu/min)	142 (8075)	123 (6995)


## Cat® C18 DIESEL GENERATOR SETS



Emissions (Nominal)?	Standb		. Crin	ie .
NOx, mg/Nm³ (g/hp-hr)	2468 (5.4	2)	2213 (4	4.91)
CO, mg/Nm³ (g/hp-hr)	100.1 (0.2	2)	75.6 (0	).17)
HC, mg/Nm³ (g/hp-hr)	23.5 (0.0	3)	24.1 (0	).06)
PM, mg/Nm³ (g/hp-hr)	11.7 (0.0	3)	10.6 (0	).03)
Alternator <sup>3</sup>	12 (a) (b) (c) (c) (d)			

Atternator,	14.				
Voltages	208 <b>V</b>	220V	240V	480V	600V
Motor starting capability @ 30% Voltage Dip	1917 skVA	2129 skVA	2501 skVA	2512 skVA	2512 skVA
Current	2602.2 amps	2460.3 amps	2512 amps	1127.6 amps	902.1 amps
Frame Size	LC7224N	LC7224L	LC7224L	LC7224L	LC7224L
Excitation	AREP	AREP	AREP	AREP	AREP
Temperature Rise	130 °C	130 °C	130 °C	105 °C	130 °C

#### **WEIGHTS & DIMENSIONS**



Dim "A" mm (in)	Dim "B" mm (in)	Dim "C" mm (in)	Dry Weight kg (lb)	
3512 (138)	1746 (69)	2322 (92)	4863 (10721)	

#### **APPLICABLE CODES AND STANDARDS:**

AS1359, CSA C22.2 No100-04, UL142, UL489, UL869, UL2200, NFPA37, NFPA70, NFPA99, NFPA110, IBC, IEC60034-1, ISO3046, ISO8528, NEMA MG1-22, NEMA MG1-33, 2006/95/EC, 2006/42/EC, 2004/108/EC.

Note: Codes may not be available in all model configurations. Please consult your local Cat Dealer representative for availability.

STANDBY: Output available with varying load for the duration of the interruption of the normal source power. Average power output is 70% of the standby power rating. Typical operation is 200 hours per year, with maximum expected usage of 500 hours per year.

PRIME: Output available with varying load for an unlimited time. Average power output is 70% of the prime power rating. Typical peak demand is 100% of prime rated ekW with 10% overload capability for emergency use for a maximum of 1 hour in 12. Overload operation cannot exceed 25 hours per year

RATINGS: Ratings are based on SAE J1349 standard conditions. These ratings also apply at ISO3046 standard conditions.

#### **DEFINITIONS AND CONDITIONS**

- <sup>1</sup> For ambient and altitude capabilities consult your Cat dealer. Air flow restriction (system) is added to existing restriction from factory.
- <sup>2</sup> Emissions data measurement procedures are consistent with those described in EPA CFR 40 Part 89, Subpart D & E and ISO8178-1 for measuring HC, CO, PM, NOx. Data shown is based on steady state operating conditions of 77° F, 28.42 in HG and number 2 diesel fuel with 35° API and LHV of 18,390 BTU/lb. The nominal emissions data shown is subject to instrumentation, measurement, facility and engine to engine variations. Emissions data is based on 100% load and thus cannot be used to compare to EPA regulations which use values based on a weighted cycle.
- <sup>3</sup> UL 2200 Listed packages may have oversized generators with a different temperature rise and motor starting characteristics. Generator temperature rise is based on a 40° C ambient per NEMA MG1-32.

#### LET'S DO THE WORK.

#### Performance Number: EM3842

Change Level: 02

SALES MODEL:	C18
BRAND:	CAT
MACHINE SALES MODEL:	
ENGINE POWER (BHP):	1,112
GEN POWER WITH FAN (EKW):	750.0
COMPRESSION RATIO:	14
RATING LEVEL:	STANDBY
PUMP QUANTITY:	1
FUEL TYPE:	DIESEL
MANIFOLD TYPE:	DRY
GOVERNOR TYPE:	ELEC
CAMSHAFT TYPE:	STANDARD
IGNITION TYPE:	CI
INJECTOR TYPE:	EUI
REF EXH STACK DIAMETER (IN):	6
MAX OPERATING ALTITUDE (FT):	3,553

COMBUSTION:	DIR
ENGINE SPEED (RPM):	1,80
HERTZ:	60
FAN POWER (HP):	42.3
ADDITIONAL PARASITICS (HP):	3.4
ASPIRATION:	TA
AFTERCOOLER TYPE:	ATA
AFTERCOOLER CIRCUIT TYPE:	JVV
NLET MANIFOLD AIR TEMP (F):	120
JACKET WATER TEMP (F):	192
FURBO CONFIGURATION:	PAI
TURBO QUANTITY:	2
FURBOCHARGER MODEL:	GT
CERTIFICATION YEAR:	201
PISTON SPD @ RATED ENG SPD (FT/MIN):	2.1

DIRECT INJECTION
1,800
60
42.2
3.4
TA
ATAAC
JVV+OC, ATAAC
120
192,2
PARALLEL
2
GTD5008 0,75 A/R
2018
2 46 2 4

INDUSTRY	SUBINDUSTRY	APPLICATION
ELECTRIC POWER	STANDARD	PACKAGED GENSET

#### General Performance Data

GENSET POWER WITH FAN	PERCENT LOAD	ENGINE POWER	BRAKE MEAN EFF PRES (BMEP)	BRAKE SPEC FUEL CONSUMPTN (BSFC)	ISO BRAKE SPEC FUEL CONSUMPTN (BSFC)	VOL FUEL CONSUMPTN (VFC)	ISO VOL FUEL CONSUMPTN (VFC)	ELEC SPEC FUEL CONSUMPTN (ESFC)	ISO ELEC SPEC FUEL CONSUMPTN (ESFC)
EKW	%	BHP	PSI	LB/BHP-HR	LB/BHP-HR	GAL/HR	GAL/HR	LB/EKW-HR	LB/EKW-HR
750.0	100	1,112	442	0.342	0,337	53,6	52.8	0.507	0.497
675.0	90	1,002	399	0.345	0.340	48.8	48,1	0.513	0.503
600.0	80	894	356	0.355	0.350	44.8	44.1	0.529	0.519
562.5	75	840	334	0.362	0.356	42.8	42.2	0.540	0.530
525.0	70	787	313	0.357	0.352	39.6	39.0	0.535	0.525
450.0	60	680	271	0.347	0.342	33.3	32.8	0.524	0.514
375.0	50	575	229	0.350	0.345	28.4	28.0	0.537	0.527
300.0	40	471	187	0.356	0.351	23.6	23.3	0.559	0.548
225.0	30	367	146	0.365	0.360	18,9	18.6	0.596	0.585
187.5	25	315	125	0.373	0,368	16.6	16.3	0,627	0.615
150.0	20	262	104	0.384	0.379	14.2	14.0	0.672	0.660
75.0	10	155	62	0.436	0.430	9.5	9.4	0.903	0.886

GENSET POWER WITH FAN	PERCENT LOAD	ENGINE POWER	INLET MFLD PRES	INLET MFLD TEMP	EXH MFLD TEMP	EXH MFLD PRES	ENGINE OUTLET TEMP	COMPRESSOR OUTLET PRES	COMPRESSOR OUTLET TEMP
EKW	%	BHP	IN-HG	DEG F	DEG F	IN-HG	DEG F	IN-HG	DEG F
750.0	100	1,112	99.6	120.6	1,297.4	91.1	847.3	106	491.8
675.0	90	1,002	94.8	116.3	1,237.8	85.6	808.8	101	471.6
600.0	80	894	90,6	110.2	1,190.8	81,2	779.6	97	456,4
562.5	75	840	88,9	106.0	1,168.7	79.4	765.3	95	449.8
525.0	70	787	83,3	102,6	1,123.3	73.0	732.9	89	427.8
450.0	60	680	70.0	97.1	1,044.2	59.2	681.5	75	378.6
375.0	50	575	58.7	92.6	995.6	48.8	659.1	63	343.0
300,0	40	471	46.1	89.2	946.5	38.8	636.5	50	296.8
225.0	30	367	33.0	85.9	891.7	28.9	613.3	36	248.4
187.5	25	315	26.7	84.2	861.7	23.9	601.4	30	224.2
150.0	20	262	20.9	82.5	823.8	19.2	583.1	23	199.8
75.0	10	155	10.7	79.1	696.6	12.2	500.0	13	150.3

#### **General Performance Data (Continued)**

GENSET POW WITH FAN	ER PERCENT LO	AD ENGINE POWER	WET INLET AIR FLOW RATE	VOL ENGINE OUTLE WET EXH GAS FLOW RATE		WET EXH GAS E MASS FLOW RATE		DRY EXH VOL FLOW RATE (32 DEG F AND 29.98 IN HG)
EKW	%	BHP	CFM	CFM	LB/HR	LB/HR	FT3/MIN	FT3/MIN
750.0	100	1,112	2,375.0	6,028.4	10,393.9	10,773.8	2,267.8	2,078.6

#### PERFORMANCE DATA[EM3842]

675.0	90	1,002	2,311.8	5,661.5	10,079.7	10,425.9	2,194.5	2,019.7
600.0	80	894	2,255,1	5,366.3	9,808.8	10,125,6	2,129.1	1,967.2
562.5	75	840	2,232.7	5,242.8	9,695.0	9,998.8	2,104.4	1,948.0
525.0	70	787	2,128.6	4,886.8	9,201.8	9,479.4	2,014.8	1,868.9
450.0	60	680	1,924.5	4,154.8	8,250.4	8,484.5	1,790.1	1,665.9
375.0	50	575	1,724.0	3,614.1	7,338.5	7,539.3	1,588.3	1,481.3
300.0	40	471	1,496.1	3,059.1	6,324.6	6,492.2	1,372.1	1,282.4
225.0	30	367	1,252.4	2,494.4	5,258.7	5,392.8	1,143.0	1.070.6
187.5	25	315	1,129.6	2,211.4	4,728.5	4,845.9	1,024.7	960.8
150.0	20	262	1,009.9	1,930.2	4,215.5	4,316.3	910.1	854.6
75.0	10	155	782.1	1,374.8	3,253.5	3,321.2	704.3	665.3

#### **Heat Rejection Data**

GENSET POWER WITH FAN	PERCENT LOAD	ENGINE POWER	REJECTION TO JACKET WATER	REJECTION TO ATMOSPHERE	REJECTION TO EXH	EXHAUST RECOVERY TO 350F	FROM OIL COOLER	FROM AFTERCOOLER	WORK RENERGY	LOW HEAT VALUE ENERGY	HIGH HEAT VALUE ENERGY
EKW	%	8HP	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN
750.0	100	1,112	12,818	8,047	40,603	22,636	6,204	15,452	47,163	116,484	124,084
675.0	90	1,002	11,743	6,958	37,522	20,109	5,654	14,340	42,509	106,146	113,072
600.0	80	894	10,952	6,200	35,048	18,214	5,186	13,597	37,916	97,360	103,713
562.5	75	840	10,640	5,836	33,785	17,352	4,962	13,346	35,638	93,166	99,245
525.0	70	787	9,859	5,705	30,827	15,116	4,587	11,983	33,363	86,117	91,736
450.0	60	680	8,318	5,623	24,979	11,650	3,854	9,300	28,853	72,352	77,073
375,0	50	575	7,503	5,062	21,470	9,629	3,289	7,357	24,380	61,743	65,772
300.0	40	471	6,805	4,763	17,924	7,664	2,736	5,257	19,977	51,373	54,726
225.0	30	367	6,315	4,137	14,360	5,834	2,190	3,423	15,572	41,123	43,806
187.5	25	315	6,146	3,592	12,622	4,998	1,918	2,650	13,357	36,017	38,367
150.0	20	262	5,811	3,166	10,852	4,120	1,647	1,979	11,122	30,914	32,931
75,0	10	155	4,464	2,714	7,429	2,021	1,106	928	6,579	20,759	22,114

#### **Emissions Data**

#### DIESEL

#### RATED SPEED NOMINAL DATA: 1800 RPM

GENSET POWER WITH		EKW	750,0	562.5	375.0	187,5	75,0
PERCENT LOAD		%	100	75	50	25	10 in 10
ENGINE POWER		BHP	1,112	840	575	315	155
TOTAL NOX (AS NO2)		G/HR	5,965	3,126	2,054	1,344	778
TOTAL CO		G/HR	243	232	76	312	1,148
TOTAL HC		G/HR	66	67	47	55	458
TOTAL CO2		KG/HR	552	441	292	172	96
PART MATTER		G/HR	33,7	34.4	21.3	25.5	73.8
TOTAL NOX (AS NO2)	(CORR 5% O2)	MG/NM3	2,468.0	1,615.7	1,594.0	1,789.0	1,769.3
TOTAL CO	(CORR 5% O2)	MG/NM3	100.1	120.0	57.8	462.4	3,203.4
TOTAL HC	(CORR 5% O2)	MG/NM3	23.5	29.8	32.1	65.0	1,156.1
PART MATTER	(CORR 5% O2)	MG/NM3	11.7	15.2	14.2	30,4	185.1
TOTAL NOX (AS NO2)	(CORR 15% O2)	MG/NM3	915.8	599.5	591.5	663.9	656.5
TOTAL CO	(CORR 15% O2)	MG/NM3	37.1	44.5	21.4	171.6	1,188.7
TOTAL HC	(CORR 15% O2)	MG/NM3	8.7	11.1	11.9	24.1	429.0
PART MATTER	(CORR 15% O2)	MG/NM3	4.3	5.7	5.3	11,3	68.7
TOTAL NOX (AS NO2)	(CORR 5% O2)	PPM	1,202	787	. 776	871	862
TOTAL CO	(CORR 5% O2)	PPM	80	96	46	370	2,563
TOTAL HC	(CORR 5% O2)	PPM	44	56	60	121	2,158
TOTAL NOX (AS NO2)	(CORR 15% O2)	PPM	446	292	288	323	320
TOTAL CO	(CORR 15% O2)	PPM	30	36	17	137	951
TOTAL HC	(CORR 15% O2)	PPM	16	21	22	45	801
TOTAL NOX (AS NO2)		G/HP-HR	5.42	3.75	3.59	4.27	5.02
TOTAL CO		G/HP-HR	0.22	0.28	0.13	0.99	7.41
TOTAL HC		G/HP-HR	0.06	0.08	0.08	0.17	2.96
PART MATTER		G/HP-HR	0.03	0.04	0.04	0.08	0.48

#### PERFORMANCE DATA[EM3842]

TOTAL NOX (AS NO2)	G/KW-HR	7.37	5,09	4,88	5.81	6.83	
TOTAL CO	G/KW-HR	0,30	0,38	0.18	1.35	10,07	
TOTAL HC	G/KW-HR	80,0	0.11	0.11	0.24	4.02	
PART MATTER	G/KW-HR	0.04	0,06	0.05	0.11	0.65	
TOTAL NOX (AS NO2)	LB/HR	13.15	6.89	4.53	2.96	1.72	
TOTAL CO	L8/HR	0.54	0.51	0.17	0.69	2.53	
TOTAL HC	LB/HR	0.14	0,15	0.10	0.12	1.01	
TOTAL CO2	LB/HR	1,217	971	644	380	211	
PART MATTER	LB/HR	0.07	0,08	0,05	0.06	0.16	
OXYGEN IN EXH	%	9.8	11.5	12.7	13.5	14.9	
DRY SMOKE OPACITY	%	0.5	0.8	0.5	1.0	0.5	
BOSCH SMOKE		0.71	0.79	0.71	0.86	0.71	
NUMBER							

#### RATED SPEED POTENTIAL SITE VARIATION: 1800 RPM

GENSET POWER WITH FAN		EKW	750.0	562.5	375.0	187.5	75.0
PERCENT LOAD		%	100	75	50	25	10
ENGINE POWER		ВНР	1,112	840	575	315	155
TOTAL NOX (AS NO2)		G/HR	6,442	3,376	2,219	1,451	840
TOTAL CO		G/HR	454	434	142	583	2,147
TOTAL HC		G/HR	124	126	89	103	866
PART MATTER		G/HR	65.6	67.1	41.6	49.7	144.0
TOTAL NOX (AS NO2)	(CORR 5% O2)	MG/NM3	2,665.4	1,745.0	1,721.5	1,932.2	1,910.9
TOTAL CO	(CORR 5% O2)	MG/NM3	187.1	224.5	108.1	864.7	5,990.4
TOTAL HC	(CORR 5% O2)	MG/NM3	44.4	56.3	60,6	122.9	2,185.0
PART MATTER	(CORR 5% O2)	MG/NM3	22.8	29.7	27.7	59.3	361,0
TOTAL NOX (AS NO2)	(CORR 15% O2)	MG/NM3	989.1	647,5	638,8	717.0	709.1
TOTAL CO	(CORR 15% O2)	MG/NM3	69.4	83,3	40.1	320.9	2,222.8
TOTAL HC	(CORR 15% O2)	MG/NM3	16.5	20.9	22.5	45.6	810.8
PART MATTER	(CORR 15% O2)	MG/NM3	8.4	11.0	10.3	22.0	134.0
TOTAL NOX (AS NO2)	(CORR 5% O2)	PPM	1,298	850	839	941	931
TOTAL CO	(CORR 5% O2)	PPM	150	180	86	692	4,792
TOTAL HC	(CORR 5% O2)	PPM	83	105	113	229	4,079
TOTAL NOX (AS NO2)	(CORR 15% O2)	PPM	482	315	311	349	345
TOTAL CO	(CORR 15% O2)	PPM	56	67	32	257	1,778
TOTAL HC	(CORR 15% O2)	PPM	31	39	42	85	1,513
TOTAL NOX (AS NO2)		G/HP-HR	5.85	4.05	3.88	4.62	5.42
TOTAL CO		G/HP-HR	0.41	0.52	0.25	1.85	13.85
TOTAL HC		G/HP-HR	0.11	0.15	0.16	0,33	5.59
PART MATTER		G/HP-HR	0,06	0,08	0.07	0.16	0.93
TOTAL NOX (AS NO2)		G/KW-HR	7.95	5,50	5.27	6.28	7.37
TOTAL CO		G/KW-HR	0.56	0.71	0.34	2.52	18.83
TOTAL HC		G/KW-HR	0.15	0.21	0.21	0.45	7.60
PART MATTER		G/KW-HR	0.08	0.11	0.10	0.22	1.26
TOTAL NOX (AS NO2)		LB/HR	14.20	7.44	4.89	3.20	1.85
TOTAL CO		LB/HR	1.00	0.96	0.31	1.28	4.73
TOTAL HC		LB/HR	0.27	0.28	0.20	0.23	1.91
PART MATTER		LB/HR	0.14	0.15	0.09	0.11	0.32

#### Regulatory Information

EPA EMERGENCY STATIO	NARY	201		보면, 걸리 보다가 하는 사람들은 얼마를 가입니다.
GASEOUS EMISSIONS DAT	TA MEASUREMENTS PROVIDED T	O THE EPA ARE CONSISTENT WITH THO	OSE DESCRIBED IN EPA 40 CFR PART 60 SUI	BPART IIII AND ISO 8178 FOR MEASURING HC,
CO, PM, AND NOX. THE "M	AX LIMITS" SHOWN BELOW ARE	WEIGHTED CYCLE AVERAGES AND ARE	IN COMPLIANCE WITH THE EMERGENCY ST	ATIONARY REGULATIONS.
Locality	Agency	Regulation	Tier/Stage	Max Limits - G/BKW - HR
U.S. (INCL CALIF)	EPA	STATIONARY	EMERGENCY STATIONARY	CO: 3.5 NOx + HC: 6.4 PM: 0.20

#### **Altitude Derate Data**

#### STANDARD

AMBIENT	50	60	70	80	90	100	110	120	130	140	NORMAL
OPERATING TEMP (F)											
ALTITUDE (FT)											
0	1,112	1,112	1,112	1,111	1,106	1,101	1,096	1,089	1,054	987	1,112
1,000	1,112	1,112	1,112	1,107	1,102	1,097	1,092	1,066	1,006	957	1,110
2,000	1,112	1,111	1,106	1,101	1,096	1,091	1,063	1,002	956	916	1,105
3,000	1,110	1,105	1,100	1,095	1,088	1,058	996	954	915	854	1,101
4,000	1,103	1,097	1,082	1,069	1,051	990	950	912	852	793	1,090
5,000	1,067	1,045	1,023	1,002	981	944	907	845	792	739	1,043
6,000	1,039	1,013	993	975	955	918	862	805	776	696	1,020
7,000	1,020	1,000	984	969	943	900	835	793	757	680	1,013
8,000	999	982	967	954	923	867	808	764	723	670	999
9,000	973	958	944	932	898	326	769	720	703	665	979
10,000	944	930	917	906	851	795	748	720	698	670	956
11,000	912	898	886	875	817	772	736	710	685	654	928
12,000	879	867	856	845	791	753	722	690	657	621	899
13,000	843	832	822	811	772	733	694	656	618	590	864
14,000	800	791	781	772	730	688	648	610	587	567	825
15,000	754	744	733	714	672	635	602	583	564	544	780

#### Cross Reference

Test Spec	Setting	Engine Arrangement	Engineering M	lodel Engineering M Version	lodel Start Effective Serial End Number Num	Effective Serial
4581998	PP7270	5365365	GS668	-	LTH00001	
4582018	PP7585	5407425	EE563	-	LT400001	
4582018	PP7585	5407426	EE563	-	LT400001	
4581998	PP7270	5411973	GS668	-	LTH00001	

#### Performance Parameter Reference

Parameters Reference:DM9600-14 PERFORMANCE DEFINITIONS

PERFORMANCE DEFINITIONS DM9600

APPLICATION:

Engine performance tolerance values below are representative of a typical production engine tested in a calibrated dynamometer test cell at SAE J1995 standard reference conditions. Caterpillar maintains ISO9001:2000 certified quality management systems for engine test Facilities to assure accurate calibration of test equipment, Engine test data is corrected in accordance with SAE J1995. Additional reference material SAE J1228, J1349, ISO 8665, 3046-1:2002E, 3046-3:1989, 1585, 2534, 2288, and 9249 may apply in part or are similar to SAE J1995. Special engine rating request (SERR) test data shall be noted. PERFORMANCE PARAMETER TOLERANCE FACTORS: Power +/- 3%

Torque +/- 3%

Exhaust stack temperature +/- 8%

Inlet airflow +/- 5%

Intake manifold pressure-gage +/- 10%

Exhaust flow +/- 6%

Specific fuel consumption +/- 3%

Fuel rate +/- 5%

Specific DEF consumption +/- 3%

DEF rate +/- 5%

Heat rejection +/- 5%

Heat rejection exhaust only +/- 10%

Heat rejection CEM only +/- 10%

Heat Rejection values based on using treated water.

Torque is included for truck and industrial applications, do not

use for Gen Set or steady state applications.

On C7 - C18 engines, at speeds of 1100 RPM and under these values are provided for reference only, and may not meet the tolerance

On 3500 and C175 engines, at speeds below Peak Torque these values are provided for reference only, and may not meet the tolerance

These values do not apply to C280/3600. For these models, see the

tolerances listed below.
C280/3600 HEAT REJECTION TOLERANCE FACTORS:

Heat rejection +/- 10%

#### PERFORMANCE DATA[EM3842]

Heat rejection to Almosphere +/- 50% Heat rejection to Lube Oil +/- 20% Heat rejection to Aftercooler +/- 5% TEST CELL TRANSDUCER TOLERANCE FACTORS: Torque =/- 0.5% Speed +/- 0.2% Fuel flow +/- 1.0% Temperature +/- 2.0 C degrees Intake manifold pressure +/- 0,1 kPa OBSERVED ENGINE PERFORMANCE IS CORRECTED TO SAE J1995 REFERENCE AIR AND FUEL CONDITIONS. REFERENCE ATMOSPHERIC INLET AIR FOR 3500 ENGINES AND SMALLER SAE J1228 AUG2002 for marine engines, and J1995 JAN2014 for other engines, reference atmospheric pressure is 100 KPA (29,61 in hg). and standard temperature is 25deg C (77 deg F) at 30% relative humidity at the stated aftercooler water temp, or inlet manifold FOR 3600 ENGINES Engine rating obtained and presented in accordance with ISO 3046/1 and SAE J1995 JANJAN2014 reference atmospheric pressure is 100 KPA (29.61 in hg), and standard temperature is 25deg C (77 deg F) at 30% relative humidity and 150M altitude at the stated aftercooler water temperature. MEASUREMENT LOCATION FOR INLET AIR TEMPERATURE Location for air temperature measurement air cleaner inlet at stabilized operating conditions REFERENCE EXHAUST STACK DIAMETER The Reference Exhaust Stack Diameter published with this dataset is only used for the calculation of Smoke Opacity values displayed in this dataset. This value does not necessarily represent the actual stack diameter of the engine due to the variety of exhaust stack adapter options available. Consult the price list, engine order or general dimension drawings for the actual stack diameter size ordered or options available REFERENCE FUEL Reference fuel is #2 distillate diesel with a 35API gravity; A lower heating value is 42,780 KJ/KG (18,390 BTU/LB) when used at 15 deg C (59 deg F), where the density is 850 G/Liter (7.0936 Lbs/Gal). GAS Reference natural gas fuel has a lower heating value of 33.74 KJ/L (905 BTU/CU Ft). Low BTU ratings are based on 18.64 KJ/L (500 BTU/CU FT) lower heating value gas. Propane ratings are based on 87.56 KJ/L (2350 BTU/CU Ft) lower heating value gas. ENGINE POWER (NET) IS THE CORRECTED FLYWHEEL POWER (GROSS) LESS EXTERNAL AUXILIARY LOAD Engine corrected gross output includes the power required to drive standard equipment; lube oil, scavenge lube oil, fuel transfer, common rait fuel, senarate circuit aftercooler and lacket water pumps. Engine net power available for the external (flywheel) load is calculated by subtracting the sum of auxiliary load from the corrected gross flywheel out put power. Typical auxiliary loads are radiator cooling fans, hydraulic pumps, air compressors and battery charging alternators. For Tier 4 ratings additional Parasitic losses would also include Intake, and Exhaust Restrictions. ALTITUDE CAPABILITY Altitude capability is the maximum altitude above sea level at standard temperature and standard pressure at which the engine could develop full rated output power on the current performance Standard temperature values versus altitude could be seen on TM2001. When viewing the altitude capability chart the ambient temperature is the inlet air temp at the compressor inlet. Engines with ADEM MEUI and HEUI fuel systems operating at conditions above the defined altitude capability derate for atmospheric pressure and temperature conditions outside the values defined, see TM2001. Mechanical governor controlled unit injector engines require a setting change for operation at conditions above the altitude defined on the engine performance sheet. See your Caterpillar technical representative for non standard ratings. REGULATIONS AND PRODUCT COMPLIANCE TMI Emissions information is presented at 'nominal' and 'Potential Site Variation' values for standard ratings. No tolerances are applied to the emissions data. These values are subject to change at any time. The controlling federal and local emission requirements need to be verified by your Caterpillar technical representative.

Customer's may have special emission site requirements that need to be verified by the Caterpillar Product Group engineer.

Cycle emissions Max Limits apply to cycle-weighted averages only. Emissions at individual load points may exceed the cycle-weighted

EMISSION CYCLE LIMITS:

Page 5 of 6

#### PERFORMANCE DATA[EM3842]

WET & DRY EXHAUST/EMISSIONS DESCRIPTION:

Wet - Total exhaust flow or concentration of total exhaust flow

Dry - Total exhaust flow minus water vapor or concentration of exhaust

flow with water vapor excluded EMISSIONS DEFINITIONS: Emissions : DM1176

EMISSION CYCLE DEFINITIONS

1. For constant-speed marine engines for ship main propulsion, including, diesel-electric drive, test cycle E2 shall be applied,

for controllable-pitch propeller sets

test cycle E2 shall be applied.
2. For propeller-law-operated main and propeller-law-operated

auxiliary engines the test cycle E3 shall be applied.

3. For constant-speed auxiliary engines test cycle D2 shall be

4. For variable-speed, variable-load auxiliary engines, not

included above, test cycle C1 shall be applied.

HEAT REJECTION DEFINITIONS: Diesel Circuit Type and HHV Balance : DM9500 HIGH DISPLACEMENT (HD) DEFINITIONS:

3500: EM1500

RATING DEFINITIONS: Agriculture: TM6008 Fire Pump : TM6009 Generator Set : TM6035 Generator (Gas): TM6041 Industrial Diesel: TM6010 Industrial (Gas): TM6040 Imigation : TM5749 Locomotive: TM6037

Marine Auxiliary: TM6036 Marine Prop (Except 3600): TM5747

Marine Prop (3600 only): TM5748


MSHA: TM6042 Oil Field (Petroleum): TM6011 Off-Highway Truck: TM6039 On-Highway Truck: TM6038 SOUND DEFINITIONS: Sound Power: DM8702 Sound Pressure: TM7080 Date Released: 10/27/21

Page 6 of 6

AIR INTAKE SYSTEM		
THE INSTALLED SYSTEM MUST COMPLY WITH THE SYSTEM LIMITS BELOW FOR ALL E TO ASSURE REGULATORY COMPLIANCE.	MISSIONS CERTI	FIED ENGINES
MAXIMUM ALLOWABLE INTAKE RESTRICTION WITH CLEAN ELEMENT	15	IN-H20
MAXIMUM ALLOWABLE INTAKE RESTRICTION WITH DIRTY ELEMENT	25	IN-H20
MAXIMUM ATAAC OUTLET TEMPERATURE (25C/77F DAY)	120	DEG F
MAXIMUM PRESSURE DROP FROM COMPRESSOR OUTLET TO MANIFOLD INLET (OR MIXER INLET FOR EGR)	6.2	IN-HG
MAXIMUM ALLOWABLE STATIC WEIGHT ON AIR INLET	3.7	LB
MAXIMUM ALLOWABLE STATIC BENDING MOMENT ON AIR INLET	1.3	LB-FT
MAXIMUM ALLOWABLE STATIC WEIGHT ON TURBO OUTLET CONNECTION	1.5	LB
MAXIMUM ALLOWABLE STATIC BENDING MOMENT ON TURBO OUTLET CONNECTION	0.3	LB-FT
COOLING SYSTEM		
ENGINE ONLY COOLANT CAPACITY	5.5	GAL
MAXIMUM ALLOWABLE JACKET WATER OUTLET TEMPERATURE	207	DEG F
REGULATOR LOCATION FOR JW (HT) CIRCUIT	OUTLET	ter en Sanatan de en en delen e en pelote de la menta de la companya de la delena de la companya de la delena d
MAXIMUM UNINTERRUPTED FILL RATE	5.0	G/MIN
MAXIMUM UNINTERRUPTED FILL RATE	5.0	G/MIN
MINIMUM COOLANT LOSS WITHOUT IMPACTING RADIATOR PERFORMANCE (PERCENT OF TOTAL)	12	PERCENT
COOLANT LOSS-MAXIMUM PERCENTAGE OF PUMP PRESSURE RISE LOSS	10	PERCENT
CHARGE AIR TEMPERATURE CONTROL TYPE	FLOATING	
ENGINE SPEC SYSTEM		
CYLINDER ARRANGEMENT	INLINE	
CYLINDER ARRANGEMENT	INLINE	
NUMBER OF CYLINDERS	6	
NUMBER OF CYLINDERS	6	
CYLINDER BORE DIAMETER	5.7	IN
PISTON STROKE	7.2	IN
TOTAL CYLINDER DISPLACEMENT	1105	CU IN
STANDARD CRANKSHAFT ROTATION FROM FLYWHEEL END	CCW	
STANDARD CYLINDER FIRING ORDER	1-5-3-6-2-4	
NUMBER 1 CYLINDER LOCATION	FRONT	
NUMBER 1 CYLINDER LOCATION	FRONT	
STROKES/COMBUSTION CYCLE	4	
STROKES/COMBUSTION CYCLE	4	
EXHAUST SYSTEM		
THE INSTALLED SYSTEM MUST COMPLY WITH THE SYSTEM LIMITS BELOW FOR ALL E TO ASSURE REGULATORY COMPLIANCE.	MISSIONS CERTI	FIED ENGINES
MAXIMUM ALLOWABLE SYSTEM BACK PRESSURE	40	IN-H20

MANIFOLD TYPE	DRY	***
EXHAUST PIPE DIAMETER AFTER TC	5.5	IN
FUEL SYSTEM		
MAXIMUM FUEL FLOW FROM TRANSFER PUMP TO ENGINE	111.0	G/HR
MAXIMUM ALLOWABLE FUEL SUPPLY LINE RESTRICTION	8.0	IN-HG
MAXIMUM ALLOWABLE FUEL TEMPERATURE AT TRANSFER PUMP INLET	174	DEG F
MAXIMUM FUEL FLOW TO RETURN LINE FROM ENGINE	103.0	G/HR
MAXIMUM ALLOWABLE FUEL RETURN LINE RESTRICTION	14.8	IN-HG
NORMAL FUEL PRESSURE IN A CLEAN SYSTEM	101.5	PSI
FUEL SYSTEM TYPE	MEUI	
MAXIMUM TRANSFER PUMP PRIMING LIFT WITHOUT PRIMING PUMP	12.1	FT
LUBE SYSTEM		
LUBE SYSTEM OIL COOLER TYPE	SHELL & TUBE	
CRANKCASE VENTILATION TYPE	TO ATMOSPHERE	
MOUNTING SYSTEM		
DRY WEIGHT - ENGINE ONLY (REFERENCE VALUE)	3803	LB
LENGTH - ENGINE ONLY (REFERENCE VALUE)	67	IN
HEIGHT - ENGINE ONLY (REFERENCE VALUE)	50	IN
WIDTH - ENGINE ONLY (REFERENCE VALUE)	37	IN
STARTING SYSTEM		
MINIMUM CRANKING SPEED REQUIRED FOR START	100	RPM
LOWEST AMBIENT START TEMPERATURE WITHOUT AIDS	32	DEG F





Placers shown may not retient actual configuration

## C13/C15/C18 SOUND ATTENUATED ENCLOSURES

US Sourced Diesel Generator Set 350 - 750 ekW 60 Hz

#### **Features**

#### **Robust/Highly Corrosion Resistant Construction**

- · Factory installed on skid base
- Environmentally friendly, polyester powder baked paint
- 14 gauge steel
- Interior zinc plated fasteners
- · Exterior stainless steel fasteners
- Internally mounted exhaust silencing system
- Designed and tested to comply with UL 2200 Listed generator set package
- · Compression door latches providing solid door seal

#### **Excellent Access**

- · Large cable entry area for installation ease
- Accommodates side mounted single or multiple breakers
- · Three doors on both sides
- Vertically hinged allow 180° opening rotation and retention with door stays
- Lube oil and coolant drains piped to the exterior of the enclosure base
- · Radiator fill cover

#### Security and Safety

- Lockable access doors which give full access to control panel and breaker
- · Cooling fan and battery charging alternator fully guarded
- · Fuel fill, oil fill and battery can only be reached via lockable access
- Externally mounted emergency stop button
- · Designed for spreader bar lifting to ensure safety
- Stub-up area is rodent proof

#### Transportability

These enclosures are of extremely rugged construction to withstand autdoor exposure and rough handling common on many construction sites.

#### Options

- Enclosure constructed with 14 gauge steel
- Enclosure constructed with 12 gauge aluminum (5052 grade)
- Caterpillar yellow or white paint
- Control panel viewing window
- UL Listed integral fuel tank with 670, 400, and 300 gallon capacities
- UL Listed sub base fuel tank with 660, 1000, 1900, and 2200 gallon capacities.
- Seismic certification per applicable building codes: IBC 2000, IBC 2003, IBC 2006, IBC 2009, IBC 2012, IBC 2015 CBC 2007, CBC 2010
- IBC Certification for 150 mph wind loading
- AC/DC lighting package
- 5 kW Canopy space heater to facilitate compliance with NFPA 110
- Motorized louvers and gravity discharge damper
- 125A Load Center
- GFCI outlets

<sup>\*</sup>Not available with aluminum enclosures.

### Enclosures



Level 1 Sound Attenuated Enclosure (Steel) Sound Levels

Model	Standby eKW		ir Flow Rate	Ambient	Capability*	Sound Pressure Levels (dBA) at 7m (23 ft)
$(x,y) \in \mathcal{C}_{k}(X)$		m³/s	cfm	°C	f,	100% Load
C12	350	8.5	18010	57	135	74
C13	400	8.5	18010	56	133	75
	350	10.4	22072	59	138	73
015	400	10.4	22072	51	124	73
C15	450	10.4	22072	46	115	74
	500	12.5	26415	48	118	75
	550	8.1	17234	45	113	75
	600	8.1	17234	43	109	75
C18	650	12.7	26909	51	123	75
	700	12.7	26909	48	118	75
	750	12.7	26909	48	118	75

#### **Sound Attenuated Enclosure (Aluminum) Sound Levels**

Model	Standby eKW	Cooling A	ir Flow Rate	Ambient	Capability*	Sound Pressure Levels (dBA) at 7m (23 ft)
		m³/s	cfm	C	FV)	100% Load
C13	350	8.5	-	57	135	75
013	400	8.5	-	56	133	75
	350	10.4	22072	59	138	72
015	400	10.4	22072	51	124	73
C15	450	10.4	22072	46	115	74
	500	12.5	26415	48	118	75
	550	8.1	17234	45	113	76
	600	8.1	17234	43	109	76
C18	650	12.7	26909	51	123	76
	700	12.7	26909	48	118	76
	750	12.7	26909	48	118	76

LEHE0465-09 2/7



#### Level 2 Sound Attenuated Enclosure (Steel) Sound Levels

Model	Standby eKW	Cooling Ai	r Flow Rate	Ambient C	apabīlity*	Sound Pressure Levels (dBA) at 7m (23 ft)
		m³/s	elm	C	T.	100% <b>L</b> oad
C13	350	7.2	15256	50	122	70
013	400	7.2	15256	50	122	70
	350	10.4	22071	50	122	72
C15	400	10.4	22071	50	122	72
613	450	10.4	22071	50	122	72
	500	12.5	26415	50	122	72

<sup>\*</sup>Cooling system performance at sea level. Consult your Cat® dealer for site specific ambient and altitude capabilities.

Note: Sound level measurements are subject to instrumentation, installation and manufacturing variability, as well as ambient site conditions.

#### **Component Weights to Calculate Package Weight**

Model	Standby eKW	Narrow S	Narrow Skid Base		cid Base		tenuated re (Steel)	Sound Attenuated Enclosure (Aluminum) km lb	
- M.C.		kg	llb	kg	lb	kg '	. Ilb	kg	lb
C13	350	253	578	579	1276	1245	2745	765	1687
013	400	200	370	3/9	12/0	1240	2740	700	1007
	350								
C15	400	273	602	465	1025	1245	2745	765	1687
(613	450	2/3	002	400	1023	1243	2740	703	1007
	500								
	550	301	664	466	1027	1301	2868	817	1801
	600	301	004	400	1027	1301	2000	017	1001
C18	650								
	700	286	630	637	1404	1393	3071	887	1955
	750								


#### **Sound Attenuated Enclosure on Skid Base**


Model	Standby eKW	Leng	th "L"	Widtl	ı "W"	Height "H"		
Would	Standay GRAV	mm	. In	mm	in	mm	in	
C13	350	4948	194.8	2014	79.3	2320	91.3	
013	400	4540	134.0	2014	75.5	2320	31.3	
	350							
C15	400	4948	194.8	2014	79.3	2320	91.3	
013	450	4540	194.0	2014	75.5	2320	91.5	
	500							
	550	5183	204.0	2014	79.3	2262	89.0	
	600	3163	204.0	2014	75.5	2202	65.0	
C18	650							
	700	5230	205.9	2315	91.1	2253	88.7	
	750							

## Enclosures




#### Sound Attenuated Enclosure on a UL Listed Integral Fuel Tank Base





Model	Standby eKW	Leng	lh "L"	Widtl				
	Stallay Ex	/ mm	th.	mm	ein e	mm.	in 💛	
C13	350	5461	215.0	2014	79.3	2743	108.0	
013	400	3401	213.0	2014	75.5	2/43	100.0	
	350							
C15	400	4948	194.8	2014	79.3	2619	103.0	
013	450	4540	154.0	2014	/3.5	2019	103.0	
	500							
	550	5187	204.2	2014	79.3	2561	101.0	
	600	3107	204.2	2014	75.5	2301	101.0	
C18	650							
	700	6977	274.7	2315	91.1	2675	105.3	
	750							



#### C13 / C15 / C18 Integral and Sub-Base Fuel Tanks

US Sourced Diesel Generator Set 350 – 750 ekW 60 Hz

Picture shown may not represent actual package.

#### **Features**

- UL Listed for United States (UL 142) and Canada (CAN/ULC S601)
- Facilitates compliance with NFPA 30 code, NFPA 37 and 110 standards and CSA C282 code
- Dual wall
- Lockable fuel fill cap, 4" (101.6 mm) NPT
- · Low fuel level warning standard, customer configurable warning or shutdown
- Primary tank leak detection switch in containment basin
- Tank design provides capacity for thermal expansion of fuel
- Fuel supply dip tube is positioned so as not to pick up fuel sediment
- Fuel return and supply dip tube is separated by an internal baffle to prevent immediate re-supply of heated return fuel
- Pressure washed with an iron phosphate solution
- · Interior tank surfaces coated with a solvent-based thin-film rust preventative
- Heavy gauge steel gussets with internal lifting rings
- Primary and secondary tanks are leak tested at 20.7 kPa (3 psi) minimum
- Compatible with open packages and enclosures
- · Gloss black polyester alkyd enamel exterior paint
- · Welded steel containment basin (minimum of 110% of primary tank capacity)
- Direct reading fuel gauge with variable electrical output
- Emergency vents on primary and secondary tanks are sized in accordance with NFPA 30

#### Sub-Base

The Sub-Base fuel tank mounts below the generator set wide base

#### Integral

- Integral diesel fuel tank is incorporated into the generator set base frame
- · Robust base design includes linear vibration isolators between tank base and engine generator

#### **Options**

- Audio/visual fuel level alarm panel
- 5 gal (18.9 L) spill containment
- 5 gal (18.9 L) spill containment with fuel fill drop tube with in 6" (152 mm) from bottom of tank
- 5 gal (18.9 L) spill containment with overfill prevention valve and fuel fill drop tube with in 6" (152 mm) from bottom of tank
- ULC Listed 7.5 gal (28.4 L) spill containment with vent extensions, vent whistle, and drop tube facilitating compliance with CSA B139-09
- ULC Listed 7.5 gal (28.4 L) spill containment with overfill prevention valve, vent extensions, vent whistle
  and drop tube facilitating compliance with CSA B139-09



## Integral & Sub-Base Fuel Tank Base Useable Capacities with Fuel Tank Dimensions & Weights

Integral - Width(W) 2014 mm (79.3 in) Sub-base - Width(W) 2056 mm (81 in) Integral\* - Width(W) 2315 mm (91.2 in) Sub-base\*-Width(W) 2357 mm (92.7in)

#### **Sound Attenuated Enclosure**

		Total		Useable		Tank Only							Overall Package Height with Tank			
C13 Tank Feature		Capacity		Capacity		Dry Weight		Height 'H'		Length 'L'		Open		Enclosure		
Design	Code	Liter	Gallon	Liter	Gallon	kg	lb	mm	ìn	mm	in	mm	in	mm	in	
Integral	FTDW013	2646	699	2540	671	1569	3450	762	30.0	5461	215.0	NA	NA	2743	108.0	
Sub-Base	FTDW005 / FTDW016	3941	1041	3876	1024	1659	3657	635	25.0	5550	218.5	NA	NA	2955	116.3	
Sub-Base	FTDW006	6980	1844	6818	1801	2033	4483	889	35.0	6184	243.5	NA	NA	3209	126.3	
Sub-Base	FTDW007	8339	2203	8244	2178	2292	5052	889	35.0	7074	278.5	NA	NA	3209	126.3	
Sub-Base	FTDW011	2476	654	2435	643	1468	3236	635	25.0	3810	150.0	NA	NA	2955	116.3	


		Total		Useable		Tank Only						Overall Package Height with Tank			
		Capacity		Capacity		Dry Weight		Height 'H'		Length 'L'		Open		Enclosure	
C15 Tank Design	Feature Code	Liter	Gallon	Liter	Gallon	kg	lb	mm	in	mm	in	mm	in	mm	in
Integral	FTDW001	1283	339	1262	333	1015	2237	639	25.0	4746	186.9	NA	NA	2619	103.0
Sub-Base	FTDW005 / FTDW016	3941	1041	3876	1024	1659	3657	635	25.0	5550	218.5	NA	NA	2955	116.3
Sub-Base	FTDW006	6980	1844	6818	1801	2228	4912	889	35.0	6184	243.5	NA	NA	3209	126.3
Sub-Base	FTDW011	2476	654	2435	643	1468	3236	635	25.0	3810	150.0	NA	NA	2955	116.3
Sub-Base	FTDW034	10887	2876	9899	2615	2847	6277	914	36	7747	305	NA	NA	3233	127.3

		To	Total		Useable		Tank Only						Overall Package Height with Tank			
C18 Tank Feature	Capacity		Capacity		Dry Weight		Height 'H'		Length 'L'		Open		Enclosure			
Design	Code	Liter	Gallon	Liter	Gallon	kg	lb	mm	in	mm	in	mm	in	mm	in	
Integral	FTDW003	1446	382	1422	376	1015	2237	635	25.0	3814	150.1	NA	NA	2560	100.8	
Integral*	FTDW030	2498	660	2381	629	1681	3703	762	30.0	4995	196.6	2670	105	2675	105.3	
Integral*	FTDW031	5175	1367	4997	1320	2046	4510	762	30.0	6737	265.3	NA	NA	2675	105.3	
Sub-Base	FTDW005 / FTDW016	3941	1041	3876	1024	1659	3657	635	25.0	5550	218.5	NA	NA	2905	114.3	
Sub-Base	FTDW007	8339	2203	8244	2178	2150	4134	889	35.0	7074	278.5	NA	NA	3209	126.3	
Sub-Base	FTDW011	2476	654	2435	643	1468	3236	635	25.0	3810	150.0	NA	NA	2905	114.3	
Sub-Base*	FTDW032	10228	2702	9994	2640	2638	5816	889	35.0	7368	290	NA	NA	3132	123.3	

<sup>\*</sup>For Ratings 650, 700 &750 ekW only

LEHE0467-09 Page 3 of 5





The heights listed above do not include lumber used during manufacturing and shipping.

#### Estimated Run Times (Hours) at 100% Load

C13 Tank			Standby Ra	itings (ekW)		Prime Ratings (ekW)				
Design	Feature Code	400	350			350	320		2 - 1	
Integral Tank	FTDW013	24	27	-	-	25	29	_	_	
Sub-Base	FTDW005 / FTDW016	36	41	_	_	. 38	43	_	_	
Sub-Base	FTDW006	65	72	_	-	72	77	-	-	
Sub-Base	FTDW007	77	87	_	-	81	93	_	_	
Sub-Base	FTDW011	23	25	_	_	24	27		-	

C15 Tank			Standby Ra	atings (ekW	)	Prime Ratings (ekW)				
Design	Feature Code	500	450	400	350	455	410	365	320	
Integral Tank	FTDW001 / FTDW002	9	9	11	11	10	10	11	12	
Sub-Base	FTDW005 / FTDW016	28	29	32	36	30	31	35	38	
Sub-Base	FTDW006	50	52	57	63	54	56	62	67	
Sub-Base	FTDW008 / FTDW011	17	18	20	22	19	20	22	24	
Sub-Base	FTDW034	72	75	82	91	78	81	90	97	

C18 Tank			Standb	y Ratings	s (ekW)		Prime Ratings (ekW)				
Design	Feature Code	750	700	650	600	550	680	635	600	545	500
Integral	FTDW003 / FTDW004	_	-	_	8	9	-	_	-	9	10
Integral*	FTDW030	11	12	13	_	_	12	13	14	-	_
Integral*	FTDW031	24	25	27	_	_	26	27	29	33	36
Sub-Base	FTDW005 / FTDW016	_	-	-	24	25	_		-	25	27
Sub-Base	FTDW007	_	_	_	51	54	_	_	-	54	59
Sub-Base	FTDW008 / FTDW011	-	-	_	15	16	-	-	_	16	17
Sub-Base*	FTDW032	49	51	54	_	_	53	55	58	_	-

<sup>\*</sup>For Ratings 650, 700 &750 ekW only

Page 4 of 5

#### **ATTACHMENTS**



Tanks with full electrical stub-up area include removable end channel. Tanks with RH stub-up include stub- up area directly below the circuit breaker or power terminal strips. Dimensions include weather-protective enclosure exhaust system.

Dual wall sub-base tanks are UL Listed and constructed in accordance with UL Standard for Safety UL 142, Steel Aboveground Tanks for Flammable and Combustible Liquids and Canada CAN/ULC S601, Standard for Shop Fabricated Steel Aboveground Horizontal Tanks for Flammable and Combustible Liquids.

Fuel tanks and applicable options facilitate compliance with the following United States NFPA Code and Standards:

NFPA 30: Flammable and Combustible Liquids Code

NFPA 37: Standard for the Installation and Use of Stationary Combustion Engines and Gas Turbines

NFPA 110: Standard for Emergency and Standby Power Systems

Fuel tanks and applicable options facilitate compliance with the following Canadian Standard and Code:

CSA C282 - Emergency Electrical Power Supply for Buildings

CSA B139-09 - Installation Code for Oil-Burning Equipment

The following sub-base fuel tanks meet Chicago code for containment and labelling:

FTDW005

FTDW008

FTDW011



#### Integral Tanks (continued)

	C18 Integral T	anks FTDW031	
Inches of Fuel on Dipstick	Measured Gallons	Inches of Fuel on Dipstick	Measured Gallons
0.5	31.4	11.5	722.6
1	62.8	12	754
1.5	94.3	12.5	785.4
2	125.7	13	816.9
2.5	157.1	13.5	848.3
3	188.5	14	879.7
3.5	219.9	14.5	911.1
4	251.3	15	942.5
4.5	282.8	15.5	974
5	314.2	16	1005.4
5.5	345.6	16.5	1036.8
6	377	17	1068.2
6.5	408.4	17.5	1099.6
7	439.9	18	1131
7.5	471.3	18.5	1162.5
8	502.7	19	1193.9
8.5	534.1	19.5	1225.3
9	565.5	20	1256.7
9.5	596.9	20.5	1288.1
10	628.4	21	1319.6
10.5	659.8	21.5	1351
11	691.2	22	1382.4

Razor5 LLC - Application for New Source Minor PSD Construction Approval and Title V Operating Permit

**CUMMINS DQFAA 750KW GENERATOR** 



April 21st, 2023

#### To Whom It May Concern:

With regards to Cummins Power Systems (CPS) manufactured diesel generator set model DQFAA rated for 60Hz operation and equipped with Cummins QST30-G5 engine:

When tested under the following conditions:

Table 1	
Fuel Specification:	ASTM D975 No. 2-D S15 diesel fuel with 0.0015% sulfur content (by weight), and 42-48
	cetane number.
Air Inlet Temperature:	77 °F
Fuel Inlet Temperature:	104 °F (at fuel pump inlet)
Barometric Pressure:	29.53 in. Hg
Humidity:	NOx measurement corrected to 75 grains H2O/lb. dry air

Based on engine emissions validation testing, the table below represents the nominal performance and exhaust emissions data for the generator set listed above:

	Standby							
PERFORMANCE DATA	10%	25%	50%	75%	80%	100%		
Power Output (kWe)	75	188	375	563	600	750		
BHP @ 1800 RPM (60 Hz)	130	287	549	811	863	1073		
Fuel Consumption (US Gal/Hr)	9	16	27	39	41	51		
Exhaust Gas Flow (CFM)	1812	2422	3618	4920	5179	6221		
Exhaust Gas Temperature (°F)	423	553	684	768	776	807		
NOx (Oxides of Nitrogen)	6.61	5.76	4.54	3.89	3.90	3.95		
NMHC (Nonmethane Hydrocarbons)	0.34	0.20	0.11	0.10	0.10	0.09		
CO (Carbon Monoxide)	2.3	1.3	0.5	0.4	0.4	0.5		
PM (Particulate Matter)	0.11	0.15	0.13	0.11	0.11	0.10		
	All emissions values above are cited as g/bhp-hr							

Steady-State emissions recorded per ISO8178-1 during operation at rated engine speed (+/-2%) and stated constant load (+/-2%) with engine temperatures, pressures and emission rates stabilized.

The NOx, HC, CO, and PM emission data tabulated here are representative of test data taken from a single engine under the test conditions shown above. Data for the other components are estimated. This data is subject to instrumentation and engine-to-engine variability. Field emissions test data is not guaranteed to these levels. Actual field test results may vary due to test ambient, site conditions, installation, fuel specification, test procedures, instrumentation and ambient correction factors. Engine operation with excessive air intake or exhaust restriction beyond published maximum limits, or with improper maintenance, may result in elevated emission levels.



Values provided in the table below are representative of "Potential Site Variation" for the AWS IAD124 site in Aldie, VA. These values account for variances as indicated above without consideration of improper generator set maintenance.

		Standby							
PERFORMANCE DATA	10%	25%	50%	75%	80%	100%			
Power Output (kWe)	75	188	375	563	600	750			
BHP @ 1800 RPM (60 Hz)	130	287	549	811	863	1073			
NOx (Oxides of Nitrogen)	8.39	7.32	5,77	4.94	4.05	5.02			
NMHC (Nonmethane	8.39	7.32	3.77	4.94	4.95	5.02			
Hydrocarbons)	0.58	0.34	0.19	0.17	0.17	0.15			
CO (Carbon Monoxide)	4.6	2.6	1.0	0.8	0.8	1.0			
PM (Particulate Matter)	0.22	0.30	0.26	0.22	0.22	0.20			
All emissions values above are cited as g/bhp-hr									

Potential Site variation values provided above are accounted for Engine, Ambient variation and measurement with no correction factors.

The values in this letter are applicable for engines operating on ASTM D975 DF2 and paraffinic fuels conforming to EN15940, including Hydrotreated Vegetable Oil (HVO). Please consult Fluids for Cummins Engines bulletin # 3379001 for more information on the applicability of HVO.

The data and information provided in this letter is for informational purposes to assist customers in making purchasing decisions appropriate for their site-specific compliance needs. Owners/operators of compression ignition internal combustion engines are responsible for ensuring compliance with applicable local, state, and federal standards when CI engines are installed at the owner/operator site. The data and information contained herein regarding site variation values in particular should be considered as part of a site-specific compliance evaluation.

This letter does not supersede any of the commercial terms of sale, including, but not limited to, warranty coverage and compliance with law obligations. THE INFORMATION IN THIS LETTER IS PROVIDED "AS IS" AND WITH ALL FAULTS AND DEFECTS. CUMMINS DOES NOT WARRANT THE ACCURACY OF THE INFORMATION PROVIDED AND THIS LETTER SHOULD NOT BE SHARED WITH THIRD PARTIES WITHOUT CUMMINS PRIOR WRITTEN CONSENT. For further questions on this product or application, please contact the local Cummins Sales and Service representative.

Best Regards,

Miguel Araujo

Highel Amis Ch

Application Engineer – Strategic Accounts (Data Center)

**Cummins Power Generation** 


Razor5 LLC - Application for New Source Minor PSD Construction Approval and Title V Operating Permit

CATERPILLER C15 400 KW GENERATOR

## Cat® C15 diesel generator sets



#### Standby & Prime: 60Hz



heage chown raight not is likelt actual configuration

Engine Model	Cat® C15 ACERT™ In-line 6, 4-cycle diesel
Bore x Stroke	137mm x 171mm (5.4in x 6.8in)
Displacement	15.2 L (928 in³)
Compression Ratio	16.1:1
Aspiration	Turbocharged Air-to-Air Aftercooled
Fuel Injection System	MEUI
Governor	Electronic ADEM™ A4

Model	Standby	Prime	Emission Strategy
C15	400 ekW, 500 kVA	365 ekW, 456 k <b>VA</b>	TIER III Non-Road

#### PACKAGE PERFORMANCE


Performance	Standby	Prime
Frequency	60	Hz
Genset Power Rating	500 kVA	456 kVA
Genset power rating with fan @ 0.8 power factor	400 ekW	365 ekW
Emissions	TIER III N	lon-Road
Performance Number	DM8151-03	DM8150-05
Fuel Consumption		
100% load with fan, L/hr (gal/hr)	120.0 (31.7)	110.3 (29.1)
75% load with fan, L/hr (gal/hr)	97.3 (25.7)	91.0 (24.0)
50% load with fan, L/hr (gal/hr)	71.9 (19.0)	66.2 (17.5)
25% load with fan, L/hr (gal/hr)	41.0 (10.8)	38.3 (10.1)
Cooling System <sup>1</sup>		
Radiator air flow restriction (system), kPa (in. Water)	0.12 (0.48)	0.12 (0.48)
Radiator air flow, m3/min (cfm)	720 (25426)	720 (25426)
Engine coolant capacity, L (gal)	20.8 (5.5)	20.8 (5.5)
Radiator coolant capacity, L (gal)	54 (14)	54 (14)
Total coolant capacity, L (gal)	75 (20)	75 (20)
Inlet Air		
Combustion air inlet flow rate, m³/min (cfm)	38.8 (1370.6)	36.9 (1303.2)
Max. Allowable Combustion Air Inlet Temp, °C (°F)	49 (120)	48 (119)
Exhaust System		
Exhaust stack gas temperature, °C (°F)	487.0 (908.6)	479.4 (894.9)
Exhaust gas flow rate, m³/min (cfm)	102.8 (3629.1)	96.2 (3395.2)
Exhaust system backpressure (maximum allowable) kPa (in. water)	10.0 (40.0)	10.0 (40.0)
Heat Rejection		
Heat rejection to jacket water, kW (Btu/min)	165 (9356)	155 (8819)
Heat rejection to exhaust (total) kW (Btu/min)	462 (26284)	429 (24376)
Heat rejection to aftercooler, kW (Btu/min)	111 (6340)	98 (5578)
Heat rejection to atmosphere from engine, kW (Btu/min)	75 (4272)	69 (3937)

LEHE1576-02 1/2



Emissions (Nominal)?	Stan	rdby	P. I	lme
NOx, mg/Nm³ (g/hp-hr)	1578.5 (3.5)		1455.	3 (3.2)
CO, mg/Nm³ (g/hp-hr)	162.5	5 (0.4)	272.0	0 (0.6)
HC, mg/Nm³ (g/hp-hr)	17.3	(0.04)	19.5 (0.05)	
PM, mg/Nm³ (g/hp-hr)	13.9	(0.04)	16.3 (0.04)	
Alternator <sup>3</sup>			a through	
Voltages	480V	600V	480V	600V
Motor starting capability @ 30% Voltage Dip	880 skVA	1057 skVA	880 skVA	1057 skVA
Current	601 amps	481 amps	549 amps	439 amps
Frame Size	LC6114B	LC6124B	LC6114B	LC6124B
Excitation	SE	AR	SE	AR
Temperature Rise	150 ° C	150 ° C	125 ° C	125 ° C

#### **WEIGHTS & DIMENSIONS**



Dim "A" mm (in)	Dim "B" mm (in)	Dim "C" mm (in)	Dry Weight kg (lb)
3476 (137)	1628 (64)	2128 (84)	4066 (8963)

#### APPLICABLE CODES AND STANDARDS:

AS1359, CSA C22.2 No100-04, UL142, UL489, UL869, UL2200, NFPA37, NFPA70, NFPA99, NFPA110, IBC, IEC60034-1, ISO3046, ISO8528, NEMA MG1-22, NEMA MG1-33, 2006/95/EC, 2006/42/EC, 2004/108/EC.

Note: Codes may not be available in all model configurations. Please consult your local Cat Dealer representative for availability.

**STANDBY:** Output available with varying load for the duration of the interruption of the normal source power. Average power output is 70% of the standby power rating. Typical operation is 200 hours per year, with maximum expected usage of 500 hours per year.

**PRIME:** Output available with varying load for an unlimited time. Average power output is 70% of the prime power rating. Typical peak demand is 100% of prime rated ekW with 10% overload capability for emergency use for a maximum of 1 hour in 12. Overload operation cannot exceed 25 hours per year

RATINGS: Ratings are based on SAE J1349 standard conditions. These ratings also apply at ISO3046 standard conditions.

#### **DEFINITIONS AND CONDITIONS**

- <sup>1</sup> For ambient and altitude capabilities consult your Cat dealer. Air flow restriction (system) is added to existing restriction from factory.
- <sup>2</sup> Emissions data measurement procedures are consistent with those described in EPA CFR 40 Part 89, Subpart D & E and ISO8178-1 for measuring HC, CO, PM, NOx. Data shown is based on steady state operating conditions of 77° F, 28.42 in HG and number 2 diesel fuel with 35° API and LHV of 18,390 BTU/lb. The nominal emissions data shown is subject to instrumentation, measurement, facility and engine to engine variations. Emissions data is based on 100% load and thus cannot be used to compare to EPA regulations which use values based on a weighted cycle.
- <sup>3</sup> UL 2200 Listed packages may have oversized generators with a different temperature rise and motor starting characteristics. Generator temperature rise is based on a 40° C ambient per NEMA MG1-32.

#### LET'S DO THE WORK."

Performance Number: DM8151 Change Level: 04

SALES MODEL: BRAND: CAT MACHINE SALES MODEL: ENGINE POWER (BHP): GEN POWER WITH FAN (EKW): 619 400.0 COMPRESSION RATIO: 16.1 RATING LEVEL: STANDBY PUMP QUANTITY: FUEL TYPE: DIESEL MANIFOLD TYPE: DRY GOVERNOR TYPE: ELEC CAMSHAFT TYPE: IGNITION TYPE: STANDARD CI EUI INJECTOR TYPE: REF EXH STACK DIAMETER (IN): MAX OPERATING ALTITUDE (FT): 6,562

COMBUSTION: DIRECT INJECTION ENGINE SPEED (RPM): 1,800 60 31.4 HERTZ: FAN POWER (HP): ASPIRATION: TA ATAAC AFTERCOOLER TYPE: AFTERCOOLER CIRCUIT TYPE: JW+OC, ATAAC INLET MANIFOLD AIR TEMP (F): 120 JACKET WATER TEMP (F): 192.2 TURBO CONFIGURATION: SINGLE TURBO QUANTITY: GTA5518BS-56T-1.58

TURBOCHARGER MODEL: GTA5518I
CERTIFICATION YEAR: 2006
PISTON SPD @ RATED ENG SPD (FT/MIN): 2,025.0

INDUSTRY	SUBINDUSTRY	APPLICATION
ELECTRIC POWER	STANDARD	PACKAGED GENSET
OIL AND GAS	LAND PRODUCTION	PACKAGED GENSET

#### General Performance Data

GENSET POWER	PERCENT LOAD	ENGINE POWER	BRAKE MEAN	BRAKE SPEC	ISO BRAKE SPEC	VOL FUEL	ISO VOL FUEL	ELEC SPEC FUEL	ISO ELEC SPEC
WITH FAN			EFF PRES (BMEP)	FUEL CONSUMPTN	FUEL CONSUMPTN	CONSUMPTN (VFC)	CONSUMPTN (VFC)	CONSUMPTN (ESFC)	FUEL CONSUMPTN
			(BMCF)	(BSFC)	(BSFC)	(0,0)		(ESFC)	(ESFC)
EKW	%	BHP	PSI	LB/BHP-HR	LB/BHP-HR	GAL/HR	GAL/HR	LB/EKW-HR	LB/EKW-HR
400.0	100	619	294	0,359	0.354	31.3	30,8	0,555	0.544
360.0	90	557	264	0.363	0,358	28.5	28,1	0.562	0.551
320.0	80	497	236	0.378	0.372	26.5	26.1	0.586	0.575
300.0	75	467	221	0.385	0.380	25.4	25.0	0.600	0.588
280.0	70	437	207	0,392	0.387	24.2	23.8	0.612	0.600
240.0	60	378	179	0.405	0.399	21.6	21.3	0.637	0.625
200.0	50	319	152	0.416	0.410	18.7	18.5	0.665	0.652
160.0	40	263	125	0.418	0.412	15.5	15.3	0,688	0.675
120.0	30	208	98	0.420	0.414	12.3	12.1	0.726	0.712
100.0	25	179	85	0.423	0,417	10.7	10.5	0.759	0.744
80.0	20	151	72	0.433	0.427	9.2	9,1	0.817	0.802
40.0	10	92.2	44	0,501	0.494	6.5	6.4	1.155	1.133

GENSET POWER WITH FAN	PERCENT LOAD	ENGINE POWER	INLET MFLD PRES	INLET MFLD TEMP	EXH MFLD TEMP	EXH MFLD PRES	ENGINE OUTLET	COMPRESSOR OUTLET PRES	COMPRESSOR OUTLET TEMP
EKW	%	BHP	IN-HG	DEG F	DEG F	IN-HG	DEG F	IN-HG	DEG F
400.0	100	619	65.6	119.6	1,209.5	46.1	908.6	69	385.1
360.0	90	557	60.9	118.8	1,178.8	41.3	893.5	63	364.0
320.0	80	497	57.6	116.5	1,153.7	39.1	879.9	60	353,5
300.0	75	467	55,3	114.7	1,140.9	37.6	873.1	58	346.5
280.0	70	437	52.4	112.8	1,126.7	35.5	866.2	55	336.4
240.0	60	378	45.6	108.3	1,094.2	30.9	852.2	48	311.2
200.0	50	319	37.4	103.2	1,055.6	25.7	837.7	40	278,4
160.0	40	263	26.7	96,9	995.2	19.3	808.5	29	230.5
120.0	30	208	16.4	91.2	915.4	13.4	764.8	18	182.8
100.0	25	179	11.9	88.8	867.9	10.7	737.3	14	160.9
80.0	20	151	8,3	87.1	812.7	8.6	701.0	10	142.7
40.0	10	92,2	3,9	85,6	674.5	6.0	593,1	5	117.3

#### **General Performance Data (Continued)**

GENSET POWE	R PERCENT LOAD	ENGINE POWER	WET INLET AIR VOL		The state of the s	WET EXH GAS	WET EXH VOL	DRY EXH VOL
WITH FAN			FLOW RATE		MASS FLOW RATE	MASS FLOW RATE		FLOW RATE (32
				FLOW RATE				DEG F AND 29.98 IN
海线线线 医线层线							HG)	HG)
EKW	%	BHP	CFM	CFM	LB/HR	LB/HR	FT3/MIN	FT3/MIN

400.0	100	619	1,370.6	3,629.1	5,963.6	5,185.6	1,304.1	1,192.5
360 0	90	557	1,298.7	3,379.0	5,631.7	5,834.1	1,227.7	1,125.4
326.0	90	497	1,265.1	3,249.5	5,479,3	5,667,0	1,192.7	1,096.8
300.0	75	467	1,241.1	3,168.3	5,370.2	5,550.2	1,168.8	1,076.4
280.0	70	437	1,206.1	3,058.6	5,211.4	5,382.8	1,134.3	1,046.0
240.0	60	378	1,118.6	2,796.7	4,818.9	4,972.0	1,048.1	969,0
200,0	50	319	1.005,9	2,472.7	4,318.1	4,451.2	937.1	868,2
160.0	40	263	845.4	2,033.6	3,618.1	3,728.2	788.4	731 9
120.0	30	208	698.4	1,596.0	2,936.4	3,023.5	640.8	596.0
160.0	25	179	618.2	1,393.0	2,632.1	2,708.0	572.2	532,6
80.0	20	151	561.7	1,219.0	2,387.9	2,453.3	516.4	481,6
40.0	10	92.2	490.4	957.1	2,080.5	2,126.7	447.0	421.0

#### Heat Rejection Data

GENSET	PERCENT	ENGINE	REJECTION	REJECTION	REJECTION	EXHAUST	FROM OIL	FROM	WORK	LOW HEAT	HIGH HEAT
POWER WITH FAN	LOAD	POWER	TO JACKET WATER	TO ATMOSPHERE	то ехн	RECOVERY TO 350F	COOLER	AFTERCOOLER	RENERGY	VALUE ENERGY	VALUE ENERGY
EKW	%	BHP	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN
400.0	100	619	9,356	4,272	26,284	14,668	3,625	6,340	26,246	68,058	72,499
360.0	90	557	8,773	3,911	24,231	13,431	3,304	5,531	23,635	62,033	66,081
320.0	30	497	8,344	3,685	22,984	12,687	3,064	5,202	21,066	57,528	61,282
300.0	75	467	8,120	3,607	22,252	12,251	2,938	4,984	19,795	55,159	58,758
280.0	70	437	7,871	3,539	21,338	11,710	2,797	4,668	18,527	52,517	55,944
240.0	60	378	7,340	3,401	19,275	10,502	2,498	3,915	16,022	46,893	49,953
200.0	50	319	6,749	3,223	16,871	9,112	2,171	3,030	13,547	40,761	43,420
160.0	40	263	6,057	3, 171	13,607	7,154	1,797	1,936	11,169	33,738	35,940
120.0	30	208	5,351	2,804	10,399	5,228	1,422	1,077	8,800	26,690	28,431
100.0	25	179	5,003	2,471	8,941	4,361	1,239	760	7,608	23,266	24,784
80,0	20	151	4,542	2,241	7,636	3,566	1,067	532	6,398	20,041	21,349
40,0	10	92.2	3,608	1,907	5,399	2,113	755	265	3,911	14,167	15,091

#### **Emissions Data**

#### OIESEL

#### RATED SPEED NOMINAL DATA: 1800 RPM

GENSET POWER WITH		EKW	400.0	300.0	200.0	100.0	40.0
PERCENT LOAD		%	100	75	50	25	10
ENGINE POWER		BHP	619	467	319	179	92.2
TOTAL NOX (AS NO2)		G/HR	2,141	1,054	646	649	409
TOTAL CO		G/HR	220	722	863	322	280
TOTAL HC		G/HR	27	38	47	35	60
TOTAL CO2		KG/HR	313	253	186	105	63
PART MATTER		G/HR	22.3	21.6	28.8	20.6	18.3
TOTAL NOX (AS NO2)	(CORR 5% O2)	MG/NM3	1,578.5	945.1	808.6	1,454.5	1,344.7
TOTAL CO	(CORR 5% O2)	MG/NM3	162.5	658.4	1,052.1	639.2	1,134.3
TOTAL HC	(CORR 5% O2)	MG/NM3	17.3	30.1	51.0	71.1	208.4
PART MATTER	(CORR 5% O2)	MG/NM3	13.9	16.8	30.5	39.3	60,5
TOTAL NOX (AS NO2)	(CORR 15% O2)	MG/NM3	585.7	350.7	300.0	539.7	499.0
TOTAL CO	(CORR 15% O2)	MG/NM3	60.3	244.3	390.4	237.2	420.9
TOTAL HC	(CORR 15% O2)	MG/NM3	6.4	11.2	18.9	26.4	77.3
PART MATTER	(CORR 15% O2)	MG/NM3	5.2	6.2	11.3	14.6	22.4
TOTAL NOX (AS NO2)	(CORR 5% O2)	PPM	769	460	394	708	655
TOTAL CO	(CORR 5% O2)	PPM	130	527	842	511	907
TOTAL HC	(CORR 5% O2)	PPM	32	56	95	133	389
TOTAL NOX (AS NO2)	(CORR 15% O2)	PPM	285	171	146	263	243
TOTAL CO	(CORR 15% O2)	PPM	48	195	312	190	337
TOTAL HC	(CORR 15% O2)	PPM	12	21	35	49	144
TOTAL NOX (AS NO2)		G/HP-HR	3.49	2.27	2.03	3.63	4.45
TOTAL CO		G/HP-HR	0,36	1.56	2,72	1.80	3,05
TOTAL HC		G/HP-HR	0.04	0.08	0.15	0.19	0.65

PART MATTER	G/HP-HR	0.04	0.05	0.09	0.12	0.20	
TOTAL NOX (AS NO2)	G/KW-HR	4.74	3,09	2.76	4.94	6.05	
TOTAL CO	G/KW-HR	0.49	2.12	3.69	2.45	4.14	
TOTAL HC	G/KW-HR	0.06	0.11	0.20	0.26	0.89	
PART MATTER	G/KW-HR	0.05	0.06	0.12	0.16	0.27	
TOTAL NOX (AS NO2)	LB/HR	4.72	2.32	1.42	1.43	0.90	
TOTAL CO	LB/HR	0.48	1.59	1.90	0.71	0.62	
TOTAL HC	LB/HR	0.06	0.08	0.10	0.08	0.13	
TOTAL CO2	LB/HR	689	557	411	231	138	
PART MATTER	LB/HR	0.05	0.05	0.06	0.05	0.04	
OXYGEN IN EXH	%	10.1	11,2	12.0	12.7	14.6	
DRY SMOKE OPACITY	%	0.5	0.6	1.0	1.2	1.1	
BOSCH SMOKE NUMBER		0.72	0.75	0.86	0.91	0.90	

#### RATED SPEED POTENTIAL SITE VARIATION: 1800 RPM

GENSET POWER WITH FAN		EKW	400.0	300.0	200.0	100,0	40.0
PERCENT LOAD		%	100	75	50	25	10
ENGINE POWER		BHP	619	467	319	179	92.2
TOTAL NOX (AS NO2)		G/HR	2,591	1,275	781	785	495
TOTAL CO		G/HR	411	1,351	1,614	602	524
TOTAL HC		G/HR	51	71	89	65	113
PART MATTER		G/HR	43.6	42.1	56.1	40.2	35.7
TOTAL NOX (AS NO2)	(CORR 5% O2)	MG/NM3	1,910.0	1,143.6	978,4	1,759.9	1,627.1
TOTAL CO	(CORR 5% O2)	MG/NM3	303.9	1,231.2	1,967.5	1,195.3	2,121.2
TOTAL HC	(CORR 5% O2)	MG/NM3	32.6	57.0	96.4	134.3	393.9
PART MATTER	(CORR 5% O2)	MG/NM3	27.1	32,8	59.4	76.7	117.9
TOTAL NOX (AS NO2)	(CORR 15% O2)	MG/NM3	708.7	424.4	363,0	653.0	603.8
TOTAL CO	(CORR 15% O2)	MG/NM3	112.8	456.8	730.1	443.6	787.1
TOTAL HC	(CORR 15% O2)	MG/NM3	12.1	21.1	35.8	49.8	146.2
PART MATTER	(CORR 15% O2)	MG/NM3	10.1	12.2	22.1	28.5	43.8
TOTAL NOX (AS NO2)	(CORR 5% O2)	PPM	930	557	477	857	793
TOTAL CO	(CORR 5% O2)	PPM	243	985	1,574	956	1,697
TOTAL HC	(CORR 5% O2)	PPM	61	106	180	251	735
TOTAL NOX (AS NO2)	(CORR 15% O2)	PPM	345	207	177	318	294
TOTAL CO	(CORR 15% O2)	PPM	90	365	584	355	630
TOTAL HC	(CORR 15% O2)	PPM	23	39	67	93	273
TOTAL NOX (AS NO2)		G/HP-HR	4.22	2.75	2.46	4.40	5.39
TOTAL CO		G/HP-HR	0.67	2.91	5.08	3.37	5.70
TOTAL HC		G/HP-HR	0.08	0.15	0.28	0.37	1.23
PART MATTER		G/HP-HR	0.07	0.09	0.18	0.22	0.39
TOTAL NOX (AS NO2)		G/KW-HR	5.73	3.74	3.34	5.98	7.33
TOTAL CO		G/KW-HR	0.91	3.96	6.91	4.58	7.75
TOTAL HC		G/KW-HR	0.11	0.21	0.38	0.50	1.68
PART MATTER		G/KW-HR	0.10	0,12	0.24	0.31	0.53
TOTAL NOX (AS NO2)		LB/HR	5.71	2.81	1.72	1.73	1.09
TOTAL CO		LB/HR	0.91	2.98	3.56	1.33	1.15
TOTAL HC		LB/HR	0.11	0.16	0.20	0.14	0.25
PART MATTER		LB/HR	0.10	0,09	0,12	0.09	0.08

#### Regulatory Information

EPA TIER 3		200	05 - 2010					
GASEOUS EMISSIONS DAT	TA MEASUREMENTS PROVIDED T	TO THE EPA ARE CONSISTENT WITH THO	OSE DESCRIBED IN EPA 40 CFR PA	ART 89 SUBPART D AND ISO 8178 FOR MEASURING HC,				
CO, PM, AND NOX. THE "MAX LIMITS" SHOWN BELOW ARE WEIGHTED CYCLE AVERAGES AND ARE IN COMPLIANCE WITH THE NON-ROAD REGULATIONS.								
Locality	Agency	Regulation	Tier/Stage	Max Limits - G/BKW - HR				
U.S. (INCL CALIF)	EPA	NON-ROAD	TIER 3	CO: 3.5 NOx + HC: 4.0 PM: 0.20				

EPA EMERGENCY STATION	ARY	2011							
GASEOUS EMISSIONS DATA	MEASUREMENTS PROVIDED	TO THE EPA ARE CONSISTENT WITH THOS	SE DESCRIBED IN EPA 40 CFR PART 60 SUI	BPART IIII AND ISO 8178 FOR MEASURING HC,					
CO, PM, AND NOX. THE "MAX LIMITS" SHOWN BELOW ARE WEIGHTED CYCLE AVERAGES AND ARE IN COMPLIANCE WITH THE EMERGENCY STATIONARY REGULATIONS.									
Locality	Agency	Regulation	Tier/Stage	Max Limits - G/BKW - HR					
U.S. (INCL CALIF)	EPA	STATIONARY	EMERGENCY STATIONARY	CO: 3.5 NOx + HC: 4.0 PM: 0.20					

#### Altitude Derate Data

#### STANDARD

#### ALTITUDE CORRECTED POWER CAPABILITY (BHP)

AMBIENT OPERATING	30 }	40	50	60	70	80	90	100	110	120	130	140	NORMAL
TEMP (F)													
ALTITUDE													
(FT)													
0	619	619	619	619	619	619	619	619	619	619	619	619	619
1,000	619	619	619	619	619	619	619	619	619	619	619	619	619
2,000	619	619	619	619	619	619	619	619	619	619	619	619	619
3,000	619	619	619	619	619	619	619	619	619	619	619	619	619
4,000	619	619	619	619	619	619	619	619	619	619	619	613	619
5,000	619	619	619	619	619	619	619	619	619	610	599	589	619
ó,000	619	619	619	619	619	619	618	607	596	586	576	566	619
7,000	619	619	619	619	616	605	594	583	573	563	554	544	619
6,000	619	619	615	604	592	581	571	560	551	541	532	523	615
9,000	615	603	591	580	569	558	548	538	529	520	511	502	595
10,000	590	579	567	556	546	536	526	517	508	499	490	482	575
11,000	567	555	544	534	524	514	505	496	487	479	471	463	556
12,000	544	533	522	512	502	493	484	476	467	459	451	444	537
13,000	521	511	501	491	482	473	464	456	448	440	433	426	519
14,000	500	490	480	471	462	453	445	437	429	422	415	408	501
15,000	479	469	460	451	442	434	426	419	411	404	397	391	483

#### Cross Reference

Test Spec	Setting	Engine Arrangemen	t Engineering Mod	lel Engineering Model Version	l Start Effective Serial Number	End Effective Serial Number
0K6279	PP5608	2729743	GS282	-	FSE00001	
0K6279	PP5608	2864922	GS282	-	FTE00001	

#### Performance Parameter Reference

Parameters Reference:DM9600-14
PERFORMANCE DEFINITIONS

PERFORMANCE DEFINITIONS DM9600

APPLICATION:

Engine performance tolerance values below are representative of a typical production engine tested in a calibrated dynamometer test cell at SAE J1995 standard reference conditions. Caterpillar maintains ISO9001:2000 certified quality management systems for engine test Facilities to assure accurate calibration of test equipment. Engine test data is corrected in accordance with SAE J1995. Additional reference material SAE J1228, J1349, ISO 8665, 3046-1:2002E, 3046-3:1989, 1585, 2534, 2288, and 9249 may apply in part or are similar to SAE J1995. Special engine rating request (SERR) test data shall be noted.

PERFORMANCE PARAMETER TOLERANCE FACTORS:
Power +/- 3%
Exhaust stack temperature +/- 8%

Exhaust stack temperature +/- 8% Inlet airflow +/- 5% Intake manifold pressure-gage +/- 10%

Exhaust flow +/- 6% Specific fuel consumption +/- 3%

Fuel rate +/- 5%

Specific DEF consumption +/- 3%

DEF rate +/- 5%

Heat rejection +/- 5%

Heat rejection exhaust only +/- 10%

Heat rejection CEM only +/- 10%

Heat Rejection values based on using treated water.

Torque is included for truck and industrial applications, do not

use for Gen Set or steady state applications.

On C7 - C18 engines, at speeds of 1100 RPM and under these values

#### PERFORMANCE DATAIDM81511

are provided for reference only, and may not meet the tolerance

On 3500 and C175 engines, at speeds below Peak Torque these values are provided for reference only, and may not meet the tolerance

These values do not apply to C280/3600. For these models, see the

tolerances listed below.

C280/3600 HEAT REJECTION TOLERANCE FACTORS:

Heat rejection +/- 10%

Heat rejection to Atmosphere +/- 50%

Heat rejection to Lube Oil +/- 20%

Heat rejection to Aftercooler +1- 5%

TEST CELL TRANSDUCER TOLERANCE FACTORS:

Torque +/- 0.5%

Speed +/- 0.2%

Fuel flow +/- 1.0%

Temperature +/- 2.0 C degrees

Intake manifold pressure +/- 0.1 kPa

OBSERVED ENGINE PERFORMANCE IS CORRECTED TO SAE J1995 REFERENCE

AIR AND FUEL CONDITIONS

REFERENCE ATMOSPHERIC INLET AIR

FOR 3500 ENGINES AND SMALLER

SAE J1228 AUG2002 for marine engines, and J1995 JAN2014 for other

engines, reference atmospheric pressure is 100 KPA (29.61 in ng),

and standard temperature is 25deg C (77 deg F) at 30% relative

humidity at the stated aftercooler water temp, or inlet manifold

temp.

FOR 3600 ENGINES

Engine rating obtained and presented in accordance with ISO 3046/1 and SAE J1995 JANJAN2014 reference atmospheric pressure is 100

KPA (29.61 in hg), and standard temperature is 25deg C (77 deg F) at 30% relative humidity and 150M altitude at the stated

aftercooler water temperature.

MEASUREMENT LOCATION FOR INLET AIR TEMPERATURE

Location for air temperature measurement air cleaner inlet at

stabilized operating conditions.

REFERENCE EXHAUST STACK DIAMETER

The Reference Exhaust Stack Diameter published with this dataset is only used for the calculation of Smoke Opacity values displayed

in this dataset. This value does not necessarily represent the

actual stack diameter of the engine due to the variety of exhaust

stack adapter options available. Consult the price list, engine order or general dimension drawings for the actual stack diameter

size ordered or options available.

REFERENCE FUEL

DIESEL

Reference fuel is #2 distillate diesel with a 35API gravity;

A lower heating value is 42,780 KJ/KG (18,390 BTU/LB) when used at

15 deg C (59 deg F), where the density is

850 G/Liter (7.0936 Lbs/Gal).

Reference natural gas fuel has a lower heating value of 33.74 KJ/L

(905 BTU/CU Ft), Low BTU ratings are based on 18,64 KJ/L (500

BTU/CU FT) lower heating value gas. Propane ratings are based on 87.56 KJ/L (2350 BTU/CU Ft) lower heating value gas.

ENGINE POWER (NET) IS THE CORRECTED FLYWHEEL POWER (GROSS) LESS

EXTERNAL AUXILIARY LOAD

Engine corrected gross output includes the power required to drive

standard equipment; lube oil, scavenge lube oil, fuel transfer,

common rail fuel, separate circuit aftercooler and jacket water pumps. Engine net power available for the external (flywheel)

load is calculated by subtracting the sum of auxiliary load from

the corrected gross flywheel out put power. Typical auxiliary loads are radiator cooling fans, hydraulic pumps, air compressors

and battery charging alternators. For Tier 4 ratings additional

Parasitic losses would also include Intake, and Exhaust Restrictions.

ALTITUDE CAPABILITY

Altitude capability is the maximum altitude above sea level at standard temperature and standard pressure at which the engine could develop full rated output power on the current performance

Standard temperature values versus altitude could be seen on TM2001.

When viewing the altitude capability chart the ambient temperature

is the inlet air temp at the compressor inlet.

Engines with ADEM MEUI and HEUI fuel systems operating at

conditions above the defined altitude capability derate for atmospheric pressure and temperature conditions outside the values

defined, see TM2001. Mechanical governor controlled unit injector engines require a

setting change for operation at conditions above the altitude defined on the engine performance sheet. See your Caterpillar

technical representative for non standard ratings REGULATIONS AND PRODUCT COMPLIANCE

TMI Emissions information is presented at 'nominal' and 'Potential Site Variation' values for standard ratings. No tolerances are applied to the emissions data. These values are subject to change

at any time. The controlling federal and local emission

requirements need to be verified by your Caterpillar technical representative.

Customer's may have special emission site requirements that need to be verified by the Caterpillar Product Group engineer.

EMISSION CYCLE LIMITS.

Cycle emissions Max Limits apply to cycle-weighted averages only.

Emissions at individual load points may exceed the cycle-weighted

limit.

WET & DRY EXHAUST/EMISSIONS DESCRIPTION:

Wet - Total exhaust flow or concentration of total exhaust flow

Dry - Total exhaust flow minus water vapor or concentration of exhaust

flow with water vapor excluded

EMISSIONS DEFINITIONS: Emissions: DM1176

EMISSION CYCLE DEFINITIONS

For constant-speed marine engines for ship main propulsion, including, diesel-electric drive, test cycle E2 shall be applied,

for controllable-pitch propeller sets

test cycle E2 shall be applied.

2. For propeller-law-operated main and propeller-law-operated

auxiliary engines the test cycle E3 shall be applied.

3. For constant-speed auxiliary engines test cycle D2 shall be applied.

4. For variable-speed, variable-load auxiliary engines, not included above, test cycle C1 shall be applied.

HEAT REJECTION DEFINITIONS:

Diesel Circuit Type and HHV Balance : DM9500

HIGH DISPLACEMENT (HD) DEFINITIONS:

3500: EM1500 RATING DEFINITIONS: Agriculture : TM6008

Fire Pump : TM6009 Generator Set : TM6035

Generator (Gas): TM6041

Industrial Diesel: TM6010

Industrial (Gas): TM6040 Irrigation: TM5749

Locomotive: TM6037

Marine Auxiliary: TM6036 Marine Prop (Except 3600): TM5747 Marine Prop (3600 only): TM5748

MSHA: TM6042

Oil Field (Petroleum) : TM6011

Off-Highway Truck : TM6039 On-Highway Truck : TM6038

SOUND DEFINITIONS:

Sound Power: DM8702


Sound Pressure: TM7080

Razor5 LLC - Application for New Source Minor PSD Construction Approval and Title V Operating Permit

CATERPILLER C9 250 KW GENERATOR



#### Standby & Prime: 60Hz



lmaga ahowa nighi nat reflect notual configuration

Engine Model	Cat® C9 ACER™ in-line 6, 4-cycle diesel
Bore x Stroke	112mm x 149mm (4.4in x 5.9in)
Displacement	8.8 L (538 in <sup>3</sup> )
Compression Ratio	16.1:1
Aspiration	Turbocharged Air-to-Air Aftercooled
Fuel Injection System	HEUI
Governor	Electronic ADEM <sup>™</sup> A4

Model	Standby	Prime	Emission Strategy
C9	250 ekW, 313 kVA	225 ekW, 281 kVA	TIER III Non-Road

#### PACKAGE PERFORMANCE


Performance	Standby	Prime	
Frequency	60	Hz	
Genset Power Rating	313 kVA	281 kVA	
Genset power rating with fan @ 0.8 power factor	250 ekW	225 ekW	
Emissions	TIER III N	lon-Road	
Performance Number	DM8501-03	DM8505-03	
Fuel Consumption			
100% load with fan, L/hr (gal/hr)	73.3 (19.4)	68.9 (18.2)	
75% load with fan, L/hr (gal/hr)	58.8 (15.5)	55.7 (14.7)	
50% load with fan, L/hr (gal/hr)	43.8 (11.6)	42.0 (11.1)	
25% load with fan, L/hr (gal/hr)	27.4 (7.3)	27.2 (7.2)	
Cooling System <sup>1</sup>	The second of the second		
Radiator air flow restriction (system), kPa (in. Water)	0.12 (0.48)	0.12 (0.48)	
Radiator air flow, m3/min (cfm)	497 (17551)	497 (17551)	
Engine coolant capacity, L (gal)	13.9 (3.7)	13.9 (3.7)	
Radiator coolant capacity, L (gal)	43 (11.5)	43 (11.5)	
Total coolant capacity, L (gal)	57 (15)	57 (15)	
Inlet Air			
Combustion air inlet flow rate, m³/min (cfm)	25.2 (889.8)	24.2 (855.3)	
Max. Allowable Combustion Air Inlet Temp, °C (°F)	50 (122)	50 (122)	
Exhaust System			
Exhaust stack gas temperature, °C (°F)	455.5 (852.0)	444.1 (831.3)	
Exhaust gas flow rate, m³/min (cfm)	63.6 (2245.6)	59.8 (2112.4)	
Exhaust system backpressure (maximum allowable) kPa (in. water)	10.0 (40.0)	10.0 (40.0)	
Heat Rejection	-c254 3	MARCH WAR	
Heat rejection to jacket water, kW (Btu/min)	104 (5928)	99 (5631)	
Heat rejection to exhaust (total) kW (Btu/min)	277 (15772)	259 (14720)	
Heat rejection to aftercooler, kW (Btu/min)	82 (4686)	72 (4115)	
Heat rejection to atmosphere from engine, kW (Btu/min)	18 (1004)	26 (1500)	


## Cat® C9 DIESEL GENERATOR SETS



	Y 15 CONT. TO MAKE	- n	the state of		
Emissions (Nominal) <sup>2</sup>		andby	, July	ine	
NOx, mg/Nm³ (g/hp-hr)	1516	6.2 (2.9)	1355	.4 (2.7)	
CO, mg/Nm³ (g/hp-hr)	172	.8 (0.4)	188.9 (0.4)		
HC, mg/Nm³ (g/hp-hr)	37.	7 (0.1)	44.2 (0.1)		
PM, mg/Nm³ (g/hp-hr)	32.	6 (0.1)	37.0	(0.1)	
Alternator <sup>3</sup>					
Voltages	480V	600V	480V	600V	
Motor starting capability @ 30% Voltage Dip	543 skVA	656 skVA	543 skVA	656 skVA	
Current	376 amps	301 amps	338 amps	271 amps	
Frame Size	LC5014H	LC5024H	LC5014H	LC5024H	
Excitation	SE	AR	SE	AR	
Temperature Rise	150 ° C	150 ° C	105 ° C	105 ° C	

#### **WEIGHTS & DIMENSIONS**





Dim "A" mm (in)	Dim "B" mm (in)	Dim "C" mm (in)	Dry Weight kg (lb)
3091 (122)	1622 (64)	2066 (82)	2248 (4956)

#### APPLICABLE CODES AND STANDARDS:

AS1359, CSA C22.2 No100-04, UL142, UL489, UL869, UL2200, NFPA37, NFPA70, NFPA99, NFPA110, IBC, IEC60034-1, ISO3046, ISO8528, NEMA MG1-22, NEMA MG1-33, 2006/95/EC, 2006/42/EC, 2004/108/EC

Note: Codes may not be available in all model configurations. Please consult your local Cat Dealer representative for availability.

**STANDBY:** Output available with varying load for the duration of the interruption of the normal source power. Average power output is 70% of the standby power rating. Typical operation is 200 hours per year, with maximum expected usage of 500 hours per year.

PRIME: Output available with varying load for an unlimited time. Average power output is 70% of the prime power rating. Typical peak demand is 100% of prime rated ekW with 10% overload capability for emergency use for a maximum of 1 hour in 12. Overload operation cannot exceed 25 hours per year

RATINGS: Ratings are based on SAE J1349 standard conditions. These ratings also apply at ISO3046 standard conditions.

#### **DEFINITIONS AND CONDITIONS**

- <sup>1</sup> For ambient and altitude capabilities consult your Cat dealer. Air flow restriction (system) is added to existing restriction from factory.
- <sup>2</sup> Emissions data measurement procedures are consistent with those described in EPA CFR 40 Part 89, Subpart D & E and ISO8178-1 for measuring HC, CO, PM, NOx. Data shown is based on steady state operating conditions of 77° F, 28.42 in HG and number 2 diesel fuel with 35° API and LHV of 18,390 BTU/lb. The nominal emissions data shown is subject to instrumentation, measurement, facility and engine to engine variations. Emissions data is based on 100% load and thus cannot be used to compare to EPA regulations which use values based on a weighted cycle.
- <sup>3</sup> UL 2200 Listed packages may have oversized generators with a different temperature rise and motor starting characteristics. Generator temperature rise is based on a 40° C ambient per NEMA MG1-32.

#### LET'S DO THE WORK.

www.Cat.com/electricpower

#### August 10, 2021

For Help Desk Phone Numbers Click here

Perf No: DM8501						Change Level:
General Heat Re	jection	Emissions	Regulatory	Altitude Derate	Cross Reference	Perf Param Ref
View PDF	a o o o o o o o o o o o o o o o o o o o	enderwise saarvangen dieskroot van vanderwer en	and these recognitions are the annual sections and the sections and the sections are the sections and the sections are the sections are the sections are the sections are the section are the			4 Saga
SALES MODEL:		C9	COMBUSTI	ON:		DIRECT INJECTION
BRAND:		CAT	ENGINE SP	EED (RPM):		1,860
ENGINE POWER (BHP):		398	HERTZ:			60
GEN POWER W/O FAN (EKW	):	265.0	FAN POWE	R (HP):		30.2
GEN POWER WITH FAN (EKV	V):	250.0	ASPIRATIO	n:		TA
COMPRESSION RATIO:		16.1	AFTERCOO	LER TYPE:		ATAAC
RATING LEVEL:		STANDBY	AFTERCOO	LER CIRCUIT TYPE:		JW+OC, ATAAC
PUMP QUANTITY:		1	INLET MAN	IFOLD AIR TEMP (F	<sup>=</sup> ):	122
UEL TYPE:		DIESEL	JACKET WA	TER TEMP (F):		192.2
AANIFOLD TYPE:		DRY	TURBO CO	NFIGURATION:		SINGLE
GOVERNOR TYPE:		ELEC	TURBO QU	ANTITY:		1
CAMSHAFT TYPE:		STANDARD	TURBOCHA	RGER MODEL:		S310-1.25
GNITION TYPE:		CI	CERTIFICA	TION YEAR:		2005
NJECTOR TYPE:		EUI	PISTON SP	D @ RATED ENG SP	D (FT/MIN):	1,759.8
REF EXH STACK DIAMETER (	IN):	4				
MAX OPERATING ALTITUDE	(FT):	3,281				
INDUSTRY	and the second	SUB INDU	ISTRY	A BOOK TO A TALL AND A TO THE ACCOUNT	APPLICATION	The Control of the Co
ELECTRIC POWER		STANDARD			PACKAGED GENSET	
OIL AND GAS		LAND PROI	DUCTION		PACKAGED GENSET	

#### General Performance Data Top

GENSET POWER WITH FAN	PERCENT LOAD	ENGINE POWER	BRAKE MEAN EFF PRES (BMEP)	BRAKE SPEC FUEL CONSUMPTN (BSFC)	VOL FUEL CONSUMPTN (VFC)
EKW	%	ВНР	PSI	LB/BHP-HR	GAL/HR
250.0	100	398	326	0.341	19.1
225.0	90	359	294	0.346	17.5
200.0	80	321	263	0,355	16.0
187.5	75	302	247	0,360	15.3
175.0	70	284	232	0.364	14.6
150.0	60	247	202	0.374	13.0
125.0	50	211	172	0.385	11.4
100.0	40	176	144	0.394	9.8
75.0	30	141	116	0.404	8.0
62.5	25	124	101	0.410	7.2
50.0	20	106	87	0.418	6.2
25.0	10	68.9	56	0.445	4.3

GENSET POWER WITH FAN	PERCENT LOAD	ENGINE POWER	INLET MFLD PRES	INLET MFLD TEMP	EXH MFLD TEMP	EXH MFLD PRES	ENGINE OUTLET TEMP	COMPRESSOR OUTLET PRES	COMPRESSOR OUTLET TEMP
EKW	%	BHP	IN-HG	DEG F	DEG F	IN-HG	DEG F	IN-HG	DEG F
250.0	100	398	77 <b>.7</b>	122.3	1,142.4	55.4	852.0	79	425.2
225.0	90	359	74.1	121.6	1,094.4	51.6	823.5	75	407.9
200.0	80	321	70 <b>.7</b>	122.1	1,050.1	48.2	800.5	72	390.0
187.5	75	302	69.0	122.5	1,029.4	46.4	790.7	70	380.5
175.0	70	284	66.6	122.4	1,010.3	44.2	782.4	67	370.2
150.0	60	247	60.6	122.2	973.8	39.4	768.3	61	346.6

GENSET POWER WITH FAN	PERCENT LOAD	ENGINE POWER	INLET MFLD PRES	INLET MFLD TEMP	EXH MFLD TEMP	EXH MFLD PRES	ENGINE OUTLET TEMP	COMPRESSOR OUTLET PRES	COMPRESSOR OUTLET TEMP
125.0	50	211	53.2	121.8	937.9	33.9	755.8	54	318.8
100.0	40	176	43.3	121.2	899.4	27.4	742.4	44	280.7
75.0	30	141	32.2	120.7	857.9	20.5	727.9	33	236.6
62.5	25	124	26.7	120.5	835.9	17.2	720.5	27	214.1
50.0	20	106	21.3	120.3	812.9	14.1	712.7	22	191.5
25.0	10	68.9	12.1	120.5	671.3	9.1	612.1	13	150.2

GENSET POWER WITH FAN	PERCENT LOAD	ENGINE POWER	WET INLET AIR VOL FLOW RATE	ENGINE OUTLET WET EXH GAS VOL FLOW RATE	WET INLET AIR MASS FLOW RATE	WET EXH GAS MASS FLOW RATE	WET EXH VOL FLOW RATE (32 DEG F AND 29.98 IN HG)	DRY EXH VOL FLOW RATE (32 DEG F AND 29.98 IN HG)
EKW	%	ВНР	CFM	CFM	LB/HR	LB/HR	FT3/MIN	FT3/MIN
250.0	100	398	889.8	2,245.6	3,863.5	3,999.1	841.8	776.8
225.0	90	359	866.1	2,131.2	3,753.5	3,877.8	816.6	756.7
200.0	80	321	845.5	2,029.1	3,641.7	3,755.4	791.7	736.4
187.5	75	302	833.2	1,976.5	3,583.9	3,692.5	777.2	724.2
175.0	70	284	815.6	1,915.7	3,500.2	3,603.4	758.3	707.7
150.0	60	247	770.3	1,777.1	3,290.5	3,382.8	711.5	666.0
125.0	50	211	711.6	1,616.1	3,025.9	3,107.0	653.7	613.6
100.0	40	176	631.2	1,409.7	2,668.7	2,738.1	576.6	542.5
75.0	30	141	539.6	1,189.0	2,266.0	2,323.1	492.3	464.1
62.5	25	124	493.0	1,076.6	2,063.6	2,114.4	448.5	423.3
50.0	20	106	447.1	961.4	1,865.3	1,909.6	403.2	380.9
25.0	10	68.9	365.7	720.7	1,521.7	1,552.4	330.6	314.7

#### Heat Rejection Data Top

GENSET			and representative and control of the second	TATION CONTRACTOR AND AND ADDRESS OF THE	#/	garter . B Bella A. 1886 Marchago		- 4		LOW	HIGH
POWER WITH FAN	PERCENT LOAD	ENGINE POWER	REJECTION TO JACKET WATER	REJECTION TO ATMOSPHERE	REJECTION TO EXH	EXHAUST RECOVERY TO 350F	FROM OIL COOLER	FROM AFTERCOOLER	WORK ENERGY	HEAT VALUE	HEAT VALUE ENERGY
EKW	%	ВНР	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN	BTU/MIN
250.0	100	398	5,928	1,004	15,772	8,470	2,214	4,686	16,886	41,564	44,276
225.0	90	359	5,517	890	14,624	7,716	2,028	4,305	15,231	38,081	40,566
200.0	80	321	5,156	844	13,650	7,085	1,859	3,906	13,615	34,894	37,171
187.5	75	302	4,986	796	13,203	6,804	1,775	3,702	12,819	33,332	35,507
175.0	70	284	4,811	750	12,693	6,507	1,688	3,474	12,026	31,686	33,754
150.0	60	247	4,487	657	11,600	5,894	1,508	2,957	10,466	28,319	30,167
125.0	50	211	4,177	565	10,395	5,241	1,323	2,387	8,931	24,835	26,456
100.0	40	176	3,834	664	8,956	4,456	1,131	1,704	7,458	21,230	22,615
75.0	30	141	3,407	764	7,418	3,634	932	1,052	5,989	17,489	18,630
62.5	25	124	3,174	722	6,658	3,239	829	773	5,246	15,560	16,575
50.0	20	106	2,926	591	5,915	2,861	723	532	4,490	13,570	14,455
25.0	10	68.9	2,390	520	4,011	1,661	501	182	2,923	9,412	10,026

#### Emissions Data Top

Units Filter All Units 🗸



#### **DIESEL**

#### **RATED SPEED NOMINAL DATA: 1800 RPM**

GENSET POWER WITH FAN ENGINE POWER	EKW BHP	250.0 398	187.5 302	125.0 211	62.5 124	25.0 68.9
PERCENT LOAD	%	100	75	50	25	10
TOTAL NOX (AS NO2)	G/HR	1,150	661	419	260	205
TOTAL CO	G/HR	144	145	113	152	144
TOTAL HC	G/HR	36	47	48	37	38
TOTAL CO2	KG/HR	193	155	115	71	43
PART MATTER	G/HR	32.1	33.9	25.1	25.1	17.5

GENSET POWER WITH FAN ENGINE POWER		EKW BHP	250.0 398	187.5 302	125.0 211	62.5 124	25.0 68.9
PERCENT LOAD		º/o	100	75	50	25	10
TOTAL NOX (AS NO2) TOTAL CO TOTAL HC PART MATTER TOTAL NOX (AS NO2) TOTAL CO TOTAL HC TOTAL NOX (AS NO2) TOTAL CO TOTAL CO TOTAL HC PART MATTER TOTAL NOX (AS NO2) TOTAL CO	(CORR 5% O2) (CORR 5% O2) (CORR 5% O2) (CORR 5% O2) (CORR 5% O2) (CORR 5% O2) (CORR 5% O2)	MG/NM3 MG/NM3 MG/NM3 MG/NM3 PPM PPM PPM G/HP-HR G/HP-HR G/HP-HR LB/HR LB/HR	1,516.2 172.8 37.7 32.6 739 138 70 2.91 0.36 0.09 0.08 2.54 0.32	1,083.8 215.5 59.9 43.3 528 172 112 2.20 0.48 0.15 0.11 1.46 0.32	918.3 229.8 93.6 43.2 447 184 156 2.00 0.54 0.23 0.12 0.92	939.9 496.4 111.9 76.0 458 397 209 2.11 1.23 0.30 0.20 0.57 0.34	1,312.7 785.9 195.8 79.5 639 629 365 2.98 2.08 0.55 0.25 0.45 0.32
TOTAL HC		LB/HR	0.08	0.10	0.11	0.08	0.08
TOTAL CO2		LB/HR	425	342	255	156	94 0.04
PART MATTER		LB/HR %	0.07	0.07	0.06	0.06	
OXYGEN IN EXH DRY SMOKE OPACITY		%	10.2	11.6 0.8	12.7 0.8	13.7	15.0 0.9
BOSCH SMOKE NUMBER		70	0.5 0.39	0.67	0.66	1.4 1.21	0.84

#### RATED SPEED POTENTIAL SITE VARIATION: 1800 RPM

GENSET POWER WITH FAN ENGINE POWER		EKW 8HP	25 <b>0.0</b> 398	187.5 302	125.0 211	62.5 124	25.0 68.9
PERCENT LOAD		%	100	75	50	25	10
TOTAL NOX (AS NO2) TOTAL CO TOTAL HC PART MATTER TOTAL NOX (AS NO2) TOTAL CO TOTAL HC PART MATTER TOTAL NOX (AS NO2) TOTAL CO TOTAL HC TOTAL NOX (AS NO2) TOTAL CO TOTAL HC TOTAL NOX (AS NO2) TOTAL CO TOTAL HC PART MATTER TOTAL NOX (AS NO2)	(CORR 5% O2) (CORR 5% O2) (CORR 5% O2) (CORR 5% O2) (CORR 5% O2) (CORR 5% O2) (CORR 5% O2)	G/HR G/HR G/HR G/HR MG/NM3 MG/NM3 MG/NM3 MG/NM3 PPM PPM PPM G/HP-HR G/HP-HR G/HP-HR LB/HR LB/HR	1,242 270 69 62.6 1,637.5 323.2 71.2 63.7 798 259 133 3.14 0.68 0.17 0.16 2.74 0.59	714 271 88 66.0 1,170.5 403.0 113.1 84.4 570 322 211 2.38 0.90 0.29 0.29 1.57 0.60	452 211 92 49.0 991.8 429.8 157.9 84.3 483 344 295 2.16 1.01 0.44 0.23 1.00 0.47	281 284 70 49.0 1,015.1 928.3 211.5 148.3 494 743 395 2.27 2.30 0.57 0.40 0.62 0.63	222 268 71 34.1 1,417.8 1,469.7 370.0 155.0 691 1,176 691 3.22 3.89 1.03 0.49 0.49
TOTAL HC PART MATTER		LB/HR LB/HR	0.15 0.14	0.19 0.15	0.20 0.11	0.15 0.11	0.16 0.08

#### Regulatory Information Top

EPA TIER 3		2005 - 2010		
,	ASURING HC, CO,	PM, AND NOX. THE		ENT WITH THOSE DESCRIBED IN EPA 40 CFR PART 89 SUBPA IN BELOW ARE WEIGHTED CYCLE AVERAGES AND ARE IN
<b>Locality</b> U.S. (INCL CALIF)	<b>Agency</b> EPA	<b>Regulation</b> NON-ROAD	Tier/Stage TIER 3	Max Limits - G/BKW - HR CO: 3.5 NOx + HC: 4.0 PM: 0.20
EPA EMERGENCY STAT	IONARY	2011	dia di kuwa kawa 1985 katawa na mai kata ini kata ini di kata ini kata ini kata ini kata ini kata ini kata ini Maja jangaran kata ini kata i	Farming Mah, 2020 State and State State State of the American State of the State of
	EASURING HC, C	D, PM, AND NOX. TH	IE "MAX LIMITS" SHO	ENT WITH THOSE DESCRIBED IN EPA 40 CFR PART 60 SUBPA WN BELOW ARE WEIGHTED CYCLE AVERAGES AND ARE IN
<b>Locality</b> U.S. (INCL CALIF)	<b>Agency</b> EPA	<b>Regulation</b> STATIONARY	Tier/Stage EMERGENCY STATE	Max Limits - G/BKW - HR IONARY CO: 3.5 NOx + HC: 4.0 PM: 0.20

#### Altitude Derate Data Top

#### **STANDARD**

#### ALTITUDE CORRECTED POWER CAPABILITY (BHP)

AMBIENT OPERATING TEMP (F)	30	40	50	50	70	80	90	100	110	120	130	140	NORMAL
ALTITUDE (FT)													
0	398	398	398	398	398	398	398	398	398	398	398	398	398
1,000	398	398	398	398	398	398	398	398	398	398	395	389	398
2,000	398	398	398	398	398	398	398	398	394	387	380	374	398
3,000	398	398	398	398	398	398	393	386	379	372	366	360	398
4,000	398	398	398	398	392	385	378	371	365	358	352	346	396
5,000	398	398	392	384	377	370	363	357	351	345	339	333	384
6,000	392	384	377	370	363	356	349	343	337	331	326	320	372
7,000	377	369	362	355	349	342	336	330	324	318	313	308	360
8,000	362	355	348	341	335	329	323	317	311	306	301	296	348
9,000	348	341	334	328	322	316	310	304	299	294	289	284	337
10,000	334	327	321	315	309	303	297	292	287	282	277	273	325
11,000	320	314	308	302	296	291	285	280	275	271	266	262	314
12,000	307	301	295	290	284	279	274	269	264	260	255	251	304
13,000	295	289	283	278	272	267	263	258	253	249	245	241	293
14,000	282	277	271	266	261	256	252	247	243	239	235	231	283
15,000	271	265	260	255	250	246	241	237	233	229	225	221	273

#### Cross Reference Too

Test Spec	Setting	Engine Arrangement	Engineering Model	Engineering Model Version	Start Effective Serial Number	End Effective Serial Number
0K6612	NAP	2575707	GS279	-	S9L00001	
0K6612	NAP	3950368	GS279	-	S9P00001	
4150078	PP5548	3950368	GS279	-	S9P00001	
4150078	PP5548	4529865	GS857	LS	S9P00001	
4150078	PP5548	5664658	PG350	G	RG300001	
4150078	PP5548	5664658	PG375	G	RE300001	DOM A 1

#### Performance Parameter Reference Top

Parameters Reference: DM9600 - 12

PERFORMANCE DEFINITIONS

#### PERFORMANCE DEFINITIONS DM9600

**APPLICATION:** Engine performance tolerance values below are representative of a typical production engine tested in a calibrated dynamometer test cell at SAE J1995 standard reference conditions. Caterpillar maintains ISO9001:2000 certified quality management systems for engine test Facilities to assure accurate calibration of test equipment. Engine test data is corrected in accordance with SAE J1995. Additional reference material SAE J1228, J1349, ISO 8665, 3046-1:2002E, 3046-3:1989, 1585, 2534, 2288, and 9249 may apply in part or are similar to SAE J1995. Special engine rating request (SERR) test data shall be noted.

PERFORMANCE PARAMETER TOLERANCE FACTORS: Power +/- 3% Torque +/- 3% Exhaust stack temperature +/- 8% Inlet airflow +/- 5% Intake manifold pressure-gage +/- 10% Exhaust flow +/- 6% Specific fuel consumption +/- 3% Fuel rate +/- 5% Specific DEF consumption +/- 3% DEF rate +/- 5% Heat rejection +/- 5% Heat rejection exhaust only +/- 10% Heat rejection CEM only +/- 10%

Heat Rejection values based on using treated water.

Torque is included for truck and industrial applications, do not use for Gen Set or steady state applications.

On C7 - C18 engines, at speeds of 1100 RPM and under these values are provided for reference only, and may not meet the tolerance listed.

These values do not apply to C280/3600. For these models, see the tolerances listed below.

C280/3600 HEAT REJECTION TOLERANCE FACTORS: Heat rejection +/- 10% Heat rejection to Atmosphere +/- 50% Heat rejection to Lube Oil +/- 20% Heat rejection to Aftercooler +/- 5%

TEST CELL TRANSDUCER TOLERANCE FACTORS: Torque +/- 0.5% Speed +/- 0.2% Fuel flow +/- 1.0% Temperature +/- 2.0 C degrees Intake manifold pressure +/- 0.1 kPa
OBSERVED ENGINE PERFORMANCE IS CORRECTED TO SAE J1995 REFERENCE AIR AND FUEL CONDITIONS.

REFERENCE ATMOSPHERIC INLET AIR <u>FOR 3500 ENGINES AND SMALLER</u> SAE J1228 AUG2002 for marine engines, and J1995 JAN2014 for other engines, reference atmospheric pressure is 100 KPA (29.61 in hg), and standard temperature is

25deg C (77 deg F) at 30% relative humidity at the stated aftercooler water temp, or inlet manifold temp.

FOR 3600 ENGINES Engine rating obtained and presented in accordance with ISO 3046/1 and SAE J1995 JANJAN2014

reference atmospheric pressure is 100 KPA (29.61 in hg), and standard temperature is 25deg C (77 deg F) at 30% relative humidity and 150M altitude at the stated aftercooler water temperature.

MEASUREMENT LOCATION FOR INLET AIR TEMPERATURE Location for air temperature measurement air cleaner inlet at stabilized operating conditions.

REFERENCE EXHAUST STACK DIAMETER The Reference Exhaust Stack Diameter published with this dataset is only used for the calculation of Smoke Opacity values displayed in this dataset. This value does not necessarily represent the actual stack diameter of the engine due to the variety of exhaust stack adapter options available. Consult the price list, engine order or general dimension drawings for the actual stack diameter size ordered or options available.

REFERENCE FUEL <u>DIESEL</u> Reference fuel is #2 distillate diesel with a 35API gravity; A lower heating value is 42,780 KJ/KG (18,390 BTU/LB) when used at 15 deg C (59 deg F), where the density is 850 G/Liter (7.0936 Lbs/Gal).

<u>GAS</u> Reference natural gas fuel has a lower heating value of 33.74 KJ/L (905 BTU/CU Ft). Low BTU ratings are based on 18.64 KJ/L (500 BTU/CU FT) lower heating value gas. Propane ratings are based on 87.56 KJ/L (2350 BTU/CU Ft) lower heating value gas.

ENGINE POWER (NET) IS THE CORRECTED FLYWHEEL POWER (GROSS) LESS EXTERNAL AUXILIARY LOAD Engine corrected gross output includes the power required to drive standard equipment; lube oil, scavenge lube oil, fuel transfer, common rail fuel, separate circuit aftercooler and jacket water pumps. Engine net power available for the external (flywheel) load is calculated by subtracting the sum of auxiliary load from the corrected gross flywheel out put power. Typical auxiliary loads are radiator cooling fans, hydraulic pumps, air compressors and battery charging alternators. For Tier 4 ratings additional Parasitic losses would also include Intake, and Exhaust Restrictions.

ALTITUDE CAPABILITY Altitude capability is the maximum altitude above sea level at standard temperature and standard pressure at which the engine could develop full rated output power on the current performance data set.

Standard temperature values versus altitude could be seen on TM2001.

When viewing the altitude capability chart the ambient temperature is the inlet air temp at the compressor inlet. Engines with ADEM MEUI and HEUI fuel systems operating at conditions above the defined altitude capability derate for atmospheric pressure and temperature conditions outside the values defined, see TM2001.

Mechanical governor controlled unit injector engines require a setting change for operation at conditions above the altitude defined on the engine performance sheet. See your Caterpillar technical representative for non standard ratings.

REGULATIONS AND PRODUCT COMPLIANCE TMI Emissions information is presented at 'nominal' and 'Potential Site Variation' values for standard ratings. No tolerances are applied to the emissions data. These values are subject to change at any time. The controlling federal and local emission requirements need to be verified by your Caterpillar technical representative.

Customer's may have special emission site requirements that need to be verified by the Caterpillar Product Group engineer.

EMISSION CYCLE LIMITS: Cycle emissions Max Limits apply to cycle-weighted averages only. Emissions at individual load points may exceed the cycle-weighted limit.

EMISSIONS DEFINITIONS: Emissions: DM1176

#### **EMISSION CYCLE DEFINITIONS**

- 1. For constant-speed marine engines for ship main propulsion, including, diesel-electric drive, test cycle E2 shall be applied, for controllable-pitch propeller sets test cycle E2 shall be applied.
- 2. For propeller-law-operated main and propeller-law-operated auxiliary engines the test cycle E3 shall be applied.
- 3. For constant-speed auxiliary engines test cycle D2 shall be applied.
- 4. For variable-speed, variable-load auxiliary engines, not included above, test cycle C1 shall be applied.

HEAT REJECTION DEFINITIONS: Diesel Circuit Type and HHV Balance: DM9500

HIGH DISPLACEMENT (HD) DEFINITIONS: 3500: EM1500

RATING DEFINITIONS: Agriculture: TM6008

Fire Pump: TM6009 Generator Set: TM6035 Generator (Gas): TM6041 Industrial Diesel: TM6010 Industrial (Gas): TM6040 Irrigation: TM5749 Locomotive: TM6037 Marine Auxiliary: TM6036

Marine Prop (Except 3600): TM5747 Marine Prop (3600 only): TM5748 MSHA: TM6042 Oil Field (Petroleum): TM6011

Oil Field (Petroleum) : TM6011 Off-Highway Truck : TM6039 On-Highway Truck : TM6038


SOUND DEFINITIONS: Sound Power: DM8702

Sound Pressure: TM7080

Date Released: 07/10/19

## Cat® GC enclosures





# SOUND ATTEMUATED LEVEL 2 ENCLOSURES D250GC — D600GC 60 Hz

#### **FEATURES**

#### **Robust/Highly Corrosion Resistant Construction**

- Factory installed on skid base or tanks base
- Environmentally friendly, polyester powder baked paint
- Enclosure constructed with 18-gauge steel
- Interior zinc plated fasteners
- Internally mounted exhaust silencing system
- Comply with ASCE/SEI 7 for Wind loads up to 100mph
- Designed and tested to comply with UL 2200 Listed generator set package

#### **Excellent Access**

- Large cable entry area for installation ease.
- Accommodates side mounted single or multiple breakers.
- Two doors on both sides.
- Vertically hinged allow 180° opening rotation
- Radiator fill cover.

#### **Security and Safety**

- Lockable access doors which give full access to control panel and breaker.
- Cooling fan and battery charging alternator fully guarded.
- Fuel fill, oil fill and battery can only be reached via lockable access.
- Externally mounted emergency stop button (Optional).
- Designed for spreader bar lifting to ensure safety.
- Stub-up area is rodent proof.

#### Sound Attenuated Level 2

- Caterpillar white paint
- UL Listed integral fuel tank with 24 hours running time capacity (Optional).
- DC lighting package (Optional)

## Cat® GC ENCLOSURES




#### **Enclosure Package Operating Characteristics**


Enclosure Type	Standby ek <i>V</i> V	•	j Air How ate		bient bility*	Sound Pressure Levels (dBA) at 7m (23 ft)	
		m³/s	cfm	°C	°F	100% Load	
. The Market Art of Committee of Strangers of the Committee of the Committ	250	6.4	13561	57	135	74	
Level 2 Sound Attenuated Enclosure (Steel)	300	6.4	13561	51	125	74	
	350	7.4	15680	57	134	71	
	400	7.4	15680	53	127	71	
	450	8.4	17692	54	130	73	
	500	8.4	17692	50	122	73	
	550	11.2	23731	56	133	73	
	600	11.2	23731	53	127	73	

<sup>\*</sup>Cooling system performance at sea level. Consult your Cat\* dealer for sile specific ambient and altitude capabilities.

Note: Sound level measurements are subject to instrumentation, installation and manufacturing variability, as well as ambient site conditions.

#### DIMENSIONS





Sound Attenuated Enclosure on Skid Base





Image shown might not reflect actual configuration



Sound Attenuated Enclosure on a UL Listed Integral Fuel Tank Base

## Cat® GC enclosures

#### WEIGHTS & DIMENSIONS

Enclosure Type	Standby Ratings,	Length, L		Width,W		Height H		Package Weights	
	ekW	mm	in	mm	in	mm	in	kg	lb
Sound Attenuated Enclosure on Skid Base	250 300	3958	155.8	1440	56.7	1991	78.4	2857 2945	6298.6 6492.6
	350 400	4633	182.4	1630	64.2	2227	87.7	3983 4017	8781.0 8856.0
	450	4823	189.8	1630	64.2	2227	87.7	4408	9718.0
	500 550	4980	196.1	1865	73.4	2172	85.5	4457 4754	9826.0 10480.8
	600							4837	10663.8
Sound Attenuated Enclosure on UL Listed Integral Fuel Tank Base	250 300	3958	155.8	1440	56.7	2487	97.9	3497 3585	7709.6 7903.6
	350 400	4633	182.4	1630	64.2	2644	104.1	4765 4799	10505.0 10580.0
	450 500	4823	189.8	1630	64.2	2777	109.3	5345 5394	11783.7 11891.7
	550 600	4980	196.1	1865	73.4	2723	107.2	5973 6056	13168.2 13351.2
Sound Attenuated Enclosure on UL Listed Extended Integral Fuel Tank Base	250 300	4608	181.4	1430	56.3	2379	93.7	3590 3678	7914.6 8108.6
	350 400	5251	203.7	1620	63.8	2561	100.8	4876 4910	10749.7 10824.7
	450 500	5909	232.6	1620	63.8	2612	102.8	5497 5546	12118.8 12226.8
	550 600	6759	266.1	1865	73.4	2487	97.9	6237 6320	13750.2 13933.2

## **LET'S DO THE WORK.**

LEHE2014-4(11-20)

risceived State of Indians

EM 95 200

Mid

Dept of Environmental Argmy Office of Air Quality

## Envelope Recycle me

CHICAGO, IL 60600

RIFF IMIKD LUL

10 IDEM, OAQ AIR PERMITS BRANCH ATTN: INCOMING APPLICATION 100 N SENATE AVENUE IGCN 1003

#### INDIANAPOLIS IN 46204

(000) 000 - 0000

REF: PN 1940106677

Fedex Express

TRK# 2762 9839 1328

TUE - 25 JUN 10:30A PRIORITY OVERNIGHT

XP GSHA

46204

IN-US IND



<sup>≈7</sup>809

1 10:30 A