



**UNDERGROUND STORAGE
TANK INSPECTION REPORT**

INDIANA DEPARTMENT OF
ENVIRONMENTAL MANAGEMENT

UST FAC ID: **40058**

Inspector's Name:	Matthew James
Date:	June 26, 2024
Time In:	12:15
Time Out:	01:00
Inspection Type:	Initial

FACILITY NAME / LOCATION

FACILITY NAME Battle Ground Middle School		FACILITY ADDRESS (number and street) 6100 N 50 W		
ADDRESS (line 2)	CITY West Lafayette	STATE IN	ZIP CODE 47906	COUNTY Tippecanoe

UST OWNER

UST Owner Name (If in Individual Capacity) Tippecanoe Co. NMSE School Building Corp				BUSINESS ID (From the Secretary of State) 2005030700368
PREFIX	FIRST NAME Mark	MI	LAST NAME Deyoung	SUFFIX
TELEPHONE NUMBER	EMAIL ADDRESS glhaltom@tsc.k12.in.us			

UST OPERATOR

UST Operator Name (If in Individual Capacity) Tippecanoe County School Corporation				BUSINESS ID (From the Secretary of State)
PREFIX	FIRST NAME	MI	LAST NAME	SUFFIX
TELEPHONE NUMBER	EMAIL ADDRESS glhaltom@tsc.k12.in.us			

PROPERTY OWNER

UST Property Owner Name (If in Individual Capacity) Tippecanoe Co. NMSE School Building Corp				BUSINESS ID (From the Secretary of State) 2005030700368
PREFIX	FIRST NAME Mark	MI	LAST NAME Deyoung	SUFFIX
TELEPHONE NUMBER	EMAIL ADDRESS glhaltom@tsc.k12.in.us			

COMPLIANCE ELEMENTS

All USTs properly registered and up-to-date notification form on file	<input checked="" type="checkbox"/>	YES	<input type="checkbox"/>	NO	<input type="checkbox"/>	UNK	
O/O is in compliance with reporting & record keeping requirements	<input type="checkbox"/>	YES	<input checked="" type="checkbox"/>	NO	<input type="checkbox"/>	UNK	
O/O is in compliance with release reporting or investigation	<input type="checkbox"/>	YES	<input type="checkbox"/>	NO	<input checked="" type="checkbox"/>	N/A	UNK
O/O is in compliance with all UST closure requirements	<input type="checkbox"/>	YES	<input type="checkbox"/>	NO	<input checked="" type="checkbox"/>	N/A	UNK
O/O has met all financial responsibility requirements	<input checked="" type="checkbox"/>	YES	<input type="checkbox"/>	NO	<input type="checkbox"/>	N/A	UNK
40 CFR 280, Subpart A installation requirements (partially excluded) met	<input checked="" type="checkbox"/>	YES	<input type="checkbox"/>	NO	<input type="checkbox"/>	N/A	UNK
40 CFR 280, Subpart B installation and upgrade requirements met	<input checked="" type="checkbox"/>	YES	<input type="checkbox"/>	NO	<input type="checkbox"/>	UNK	
40 CFR 280, Subpart C spill/overfill control requirements met	<input checked="" type="checkbox"/>	YES	<input type="checkbox"/>	NO	<input type="checkbox"/>	N/A	UNK
40 CFR 280, Subpart C compatibility requirements met	<input checked="" type="checkbox"/>	YES	<input type="checkbox"/>	NO	<input type="checkbox"/>	N/A	UNK
40 CFR 280, Subpart C O&M and testing requirements met	<input type="checkbox"/>	YES	<input checked="" type="checkbox"/>	NO	<input type="checkbox"/>	UNK	
Need LLD, LTT, spill bucket, sump/UDC, overfill and ATG testing. Need walk through document.							
40 CFR 280, Subpart D release detection requirements met	<input type="checkbox"/>	YES	<input checked="" type="checkbox"/>	NO	<input type="checkbox"/>	UNK	
Need interstitial monitoring records for tanks and piping.							
40 CFR 280, Subpart J operator training requirements met	<input type="checkbox"/>	YES	<input checked="" type="checkbox"/>	NO	<input type="checkbox"/>	UNK	
Need A, B and C training certificates.							