



# Indiana Department of Environmental Management

## Emergency Response Incident Report

### Description

Incident # 112883

**Incident Description:** Diesel from a pump onto the ground  
**Incident Type:** Emergency Response-Reportable Spill  
**Occurred Date/Time:** 06/11/2024 8:30 pm  
**Regulatory Program:** Emergency Response  
**Sub-Program:** Commercial  
**Follow-Up Priority:** 3-Low  
**Follow-Up Status:** Closed  
**Incident Priority:** 3-Low  
**Incident Status:** Closed  
**Closure Method:** Emergency Response Complete  
**Weather Condition:** Calm  
**Lead Investigator:** Caldwell, Dwayne  
**Resolution Desc:** Correspondence

	Parameter	CAS #	Quantity	Units
<b>Substances/Impacts:</b>	Diesel	68334305	2	gallons

**Media Impacted:** Paved Surface

### Location

**Location Description:** Petro Travel Center  
14000 IN-28  
Gaston  
Delaware County  
**Region Code:** Indianapolis Office  
**County:** Delaware  
**Municipality:** Gaston  
**Latitude DD:** 40.278  
**Longitude DD:** -85.5527  
**Method:** Interpolation-Map  
**System:** Lat.\Long - Decimal Degrees  
**Datum:** NAD83  
**Collected By:** IDEM Staff



# Indiana Department of Environmental Management

## Emergency Response Incident Report

### Source Entity

**Source Type:** Agency Interest

**Source Entity Name:** Petro Stopping Center

**Address 1:** 14000 SR 28 W

**Municipality:** Gaston

**County:** Delaware

**State:** IN

**Zip Code:** 47342

**Telecom:** Business phone number 1 7653583326

### Reporter

**Received By:** Caldwell, Dwayne

**Received Date/Time:** 06/12/2024 9:04:18 am

**Receipt Method:** Emergency Response Hotline

**Reporter Type:** Anonymous

**Comments:** NRC#1401594

### Actions

Task	Staff Assigned	Start Date	Due Date	Completed Date	Hours Spent
Complete Emergency Response Comments: sent to VFC	Caldwell, Dwayne			06/12/2024	
Conduct Follow-up Comments: OSC spoke with Terry the Fuel Manager. She stated a customer walked away from fueling and the auto stop failed releasing ~ 2 gallons of diesel. They applied absorbent and the company sent a contractor out to finish cleaning. No further IDEM involvement needed.	Caldwell, Dwayne			06/12/2024	
Lead ER Staff Comments: Per NRC; CALLER IS REPORTING A DISCHARGE OF DIESEL FROM A FUEL PUMP ONTO THE GROUND. THE CAUSE OF THE DISCHARGE IS UNKNOWN. CALLER STATES THAT SOME KITTY LITTER WAS APPLIED BUT THERE IS STILL STANDING PRODUCT ON THE GROUND.	Caldwell, Dwayne			06/12/2024	