

From: [Scott Blackwell](#)
To: [IDEM WWWiolationresponse](#)
Subject: Response for noncompliance letter
Date: Wednesday, June 26, 2024 2:10:06 PM

**** This is an EXTERNAL email. Exercise caution. DO NOT open attachments or click links from unknown senders or unexpected email. ****

A. - We have included sample and analysis times to the bench sheet and we are calibrating the ph meter daily.

B.- We have raised our sample volume up to 1000mL and we have replaced the desiccant.

C. - We are trying new cleaning and rinsing techniques for the BOD bottles.

D.- We are having success with shaking the sample bottle to get the DO below 9.0 mg/L and keeping it stored at 20 degrees Celsius.

E.- We are running duplicate and blanks for TSS and CBOD

F.- We are now recording the set up time and the read out times for Ecoli

G.- Revised bench sheet to include sample, analysis times and method for ammonia

H.- We have not completed the DMR-QA but we are reaching out to complete it.

Becky Ruark visited our lab on June 20, 2024 to give assistance to our operators.

Thank you
Scott Blackwell