



NONCOMPLIANCE 24-HOUR NOTIFICATION REPORT

State Form 52415 (R / 10-13)

Indiana Department of Environmental Management
Office of Water Quality

INSTRUCTIONS: Complete all sections of this form and email it to Office of Water Quality, Compliance Data Section at wwreports@idem.IN.gov. Thorough completion of this report will satisfy the Office of Water Quality (OWQ) telephone and 5-day written noncompliance notification reporting requirements of your NPDES permit. To speak with someone in OWQ, call (317) 232-8670.

Additionally, any noncompliance which may pose a significant danger to human health or the environment (including a fish kill) must be immediately reported to the Emergency Response Section spill response line at: (317) 233-7745 or toll free within Indiana at (888) 233-7745.

FACILITY INFORMATION		
Facility Name	County	NPDES Permit Number
William Edwin Ross WWTF	Wayne	IN0025615
Individual Reporting	Telephone Number	Reporting Date (month, day, year)
Tim L Orrill	765-983-7447	6/27/2024
Email Address		
torrill@richmondindiana.gov		

NONCOMPLIANCE INFORMATION				
Date (month, day, year)	Outfall	Parameter	Permit Limit (Units/Daily/Weekly/Ave/Max/Min)	Monitored Value
6/26/2024	001	Ecoli	235 Daily Max.	365.4
Date (month, day, year)	Outfall	Parameter	Permit Limit (Units/Daily/Weekly/Ave/Max/Min)	Monitored Value

Description of the Noncompliance and its Cause:
 Violation of permit # IN0025615 has taken place for the daily maximum Ecoli with a value of 365.4 MPN on 6/26/2024 and realized on 6/27/24, no clear suspected issues have attributed to the the violation. No POTW operational changes have occurred however flow decreases and plant size may have caused a period of regrowth through the contact tank. The District believes these events along with high humidity for the week resulted in the violation seen.

Description of the Period of Noncompliance, Including Exact Dates and Time, and if the Noncompliance has not been Corrected, the Anticipated Time it is Expected to Continue:
 Period of noncompliance, the District has seen low flow, high humidity and nonsignificant rain events, no CSO overflows. Solids inventory and ammonia concentration is showing normal levels. Plant is undergoing some site construction on aeration basins. Due to the nature of the analysis, the District is unaware of continued noncompliance. Chlorine feed has been increased, and multiple Ecoli samples taken for the day will act as initial corrective actions.

Steps Taken or Planned to Reduce, Eliminate, and Prevent Reoccurrence of the Noncompliance:
 The District at this point is unclear as to steps to reduce or eliminate reoccurrence of the Ecoli issue. Results tomorrow will help show either a trending problem or corrective action success. As mentioned multiple Ecoli samples were taken along with increased addition of chlorine. This Ecoli noncompliance was the District's first for June 2024 and we expect to remove the violation using the "10%" rule.

CERTIFICATION AND SIGNATURE	
I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	
SIGNATURE: <u>Tim Orrill</u>	DATE (month, day, year): <u>6/27/2024</u>