



**MONTHLY REPORT OF OPERATION
WATER TREATMENT PLANT**

State Form 34609 (R11 / 1-17)

INDIANA DEPARTMENT OF
ENVIRONMENTAL MANAGEMENT

System Name Town Of Odon PWSID Number IN 5124005

For the Month of May Year 2024 IDEM Field Rep. Anna Readle

Signed Robert Franklin Title Operator

I certify **under penalty of law**, by this signature that this document was prepared by me, or under my direction, and the information submitted is to the best of my knowledge and belief, true, accurate, and complete.
I am also aware that there are significant penalties for submitting false information.

Certification Number 823579

PHYSICAL AND CHEMICAL DATA *

Date	Turbidity		Alkalinity		pH		Hardness		Iron		Manganese		Phosphate	Fluoride
	Raw	Finished	Raw	Finished	Raw	Finished	Raw	Finished	Raw	Finished	Raw	Finished	Finished	Finished
1									.9	.03	.23	.02		
2									1.0	.02	.23	.01		
3									1.0	.04	.23	.00		
4									1.0	.03	.23	.01		
5									1.0	.03	.21	.00		
6									.8	.02	.23	.00		
7					8.3				.8	.02	.21	.00		
8									.9	.00	.24	.02		
9									1.0	.01	.24	.01		
10									.9	.03	.22	.02		
11									1.0	.02	.21	.02		
12									.9	.01	.22	.01		
13									.9	.02	.21	.00		
14					8.2				1.1	.00	.23	.00		
15									1.0	.00	.23	.00		
16									.9	.03	.23	.01		
17									1.0	.00	.22	.00		
18									1.0	.00	.23	.02		
19									.8	.00	.23	.04		
20					8.2				.8	.01	.19	.00		
21									.7	.03	.20	.00		
22									.8	.00	.21	.00		
23									.9	.00	.25	.01		
24									.8	.02	.22	.00		
25									1.1	.03	.23	.01		
26									1.0	.02	.22	.02		
27									.9	.01	.23	.00		
28					8.3				.5	.00	.21	.03		
29									.8	.00	.21	.04		
30									.7	.00	.21	.04		
31									.9	.01	.23	.02		

* All parameters are to be expressed in mg/l except pH and turbidity.

DUE BY THE 10TH OF THE MONTH FOLLOWING THE REPORTING PERIOD.

Date	Water Treated 1000 gallons	Chemicals Used – Pounds								Filters		Chlorine Residual				Remarks	
		Salt	Alum	Lime	Soda Ash	<i>pracie</i> Sodium Chlorine	Fluoride	Phos- phate	Filter Run (hours)	Gallons per wash x 1000	Plant Tap		D. S.				
											Free	Total	Free	Total			
1	154					2.2	1.5					1.0	1.1	.8	.9		
2	143					2.9	1.8					1.0	1.1	.8	.9		
3	146					9.4	1.5			46.0	15	1.0	1.1	.7	.9		
4	170					9.7	1.6					1.0	1.1	.8	.9		
5	133					5.5	1.2					1.0	1.0	.9	.9		
6	135					5.8	1.0					.9	1.0	.8	.8		
7	162					6.6	1.3					1.0	1.1	.8	.8		
8	143					5.7	1.5					1.0	1.0	.8	.9		
9	143					6.1	1.2					1.0	1.0	.7	.9		
10	139					5.7	1.2			45.7		1.0	1.1	.8	.8		
11	177					7.3	1.6					1.0	1.0	.8	.9		
12	150					4.8	1.3					.9	1.0	.8	.9		
13	108					2.0	.9					.9	1.0	.7	.8		
14	153					3.3	1.4					.9	1.0	.8	.9		
15	140					2.9	1.3					.9	1.0	.7	.8		
16	147					3.0	1.4			37.7		1.0	1.1	.8	.8		
17	149					3.3	1.4					.9	1.0	.8	.9		
18	136					2.7	1.8					.8	.9	.7	.8		
19	165					3.4	2.3					.8	.8	.8	.8		
20	137					2.6	1.3					1.0	1.1	.8	.8		
21	158					3.4	1.5					.9	1.0	.8	.9	Monthly Water Treatment	
22	161					3.4	1.6					1.0	1.1	.8	.8	Total Gallons 4,497,000	
23	155					3.3	1.1					.9	1.1	.8	.9	Max. Day 170,000	
24	138					2.8	1.0			48.1		1.0	1.1	.8	.9	Min. Day 84,000	
25	169					3.6	1.7					1.0	1.1	.8	.9	Avg. Daily 145,000	
26	133					2.7	1.0					1.0	1.0	.9	.9	E-Mail To: DWBMRO@idem.in.gov	
27	84					1.6	.6					1.0	1.0	.7	.8	Mail To: Indiana Department of Environmental Management Drinking Water Branch 100 N. Senate Ave. Room N1201 Indianapolis, IN 46204-2237	
28	135					2.4	1.4					1.1	1.1	.8	.9		
29	144					1.0	1.5					1.1	1.1	.8	.9		
30	143					3.1	1.0			30.8		1.0	1.1	.7	.8		
31	147					3.0	1.3					1.1	1.1	.8	.9		