

**INFORMATION ABOUT YOUR DRINKING WATER  
GROUNDWATER RULE  
Monitoring and Reporting Requirements Not Met for:  
Etna Acres Golf Club**

Our water system recently failed to collect source water sample(s) for fecal indicators following a total coliform-positive routine distribution system sample collected on **September 21, 2020**. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what we are doing to correct this situation.

**What should I do?** There is nothing you need to do at this time. You do not need to boil your water or take other corrective actions. You may continue to drink the water.

**What does this mean?** This is not an immediate risk. If it had been, you would have been notified immediately. If a situation arises where the water is no longer safe to drink, you will be notified within 24 hours.

**What Happened? What is being done? Explain below.**

We anticipate resolving the problem within has been resolved & every test since then has been absent.

For more information, please contact the public water system:

Contact Name: Jodie Dale Phone Number: 260 468-4290

*\*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.\**

This notice is being sent to you by: IN2350858 Etna Acres Golf Club

Date Distributed: 6-19-24

Certification of Public Notice

PWSID# IN2350858 PWS Name: Etna Acres Golf Club

For Violation: GWR Monitoring & Reporting Occurring in: September 2020

The public water system indicated above hereby affirms that the public notice has been provided to consumers in accordance with the delivery, content, and format requirements and deadline in 327 IAC 8-2.1-7

Name & Signature of System Representative: Jodie Dale Date: 6-19-24