





**EZY CHEK SYSTEMS**  
**PRODUCT LINE TEST**  
**FINAL REPORT**

**TEST DATE** 2/21/2024

**Testing Company Information**

Name: Oscar W. Larson

Address:

City:

Phone:

**Test Location Information**

Name: PARADISE EXPRESS

Address: 2040 N. 200 W.

City: Angola

Phone:

Contact:

**Technician Information**

Name: Chris Akey

Cert #: 80-8574

**Applied Pressure** 1.5X

**PRODUCT LINE TEST**  
**FINAL REPORT**


<i>Product Type</i>	<i>Line ID Number</i> <i>(if applicable)</i>	<input checked="" type="checkbox"/> <i>Pass</i>	<input checked="" type="checkbox"/> <i>Fail</i>
Diesel	1		<input checked="" type="checkbox"/>

Comments/Recommendations: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Technician Signature 

Date: 2/21/2024



**EZY CHEK SYSTEMS**  
**PRODUCT LINE TESTER**  
**DATA SHEET**

Oscar W. Larson Co.  
 10100 Dixie Hwy.  
 Clarkston, MI 48348

Service Call Number  
 240219-0039

**TEST DATE** 3/13/2024

<input type="radio"/> Clarkston, MI 248-620-0070	<input type="radio"/> Grand Rapids, MI 616-698-0001
<input type="radio"/> Dearborn, MI 810-217-6524	<input type="radio"/> Gaylord, MI 989-732-4190
<input type="radio"/> Columbus, OH 1-800-819-7750	<input checked="" type="checkbox"/> Fort Wayne, IN 260-496-9870
<input type="radio"/> Toledo, OH 419-873-0555	<input type="radio"/> Indianapolis, IN 317-337-9473

**Test Location Information**

Name: PARADISE EXPRESS  
 Address: 2040 N. 200 W.  
 City: Angola  
 Phone: \_\_\_\_\_  
 Contact \_\_\_\_\_

**Technician Information**

Name Chris Akey  
 Cert # 80-8574

**Applied Pressure** 1.5X

**Product Type:** Diesel

TIME	DATA	-/+	GPL	RES	GPH
13:50	70		0.0037		
14:05	69.5	-0.5	0.0037	-0.00185	-0.0074
14:20	69	-0.5	0.0037	-0.00185	-0.0074
14:35	68.5	-0.5	0.0037	-0.00185	-0.0074
14:50	68	-0.5	0.0037	-0.00185	-0.0074
15:05	67.5	-0.5	0.0037	-0.00185	-0.0074

**Final Result:** PASS

**Product Type:** \_\_\_\_\_

TIME	DATA	-/+	GPL	RES	GPH
			0.0037		
		0	0.0037	0	0
		0	0.0037	0	0
		0	0.0037	0	0
		0	0.0037	0	0
		0	0.0037	0	0

**Final Result:** \_\_\_\_\_

**Product Type:** \_\_\_\_\_

TIME	DATA	-/+	GPL	RES	GPH
			0.0037		
		0	0.0037	0	0
		0	0.0037	0	0
		0	0.0037	0	0
		0	0.0037	0	0
		0	0.0037	0	0

**Final Result:** \_\_\_\_\_

**Product Type:** \_\_\_\_\_

TIME	DATA	-/+	GPL	RES	GPH
			0.0037		
		0	0.0037	0	0
		0	0.0037	0	0
		0	0.0037	0	0
		0	0.0037	0	0
		0	0.0037	0	0

**Final Result:** \_\_\_\_\_

**Product Type:** \_\_\_\_\_

TIME	DATA	-/+	GPL	RES	GPH
			0.0037		
		0	0.0037	0	0
		0	0.0037	0	0
		0	0.0037	0	0
		0	0.0037	0	0
		0	0.0037	0	0

**Final Result:** \_\_\_\_\_

**Product Type:** \_\_\_\_\_

TIME	DATA	-/+	GPL	RES	GPH
			0.0037		
		0	0.0037	0	0
		0	0.0037	0	0
		0	0.0037	0	0
		0	0.0037	0	0
		0	0.0037	0	0

**Final Result:** \_\_\_\_\_



**EZY CHEK SYSTEMS**  
**PRODUCT LINE TEST**  
**FINAL REPORT**

**TEST DATE** 3/13/2024

**Testing Company Information**

Name: Oscar W. Larson

Address:

City:

Phone:

**Test Location Information**

Name: PARADISE EXPRESS

Address: 2040 N. 200 W.

City: Angola

Phone:

Contact:

**Technician Information**

Name: Chris Akey

Cert #: 80-8574

**Applied Pressure** 1.5X

**PRODUCT LINE TEST**  
**FINAL REPORT**

<b>Product Type</b>	<b>Line ID Number</b> <i>(if applicable)</i>	<input checked="" type="checkbox"/> <b>Pass</b>	<input checked="" type="checkbox"/> <b>Fail</b>
Diesel	3	<input checked="" type="checkbox"/>	<input type="checkbox"/>
		<input type="checkbox"/>	<input type="checkbox"/>
		<input type="checkbox"/>	<input type="checkbox"/>
		<input type="checkbox"/>	<input type="checkbox"/>
		<input type="checkbox"/>	<input type="checkbox"/>
		<input type="checkbox"/>	<input type="checkbox"/>

Comments/Recommendations: All good

Technician Signature  Date: 3/13/2024