

BOIL ORDER PROCEDURES FOR IDEM

Notify dwbmgr@idem.in.gov TWiseman@idem.IN.gov

Include:

- System name - Yorktown water
- PWSID# 5218014
- Date of boil order - 6-5-2024
- Number of customers affected 40
- Reason for boil order (ex: 12" main break pressure reduction) Loss of pressure due to putting new meter in
- Copy of the advisory
- Copy of samples taken with explanation to represent upstream/downstream of leak
- Cancellation form (when boil advisory lifted)
- Name and phone# of operator in responsible charge
Jamie Mixell - (765) - 620-0710

BOIL WATER ADVISORY

June 5, 2024

Dear Water Customer:

It has been determined that water customers in certain buildings of Grandview Square Apartments should boil their drinking water beginning June 5, 2024. This precautionary measure is recommended due to a water meter replacement that day which caused a loss of water pressure to apartments in certain buildings in the complex.

It is recommended that all cooking and drinking water be brought to a complete boil for five (5) minutes before using. Please continue to boil all cooking and drinking water until we notify you that it is no longer necessary.

After repairs are completed, the Town will obtain two clean bacteria tests before the Boil Advisory is lifted. It is still safe to shower, wash clothing, and clean with the water.

We appreciate your cooperation during this time and will update you as necessary until the drinking water problem has been solved. If you have any questions concerning the drinking water problem, please contact your water department at 759-4003.

James Mixell
(Water Superintendent)

PWSID: 5218014



Town of Yorktown
9800 W Smith St • PO Box 518
Yorktown, IN 47396
765-759-4003p • 765-759-4016f
www.yorktownindiana.org

Dear Water Customer:

As of Sunday, June 9, 2024 water samples in your area tested at satisfactory levels, so the Boil Advisory has been lifted.

Thank you for your patience.

Please call Yorktown Town Hall at 759-4003 with any questions.

Sincerely,

James Mixell
Water Superintendent

PWSID: 5218014



HOOSIER MICROBIOLOGICAL LABORATORY
 912 W. McGalliard Rd.
 Muncie, IN 47303
 (765) 288-1124

Bacteriological Examination of Public Water

Certified by the Indiana State Board of Health
Certified Lab ID# M-18-03

Date/Time Received: 6/6/2024 at 10:50:00 AM	County: Delaware
BOTTLE Number: 240606105B (465270 RUSH)	Site: Yorktown Water Dept.
Started: 6/6/24 11:00 AM	Address: 1420 S. Grandview Ct.
Company Name: Yorktown Water Dept.-5218014	City/St/Zip: Yorktown, IN 47396
Address: 9800 W. Smith St.	Collected By: Kyle Studebaker
City/St/Zip: Yorktown, IN 47396	Place Collected: Sample Tap
Telephone: 765-716-7882	Date Collected: 6/6/2024
	Time Collected: 10:40 AM
	PWSID: 5218014

Analysis	Result	Units	Read	Tech	Method
E.coli, PA	Absent	n/a	6/7/2024 11:30:00 AM	TP	Colilert
Total Coliform, PA	Absent	n/a	6/7/2024 11:30:00 AM	TP	Colilert

- SATISFACTORY: At examination time this water was bacteriologically safe based on USEPA standards
- UNSATISFACTORY: At examination time this water was bacteriologically unsafe.
- PLEASE SUBMIT ANOTHER SAMPLE TEST NOT VALID BECAUSE
 - TOO LONG AT TIME BETWEEN COLLECTION AND RECEIPT OF SAMPLE
 - INVALID OR NO COLLECTION DATE AND/OR TIME
 - SAMPLE LEAKED OR BROKEN IN SHIPMENT, INSUFFICIENT VOLUME
 - RESIDUAL CHLORINE PRESENT
 - HIGH BACKGROUND COUNT
 - INCORRECT SAMPLE CONTAINER
 - NONCONFORMANCE WITH TEMPERATURE REQUIREMENTS >4°C

Signed: Donald A. Hendrickson



HOOSIER MICROBIOLOGICAL LABORATORY
 912 W. McGalliard Rd.
 Muncie, IN 47303
 (765) 288-1124

Bacteriological Examination of Public Water

Certified by the Indiana State Board of Health
 Certified Lab ID# M-18-03

Date/Time Received: 6/7/2024 at 11:40:00 AM	County: Delaware
BOTTLE Number: 2406071143 (465373 RUSH)	Site: Yorktown Water Dept.
Started: 6/7/24 5:05 PM	Address: 1420 S. Grandview
Company Name: Yorktown Water Dept.-5218014	City/St/Zip: Yorktown, IN 47396
Address: 9800 W. Smith St.	Collected By: Kyle Studebaker
City/St/Zip: Yorktown, IN 47396	Place Collected: Sample Tap
Telephone: 765-716-7882	Date Collected: 6/7/2024
	Time Collected: 11:16 AM
	PWSID: 5218014

Analysis	Result	Units	Read	Tech	Method
E.coli, PA	Absent	n/a	6/8/2024 3:00:00 PM	TK	Colilert
Total Coliform, PA	Absent	n/a	6/8/2024 3:00:00 PM	TK	Colilert

- SATISFACTORY: At examination time this water was bacteriologically safe based on USEPA standards
- UNSATISFACTORY: At examination time this water was bacteriologically unsafe.
- PLEASE SUBMIT ANOTHER SAMPLE TEST NOT VALID BECAUSE
 - TOO LONG AT TIME BETWEEN COLLECTION AND RECEIPT OF SAMPLE
 - INVALID OR NO COLLECTION DATE AND/OR TIME
 - SAMPLE LEAKED OR BROKEN IN SHIPMENT, INSUFFICIENT VOLUME
 - RESIDUAL CHLORINE PRESENT
 - HIGH BACKGROUND COUNT
 - INCORRECT SAMPLE CONTAINER
 - NONCONFORMANCE WITH TEMPERATURE REQUIREMENTS >4°C

Signed: Donald A. Hendrickson