



**MONTHLY REPORT OF OPERATION
WATER TREATMENT PLANT**



Astbury Water Technology
Northeast Regional Office
601 West 400 North
Angola, IN 46703

System Name: **Laville Elementary School**

PWSID Number: **2500826**

For the Month of: **June** Year: **2024** Printed Name/Title:

Daniel Ringer - Operator

Signed: **Daniel Ringer**

Certification Number: **100207**

I certify **under penalty of law**, by this signature that this document was prepared by me, or under my direction, and the information submitted is to the best of my knowledge and belief, true, accurate, and complete. **I am also aware that there are significant penalties for submitting false information.**

IDEM Field Rep.: _____

Date	Meter Reading	Water Treated x1000 gallons	Chemicals Used				Chlorine Residual			
			Chlorine		Phosphate		Plant Tap		D.S.	
			INCHES USED	Gallon Used	INCHES USED	Gallon Used	FREE	TOTAL	FREE	TOTAL
1										
2		14.9		0.2		0.19				
3		0.9		0.1		0.06	0.24	0.32	0.18	0.22
4		3.7		0.1		0.08	0.25	0.38	0.20	0.24
5		0.7		0.0		0.04	0.20	0.24	0.18	0.14
6		3.5		0.1		0.1	0.24	0.28	0.19	0.22
7							0.36	0.42	0.20	0.24
8										
9		2.9		0.1		0.13				
10		0.8		0.1		0.09	0.24	0.32	0.18	0.20
11		3.0		0.1		0	0.28	0.36	0.20	0.24
12		0.4		0.0		0.1	0.24	0.26	0.20	0.22
13		0.7		0.1		0.08	0.18	0.22	0.14	0.16
14							0.22	0.26	0.18	0.20
15										
16		9.3		0.3		0.35				
17		1.3		0.1		0.08	0.24	0.30	0.14	0.19
18		1.3		0.1		0.1	0.14	0.20	0.08	0.12
19		4.0		0.1		0.13	0.18	0.24	0.17	0.20
20		1.3		0.1		0.08	0.20	0.28	0.19	0.20
21							0.24	0.30	0.11	0.17
22										
23		5.7		0.2		0.26				
24		4.0		0.1		0.14	0.18	0.24	0.13	0.16
25		1.2		0.1		0.06	0.22	0.28	0.18	0.20
26		3.4		0.1		0.1	0.14	0.20	0.13	0.16
27		0.6		0.4		0.04	0.24	0.28	0.20	0.22
28							0.20	0.24	0.14	0.19
29										
30		5.0		0.2		0.2				
31										

MONTHLY WATER TREATMENT	
Total Gallons	68.60
Max. Day	14.90
Min. Day	0.40
Average Daily	3.27

Email To:
DWBMRO@idem.in.gov

Mail To:
IDEM Drinking Water Branch
100 N. Senate Ave. Room N1201
Indianapolis, IN 46204-2237

