



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

100 N. Senate Avenue • Indianapolis, IN 46204
(800) 451-6027 • (317) 232-8603 • www.idem.IN.gov

Eric J. Holcomb
Governor

Brian C. Rockensuess
Commissioner

July 2, 2024

City of Madison
Attn: Tony Sorrels, Street Supervisor
101 W Main St
Madison, IN 47250

City of Madison Street Department
Attn: Tony Sorrels, Street Supervisor
via email: streetsec@madison-in.gov

Re: Violation Letter
City of Madison Street Department
1215 Walnut St
Madison, Jefferson County
UST Facility ID # **12535**

Dear Owner and Operator:

An inspector from the Indiana Department of Environmental Management (IDEM), Underground Storage Tank (UST) Section, conducted an inspection of the site referenced above on June 20, 2024.

The inspection was conducted pursuant to Indiana Code (IC) 13-14-2-2 to determine compliance with the provisions of IC 13-23 and 329 IAC 9. In accordance with IC 13-14-5, a summary of the inspection is provided below:

Type of Inspection: Initial

Results of Inspection: Violations were discovered and require a submittal.

Within thirty (30) days of receipt of this letter, documentation demonstrating compliance with each of the requirements listed in the attached Inspection Report and Description of Violations (DOV) must be submitted to IDEM. Failure to submit this documentation may lead to this facility being referred for enforcement.

An enforcement action may include civil penalties of up to \$10,000 per UST. Enforcement actions may also affect the owner's and/or operator's eligibility for reimbursement from the Excess Liability Trust Fund (ELTF). Additionally, IDEM may deem the USTs at this facility ineligible for delivery, deposit or acceptance of regulated substances pursuant to IC 13-23-1-4. Finally, federal and criminal penalties may apply for failure to provide required notification; or submitting false information pursuant to IC 13-23-14-2 and liable under IC 13-30-10.

Thank you for your attention to this matter. Please submit the required documents to the UST Section via email at USTCompliance@idem.in.gov. Include in the subject line of the response the UST Facility ID # **12535**.

Inspector: Matt Rozycki
Phone: (317) 296-1853

Direct any questions regarding the inspection to:

Compliance Manager: Loic Maniet
Phone: (317) 232-3592

Sincerely,



Thomas F. Newcomb, Chief
UST Compliance Section
Office of Land Quality

cc: Loic Maniet
Matt Rozycki
UST Facility ID File # 12535

DESCRIPTION OF VIOLATIONS

This inspection or records review revealed that the owner and/or operator of this facility is in violation of Indiana UST Rule 329 IAC 9. 329 Indiana Administrative Code ("IAC") 9 incorporates certain federal underground storage tank requirements found in 40 Code of Federal Regulations ("CFR") Part 280, including those identified below. The Description of Violations (DOV) and corrective measures are as follows:

FACILITY NAME: City of Madison Street	UST FACILITY ID: 12535
ADDRESS: 1215 N Walnut St, Madison Jefferson County	INSPECTION DATE: 6/20/2024

VIOLATIONS NOTED IN THIS INSPECTION

329 IAC 9-2-2(c) – Failure to register/notify with complete information

Citation:

Pursuant to 329 IAC 9-2-2(c), an owner required to submit a notification under this section shall provide:

- (1) a notification for each UST owned;
- (2) complete information required on the form for each UST owned; and
- (3) if applicable, a separate notification form for each separate place of operation at which the USTs are located.

Violation Details:

The owner and/or operator of the UST system(s) at this site are in violation of this rule because an updated notification form 45223 with the correct overfill prevention method is needed.

Corrective Action:

The owner and/or operator of the UST systems at this site shall fill out and submit to IDEM a correct and complete copy of the appropriate state form with required attachments, within fifteen (15) days of receipt of this notice.

§ 280.34 – Reporting and recordkeeping (general provisions)

Citation:

Pursuant to 40 CFR 280.34, owners and operators of UST systems must cooperate fully with inspections, monitoring and testing conducted by the implementing agency, as well as requests for document submission, testing, and monitoring by the owner or operator pursuant to section 9005 of Subtitle I of the Solid Waste Disposal Act, as amended.

Violation Details:

The owner and/or operator of the UST system(s) at this site are in violation of this rule because no paperwork was provided at the time of the records request nor during the inspection.

Corrective Action:
The owner and/or operator of the UST systems at this site shall immediately perform the monitoring or testing required by the rules and/or submit the requested documentation within seven (7) days of receipt of this notice.

329 IAC 9-6-2.5(d) – Failure to complete closure process
Citation:
Pursuant to 329 IAC 9-6-2.5(d), the permanent closure or change-in-service is not considered complete until all permanent closure or change-in-service requirements and site assessment requirements are met.
Violation Details:
<i>The owner and/or operator of the UST system(s) at this site are in violation of this rule because closure documentation was not provided for the tank removed in 1992.</i>
Corrective Action:
The owner and/or operator of the UST systems at this site shall submit to IDEM the complete documentation as required by this rule within thirty (30) days of receipt of this notice.

§ 280.40(a)(3)(iii) – Failure to perform annual tests of ALLD
Citation:
Pursuant to 40 CFR 280.40(a)(3)(iii), owners and operators of UST systems must provide a method, or combination of methods, of release detection that beginning on October 13, 2018, is operated and maintained, and electronic and mechanical components are tested for proper operation, in accordance with one of the following: manufacturer’s instructions; a code of practice developed by a nationally recognized association or independent testing laboratory; or requirements determined by the implementing agency to be no less protective of human health and the environment than the two options listed in paragraphs (a)(1) and (2) of this section. A test of the proper operation must be performed at least annually and, at a minimum, as applicable to the facility, cover the following components and criteria: (iii) Automatic line leak detector: test operation to meet criteria in § 280.44(a) by simulating a leak.
Violation Details:
<i>The owner and/or operator of the UST system(s) at this site are in violation of this rule because an annual leak detector test was not provided.</i>
Corrective Action:
The owner and/or operator of the UST systems at this site shall have the automatic line leak detectors tested for proper operation by simulating a leak within thirty (30) days of receipt of this notice and submit the results within forty five (45) days of receipt of this notice.

§ 280.35(a)(1) – Failure to perform periodic testing of spill prevention equipment and containment sumps used for IM

Citation:

Pursuant to 40 CFR 280.35(a)(1), owners and operators of UST systems with spill and overfill prevention equipment and containment sumps used for interstitial monitoring of piping must meet these requirements to ensure the equipment is operating properly and will prevent releases to the environment:

(1) Spill prevention equipment (such as a catchment basin, spill bucket, or other spill containment device) and containment sumps used for interstitial monitoring of piping must prevent releases to the environment.

Violation Details:

The owner and/or operator of the UST system(s) at this site are in violation of this rule because periodic testing of the spill prevention equipment was not provided.

Corrective Action:

The owner and/or operator of the UST systems at this site shall, within thirty (30) days of receipt of this notice, contract with a certified contractor to inspect, repair and test all spill prevention equipment and containment sumps. Documentation, to include photographs, inspection, repair and testing results, showing the spill prevention equipment and containment sumps are liquid tight must be submitted within forty five (45) days of the receipt of this notice.

§ 280.35(a)(2) – Failure to perform periodic testing of overfill prevention equipment

Citation:

Pursuant to 40 CFR 280.35(a)(2), overfill prevention equipment must be inspected at least once every three years. At a minimum, the inspection must ensure that overfill prevention equipment is set to activate at the correct level specified in § 280.20(c) and will activate when regulated substance reaches that level.

Inspections must be conducted in accordance with one of the criteria in paragraph (a)(1)(ii)(A) through (C) of this section.

Violation Details:

The owner and/or operator of the UST system(s) at this site are in violation of this rule because periodic testing of the overfill prevention equipment was not provided.

Corrective Action:

The owner and/or operator of the UST systems at this site shall, within thirty (30) days of receipt of this notice, contract with a certified contractor to inspect, repair and test all overfill prevention equipment. Documentation, to include photographs, inspection, repair, measurements and testing results, showing the overfill prevention equipment is fully functional and set at the correct level must be submitted within forty five (45) days of the receipt of this notice.

§ 280.40(a)(3)(i) – Failure to perform annual tests of ATG

Citation:

Pursuant to 40 CFR 280.40(a)(3)(i), owners and operators of UST systems must provide a method, or combination of methods, of release detection that beginning on October 13, 2018, is operated and maintained, and electronic and mechanical components are tested for proper operation, in accordance with one of the following: manufacturer's instructions; a code of practice developed by a nationally recognized association or independent testing laboratory; or requirements determined by the implementing agency to be no less protective of human health and the environment than the two options listed in paragraphs (a)(1) and (2) of this section. A test of the proper operation must be performed at least annually and, at a minimum, as applicable to the facility, cover the following components and criteria:
(i) Automatic tank gauge and other controllers: test alarm; verify system configuration; test battery backup.

Violation Details:

The owner and/or operator of the UST system(s) at this site are in violation of this rule because an ATG functionality test was not provided.

Corrective Action:

The owner and/or operator of the UST systems at this site shall have all components of the automatic tank gauge or other controllers tested for proper operation within thirty (30) days of receipt of this notice and submit the results within forty five (45) days of receipt of this notice.

§ 280.40(a)(3)(ii) – Failure to perform annual tests of probes & sensors

Citation:

Pursuant to 40 CFR 280.40(a)(3)(ii), owners and operators of UST systems must provide a method, or combination of methods, of release detection that beginning on October 13, 2018, is operated and maintained, and electronic and mechanical components are tested for proper operation, in accordance with one of the following: manufacturer's instructions; a code of practice developed by a nationally recognized association or independent testing laboratory; or requirements determined by the implementing agency to be no less protective of human health and the environment than the two options listed in paragraphs (a)(1) and (2) of this section. A test of the proper operation must be performed at least annually and, at a minimum, as applicable to the facility, cover the following components and criteria:

(ii) Probes and sensors: inspect for residual buildup; ensure floats move freely; ensure shaft is not damaged; ensure cables are free of kinks and breaks; test alarm operability and communication with controller.

Violation Details:

The owner and/or operator of the UST system(s) at this site are in violation of this rule because a functionality test of the probes was not provided.

Corrective Action:

The owner and/or operator of the UST systems at this site shall have all components of the automatic tank gauging probes and sensors tested for proper operation within thirty (30) days of receipt of this notice and submit the results within forty five (45) days of receipt of this notice.

§ 280.36(a)(1)(i) – Failure to perform 30 day walkthrough inspections

Citation:

Pursuant to 40 CFR 280.36(a)(1)(i), to properly operate and maintain UST systems, not later than June 28, 2021, owners and operators must conduct a walkthrough inspection every 30 days that, at a minimum, checks spill prevention equipment and release detection equipment (Exception: spill prevention equipment at UST systems receiving deliveries at intervals greater than every 30 days may be checked prior to each delivery).

Violation Details:

The owner and/or operator of the UST system(s) at this site are in violation of this rule because the most recent 12 months of walkthroughs have not been provided.

Corrective Action:
The owner and/or operator of the UST systems at this site shall, within seven (7) days of receipt of this notice, perform the 30 day walkthrough inspection for all UST systems at the site in accordance with a standard of practice referenced in the rule. Documentation, to include photographs, inspection forms, repair documents, and waste disposal records, showing the walkthrough inspection has been completed must be submitted within forty five (45) days of the receipt of this notice.
§ 280.36(a)(1)(ii) – Failure to perform annual walkthrough inspections
Citation:
Pursuant to 40 CFR 280.36(a)(1)(ii), to properly operate and maintain UST systems, not later than June 28, 2021 owners and operators must conduct a walkthrough inspection annually that, at a minimum, checks containment sumps and hand held release detection equipment.
Violation Details:
<i>The owner and/or operator of the UST system(s) at this site are in violation of this rule because the most recent annual walkthrough inspection was not provided.</i>
Corrective Action:
The owner and/or operator of the UST systems at this site shall, within seven (7) days of receipt of this notice, perform the annual walkthrough inspection for all UST systems at the site in accordance with a standard of practice referenced in the rule. Documentation, to include photographs, inspection forms, repair documents, and waste disposal records, showing the walkthrough inspection has been completed must be submitted within forty five (45) days of the receipt of this notice.

§ 280.245 – Failure to maintain list of designated operators and/or training records

Citation:

Pursuant to 40 CFR 280.245, owners and operators of underground storage tank systems must maintain a list of designated Class A, Class B, and Class C operators and maintain records verifying that training and retraining, as applicable, have been completed, in accordance with § 280.34.

Violation Details:

The owner and/or operator of the UST system(s) at this site are in violation of this rule because operator A, B, and C certificates were not provided.

Corrective Action:

The owner or operator of the UST systems at this site shall submit a list of those employees designated to be Class A, Class B and Class C operators. Those so designated must be trained and certification of that training submitted within thirty (30) days of receipt of this notice.



**UNDERGROUND STORAGE
TANK INSPECTION REPORT**

INDIANA DEPARTMENT OF
ENVIRONMENTAL MANAGEMENT

UST FAC ID: **12535**

Inspector's Name:	Matt Rozycki
Date:	June 20, 2024
Time In:	10:20
Time Out:	10:40
Inspection Type:	Initial

FACILITY NAME / LOCATION

FACILITY NAME City of Madison Street Department		FACILITY ADDRESS (number and street) 1215 N Walnut St			
ADDRESS (line 2)	CITY Madison	STATE IN	ZIP CODE 47250	COUNTY Jefferson	

UST OWNER

UST Owner Name (If in Individual Capacity) City of Madison					BUSINESS ID (From the Secretary of State)
PREFIX	FIRST NAME Tony	MI	LAST NAME Sorrels	SUFFIX	
TELEPHONE NUMBER	EMAIL ADDRESS streetsec@madison-in.gov				

UST OPERATOR

UST Operator Name (If in Individual Capacity) City of Madison Street Department					BUSINESS ID (From the Secretary of State)
PREFIX	FIRST NAME Tony	MI	LAST NAME Sorrels	SUFFIX	
TELEPHONE NUMBER	EMAIL ADDRESS streetsec@madison-in.gov				

PROPERTY OWNER

UST Property Owner Name (If in Individual Capacity) City of Madison					BUSINESS ID (From the Secretary of State)
PREFIX	FIRST NAME Tony	MI	LAST NAME Sorrels	SUFFIX	
TELEPHONE NUMBER	EMAIL ADDRESS streetsec@madison-in.gov				

COMPLIANCE ELEMENTS

All USTs properly registered and up-to-date notification form on file	<input type="checkbox"/>	YES	<input checked="" type="checkbox"/>	NO	<input type="checkbox"/>	UNK	
Updated notification form with the proper overfill prevention method							
O/O is in compliance with reporting & record keeping requirements	<input type="checkbox"/>	YES	<input checked="" type="checkbox"/>	NO	<input type="checkbox"/>	UNK	
No paperwork was provided at the time of the records request nor during the inspection							
O/O is in compliance with release reporting or investigation	<input type="checkbox"/>	YES	<input type="checkbox"/>	NO	<input checked="" type="checkbox"/>	N/A	UNK
O/O is in compliance with all UST closure requirements	<input type="checkbox"/>	YES	<input checked="" type="checkbox"/>	NO	<input type="checkbox"/>	N/A	UNK
Closure documentation for the tank removed in 1992 has not been provided							
O/O has met all financial responsibility requirements	<input checked="" type="checkbox"/>	YES	<input type="checkbox"/>	NO	<input type="checkbox"/>	N/A	UNK
40 CFR 280, Subpart A installation requirements (partially excluded) met	<input checked="" type="checkbox"/>	YES	<input type="checkbox"/>	NO	<input type="checkbox"/>	N/A	UNK
40 CFR 280, Subpart B installation and upgrade requirements met	<input checked="" type="checkbox"/>	YES	<input type="checkbox"/>	NO	<input type="checkbox"/>		UNK
40 CFR 280, Subpart C spill/overfill control requirements met	<input checked="" type="checkbox"/>	YES	<input type="checkbox"/>	NO	<input type="checkbox"/>	N/A	UNK
40 CFR 280, Subpart C compatibility requirements met	<input checked="" type="checkbox"/>	YES	<input type="checkbox"/>	NO	<input type="checkbox"/>	N/A	UNK
40 CFR 280, Subpart C O&M and testing requirements met	<input type="checkbox"/>	YES	<input checked="" type="checkbox"/>	NO	<input type="checkbox"/>		UNK
Spill bucket test, overfill functionality test, monthly / annual walkthroughs not provided							
40 CFR 280, Subpart D release detection requirements met	<input type="checkbox"/>	YES	<input checked="" type="checkbox"/>	NO	<input type="checkbox"/>		UNK
ATG/probe functionality test, leak detector test							
40 CFR 280, Subpart J operator training requirements met	<input type="checkbox"/>	YES	<input checked="" type="checkbox"/>	NO	<input type="checkbox"/>		UNK
Operator A B & C certificates were not provided							

The information contained on this page is based upon a review of files related to this site and/or observations from an underground storage tank inspector. This page may contain information not specifically related to possible violations found during the review or inspection and is meant to give the owners and/or operator specific information to assist them.

Site Maintains:

- Two (2) FG SW USTs installed in September 1992
- One (1) 10K REG GSL
- One (1) 8K DSL
- Piping is FG SW and pressurized

RD UST = ATG

RD Piping = LLD, ATG

Overfill/Spill = Spill Buckets + Auto Shutoff (consistent) + Ball Float (removed)

ATG Certification = N

Overfill Protection Test = N

Spill bucket Test = N

Containment Sumps Test (not required) = N

Site History:

Site is a city facility with fueling capability. One (1) UST was removed in November 1992 (no closure report on file).

Contact Information

Tony Sorrels, streetsec@madison-in.gov

Documentation not provided at the time of the file review:

- (NF 12/2/2014, Approval 6/29/2016 - incorrect overfill information)
- Operator Certificates
- Release Detection Records
- Line and leak detector test
- ATG/Probes certification
- Spill bucket test
- Overfill test
- Monthly walkthrough
- Annual inspection

Inspector Notes

- Auto shut off observe on both tanks
- The flex connectors appeared to be isolated from backfill in the STP risers and under the dispensers

The information contained on this page is based upon a review of files related to this site and/or observations from an underground storage tank inspector. This page may contain information not specifically related to possible violations found during the review or inspection and is meant to give the owners and/or operator specific information to assist them.

The following are AREAS OF CONCERN found during the inspection that will need to be addressed by the owner and/or operator:

1. The spill buckets had some debris, they should be monitored and cleaned out as needed
2. The DSL spill bucket lid rests on the drain plug, the plug handle may need to be shortened to allow the lid to close properly

The following are VIOLATIONS discovered during the inspection that will need to be corrected within 30 days of receipt of this inspection report to avoid further action and achieve compliance with the state underground storage tank program:

1. An updated notification form with the current overfill prevention method is needed
2. No paperwork was provided at the time of the records request nor during the inspection
3. Closure documentation for the tank removed in 1992 has not been provided
4. An annual leak detector test was not provided
5. Spill bucket testing was not provided
6. Overfill functionality testing was not provided
7. ATG functionality testing was not provided
8. Functionality testing of the probes was not provided
9. Monthly walkthroughs were not provided
10. An annual walkthrough inspection was not provided
11. Operator A B & C certificates were not provided

The following are RECORDS to be submitted to the inspector within 30 days of receipt of this inspection report to avoid further action and achieve compliance with the state underground storage tank program (update accordingly):

- Updated notification form (incorrect overfill information)
- Operator Certificates
- Leak detector test
- ATG/Probes certification
- Spill bucket test
- Overfill test
- Monthly walkthrough
- Annual inspection
- Closure documents for USTs removed in 1992