

Report for: Kraft Heinz Company. - Kendallville, IN
 Public Water Supply I.D. No.: 2570866 IDEM Inspector: Rick Massoels
 for the month of: Jun-24

Drinking Water Operator Signature [Signature] Certification Number Provisional

I certify under penalty of law, by this signature that this document was prepared by me, or under my direction and the information submitted is to the best of my knowledge and belief, true, accurate and complete. I am also aware that there are significant penalties for submitting false information

Date	Water Treated 1000 gallons	Boiler Room Tap		Sink in Maint Shop		Daily Chlorine Usage Pounds	Remarks
		Free Chlorine (mg/l)	Total Chlorine	Free Chlorine (mg/l)	Total Chlorine		
1	148.7	0.70	1.00	0.50	0.80	8.68	
2	47.7	0.40	0.70	0.50	0.60	7.23	
3	137.2	0.60	0.90	0.40	0.60	7.23	
4	99.7	1.20	0.60	0.70	1.20	11.57	
5	152.6	0.50	0.40	0.50	0.70	10.12	
6	170.2	0.50	0.60	0.70	0.80	10.12	
7	150.1	1.00	0.60	0.70	0.60	5.78	
8	167.6	2.00	2.80	1.40	2.20	11.57	
9	54.5	2.00	2.80	1.40	2.20	8.68	
10	65.7	1.10	1.30	0.90	1.00	10.12	
11	137.4	0.90	1.20	0.70	0.90	8.68	
12	135.2	0.60	0.40	0.70	0.60	15.90	
13	155.6	1.40	2.80	0.80	1.00	8.68	
14	145.4	1.00	1.40	0.90	1.20	8.68	
15	160.7	0.80	1.10	0.70	0.90	10.12	
16	82.8	0.50	0.80	0.40	0.90	8.68	
17	172.4	1.20	0.70	0.60	0.50	5.78	
18	269.0	1.20	1.00	0.80	0.60	8.68	
19	141.8	0.50	0.40	0.80	0.60	7.23	
20	165.1	0.70	0.60	0.90	0.70	10.12	
21	205.9	1.20	0.80	0.70	0.70	7.23	
22	139.4	1.00	0.90	0.90	0.80	8.68	
23	94.7	0.70	0.60	0.50	0.70	10.12	
24	62.9	0.90	0.70	0.80	0.70	8.68	
25	165.8	1.10	0.80	0.90	0.60	10.12	
26	147.9	1.00	0.70	0.80	0.50	4.34	
27	158.9	0.80	0.60	0.50	0.40	8.68	
28	149.7	0.90	0.70	0.60	0.40	4.34	
29	171.5	1.00	0.60	0.50	0.50	2.17	
30	73.7	1.10	0.80	0.70	0.60	18.79	
31							

266.80

Monthly Water Treatment (1000 gallons)

Total	4,129.8	_____
Max. Day	269.0	_____
Min. Day	47.7	_____
Avg Day	137.7	_____

Corrective Actions: If chlorination pump is down more than 24 hours quality needs to be notified and the plant needs to switch to city water

**Acceptance Criteria 0.1 mg/l- 4.0 mg/l