



**MONTHLY REPORT OF OPERATION
WATER TREATMENT PLANT**



Astbury Water Technology
Northeast Regional Office
601 West 400 North
Angola, IN 46703

System Name: **Culver Educational Foundation**

PWSID Number: **5250004**

For the Month of: **June**

Year: **2024**

Printed Name/Title: **Daniel Ringer - Operator**

Signed: *Daniel Ringer*

Certification Number: **100207**

I certify **under penalty of law**, by this signature that this document was prepared by me, or under my direction, and the information submitted is to the best of my knowledge and belief, true, accurate, and complete. *I am also aware that there are significant penalties for submitting false information.*

IDEM Field Rep.: _____

Date	Meter Reading	Water Treated per 1000 gal	Chemicals Used				Chlorine Residual			
			Chlorine		Phosphate		Plant Tap		D.S.	
			INCHES USED	gallon used	INCHES USED	gallon used	FREE	TOTAL	FREE	TOTAL
1		95.5		2.6		3	1.06	1.78	0.10	0.12
2		65.3		1.9		2	1.05	1.73	0.10	0.15
3		67.3		1.7		1	1.30	1.62	0.60	0.72
4		65.9		1.8		1	1.05	1.56	0.65	0.84
5		76.7		2.7		1	1.13	1.47	0.34	0.45
6		56.5		0.9		2	1.16	1.48	0.48	0.78
7		66.7		1.4		1	0.98	1.29	0.57	0.62
8		39.0		1.1		1	0.77	0.95	0.59	0.69
9		44.3		1.2		1	1.04	1.10	0.60	0.79
10		55.5		1.3		1	1.07	1.34	0.53	0.56
11		48.9		1.4		1	1.30	1.44	0.33	0.34
12		94.3		2.1		2	0.81	1.35	0.31	0.39
13		63.5		1.9		2	0.94	1.48	0.49	0.58
14		70.3		1.8		2	0.92	1.27	0.30	0.32
15		52.8		1.6		1	1.45	1.56	0.43	0.48
16		90.5		2.6		2	0.46	0.62	0.16	0.18
17		105.4		2.6		3	1.08	1.12	0.36	0.45
18		81.9		1.1		2	0.84	1.27	0.44	0.52
19		130.5		2.9		3	0.92	1.15	0.14	0.26
20		104.7		3.3		2	0.75	0.81	0.34	0.27
21		104.2		1.9		2	1.52	1.94	0.33	0.48
22		101.7		3.3		3	1.00	1.23	0.54	0.62
23		95.8		2.9		1	0.65	0.78	0.44	0.52
24		115.3		3.3		3	0.93	1.44	0.67	0.74
25		106.6		2.5		2	0.87	1.52	0.55	0.69
26		105.2		2.4		2	0.80	0.91	0.44	0.57
27		91.6		2.6		2	1.12	1.28	0.42	0.55
28		91.7		2.5		2	1.23	1.27	0.64	0.79
29		71.4		1.9		2	0.65	0.93	0.48	0.51
30		95.7		2.6		2	0.77	1.13	0.44	0.55
31										

MONTHLY WATER TREATMENT	
Total Gallons	2454.70
Max. Day	130.50
Min. Day	39.00
Average Daily	81.82

Email To:
DWBMRO@idem.in.gov

Mail To:
IDEM Drinking Water Branch
100 N. Senate Ave. Room N1201
Indianapolis, IN 46204-2237

