


Monthly Report of Operation of Water Treatment Plant

System Name : Sisters of the Holy Cross

PWSID Number : IN5271025

For the Month of : June 2024

IDEM Field Rep: Paula Reinhold

Signed: 

Title: Director of Facilities

I certify, under penalty of law, by this signature that this document was prepared by me, or under my direction, and the information submitted is to the best of my knowledge and belief, true,

Certification Number : 041943

accurate, and complete. I am also aware that there are significant penalties for submitting false information.

Date	Water Production	Phosphate	Phosphate Test	Chlorine Feed	Plant Chlorine Residual FREE	Plant Chlorine Residual TOTAL	D.S. Chlorine Residual FREE	D.S. Chlorine Residual TOTAL	D.S. Location
	Gallons	Pounds	mg / L	Pounds	mg / L	mg / L	mg / L	mg / L	
1	128000	12	0.27	14	0.41	0.47	0.41	0.47	5
2	116000	10	0.31	12	0.42	0.46	0.42	0.46	5
3	125000	19	0.24	23	0.43	0.47	0.32	0.39	1
4	143000	15	0.21	18	0.45	0.49	0.21	0.24	2
5	164000	16	0.26	21	0.44	0.48	0.22	0.25	3
6	151000	17	0.21	21	0.51	0.69	0.29	0.32	4
7	166000	16	0.32	23	0.41	0.44	0.41	0.44	5
8	148000	15	0.25	20	0.43	0.49	0.43	0.49	5
9	109000	10	0.28	14	0.39	0.46	0.39	0.46	5
10	219000	24	0.26	31	0.29	0.48	0.23	0.26	1
11	179000	20	0.24	25	0.41	0.48	0.25	0.27	2
12	305000	33	0.21	40	0.39	0.44	0.22	0.25	3
13	375000	40	0.22	49	0.61	0.71	0.21	0.26	4
14	302000	34	0.25	40	0.25	0.31	0.25	0.31	5
15	279000	31	0.23	36	0.35	0.39	0.35	0.39	5
16	265000	27	0.29	32	0.36	0.42	0.36	0.42	5
17	196000	20	0.22	29	0.42	0.61	0.32	0.38	1
18	355000	36	0.31	48	0.55	0.62	0.23	0.26	2
19	537000	53	0.25	84	0.53	0.61	0.32	0.38	3
20	325000	30	0.26	54	0.43	0.51	0.24	0.28	4
21	416000	39	0.29	74	0.51	0.59	0.51	0.59	5
22	353000	30	0.21	51	0.48	0.61	0.48	0.61	5
23	181000	16	0.24	37	0.44	0.52	0.44	0.52	5
24	150000	12	0.23	27	0.45	0.52	0.24	0.27	1
25	250000	29	0.26	34	0.24	0.32	0.21	0.25	2
26	250000	28	0.21	37	0.65	0.72	0.26	0.33	3
27	75000	7	0.26	13	0.64	0.69	0.25	0.28	4
28	148000	16	0.26	24	0.27	0.35	0.27	0.35	5
29	153000	16	0.24	22	0.31	0.38	0.31	0.38	5
30	135000	12	0.31	15	0.29	0.35	0.29	0.35	5

Location

1-McCandless

2-Madeleva

3-Lemans

4-Convent

5-Central Utilities