

From: [Wiseman, Thomas A](#)
To: [Sims, April](#)
Subject: IN2492839 Brewskie's Corrections
Date: Tuesday, July 2, 2024 2:08:22 PM
Attachments: [image001.png](#)
[image002.png](#)
[image003.png](#)
[image004.png](#)
[image005.png](#)
[image006.png](#)

April,

This system has installed a proper smooth bore sample tap ahead of treatment/storage, and should be good to have their 2014 deficiency closed.

Thanks,
Tom



Thomas A. Wiseman, Field Inspector
Field Inspection Section-Drinking Water Branch
Office of Water Quality-IDEM
100 North Senate Avenue-MC: 66-34
Indianapolis, IN 46204
(317) 607-9023 • TWiseman@idem.in.gov

Indiana Department of Environmental Management



Scan the QR code to leave your feedback.

We appreciate your input!

