



MONTHLY REPORT OF OPERATION WATER TREATMENT PLANT

State Form 34609 (R11 / 1-17)

INDIANA DEPARTMENT OF
ENVIRONMENTAL MANAGEMENT

System Name Rockport PWSID Number 5274007

For the Month of June Year 2024 IDEM Field Rep. Anne Roedke

Signed Donald A Wood Title Operator

I certify under penalty of law, by this signature that this document was prepared by me, or under my direction, and the information submitted is to the best of my knowledge and belief, true, accurate, and complete. I am also aware that there are significant penalties for submitting false information.

Certification Number 864616

PHYSICAL AND CHEMICAL DATA *

Date	Turbidity		Alkalinity		pH		Hardness		Iron		Manganese		Phosphate	Fluoride
	Raw	Finished	Raw	Finished	Raw	Finished	Raw	Finished	Raw	Finished	Raw	Finished	Finished	Finished
1									.352	.032	-	.036		
2									.344	.026	-	.043		
3									.353	.037	-	.035		
4									.316	.006	-	.054		
5									.324	.005	-	.038		
6									.352	.015	-	.043		
7									.272	.005	-	.048		
8									.314	.008	-	.048		
9									.345	.012	-	.053		
10									.343	.002	-	.037		
11									.288	.005	-	.037		
12									.322	.008	-	.045		
13									.268	.016	-	.040		
14									.281	.013	-	.040		
15									.382	.016	-	.037		
16									.393	.012	-	.045		
17									.419	.001	-	.043		
18									.266	.001	-	.025		
19											-			
20									.408	.022	-	.048		
21									.354	.015	-	.027		
22											-			
23											-			
24									.274	.010	-	.045		
25									.289	.013	-	.051		
26									.333	.001	-	.033		
27									.297	.007	-	.049		
28									.285	.005	-	.045		
29											-			
30											-			
31											-			

* All parameters are to be expressed in mg/l except pH and turbidity.
DUE BY THE 10TH OF THE MONTH FOLLOWING THE REPORTING PERIOD.

265

Date	Water Treated 1000 gallons	Chemicals Used - Pounds								Filters		Chlorine Residual				Remarks
		Salt	Alum	Lime	Soda Ash	Carbon	Chlorine	Fluoride	Phos- phate	Filter Run (hours)	Gallons per wash x 1000	Plant Tap		D. S.		
												Free	Total	Free	Total	
1	199					5						1.3	1.66			Hydrant flushing
2	182					5						1.79	1.91			
3	179					4						1.28	1.67	1.21	1.34	Drain & Fill North tower 300,000 gal
4	233					7						1.04	1.40	1.56	1.20	
5	194					5						1.44	1.58	1.33	1.51	
6	226					5						1.25	1.40	1.11	1.26	
7	234					4						1.13	1.21	.99	1.11	
8	239					5						1.19	1.38			
9	162					5						1.4	1.57			
10	186					4						1.4	1.48	1.00	1.4	
11	222					5						1.41	1.55	.96	1.08	
12	218					5						1.35	1.52	1.05	1.24	
13	201					5						1.3	1.35	1.01	1.23	
14	220					3						1.08	1.42	.96	1.22	
15	209					5						1.19	1.38			
16	195					5						1.23	1.41			
17	201					4						1.25	1.44	.95	1.13	
18	240					6						1.16	1.25	.81	.87	
19	189					6						1.46	1.84	.99	1.13	
20	220					6						1.52	1.72	1.31	1.45	
21	240					6						1.67	1.84	1.03	1.45	Monthly Water Treatment
22	211					5						1.57	1.77			Total Gallons 6,602
23	226					7						1.67	1.78			Max. Day 305
24	208					5						1.65	1.84	1.16	1.18	Min. Day 162
25	253					6						1.4	1.53	1.17	1.34	Avg. Daily 220
26	210					6						1.74	1.92	1.19	1.34	E-Mail To: DWBMRO@idem.in.gov
27	296					7						1.74	1.96	1.23	1.31	Mail To: Indiana Department of Environmental Management Drinking Water Branch 100 N. Senate Ave. Room N1201 Indianapolis, IN 46204-2237
28	305					8						1.75	1.95	1.49	1.62	
29	252					6						1.62	1.87			
30	252					8						1.71	1.82			
31																