UNDERGROUND STORAGE TANK INSPECTION REPORT

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

UST FAC ID: 2909

Inspector's Name:	Tristan Voge
Date:	June 25, 2024
Time In:	11:25
Time Out:	12:00
Inspection Type:	Initial

FACILITY NAME / LOCATION

FACILITY NAME	FACILITY ADDRESS *(number and street)*			
Quick Exchange 100	2504 W Washington St			
ADDRESS *(line 2)*	**CITY**	**STATE**	**ZIP CODE**	**COUNTY**
	Indianapolis	IN	46222	Marion

UST OWNER

UST Owner Name (If in Individual Capacity)				BUSINESS ID *(From the Secretary of State)*
Tight LLC				2015040100775
PREFIX	**FIRST NAME**	**MI**	**LAST NAME**	**SUFFIX**
	Ali		Qazi	
TELEPHONE NUMBER	**EMAIL ADDRESS**			
(317) 772-4292	keystone.corps@gmail.com			

UST OPERATOR

UST Operator Name (If in Individual Capacity)				BUSINESS ID *(From the Secretary of State)*
Aroys LLC				2015042100338
PREFIX	**FIRST NAME**	**MI**	**LAST NAME**	**SUFFIX**
	Ali		Qazi	
TELEPHONE NUMBER	**EMAIL ADDRESS**			
(317) 772-4292	keystone.corps@gmail.com			

PROPERTY OWNER

UST Property Owner Name (If in Individual Capacity)				BUSINESS ID *(From the Secretary of State)*
Tight LLC				2015040100775
PREFIX	**FIRST NAME**	**MI**	**LAST NAME**	**SUFFIX**
	Ali		Qazi	
TELEPHONE NUMBER	**EMAIL ADDRESS**			
(414) 208-9375	keystone.corps@gmail.com			

COMPLIANCE ELEMENTS

All USTs properly registered and up-to-date notification form on file		YES	X	NO				UNK
An updated notification form is needed with the correct release detection indicated. 2022 and 2024 tank fees are in arrears.								
O/O is in compliance with reporting & record keeping requirements		YES	X	NO				UNK
The owner and/or operator did not respond to IDEM's records request dated 05/17/2024.								
O/O is in compliance with release reporting or investigation		YES		NO	X	N/A		UNK
O/O is in compliance with all UST closure requirements		YES		NO	X	N/A		UNK
O/O has met all financial responsibility requirements	X	YES		NO		N/A		UNK
40 CFR 280, Subpart A installation requirements (partially excluded) met		YES		NO	X	N/A		UNK
40 CFR 280, Subpart B installation and upgrade requirements met	X	YES		NO				UNK
40 CFR 280, Subpart C spill/overfill control requirements met	X	YES		NO		N/A		UNK
40 CFR 280, Subpart C compatibility requirements met	X	YES		NO		N/A		UNK
40 CFR 280, Subpart C O&M and testing requirements met		YES	X	NO				UNK
Spill/overfill/corrosion test reports, 07/23-06/24 monthly/annual walkthroughs were not provided.								
40 CFR 280, Subpart D release detection requirements met		YES	X	NO				UNK
An annual ATG, probes and line leak detector test reports were not provided.								
40 CFR 280, Subpart J operator training requirements met		YES	X	NO				UNK
A, B and C operator certificates were not provided.								



Imagery ©2024 Airbus, Maxar Technologies, Map data ©2024 Google 50 ft



Imagery ©2024 Airbus, Map data ©2024 Google 20 ft

conoco
OPEN
conoco
Washington St

Belleview Pl
Washington St
conoco
3.69
SALE

Belleview Pl
Washington
conoco
conoco
3.69
YARD SALE
WHY PAY MORE?
THE MONEY

SMOKE SHOP E-CIGS
NO LOITERING
BBQ Tank Trader Program
BBQ Tank Trader Program
ICE
Try Our New Kitchen
Fried Chicken
Gyro Sandwich
Good Quality Best Price

Clearance 13' 0"
canteen
Office Coffee Service
IDEM



SMOKE SHOP
E-CIGS

conoco
Save 20¢/gal.
with the Fuel Forward® App on your first fill-up at participating sites.
GO GO GO
$
Gallons
2
Regular
Plus
Premium
87
89
93
conoco

conoco
YOUR CAR
HAS ALMOST
40% BLIND SPOTS
Regular
87
89
93
conoco

conoco
Save 20¢/gal.
with the Fuel Forward™ App on your first fill-up at participating sites.
GO GO GO
5
$
Gallons
10.00
27.03
Fuel Forward App
Regular
Plus
Premium
87
89
93
conoco

GUICK EXCHANGE
2504 W.WASHINGTON
INDPLS IN, 46222

06-25-24 10:05 AM

SYSTEM STATUS REPORT

ALL FUNCTIONS NORMAL

INVENTORY REPORT

T 1:REG.
VOLUME = 5539 GALS
ULLAGE = 6493 GALS
90% ULLAGE= 5289 GALS
TC VOLUME = 5493 GALS
HEIGHT = 45.01 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 71.6 DEG F

T 2:PREM.
VOLUME = 1201 GALS
ULLAGE = 10831 GALS
90% ULLAGE= 9627 GALS
TC VOLUME = 1192 GALS
HEIGHT = 15.01 INCHES
WATER VOL = 0 GALS
WATER = 0.00 INCHES
TEMP = 70.7 DEG F

* * * * * END * * * * *

GUICK EXCHANGE
2504 W.WASHINGTON
INDPLS IN, 46222

06-25-24 10:06 AM

PRESSURE LINE LEAK TEST
HISTORY

Q 1:REG.

LAST 3.0 GAL/HR PASS:
06-25-24 10:04 AM

FIRST 0.20 GAL/HR PASS
EACH MONTH:

06-01-24 11:56 PM
05-02-24 1:47 AM
04-01-24 12:25 AM
03-03-24 4:44 AM
02-02-24 11:13 PM
01-01-24 2:55 AM
12-04-23 2:40 AM
11-04-23 1:36 AM
10-01-23 4:17 AM
09-03-23 3:02 AM
08-04-23 3:21 AM
07-01-23 2:08 AM

FIRST 0.10 GAL/HR PASS
EACH MONTH:

04-02-24 1:40 AM
10-01-23 4:33 AM
03-31-23 12:59 AM
09-27-22 12:10 AM
03-24-22 11:24 PM

* * * * * END * * * * *

GUICK EXCHANGE
2504 W.WASHINGTON
INDPLS IN, 46222

06-25-24 10:06 AM

PRESSURE LINE LEAK TEST
HISTORY

Q 2:PREM.

LAST 3.0 GAL/HR PASS:
06-25-24 10:03 AM

FIRST 0.20 GAL/HR PASS
EACH MONTH:

06-01-24 11:55 PM
05-04-24 1:09 AM
04-02-24 9:57 PM
00-03-24 1:50 AM
02-02-24 2:28 AM
01-03-24 3:46 AM
12-04-23 12:33 AM
11-02-23 9:42 PM
10-01-23 4:04 AM
09-03-23 3:31 AM
08-02-23 12:43 AM
07-01-23 2:52 AM

FIRST 0.10 GAL/HR PASS
EACH MONTH:

03-21-24 2:25 AM
09-19-23 2:59 AM
03-19-23 3:14 AM
09-16-22 4:21 AM
03-16-22 11:22 PM

* * * * * END * * * * *

GUICK EXCHANGE
2504 W.WASHINGTON
INDPLS IN, 46222

06-25-24 10:06 AM

TANK LEAK TEST HISTORY

T 1:REG.

LAST GROSS TEST PASSED:
06-25-24 2:25 AM
STARTING VOLUME= 5762
PERCENT VOLUME = 47.9
TEST TYPE = STANDARD

LAST ANNUAL TEST PASSED:

NO TEST PASSED

FULLEST ANNUAL TEST PASS

NO TEST PASSED

LAST PERIODIC TEST PASS:
06-25-24 3:07 AM
TEST LENGTH 26 HOURS
STARTING VOLUME= 5433
PERCENT VOLUME = 45.2
TEST TYPE = CSLD

FULLEST PERIODIC TEST
PASSED EACH MONTH:

01-02-24 3:40 AM
TEST LENGTH 25 HOURS
STARTING VOLUME= 6162
PERCENT VOLUME = 51.2
TEST TYPE = CSLD

02-10-24 6:01 AM
TEST LENGTH 27 HOURS
STARTING VOLUME= 6326
PERCENT VOLUME = 52.6
TEST TYPE = CSLD

03-01-24 5:52 AM
TEST LENGTH 29 HOURS
STARTING VOLUME= 5556
PERCENT VOLUME = 46.2
TEST TYPE = CSLD

04-29-24 3:12 AM
TEST LENGTH 27 HOURS
STARTING VOLUME= 5723
PERCENT VOLUME = 47.6
TEST TYPE = CSLD

05-07-24 10:54 PM
TEST LENGTH 27 HOURS
STARTING VOLUME= 6445
PERCENT VOLUME = 53.6
TEST TYPE = CSLD

06-07-24 3:02 AM
TEST LENGTH 27 HOURS
STARTING VOLUME= 5925
PERCENT VOLUME = 49.2
TEST TYPE = CSLD

07-03-23 3:30 AM
TEST LENGTH 21 HOURS
STARTING VOLUME= 6634
PERCENT VOLUME = 55.1
TEST TYPE = CSLD

08-13-23 2:32 AM
TEST LENGTH 24 HOURS
STARTING VOLUME= 5427
PERCENT VOLUME = 45.1
TEST TYPE = CSLD

09-28-23 4:47 AM
TEST LENGTH 24 HOURS
STARTING VOLUME= 7029
PERCENT VOLUME = 58.4
TEST TYPE = CSLD

10-07-23 3:33 AM
TEST LENGTH 23 HOURS
STARTING VOLUME= 7771
PERCENT VOLUME = 64.6
TEST TYPE = CSLD

11-06-23 2:31 AM
TEST LENGTH 27 HOURS
STARTING VOLUME= 6194
PERCENT VOLUME = 51.5
TEST TYPE = CSLD

12-15-23 12:20 AM
TEST LENGTH 23 HOURS
STARTING VOLUME= 6343
PERCENT VOLUME = 52.7
TEST TYPE = CSLD

* * * * * END * * * * *

GUICK EXCHANGE
2504 W.WASHINGTON
INDPLS IN, 46222

06-25-24 10:06 AM

TANK LEAK TEST HISTORY

T 2:PREM.

LAST GROSS TEST PASSED:
06-25-24 2:25 AM
STARTING VOLUME= 1205
PERCENT VOLUME = 10.0
TEST TYPE = STANDARD

LAST ANNUAL TEST PASSED:

NO TEST PASSED

FULLEST ANNUAL TEST PASS

NO TEST PASSED

LAST PERIODIC TEST PASS:
06-25-24 3:07 AM
TEST LENGTH 31 HOURS
STARTING VOLUME= 1096
PERCENT VOLUME = 9.1
TEST TYPE = CSLD

FULLEST PERIODIC TEST
PASSED EACH MONTH:

01-30-24 4:23 AM
TEST LENGTH 27 HOURS
STARTING VOLUME= 1246
PERCENT VOLUME = 10.4
TEST TYPE = CSLD

02-12-24 3:43 AM
TEST LENGTH 22 HOURS
STARTING VOLUME= 1302
PERCENT VOLUME = 10.8
TEST TYPE = CSLD

03-22-24 3:01 AM
TEST LENGTH 25 HOURS
STARTING VOLUME= 1226
PERCENT VOLUME = 10.2
TEST TYPE = CSLD

04-07-24 4:06 AM
TEST LENGTH 25 HOURS
STARTING VOLUME= 1364
PERCENT VOLUME = 11.3
TEST TYPE = CSLD

05-14-24 3:04 AM
TEST LENGTH 27 HOURS
STARTING VOLUME= 1319
PERCENT VOLUME = 11.0
TEST TYPE = CSLD

06-06-24 4:21 AM
TEST LENGTH 24 HOURS
STARTING VOLUME= 1132
PERCENT VOLUME = 9.4
TEST TYPE = CSLD

07-15-23 8:00 AM
TEST LENGTH 18 HOURS
STARTING VOLUME= 1393
PERCENT VOLUME = 11.6
TEST TYPE = CSLD

08-19-23 9:11 AM
TEST LENGTH 18 HOURS
STARTING VOLUME= 1223
PERCENT VOLUME = 10.2
TEST TYPE = CSLD

09-02-23 8:00 AM
TEST LENGTH 19 HOURS
STARTING VOLUME= 1098
PERCENT VOLUME = 9.1
TEST TYPE = CSLD

10-31-23 8:00 AM
TEST LENGTH 20 HOURS
STARTING VOLUME= 1236
PERCENT VOLUME = 10.3
TEST TYPE = CSLD

11-02-23 3:35 AM
TEST LENGTH 24 HOURS
STARTING VOLUME= 1259
PERCENT VOLUME = 10.5
TEST TYPE = CSLD

12-25-23 7:38 AM
TEST LENGTH 22 HOURS
STARTING VOLUME= 1181
PERCENT VOLUME = 9.8
TEST TYPE = CSLD

* * * * * END * * * * *