



**UNDERGROUND STORAGE
TANK INSPECTION REPORT**

INDIANA DEPARTMENT OF
ENVIRONMENTAL MANAGEMENT

UST FAC ID: **15216**

Inspector's Name:	Danny Rice
Date:	July 1, 2024
Time In:	10:30
Time Out:	11:00
Inspection Type:	Initial

FACILITY NAME / LOCATION

FACILITY NAME DeFouw Chevrolet		FACILITY ADDRESS (number and street) 320 Sagamore Pkwy S		
ADDRESS (line 2)	CITY Lafayette	STATE IN	ZIP CODE 47905	COUNTY Tippecanoe

UST OWNER

UST Owner Name (Business Name as registered with the Secretary of State) DeFouw Chevrolet Inc				BUSINESS ID (From the Secretary of State) 194180-085	
PREFIX	FIRST NAME Mike	MI	LAST NAME Eiler	SUFFIX	
TELEPHONE NUMBER (765) 449-2800		EMAIL ADDRESS meiler@defouw.com			

UST OPERATOR

UST Operator Name (Business Name as registered with the Secretary of State) DeFouw Chevrolet Inc				BUSINESS ID (From the Secretary of State) 194180-085	
PREFIX	FIRST NAME	MI	LAST NAME	SUFFIX	
TELEPHONE NUMBER (765) 449-2800		EMAIL ADDRESS			

PROPERTY OWNER

UST Property Owner Name (Business Name as registered with the Secretary of State) Metzger & Sanchelli LLC				BUSINESS ID (From the Secretary of State) 202104081478588	
PREFIX	FIRST NAME	MI	LAST NAME	SUFFIX	
TELEPHONE NUMBER		EMAIL ADDRESS			

COMPLIANCE ELEMENTS

All USTs properly registered and up-to-date notification form on file	<input checked="" type="checkbox"/>	YES	<input type="checkbox"/>	NO	<input type="checkbox"/>	UNK	
O/O is in compliance with reporting & record keeping requirements	<input checked="" type="checkbox"/>	YES	<input type="checkbox"/>	NO	<input type="checkbox"/>	UNK	
O/O is in compliance with release reporting or investigation	<input type="checkbox"/>	YES	<input type="checkbox"/>	NO	<input checked="" type="checkbox"/>	N/A	UNK
O/O is in compliance with all UST closure requirements	<input type="checkbox"/>	YES	<input type="checkbox"/>	NO	<input checked="" type="checkbox"/>	N/A	UNK
O/O has met all financial responsibility requirements	<input checked="" type="checkbox"/>	YES	<input type="checkbox"/>	NO	<input type="checkbox"/>	N/A	UNK
40 CFR 280, Subpart A installation requirements (partially excluded) met	<input checked="" type="checkbox"/>	YES	<input type="checkbox"/>	NO	<input type="checkbox"/>	N/A	UNK
40 CFR 280, Subpart B installation and upgrade requirements met	<input checked="" type="checkbox"/>	YES	<input type="checkbox"/>	NO	<input type="checkbox"/>	UNK	
40 CFR 280, Subpart C spill/overfill control requirements met	<input checked="" type="checkbox"/>	YES	<input type="checkbox"/>	NO	<input type="checkbox"/>	N/A	UNK
40 CFR 280, Subpart C compatibility requirements met	<input checked="" type="checkbox"/>	YES	<input type="checkbox"/>	NO	<input type="checkbox"/>	N/A	UNK
40 CFR 280, Subpart C O&M and testing requirements met	<input type="checkbox"/>	YES	<input checked="" type="checkbox"/>	NO	<input type="checkbox"/>	UNK	
Spill bucket, overfill testing, rectifier log reading April 2024							
40 CFR 280, Subpart D release detection requirements met	<input checked="" type="checkbox"/>	YES	<input type="checkbox"/>	NO	<input type="checkbox"/>	UNK	
40 CFR 280, Subpart J operator training requirements met	<input checked="" type="checkbox"/>	YES	<input type="checkbox"/>	NO	<input type="checkbox"/>	UNK	