



MONTHLY REPORT OF OPERATION WATER TREATMENT PLANT

State Form 34609 (R11 / 1-17)

INDIANA DEPARTMENT OF
ENVIRONMENTAL MANAGEMENT

System Name Yorktown Water Department PWSID Number IN5218014

For the Month of June Year 2024 IDEM Field Rep. Thomas Wiseman

Signed [Signature] Title Water superintendent

I certify under penalty of law, by this signature that this document was prepared by me, or under my direction, and the information submitted is to the best of my knowledge and belief, true, accurate, and complete. I am also aware that there are significant penalties for submitting false information.

Certification Number DS 190140 WT 200066

PHYSICAL AND CHEMICAL DATA *

Date	Turbidity		Alkalinity		pH		Hardness		Iron		Manganese		Phosphate	Fluoride
	Raw	Finished	Raw	Finished	Raw	Finished	Raw	Finished	Raw	Finished	Raw	Finished	Finished	Finished
1													2.7	
2													2.8	
3													2.9	
4													2.8	
5													3.4	
6													2.6	
7													3.2	
8													2.6	
9													3.1	
10													2.8	
11													3.4	
12													2.2	
13													2.8	
14													3.0	
15													3.0	
16													2.9	
17													2.9	
18													2.5	
19													3.1	
20													2.9	
21													2.8	
22													2.9	
23													2.7	
24													2.6	
25													2.8	
26													3.5	
27													3.7	
28													2.0	
29													3.3	
30													2.1	
31														

* All parameters are to be expressed in mg/l except pH and turbidity.

DUE BY THE 10TH OF THE MONTH FOLLOWING THE REPORTING PERIOD.

Date	Water Treated 1000 gallons	Chemicals Used – Pounds								Filters		Chlorine Residual				Remarks	
		Salt	Alum	Lime	Soda Ash	Carbon	Chlorine	Fluoride	Phos- phate	Filter Run (hours)	Gallons per wash x 1000	Plant Tap		D. S.			
												Free	Total	Free	Total		
1	422						10					.47	.50	.29	.37		
2	439						8					.40	.48	.39	.51		
3	423						7					.49	.58	.42	.48		
4	443						8					.31	.64	.33	.41		
5	227						4					.55	.67	.37	.49		
6	647						10					1.10	1.04	.33	.41		
7	178						4					.49	.58	.49	.52	VFD's installed on 6/25, 6/26	
8	446						4					.20	.26	.42	.51	wells 1,2 were down.	
9	403						9					.46	.47	.39	.52		
10	424						7					.21	.38	.42	.51		
11	485						8					.45	.47	.37	.42		
12	494						7					.82	.97	.34	.45		
13	332						6					.95	.98	.29	.37		
14	415						5					.64	.78	.37	.42		
15	531						8					.20	.25	.55	.69		
16	529						5					.68	.97	.61	.69		
17	405						4					.28	.40	.81	.86		
18	585						12					.22	.22	.73	.89		
19	440						6					.44	.64	.50	.58		
20	520						8					.33	.38	.51	.62		
21	442						7					.79	1.06	.27	.33	Monthly Water Treatment	
22	563						9					.62	.73	.40	.49	Total Gallons	13,018,000
23	449						10					.29	.37	.30	.36	Max. Day	647,000
24	419						5					.35	.47	.95	1.05	Min. Day	178,000
25	476						7					.35	.44	.59	.67	Avg. Daily	433,933
26	311						7					0	0	.38	.41	E-Mail To: DWBMR0@idem.in.gov	
27	454						9					.78	.82	.32	.42	Mail To: Indiana Department of Environmental Management Drinking Water Branch 100 N. Senate Ave. Room N1201 Indianapolis, IN 46204-2237	
28	458						6					.80	.94	.33	.41		
29	217						5					.19	.26	.48	.60		
30	443						8					.60	.79	.43	.57		
31																	