

MONTHLY REPORT OF OPERATION FOR THE MONTH OF JUNE, 2024

POE #1 SPENCER STREET WATER TREATMENT PLANT, BREMEN, INDIANA, PUBLIC WATER SUPPLY I. D. 5250003

SIGNED [Signature], SUPERINTENDENT, CERTIFICATION NUMBER 110143

IDEM FIELD REPRESENTATIVE Kali Young

"I certify, under penalty of law, by this signature that this document was prepared by me, or under my direction, and the information submitted is to the best of my knowledge and belief, true, accurate and complete."

DATE	pH FIN	PO4	IRON		FI2 RAW	DATE	WATER TREATED 1,000 GALLONS	Cl2 LBS	Ferric LBS	PO4 LBS	NH3-N LBS.	FILTER WASH RUN HOURS	FILTER WASH 1,000 GALS	CHLORINE FINISHED		RESIDUAL DISTRIBUTION	
			RAW	FIN										FREE	TOTAL	FREE	TOTAL
1	7.43	1.22	1.31	0.00		1	150	77	1	4.0	16.0			0.10	2.11	0.01	1.20
2	7.47	1.14	1.25	0.00		2	167	54	3	4.0	14.0			0.04	2.02	0.03	0.70
3	7.46	1.12	1.22	0.00		3	183	58	2	6.0	15.0			0.01	2.13	0.01	1.08
4	7.45	1.10	1.23	0.00		4	261	85	2	6.0	20.0			0.01	1.86	0.01	1.35
5	7.45	1.08	1.30	0.00	0.55	5	96	32	0	2.0	6.0			0.00	2.05	0.01	1.09
6	7.45	1.06	1.30	0.00		6	207	65	4	5.0	17.0			0.01	2.04	0.00	1.11
7	7.43	1.10	1.30	0.00		7	200	79	4	7.0	20.0	1.00	92.50	0.01	2.06	0.02	1.26
8	7.46	1.24	1.30	0.00		8	178	79	2	6.0	17.0			0.01	2.19	0.00	1.48
9	7.44	1.09	1.09	0.00		9	170	57	1	4.0	12.0			0.01	2.00	0.00	1.52
10	7.43	0.98	1.25	0.00		10	180	60	5	6.0	14.0			0.01	1.60	0.04	1.36
11	7.44	0.92	1.29	0.00		11	225	68	2	7.0	18.0			0.02	1.68	0.02	1.49
12	7.42	1.15	1.02	0.00	0.57	0	275	83	2	7.0	22.0			0.03	2.00	0.00	1.58
13	7.41	1.08	1.81	0.00		13	243	81	0	6.0	21.0	1.00	92.50	0.01	1.71	0.00	1.00
14	7.40	1.03	1.21	0.00		14	157	68	2	6.0	17.0			0.02	2.02	0.04	1.66
15	7.42	1.12	1.07	0.00		15	189	56	4	6.0	16.0			0.00	1.83	0.01	1.36
16	7.40	1.17	1.19	0.00		16	185	59	3	6.0	15.0			0.01	1.92	0.02	1.66
17	7.46	1.16	1.04	0.00		17	244	74	0	11.0	20.0			0.04	1.91	0.03	1.45
18	7.41	1.13	1.00	0.00		18	261	76	2	6.0	16.0			0.03	2.08	0.00	1.32
19	7.41	1.24	1.03	0.00	0.69	19	232	71	4	8.0	20.0			0.01	1.78	0.06	1.58
20	7.36	1.17	1.05	0.00		20	408	140	6	12.0	34.0			0.01	1.92	0.02	1.09
21	7.44	1.10	1.15	0.00		21	240	74	3	6.0	20.0	1.00	92.50	0.03	2.00	0.01	1.83
22	7.43	1.08	0.97	0.00		22	310	117	4	8.0	33.0			0.04	2.19	0.05	1.14
23	7.41	1.31	1.03	0.00		23	252	77	3	4.0	21.0			0.03	1.92	0.05	1.10
24	7.41	1.10	1.16	0.00		24	167	55	5	8.0	14.0			0.01	1.64	0.02	1.05
25	7.41	1.12	1.21	0.00		25	264	71	3	6.0	20.0			0.03	2.05	0.02	1.06
26	7.38	1.15	1.19	0.01		26	249	80	4	6.0	19.0			0.05	1.18	0.00	1.06
27	7.39	1.16	1.42	0.00		27	223	76	5	8.0	17.0			0.06	1.87	0.05	1.24
28	7.35	1.05	0.58	0.00		28	222	72	3	6.0	18.0	1.00	92.50	0.02	1.87	0.03	1.24
29	7.44	1.18	1.26	0.00		29	159	67	2	4.0	17.0			0.06	2.60	0.01	0.54
30	7.16	1.09	1.25	0.00		30	164	49	3	6.0	13.0			0.04	1.93	0.05	0.75

TOTAL GALLONS 6.461 MG
 MAX DAY 0.408 MG
 MIN DAY 0.096 MG 0
 AVG DAY 0.215 MG 0

MONTHLY REPORT OF OPERATION FOR THE MONTH OF JUNE, 2024

POE #2 ALEXANDER STREET WATER TREATMENT PLANT, BREMEN, INDIANA, PUBLIC WATER SUPPLY I. D. 5250003

SIGNED _____, SUPERINTENDENT, CERTIFICATION NUMBER 110143

IDEM FIELD REPRESENTATIVE Kali Young

"I certify, under penalty of law, by this signature that this document was prepared by me, or under my direction, and the information submitted is to the best of my knowledge and belief, true, accurate and complete."

DATE	pH FIN	PO4	IRON		FI2 FIN	DATE	WATER TREATED 1,000 GALLONS	NaClO LBS	NaF GALS	PO4 LBS	NH3-N LBS.	FILTER WASH RUN HOURS	FILTER WASH 1,000 GALS	CHLORINE		RESIDUAL DISTRIBUTION	
			RAW	FIN										FINISHED FREE	TOTAL	FREE	TOTAL
1	7.58	0.89	1.32	0.02		1	502	183		16.0	64.0			0.00	1.36	0.01	1.20
2	7.57	0.89	1.30	0.02		2	486	141		16.0	49.0			0.00	1.39	0.03	0.70
3	7.47	1.10	1.28	0.00		3	541	99		16.0	33.0			0.00	1.61	0.01	1.08
4	7.48	1.08	1.24	0.01		4	580	183		19.0	64.0	0.35	17.00	0.00	1.87	0.01	1.35
5	7.50	1.22	1.12	0.01	0.63	5	647	229		19.0	75.0	0.35	16.00	8.00	1.64	0.01	1.09
6	7.70	0.48	1.17	0.00		6	618	176		18.0	64.0	0.70	33.00	0.05	1.74	0.00	1.11
7	7.64	1.10	1.29	0.01		7	588	159		17.0	58.0			0.03	1.71	0.02	1.26
8	7.50	1.11	1.04	0.00		8	609	169		20.0	65.0			0.04	1.82	0.00	1.48
9	7.63	1.07	1.10	0.00		9	499	120		15.0	53.0			0.02	1.69	0.00	1.52
10	7.74	1.23	1.21	0.00		10	514	157		17.0	58.0	0.35	16.00	0.03	1.33	0.04	1.36
11	7.65	1.17	1.19	0.02		11	661	213		19.0	75.0			0.01	1.88	0.02	1.49
12	7.71	1.07	1.22	0.00	0.52	12	631	198		26.0	74.0	0.35	16.00	0.06	2.01	0.00	1.58
13	7.75	1.22	1.15	0.00		13	809	256		14.0	95.0	0.35	16.00	0.02	1.63	0.00	1.00
14	7.68	1.01	1.17	0.00		14	769	241		20.0	80.0	0.70	33.00	0.06	1.85	0.04	1.66
15	7.71	0.84	1.39	0.01		15	653	207		18.0	81.0			0.00	1.39	0.01	1.36
16	7.62	0.98	1.29	0.00		16	567	175		18.0	50.0			0.00	1.30	0.02	1.66
17	7.67	1.00	1.26	0.00		17	747	212		24.0	67.0	0.70	32.00	0.00	2.20	0.03	1.45
18	7.69	1.24	1.29	0.01		18	901	276		26.0	73.0	0.35	17.00	0.00	1.82	0.00	1.32
19	7.66	1.02	0.88	0.00	0.44	19	1135	334		36.0	82.0	0.35	16.00	0.03	1.43	0.06	1.58
20	7.62	1.34	1.12	0.00		20	1005	226		30.0	92.0			0.03	1.60	0.02	1.79
21	7.62	0.91	1.22	0.01		21	796	276		26.0	98.0	0.70	33.00	0.02	1.70	0.01	1.83
22	7.64	1.14	1.11	0.00		22	979	226		29.0	74.0	0.35	16.00	0.06	1.48	0.05	1.14
23	7.71	1.12	1.18	0.00		23	768	209		24.0	79.0			0.03	1.21	0.05	1.10
24	7.70	1.02	1.25	0.00		24	493	148		15.0	52.0			0.00	1.29	0.02	1.05
25	7.67	1.08	1.35	0.01		25	822	239		25.0	53.0			0.02	1.94	0.02	1.06
26	7.65	1.01	1.25	0.01	0.48	26	545	197		18.0	80.0			0.04	2.00	0.00	1.06
27	7.66	1.02	1.24	0.02		27	497	179		10.0	80.0	1.40	76.00	0.05	1.68	0.05	1.24
28	7.71	1.01	1.24	0.01		28	631	165		20.0	70.0			0.00	1.63	0.03	1.24
29	7.74	0.95	1.32	0.10		29	512	179		9.0	78.0			0.01	0.84	0.01	0.54
30	7.69	0.82	1.31	0.01		30	508	147		16.0	66.0			0.00	1.11	0.05	0.75

TOTAL GALLONS 20.013 MG
 MAX DAY 1.135 MG
 MIN DAY 0.486 MG
 AVG DAY 0.667 MG