P.O. Box 456, 308 S. Main St.
New Knoxville, OH 45871
Phone: (419) 753-2448
Fax: (419) 753 2949

Brookside Laboratories, Inc.
Analytical Report

Client Number: 63341
Client Name: Artesian Water Lab
Consultant Name: Home Office
Date Collected: 01/03/2006 2:30:00 PM
Date Received: 01/04/2006

Lab Number: DI0104022
Location: NEW PROVIDENCE
Description: CHILD MIN.
Sub Description: 17741

Code	Procedure Name	Prep Method	Analysis Method	Analysis Complete	Analyst	Result	MDL
IA574	PCB'S (TOTAL 508A)	508A	508A	01/20/2006	SRE	< 0.1 ug/l	0.1
IG080	PENTACHLOROPHENOL	515.1	515.1	01/23/2006	SRE	< 0.1 ug/l	0.1
IG085	PICLORAM	515.1	515.1	01/23/2006	SRE	< 50 ug/l	50
IH070	DI(2-ETHYLHEXYL)ADIPATE	525.2	525.2	01/14/2006	SRE	< 0.04 mg/l	0.04
IH076	OXAMYL(VYDATE)		531.1	01/12/2006	THB	< 20 ug/l	20
IH078	DIQUAT	549.2	549.2	01/11/2006	THB	< 2 ug/l	2
IH079	ENDOTHALL	548.1	548.1	01/20/2006	SRE	< 10 ug/l	10
IH080	DI(2-ETHYLHEXYL)PHTHALATE	525.2	525.2	01/14/2006	SRE	< 0.0006 mg/l	0.0006
IK050	BENZO (a) PYRENE	550.1	550.1	01/16/2006	THB	< 0.02 ug/l	0.02
IM020	HEXACHLOROBENZENE	525.2	525.2	01/14/2006	SRE	< 0.0001 mg/l	0.0001
IM040	HEXACHLOROCYLOPENTADIENE	525.2	525.2	01/14/2006	SRE	< 0.005 mg/l	0.005
IN050	LINDANE	508	508	01/20/2006	SRE	< 0.02 ug/l	0.02
IN060	CHLORDANE	508	508	01/20/2006	SRE	< 0.2 ug/l	0.2
IN140	ENDRIN	508	508	01/20/2006	SRE	< 0.2 ug/l	0.2
IN160	HEPTACHLOR	508	508	01/20/2006	SRE	< 0.04 ug/l	0.04
IN170	HEPTACHLOR EPOXIDE	508	508	01/20/2006	SRE	< 0.02 ug/l	0.02
IN250	TOXAPHENE	508	508	01/20/2006	SRE	< 1 ug/l	1
IO010	AATREX (ATRAZINE)	525.2	525.2	01/14/2006	SRE	< 0.0003 mg/l	0.0003
IO020	ALACHLOR (LASSO)	525.2	525.2	01/14/2006	SRE	< 0.0002 mg/l	0.0002
IO115	CARBOFURAN		531.1	01/12/2006	THB	< 4 ug/l	4
IO130	2,4-D	515.1	515.1	01/23/2006	SRE	< 7 ug/l	7
IO137	DALAPON	515.1	515.1	01/23/2006	SRE	< 20 ug/l	20
IO139	DINOSEB	515.1	515.1	01/23/2006	SRE	< 0.7 ug/l	0.7
IO240	METHOXYCHLOR	525.2	525.2	01/14/2006	SRE	< 0.004 mg/l	0.004
IO290	PRINCEP (SIMAZINE)	525.2	525.2	01/14/2006	SRE	< 0.0004 mg/l	0.0004
IO367	GLYPHOSATE (ROUNDUP)		547	01/11/2006	THB	< 70 ug/l	70
IO410	2,4,5-TP (SILVEX)	515.1	515.1	01/23/2006	SRE	< 5 ug/l	5
IP188	DIBROMOCHLOROPROPANE (DBCP)	504.1 P	504.1	01/16/2006	SRE	< 0.02 ug/l	0.02
IP187	ETHYLENEDIBROMIDE (EDB)	504.1 P	504.1	01/16/2006	SRE	< 0.02 ug/l	0.02

Approval:

Comments: 1st Floor Restroom by Daycare Sink Faucet
PWSID # 2670010

Steven Earl
Chief Chemist