Indiana Department of Environmental Management
OWM - Drinking Water Branch
Inorganic Chemicals in Drinking Water

Return Completed Form to:
Indiana Department of Environmental Management
P.O. Box 7148
Indianapolis, IN 46207-7418

Sample Receipt Date: 03/22/2005 09:28:53 AM
QA Review Date: 03/29/2005
Report Date: 03/29/2005
PWS ID:
PWS Facility Name: Connersville Utilities
PWS Address: 2300 OHIO AVE.
P.O. BOX 325
CONNERSVILLE, IN 47331-0325
Sampling Site: WELL 2
Comments: ~~Point~~ "SP" no; well data

Lab: Environmental Labs, Inc.
Lab Cert. No.: C-39-1
Lab Report No.: 2005030492
Contact : Chris E. Myers
Phone No.: 812-273-6699

Environmental Laboratories
P.O. Box 968, 635 Green Rd.
Madison, IN 47250

Date Sampled: 03/21/2005
Sample ID#: P3- 077

Sample Type:
- [x] Routine Annual
- [ ] Routine Quarterly
- [ ] Detection Monitoring
- [ ] Confirmation Sample
- [ ] Special Purpose

Location Code:

Does system chlorinate? Yes No

Was the sample dechlorinated at the Laboratory? Yes No

Has this information been sent to IDEM by the Laboratory? Yes No

Field treatment: Iced HNO3 NaOH Other-(explain) H2SO4

Compound ID #	Parameter	Method #	Analysis Date	Result	Units	Det. Limit
1	ANTIMONY-(GFAA)	18-3113B	03/23/2005	<0.0004	mg/L	0.0004
1	ARSENIC-(GFAA)	18-3113B	03/23/2005	0.0061	mg/L	0.0006
1	BARIUM-(ICP)	18-3120B	03/23/2005	0.0967	mg/L	0.0004
1	BERYLLIUM-(ICP)	18-3120B	03/23/2005	<0.00008	mg/L	0.00008
1	CADMIUM -(GFAA)	18-3113B	03/23/2005	<0.00002	mg/L	0.00002
1	CHROMIUM-(ICP)	18-3120B	03/23/2005	<0.0007	mg/L	0.0007
2	CYANIDE, TOTAL	18-4500-CN-E	03/23/2005	0.0100	mg/L	0.005
3	FLUORIDE,ADJUSTED	18-4500-F-C	03/23/2005	0.1000	mg/L	0.1
1	MERCURY-(CVAA)	18-3112B	03/25/2005	<0.0001	mg/L	0.0001
1	NICKEL-(ICP)	18-3120B	03/23/2005	<0.001	mg/L	0.001
1	SELENIUM-(GFAA)	18-3113B	03/23/2005	0.0144	mg/L	0.0008
1	SODIUM-(ICP)	18-3120B	03/23/2005	9.168	mg/L	0.0015
1	THALLIUM-(GFAA)	18-3113B	03/23/2005	<0.0005	mg/L	0.0005

not for Compliance.

Reviewed by: Chris E. Myers