INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
We Protect Hoosiers and Our Environment.
100 N. Senate Avenue • Indianapolis, IN 46204
(800) 451-6027 • (317) 232-8603 • www.idem.IN.gov

Michael R. Pence
Governor

Thomas W. Easterly
Commissioner

April 15, 2014

65-40 LN
Jackson Township Regional Sewage District
PO Box 614
Hartford City, IN 47348

Dear Board of Trustees:

Re: Regional District Plan

Pursuant to Indiana Code (IC) 13-26, and as required in the Order forming the Regional District (District), a district plan (Plan) was required to be submitted by the District to the Indiana Department of Environmental Management (IDEM).

IDEM has received and reviewed the District Plan and determined the Plan to be complete. No further action regarding the Plan is required at this time. Please note that the District should send updates to the Plan to IDEM as they occur.

If you have any questions, please feel free to contact me at 800-451-6027, extension (3-0476) or at lnewlon@idem.in.gov.

Sincerely,

Lynne Newlon

Lynne Newlon
Regional District Coordinator
Indiana Department of Environmental Management

JACKSON TOWNSHIP REGIONAL SEWAGE DISTRICT

April 10, 2014

Indiana Department of Environmental Management
100 N Senate Avenue
Indianapolis, IN 46204

Dear Lynne Newlon,

Jackson Township Regional Sewer District has not done any new construction since the initial project was completed. We received a federal grant to complete the project and there are no outstanding loans. We have no plans for expansion. It is a wetlands system with 0.0132 mgd capacity. We have thirty-eight (38) customers right now. I have enclosed a a district map.

Sincerely,

Sheila M. Hyer

Verizon Cell Phone & Texting
765-499-1145
Email:
Sheila.hyer@gmail.com

JTRSD

Jackson Township Regional
Sewage District
P.O. Box 614
Hartford City, IN 47348





Attachment 1
MAP

JACKSON TOWNSHIP REGIONAL SEWER DISTRICT

IDEM
OFFICE OF
WATER QUALITY

2013 OCT 15 A 11:58

October 11, 2013

Dear Lynne Newton,

I have looked all over for the Regional District Plan. First of all I'm not sure what I'm looking for. I have a copy of what I think you might need if I'm wrong please forgive me.

Sincerely,

Sheila M. Hyer

Sheila M. Hyer
JTRSD Secretary/Treasurer

Verizon Cell Phone & Texting
765-499-1145
Email:
Sheila.hyer@gmail.com

JTRSD

Jackson Township Regional
Sewer District
P.O. Box 614
Hartford City, IN 47348

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
We make Indiana a cleaner, healthier place to live

Frank O'Bannon
Governor

Lori F. Kaplan
Commissioner

100 North Senate Avenue
P.O. Box 6015
Indianapolis, Indiana 46206-6015
(317) 232-8603
(800) 451-6027
www.ai.org/idem

August 3, 1999

VIA CERTIFIED MAIL Z376 766 120

Jackson Township Regional Sewer District
Millgrove Sewer Steering Committee
105 West Court Street
Hartford City, Indiana 47348

Dear Applicant:

Re: 327 IAC Article 3 Construction
Permit Application
Plans and Specifications for
Division "A" - Septic Tank Effluent Pump System
and Division "B" - Wastewater Treatment Plant
SRF Loan No. CS182231 01
Jackson Township Regional Sewer District
Blackford County, Indiana

The application, plans and specifications, and supporting documents for the above-referenced project have been reviewed and processed in accordance with rules adopted under 327 IAC Article 3. Enclosed is the Construction Permit (Approval No. L-0075), which applies to the construction of the above-referenced proposed water pollution treatment/control facility to be located at the unincorporated community of Millgrove, Jackson Township, Blackford County, Indiana.

Please review the enclosed permit carefully and become familiar with its terms and conditions. In addition, it is imperative that the applicant, consulting architect/engineer (A/E), inspector, and contractor are aware of these terms, conditions, and reporting and testing requirements. You will note the Attachment 1 to the permit must be signed and returned by the authorized official for the project applicant as named on Attachment 1. (We do not need signed copies from other persons receiving copies of this permit).

It should be noted that any person affected or aggrieved by the agency's decision in authorizing the construction of the above-referenced facility may, within fifteen (15) days from date of mailing, appeal by filing a request with the Office of Environmental Adjudication for an adjudicatory hearing in accordance with IC 4-21.5-3-7 and IC 13-15-6. The procedure for appeal is outlined in more detail in Part III of the attached construction permit.

The approval applies to the technical and operational acceptability of the submitted plans and does not imply that the entire project is eligible for SRF financing or that funds are available.

Plans and specifications were prepared by Commonwealth Engineers, Inc., certified by Mr. Edwin Tinkle, II, P.E., and Mr. Mark L. Harrison, P.E., and submitted for review on April 29, 1999, with additional information submitted on June 8, 1999, and June 22, 1999.

Any technical/engineering questions concerning this permit may be addressed to Mr. Matthew Florczyk, of our staff, at 317/232-8664. Questions concerning appeal procedures should be addressed to the Office of Environmental Adjudication, at 317/232-8591.

Sincerely,

Kenneth A. Lee

Kenneth A. Lee, Chief
Facility Construction Section
Office of Water Management

MJF/cd
Project No. SRF-0069
Enclosures
cc: Blackford County Health Department
Blackford County Commissioner
Commonwealth Engineers, Inc.
Hartford City News Times
Pearlie Bunch
Homer Darnell
Mildred Green
Judy Morris
Carl Sargent
County Drainage Board
Blackford County Courthouse
David Beatrice
Verdie Cooper
Mary Ann Green
Janie Marcum
William Randolph
Craig Zapf

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
AUTHORIZATION FOR CONSTRUCTION OF
WATER POLLUTION TREATMENT/CONTROL FACILITY
UNDER 327 IAC ARTICLE 3

DECISION OF APPROVAL

Jackson Township Regional Sewer District, in accordance with the provisions of IC 13-15 and 327 IAC Article 3 is hereby issued a permit to construct the water pollution treatment/control facility to be located at the unincorporated community of Millgrove, Jackson Township, Blackford County, Indiana. The permittee is required to comply with requirements set forth in Parts I, II and III hereof. The permit is effective pursuant to IC 4-21.5-3-4(d). If a petition for review and a petition for stay of effectiveness are filed pursuant to IC 13-15-6, an Environmental Law Judge may be appointed for an adjudicatory hearing. The force and effect of any contested permit provision may be stayed at that time.

NOTICE OF EXPIRATION DATE

This permit and the authorization to initiate construction of this pollution treatment/control facility shall expire at midnight August 1, 2000. In order to receive authorization to begin construction beyond the date of expiration, the permittee shall submit such information and forms as are required by the Indiana Department of Environmental management at least sixty (60) days prior to the expiration date.

Signed this 3rd day of August, 1999, for the Indiana Department of Environmental Management.

Kenneth A. Lee, Chief
Facility Construction Section
Office of Water Management

WATER POLLUTION TREATMENT/CONTROL FACILITY DESCRIPTION

The proposed project consists of 1,000 gallon and 1,500 gallon individual septic tanks with 12 - 14 gpm / 10-70 TDH feet effluent pump, approximately 6,450 feet of 1 ½-inch diameter, 1,050 feet of 2-inch diameter, 3,800 feet of 2 ½-inch diameter and 110 feet of 3-inch diameter PVC, SDR 26 pipe force main collection system, magnetic flow meter, 7,800 gallons biological aerated filter tank, three cell subsurface constructed wetlands, ultraviolet disinfection unit (UV) and gravity flow pipe for effluent discharge to the Big Lick Creek.

Inspection during construction will be provided by the Commonwealth Engineers, Inc. Maintenance after project completion will be provided by the Jackson Township Regional Sewer District.

CONDITIONS AND LIMITATIONS TO THE AUTHORIZATION FOR CONSTRUCTION OF WATER POLLUTION TREATMENT/CONTROL FACILITY

During the period beginning on the effective date of this permit and extending until the expiration date, the permittee is authorized to construct the above described water pollution treatment/control facility. Such construction shall conform to all provisions of State Rule 327 IAC Article 3 and the following specific provisions:

PART I

SPECIFIC CONDITIONS AND LIMITATIONS TO THE CONSTRUCTION PERMIT

Unless specific authorization is otherwise provided under the permit, the permittee shall comply with the following conditions:

1. Additional treatment facilities shall be installed if the proposed facilities prove to be inadequate or cannot meet applicable federal or state standards.

2. All local permits, including zoning, shall be obtained before construction is begun on this project.

3. Roof drains, foundation drains, and other clean water connections to the sanitary sewer shall be prohibited by enforcement of legally adopted rules regulating the use of sanitary sewers.

4. As-built plans shall be submitted to this office pursuant to 327 IAC 3-3-1.

5. After construction, this agency shall be given advance notice of the start-up of the facilities.

6. If pollution or nuisance conditions are created, immediate corrective action will be taken by the permittee.

7. If construction is located within a floodway, a permit may also be required from the Department of Natural Resources prior to the start of construction. It is the permittee's responsibility to coordinate with that agency and obtain any required approvals if applicable. Questions may be directed to the Permit Administration Section, Division of Water at 317/233-5635.

8. Technical supervision, by a certified operator, shall be provided for operation and control of the wastewater treatment facilities and monthly reports of operation shall be submitted to the Department of Environmental Management.

9. Analysis of the necessary wastewater parameters must be provided, either by in-house laboratory equipment or by contract with an outside laboratory.

10. Air relief valves shall be installed at high points in the force main.

11. All force main must be tested (two hour minimum) at 150% of design working pressure for leakage. Leakage (gallons per hour) shall be less than ((# of joints) (d in inches) psi $^{1/2}$)/3700. Test procedures from the appropriate AWWA specifications for pressure pipe may be used as an alternate.

Failure to submit test results within the allotted time period or failure to meet guidelines as set forth in the above conditions could be subject to enforcement proceedings as provided by 327 IAC 3-5-3.

This construction permit shall be considered void if Attachment 1 to this letter is not signed by the permittee on the space provided affirming that all conditions are expressly agreed to and will be complied with fully, and returned to the undersigned by certified mail within 30 days of the date of this letter.

PART II

GENERAL CONDITIONS

1. No significant or material changes in the scope of the plans or construction of this project shall be made unless the following provisions are met:

   a. Request for permit modification is made 60 days in advance of the proposed significant or material changes in the scope of the plans or construction;

   b. Submit a detailed statement of such proposed changes;

   c. Submit revised plans and specifications including a revised design summary; and

   d. Obtain a revised construction permit form this agency.

2. This permit may be modified, suspended, or revoked for cause including, but not limited to the following:

   a. Violation of any term or conditions of this permit;

   b. Obtaining this permit by misrepresentation or failure to disclose fully all relevant facts.

3. Nothing herein shall be construed as guaranteeing that the proposed water pollution treatment/control facility shall meet standards, limitations or requirements of this or any other agency of state or federal government, as this agency has no direct control over the actual construction and/or operation of the proposed project.

PART III

APPEALS PROCEDURE

Anyone wishing to challenge this agency's decision for authorizing the construction of this facility may do so, provided that a petition for administrative review is filed as required by IC 4-21.5-3-7. The petition must be submitted within fifteen (15) days of the date of mailing of this permit notification. The petition must include facts demonstrating that you are either the applicant, a person aggrieved or adversely affected by this decision, or otherwise entitled to review by law. Additionally, IC 13-15-6-2 requires that your petition include:

1. The name and address of the person making the request;

2. The interest of the person making the request;

3. Identification of any persons represented by the person making the request;

4. The reasons, with particularity, for the request;

5. The issues, with particularity, proposed for consideration at the hearing; and

6. Identification of the permit terms and conditions which, in the judgement of the person making the request, would be appropriate in the case in question to satisfy the requirements of the law governing permits of the type granted or denied by the Assistant Commissioner's action.

7. Pursuant to IC 4-21.5-3-1(f), any document serving as a petition for review or review and stay must be filed with the Office of Environmental Adjudication. Filing of such a document is complete on the earliest of the following dates:

   a. The date on which the petition is delivered to the Office of Environmental Adjudication, ISTA Building, 150 West Market Street, Suite 618, Indianapolis, Indiana 46204;

   b. The date of the postmark on the envelope containing the petition, if the petition is mailed by United States mail; or

   c. The date on which the petition is deposited with a private carrier, as shown by a receipt issued by the carrier, if the petition is sent by private carrier.

ATTACHMENT 1

I hereby certify that I have received Construction Permit No. L-0075 issued _____, for Project No. SRF 0069, and expressly agree to comply full with all conditions contained therein.

_____
Signature of Authorized Official

David Beatrice, President
Jackson Township Regional Sewer District

Please sign and return this attachment via certified mail to the Indiana Department of Environmental Management, Attention: Facility Construction Section, 100 North Senate Avenue, P.O. Box 6015, Indianapolis, Indiana 46206-6015. Return only this page.