



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

100 N. Senate Avenue • Indianapolis, IN 46204
(800) 451-6027 • (317) 232-8603 • www.idem.IN.gov

Eric J. Holcomb
Governor

Bruno Pigott
Commissioner

Re: Actions for Reopening a Public Water Supply
After a Long Shut Down
IN2670014 Somerset Christian Ch/lifespring

Church

Below is a list of IDEM recommendations and requirements for a Public Water Supply system before reopening after being closed for a period of time due to the COVID-19 pandemic. Studies show that water will become stagnant after seven to nine days of standing still. *If you have any questions please contact your IDEM Field Inspector Joe Stapinski at (317) 431-6941.*

Recommended actions:

- Visually inspect system components to be sure all components are intact
- Flush building piping systems thoroughly
- Check if well and pump are operating correctly
- See if all valves, gauges and controls are working properly
- Ensure system is fully pressurized (at least 20 psi) and not leaking
- Make sure all treatment equipment is operating correctly (*if applicable*)
- Inspect/change inline filters, regenerate softeners, chlorine residual, etc. for any treatment that applies
- Make sure storage tanks are sealed, not leaking, and in working order
- Collect a special purpose total coliform sample from the farthest point in the distribution system. Submit the results of the sample to IDEM.
- Optionally chlorinate the well and distribution system

Required action:

- **Collect a routine total coliform sample within seven (7) days of returning to normal operations. Submit the results to IDEM.**
- Your estimated reopen date is June 2020. Please notify the IDEM Compliance Section at dwbmgr@idem.in.gov **if that date changes**, so we can adjust your requirements accordingly.

Sincerely,

Drinking Water Branch
Office of Water Quality
IDEM
DWBmgr@idem.in.gov

cc: Joe Stapinski, Field Inspector



A State that Works



Guidance for Flushing Public Water Systems

Office of Water Quality – Drinking Water Branch

(317) 232-8603 • (800) 451-6027

www.idem.IN.gov

100 N. Senate Ave., Indianapolis, IN 46204

This document is designed to help public water systems prepare their systems for safe use once they reopen buildings that may have been temporarily closed or used less frequently due to the COVID-19 pandemic. It is imperative that operators adhere to the flushing instructions below to ensure their indoor plumbing is receiving fresh water and not stagnant water. The flushing instructions apply to:

- Community water systems such as municipal water supplies, subdivisions, or mobile home parks
- Non-transient non-community water systems such as schools, daycares or factories
- Transient water systems such as churches, restaurants/bars or campgrounds

Issues Caused by Stagnant Water

When water is not used over an extended period, it will become stagnant. Stagnant or standing water can cause conditions that increase the risk for growth and spread of *Legionella* and other harmful biofilm-associated bacteria. When water is stagnant, hot water temperatures can decrease to the *Legionella* growth range (77–108°F, 25–42°C). Stagnant water can also lead to low or undetectable levels of disinfectants such as chlorine and could also cause corrosion issues. It is critical to ensure water systems are safe to use after a prolonged shutdown to minimize the risk of Legionnaires' and other diseases associated with stagnant water.

How to Remove Stagnant Water

Since stagnant water is a potential health risk and can impact water quality, it is necessary to systematically flush the plumbing. In general, flushing involves opening taps and other fixtures and letting water run to remove any stagnant water within plumbing and fixtures. To protect the health and safety of consumers, IDEM recommends that you carefully read and adhere to the following instructions, which provide a systematic approach for conducting a complete flush.

NOTE: Some buildings have water treatment systems and those treatment devices need to be cleaned, flushed, and maintained as part of the start-up process. After flushing, water filters need to be replaced. If there is a point-of-entry water treatment system such as a water softener or filter, please refer to the instruction manual for information on how to replace the filter.

Flushing Instructions

Please complete these steps in the order set out below. Finish each step completely before moving on to the next step. During the initial flushing, it is a good idea to wear protective respiratory equipment. Discoloration and a lingering odor may occur during flushing; these issues are expected and are not a health issue.

1. Flush ALL cold water taps for at least 5 minutes.

Begin the cold water flushing procedure. Open ALL cold-water fixtures and run them for at least 5 minutes. Shut the water off after 5 minutes. Flush each toilet at least one time. This step includes the water in your refrigerator water dispenser.

Flushing should begin at the water service entrance and proceed through the building to the end points of the plumbing system in the building(s). Depending on flow and pressure, you may need to increase the flushing time to ensure all stagnant water has been flushed.

2. Flush ALL hot water taps for 15 minutes.

Once the cold water lines have been flushed, begin the hot water flushing procedure. Open ALL hot water taps in your bathroom(s) including lavatory (sink) fixtures, hot water bath fixtures, and any other hot water fixtures such as kitchens, wet bars, etc. Run these hot water fixtures for at least 15 minutes. Shut the water off after 15 minutes. Depending on the size of the hot water tank, you may need to flush longer to ensure the water in the tank has drained and fresh water has refilled the tank. These steps should be effective at removing contaminants from the water heater. However, for information on draining and cleaning the water heater, please consult the manufacturer.

3. Flush ALL remaining appliances and faucets for 5 minutes.

Open any remaining fixtures such as hose bibs, external faucets, or fixtures not used for drinking for at least 5 minutes to finish the plumbing system flushing. Take additional steps to remove water from other appliances including:

- Ice Makers
- Dishwashers
- Washing Machines
- Humidifiers
- CPAP Machines
- Oral, Medical, or Health Care Devices
- Baby Formula
- Water Filters
- Water Softeners
- Filters (point of use and whole house)

Remove ice from the ice maker bin and discard 2 additional batches of ice. Run empty dishwasher and washing machine once on rinse cycle.

4. Perform periodic ongoing flushes.

Periodic flushing is important to maintain water quality. Full-building, periodic flushes proceed the same as the initial flush except water tanks do not need to be drained and hot water flushing times are the same as cold water flushing times.

If you have chlorinated water, it is a good idea to measure chlorine residual during periodic flushes.

For additional COVID-19 response information that is more detailed, please visit:

<https://engineering.purdue.edu/PlumbingSafety/project>

Other Resources

- [Guidance for Building Water Systems](#) (Centers for Disease Control and Prevention)
- [Return to Service Guidance](#) (American Water Works Association)

Tobias, Anthony

From: Decastro, Sandra
Sent: Wednesday, April 22, 2020 3:01 PM
To: Lori Herbert
Cc: Tobias, Anthony
Subject: RE: 2670014 - Somerset Christian

Follow Up Flag: Follow up
Flag Status: Flagged

Good afternoon Lori,

We have noted you will not collect a Total Coliform sample in April 2020. We will also add the month of May 2020.

Please ensure the water is not accessible to the public; and if the water is accessible, then you would be required to collect a sample.

We ask that you continue to update us on a monthly basis.

Have a good day.

Thank you,

Coping with COVID-19:

- **Indiana State Dept. of Health (ISDH) COVID-19 Call Center:** Call 877-826-0011 (open 24/7)
- **Anthem NurseLine:** Call 800-337-4770 or visit the Anthem NurseLine online for a FREE symptom screening. Available to anyone with an Anthem health plan (this includes State of IN employees)
- **Anthem Employee Assistance Program (EAP):** Available to ALL state employees and adults in household regardless of health plan participation. Call 800-223-7723 or visit anthemeap.com (enter State of Indiana) for crisis counseling, help finding child/elder care, legal/financial consultation and much more.

Sandra De Castro

Senior Environmental Manager
Indiana Dept. of Env. Mgt. (IDEM)
Drinking Water Branch / Compliance Section
email: sdecastr@idem.in.gov
tel# - 317/234-7444
fax# - 317/234-7436

IDEM values your feedback.

Please take two minutes and complete this brief survey.



From: Lori Herbert [<mailto:lifespringom@gmail.com>]
Sent: Wednesday, April 22, 2020 2:18 PM

To: Decastro, Sandra <SDECASTR@idem.IN.gov>

Subject: Fwd: 2670014 - Somerset Christian

**** This is an EXTERNAL email. Exercise caution. DO NOT open attachments or click links from unknown senders or unexpected email. ****

Hi my name is Lori Herbert from Somerset church / Lifespring church. I am the office manager here and received this email from Becky Peterson who sends in our water samples each month. I just want to let you know that our office is closed due to Covid19 and we will be closed in May as well. I expect our next sample to be done in June. Please respond with acknowledgement of this email and request to waiver our water sampling until June. Thank you

Sent from my iPhone

Begin forwarded message:

From: Becky Peterson <beckypeterson10@gmail.com>

Date: April 22, 2020 at 10:12:47 AM EDT

To: Lifespring <lifespringom@gmail.com>

Subject: Fwd: 2670014 - Somerset Christian

Good morning, Lori!! I wanted to let you know that I made some phone calls this week to try to reach the right person for an update on our drinking water compliance requirements for the church. This would be about the time of the month that Bruce and I would be taking a sample to the health department for testing. I did finally connect with the right person of authority for this and explained that our church has not been open for services this month. I am forwarding Sandra's email to you, where she confirms that the church does has a compliance waiver for the month of April, and that we should provide her with an update on the status of re-opening the church month to month.

If you think it's best to go ahead and take a sample this month anyway, just for continuity of our record-keeping, Bruce and I are glad to do that. It's probably a waiver for this month only, since we'll likely be back in the church for services in May.

Please let me know your thoughts, and we will do whatever you tell us for this month and future months. Thank you!!!

----- Forwarded message -----

From: Decastro, Sandra <SDECASTR@idem.in.gov>

Date: Wed, Apr 22, 2020 at 7:57 AM

Subject: 2670014 - Somerset Christian

To: beckypeterson10@gmail.com <beckypeterson10@gmail.com>

Cc: Tobias, Anthony <ATobias@idem.in.gov>

Good morning Becky,

Per our phone conversation this morning, the church is closed. Please respond to this email regarding the reason of the temporary closure, and we will adjust the schedule for total coliform for the month of April 2020. Our office will automatically send a courtesy reminder regarding the monthly monitoring for Total Coliform at which time a response is required, so we may be updated on the church's status.

At this time, the reminders are being sent to Lori Herbert. Let me know if we need to change this contact information.

Have a nice day.

Thank you,

Coping with COVID-19:

• **Indiana State Dept. of Health (ISDH) COVID-19 Call Center:** Call 877-826-0011 (open 24/7)

• **Anthem NurseLine:** Call 800-337-4770 or visit the Anthem NurseLine online for a FREE symptom screening. Available to anyone with an Anthem health plan (this includes State of IN employees)

• **Anthem Employee Assistance Program (EAP):** Available to ALL state employees and adults in household regardless of health plan participation. Call 800-223-7723 or visit anthemeap.com (enter State of Indiana) for crisis counseling, help finding child/elder care, legal/financial consultation and much more.

Sandra De Castro

Senior Environmental Manager

Indiana Dept. of Env. Mgt. (IDEM)

Drinking Water Branch / Compliance Section

email: sdecastr@idem.in.gov

tel# - 317/234-7444

fax# - 317/234-7436

IDEM values your feedback.
Please take two minutes and complete this brief survey.





Virus-free. www.avast.com