Date (month, day, year)



Seasonal System Start-up Requirements

State Form 55927 (R2 / 9-16)

This checklist must be completed as you start up your system. It will aid in preventing contamination from entering your water system and will help you identify problems with your system. You must complete the following tasks (if applicable), check completion of each task, and mail, fax, or e-mail a signed copy with a copy of the special purpose sample result to the IDEM Drinking Water Branch. Make and keep a copy for your records.

Review Sampling Requirements	Done?
Review sampling schedule available at myweb in gov/IDEM/DWW/ or you can call 1(800) 451-6027 ext. 47430	Yes
Make arrangements for sample collection analysis with a certified lab (including SSLAP)	Yes
Review your site sampling plan and make sure it is up to date	Yes
Well(s)	Done 2
Well cap is tight and secure	Yes
Pump house is locked and secure	Yes n/a
Well casing is structurally sound and there is no visible damage	Yes
Vent screen is in place and downturned	Yes n/a
Rodents and insects are kept out of any enclosure around the well (e.g. keep area mowed)	Yes
The source or well sample tap* does not leak and flows freely when opened *This is typically a spigot, hose bib, or sample tap located after the well but before the storage tank or any water treatment device	Yes
Contaminant sources such as chemicals, livestock, and fuel are kept at least 100 feet from the well	Yes
Check for evidence of flooding or standing water near the well	Yes
The Edmilennemi	B\6(n)@?
All components are operating properly and free of corrosion or damage	Yes n/a
ANSI- or NSF-approved water treatment chemicals are on hand	Yes n/a
Storage Tank(s)	Done?
All valves, gauges, and controls are working properly APR 27 2020	Yes n/a

IDEM/OWQ DRINKING WATER BRANCH

System Name Stouber Court Work-Fairground	PWSID TN 2766	5921	Date (month, day, year) イーシャースの30
Stonage Table(a) CONTINUED			Dromé?
Pressure is being maintained and the pump is cyc (once the system is pressurized)	cling normally	,	Yes
Tanks are sealed, not leaking, and in working ord	er ·		Yes
For a non-pressurized tank, the vent screen is in p	olace and downtu	rned	Yes n/a
Distribution System	and the state of the last	groupe Nation	Senne (C)
All accessible lines and equipment are free of corr	rosion, damage, o	or leaks	Yes
All valves open and close freely	•		Yes n/a
Outdoor spigots or yard hydrants have vacuum br	eakers or backflo	w preventers	Yes n/a
All testable backflow preventers have been tested the last twelve (12) months.	by a certified bac	ckflow tester in	Yes
Avadivalle amid Pressurize	314 7 EFF : 4	- 9 m ir si yaqe Loomatika	Done
Well and pump are operating correctly		•	Yes
System is fully pressurized (at least 20 psi) and no	ot leaking		Yes
Water treatment equipment is operating correctly	, , ,		Yes n/a
Disindestrand Flush System		olegy (S. G. 1974) ett (g. 1974) States (g. 1974) ett (g. 1974) States (g. 1974) ett (g. 1974)	Done?
System was disinfected			Yes No
System was flushed		•.	Yes
Collected a satisfactory special purpose total colifcing the distribution system. Submit results of sample		farthest point	4-16-2020 Date Collected
Keep a copy of this checklist and submit the original	al to IDEM.		Yes
Dede a demogram for the second 5-1-202.	6 ? ?		
Comments (Attach an additional sheet if more space is needed.) we may not open on 5-1-20 timless the Governor or K'S			
I certify, under penalty of law, that this document was me, and that any deficiencies found during this seaso inspection have, to the best of my knowledge and be corrected.	onal start-up	checklist and Indiana D	c, or e-mail sample result to epartment of al Management

Name

Signature

Date (month, day, year)

Environmental Management 100 N. Senate Ave IGCN 1255 Indianapolis, IN 46204 Fax: 317-234-7462

Email: CapCert@idem.in.gov