

# TOWN OF TRAFALGAR

---

P.O Box 57  
Phone 317-878-5194

2770 W. State Road 252

Trafalgar, IN 46181-0057  
Fax 317-878-4402

I.D.E.M.,

This letter is in response to the Compliance Evaluation Inspection for IN0040681 completed on July 22, 2020. The Town's Engineer is evaluating the WWTP and the collection system in preparation to apply for an OCRA grant in early 2021. The violations noted have been reviewed and will be addressed during this project for future compliance.

The response to the concerns noted in the Inspection Letter are as follows.

1. The Town smoke tested about 50% of the sanitary sewer system in early September 2020 to locate potential I/I contributors starting with the oldest portion of the system. The overflow that was noted in the last 12 months was due to a sanitary line that was damaged due to erosion of the creek bank during high water from rainfall, the line was repaired immediately and the creek bank was stabilized to eliminate any future damage.
2. The Stott's Creek lift station does have deteriorating concrete walls and will be rehabilitated during the project noted above in 2021. The inspection letter was noted that the Lancaster lift station was beyond its useful life however it is the Stott's Creek station.  
The alarm system and plant monitoring are a concern that is being evaluated by the Engineer as well.

Thank You  
Lee Rodgers  
Town of Trafalgar  
Utility/Street Supt.  
317-878-3007