

To: Agnew, Dianna[DAgnew@idem.IN.gov]
From: DWBMGR
Sent: Mon 7/20/2020 2:06:31 PM
Importance: Normal
Subject: FW: Boil Water Advisory- Mecca
Received: Mon 7/20/2020 2:06:32 PM

From: Carrie E Lowe <Carrie.Lowe@amwater.com>
Sent: Monday, July 20, 2020 10:01 AM
To: sanitarian@parkecounty-in.gov; STAPINSKI, JOSEPH <JSTAPINS@idem.IN.gov>; DWBMGR <DWBMGR@idem.IN.gov>; Kimberly Brown <Kimberly.Brown@amwater.com>; Christina L Gosnell <Christina.Gosnell@amwater.com>; Holly S True <Holly.True@amwater.com>
Subject: Boil Water Advisory- Mecca

**** This is an EXTERNAL email. Exercise caution. DO NOT open attachments or click links from unknown senders or unexpected email. ****

Hello all,

The Mecca system (PWSID 5261004) issued a boil water advisory due to a potential drop in pressure due to a pump failure. The affected customers were notified to boil water for drinking, cooking and/or oral hygiene purposes. Sample analyses were underway at the Terre Haute laboratory M-84-01 using either Colilert or Colilert-18 media.

BWA issued: 7/19/2020 @ 17:30

Indiana American Water - Mecca - PWSID 5261004
Residential customers affected: 55
Commercial customers affected: 0
Area affected: Mecca- Everything past the west booster

Cause: Pump failure

Result: water pressure < 20 psi
BWA cancellation: 7/20/2020 @ 14:30 or unless otherwise notified.

Thanks,

Carrie Lowe

Supervisor of Water Quality and Environmental Compliance

Cell: 260-557-2694

Fax: 317-885-2406

E-mail: Carrie.Lowe@amwater.com

This email and any files transmitted with it are confidential and intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error, please notify the sender. Please note that any views or opinions presented in this email are solely those of the author and do not necessarily represent those of American Water Works Company Inc. or its affiliates. The recipient should check this email and any attachments for the presence of viruses. American Water accepts no liability for any damages caused by any virus transmitted by this email. American Water Works Company Inc., 1 Water Street, Camden, NJ 08102 www.amwater.com