



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

100 N. Senate Avenue • Indianapolis, IN 46204
(800) 451-6027 • (317) 232-8603 • www.idem.IN.gov

Eric J. Holcomb
Governor

Bruno L. Pigott
Commissioner

January 3, 2022

Via Certified Mail:

7007 1490 0000 0839 2518

Mr. Thomas M. Collins III, President and
Registered Agent
Luke Oil Co. Inc.
3592 North Hobart Road
Hobart, Indiana 46342

Via Certified Mail:

7007 1490 0000 0839 2525

Mr. Thomas M. Collins III, President and
Registered Agent
Gateway Triangle Corp.
3592 North Hobart Road
Hobart, Indiana 46342

Dear Mr. Collins:

Re: Notice of Violation and Proposed Agreed Order
Luke Oil Co, Inc. and Gateway Triangle Corp.
Case No. 2021-28224-U
FID No. 604
Hobart, Lake County

Qualified offer of settlement: inadmissible per Rule 408 of the Ind. Rules of Evidence. IDEM asserts that any offer to compromise a claim or any acceptance of such offer does not bind or obligate the parties of this enforcement action in the absence of a final order of the agency.

IDEM conducted an investigation of the site with FID# 604 and has made a preliminary determination that violations of environmental management rules exist. Per IC 13-30-3-3, enclosed please find a Notice of Violation that sets forth the alleged violations and a proposed Agreed Order which constitutes a qualified offer of settlement.

Please note, per IC 13-23-1-4(b), the Commissioner may determine whether an underground storage tank ("UST") is eligible for delivery, deposit, or acceptance of a regulated substance, and may issue a temporary order to prohibit the use of the UST that is deemed ineligible and demand compliance if the facility is in violation of requirements described in IC 13-23-1-4(b)(2)(A), (B), and/or (C) that regulate USTs. You may have already received or may receive in the future a separate correspondence from IDEM regarding this delivery prohibition.

You may request a settlement conference to discuss the allegations and the actions necessary to correct and resolve the violations, which may include injunctive relief and the establishment of a compliance schedule. Payment of a civil penalty will also be discussed. The civil penalty amount noted in the proposed Agreed Order contains a preliminary penalty figure

for settlement discussion purposes only and is based on penalty calculations associated with the alleged violations set forth in the Notice of Violation.

The individual signing the enclosed Agreed Order should be fully authorized to execute the document and legally bind the parties. The timely entry into an Agreed Order, which saves you and IDEM time and resources, may lead to a reduction in the civil penalty.

IDEM is not required to extend the offer of entry into an Agreed Order for more than 60 days. You may enter into an Agreed Order without admitting that the violations occurred. Additionally, to encourage a timely agreement, IDEM may offer a one time twenty percent reduction (20%) to the Civil Penalty for 60 days after receipt of this Notice of Violation.

If an Agreed Order is not entered into, IDEM may proceed to issue a unilateral notice and order requiring compliance with the environmental laws, rules, and/or permit, including payment of a civil penalty. Please contact me at (317) 232-8617 or via email at JHenders@idem.IN.gov if you have any questions or if you wish to request a settlement conference.

Sincerely,



Jillian Henderson
Case Manager
Enforcement Section
Office of Land Quality

Enclosures

cc: IDEM Virtual Cabinet
Porter County Health Department
Loic Manet, IDEM UST Compliance Section
Rick Massoels, Deputy Director, NWRO



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

100 N. Senate Avenue • Indianapolis, IN 46204
(800) 451-6027 • (317) 232-8603 • www.idem.IN.gov

Eric J. Holcomb
Governor

Bruno L. Pigott
Commissioner

NOTICE OF VIOLATION

To: Mr. Thomas M. Collins III, President and
Registered Agent
Luke Oil Co. Inc.
3592 North Hobart Road
Hobart, Indiana 46342

To: Mr. Thomas M. Collins III, President and
Registered Agent
Gateway Triangle Corp.
3592 North Hobart Road
Hobart, Indiana 46342

Case No.2021-28224-U

Based on an investigation including an inspection conducted on January 28, 2020, the Indiana Department of Environmental Management ("IDEM") has reason to believe that Luke Oil Co., Inc. ("Respondent") has violated environmental rules. The violations are based on the following:

1. Respondent Luke Oil Co., Inc. owns Underground Storage Tank ("UST") systems, with UST Facility ID 604, located at 6259 Melton Road, parcel # 64-05-01-451-001.000-016, in Hobart, Porter County, Indiana (the "Site").
2. Respondent Gateway Triangle Corp. operates the UST systems, located at 6259 Melton Road, parcel # 64-05-01-451-001.000-016, in Hobart, Porter County, Indiana (the "Site").
3. Respondent Luke Oil Co., Inc. owns four 8,000-gallon gasoline USTs. Three USTs were installed in 1971 and one was installed in 2005.
4. Owner as defined in IC 13-11-2-150(a)(1)(A) means, for an UST that was in use on November 8, 1984 or brought into use after November 8, 1984 for the storage, use, or dispensing of regulated substances, a person who owns the UST or the real property that is the UST site, or both. According to the Porter County Assessor's Office, Respondent Luke Oil Co., Inc. is the owner of the Site.
4. A Violation Letter was issued to Respondent Luke Oil Co., Inc. on February 14, 2020 which required Respondent to submit a Notification form within thirty (30) days of receipt of the Violation Letter. Respondent failed to fully respond to the Violation Letter.
5. Pursuant to 329 Indiana Administrative Code ("IAC") 9-2-2(c), an owner required to submit a notification under this section shall provide:
 - (1) a notification for each UST owned.
 - (2) complete information required on the form for each UST owned; and
 - (3) if applicable, a separate notification form for each separate place of operation at which the USTs are located.



A State that Works

As noted during the inspection, a corrected notification form was required and the notification form submitted on February 17, 2020 was rejected on August 18, 2020. An updated form has not been submitted.

6. Pursuant to 40 Code of Federal Regulations (“CFR”) 280.34, owners and operators of UST systems must cooperate fully with inspections, monitoring and testing conducted by the implementing agency, as well as requests for document submission, testing, and monitoring by the owner or operator pursuant to section 9005 of Subtitle I of the Solid Waste Disposal Act, as amended.

As noted during the inspection, Respondents failed to perform the monitoring or testing required by the rules and/or submit the requested documentation as required.

7. Pursuant to 329 IAC 9-8-11(a), an owner or operator may satisfy the financial responsibility requirements of section 4 of this rule by participation in the excess liability trust funder under 328 IAC 1. Reimbursement from the fund is determined by compliance with 328 IAC 1. Pursuant to 329 IAC 9-8-11(b), an owner or operator of:
 - (1) twelve (12) or fewer USTs shall demonstrate the ability to pay the applicable deductible amount under IC 13-23-9-1.3; or
 - (2) more than twelve (12) USTs shall demonstrate the ability to pay two (2) times the applicable deductible amount under IC 13-23-9-1.3.

As noted during the inspection, Respondents failed to demonstrate the ability to pay the applicable deductible.

8. Pursuant to 40 CFR 280.20(c)(1)(ii), to prevent spilling and overfilling associated with product transfer to the UST system, owners and operators must use the following spill and overfill prevention equipment:
 - (ii) Overfill prevention equipment that will:
 - (A) Automatically shut off flow into the tank when the tank is no more than 95 percent full; or
 - (B) Alert the transfer operator when the tank is no more than 90 percent full by restricting the flow into the tank or triggering a high-level alarm; or
 - (C) Restrict flow 30 minutes prior to overfilling, alert the transfer operator with a high-level alarm one minute before overfilling, or automatically shut off flow into the tank so that none of the fittings located on top of the tank are exposed to product due to overfilling.

As noted during the inspection, auto shutoff devices were not observed in the fill ports, but previous notification forms indicated auto shut off devices were present.

9. Pursuant to 40 CFR 280.32(a), owners and operators must use an UST system made of or lined with materials that are compatible with the substance stored in the UST system.

As noted during inspection, Respondents failed to demonstrate that the UST system or tank liners are fully compatible with the product stored in the tanks.

10. Pursuant to 40 CFR 280.240, not later than October 13, 2018, all owners and operators of UST systems must ensure they have designated Class A, Class B, and Class C operators who meet the requirements of this subpart.

As noted during the inspections, Respondent failed to have designated Class A, Class B, or Class C operators at the Site.

11. Pursuant to 40 CFR 280.41(a)(1), considering previous Indiana rule at 329 IAC 9-3-1.3 (repealed 2018), tanks installed on or before September 2, 2009 must be monitored for releases at least every 30 days using one of the methods listed in § 280.43(d) through (i).

As noted during the inspection, 12-months of release detection records or tank tightness tests for the USTs were not provided. The premium UST also contained three inches of water.

12. Pursuant to 40 CFR 280.41(b)(1)(i)(A), considering previous Indiana rules at 329 IAC 9-2-1(2)(D) and 329 IAC 9-3-1.3 (both repealed 2018), pressurized underground piping installed on or before September 2, 2009 that routinely contains regulated substances must be equipped with an automatic line leak detector conducted in accordance with § 280.44(a).

As noted during the inspection, the leak detection test was not provided for the regular unleaded UST. The premium STP did not appear to have a functioning leak detector present.

13. Pursuant to 40 CFR 280.41(b)(1)(i)(B), considering previous Indiana rules at 329 IAC 9-2-1(2)(D) and 329 IAC 9-3-1.3 (both repealed 2018), pressurized underground piping installed on or before September 2, 2009 that routinely contains regulated substances must have an annual line tightness test conducted in accordance with § 280.44(b) or have monthly monitoring conducted in accordance with § 280.44(c).

As noted during the inspection, Respondents failed to provide line tightness test results or monthly monitoring records.

In accordance with IC 13-30-3-3, the Commissioner herein provides notice that violations may exist and offers an opportunity to enter into an Agreed Order providing for the actions required to correct the violations and, as necessary and appropriate, for the payment of a civil penalty. The Commissioner is not required to extend this offer for more than sixty (60) days.

As provided in IC 13-30-3-3, an alleged violator may enter into an Agreed Order without admitting that the violations occurred. IDEM encourages settlement by Agreed Order, thereby resulting in quicker correction of the environmental violations and avoidance of extensive litigation. Timely settlement by Agreed Order may result in a reduced civil penalty. Also, settlement discussions will allow the opportunity to present any mitigating factors that may be relevant to the violations.

If an Agreed Order is not entered into within sixty (60) days of receipt of this Notice of Violation, the Commissioner may issue a Notice and Order under IC 13-30-3-4 containing the actions that must be taken to correct the violations and requiring the payment of an appropriate civil penalty. Pursuant to IC 13-23-14-3, the Commissioner may assess penalties of up to \$10,000 per day for each underground storage tank.

Please contact Jillian Henderson at 317-232-8617 or JHenders@idem.in.gov within fifteen (15) days after receipt of this Notice to discuss resolution of this matter.

For the Commissioner:

Date: 1/3/2022



Bruce Kizer, Branch Chief
Compliance Branch
Office of Land Quality



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

100 N. Senate Avenue • Indianapolis, IN 46204
(800) 451-6027 • (317) 232-8603 • www.idem.IN.gov

Eric J. Holcomb
Governor

Bruno L. Pigott
Commissioner

STATE OF INDIANA) SS: BEFORE THE INDIANA DEPARTMENT OF
COUNTY OF MARION) ENVIRONMENTAL MANAGEMENT

COMMISSIONER OF THE DEPARTMENT
OF ENVIRONMENTAL MANAGEMENT,)

Complainant,)

v.) Case No. 2021-28224-U

LUKE OIL CO., INC.)
GATEWAY TRIANGLE CORP.,)

Respondents.)

AGREED ORDER

Complainant and Respondents desire to settle and compromise this action without hearing or adjudication of any issue of fact or law, and consent to the entry of the following Findings of Fact and Order. Pursuant to Indiana Code (“IC”) 13-30-3-3, entry into the terms of this Agreed Order does not constitute an admission of any violation contained herein. Respondents’ entry into this Agreed Order shall not constitute a waiver of any defense, legal or equitable, which Respondents may have in any future administrative or judicial proceeding, except a proceeding to enforce this order.

I. FINDINGS OF FACT

1. Complainant is the Commissioner (“Complainant”) of the Indiana Department of Environmental Management (“IDEM”), a department of the State of Indiana created by Indiana Code (“IC”) 13-13-1-1.
2. Respondent Luke Oil Co., Inc. owns the Underground Storage Tank (“UST”) system, with UST Facility ID 604, located at 6259 Melton Road, in Portage, Porter County, Indiana (“Site”).
3. Respondent Gateway Triangle Corp. operates the UST systems, located at 6259 Melton Road, parcel # 64-05-01-451-001.000-016, in Hobart, Porter County, Indiana (the “Site”).
4. Respondent Luke Oil Co., Inc. owns four fiberglass 8,000-gallon gasoline USTs. Three USTs were installed in 1971 and one was installed in 2005.

5. IDEM has jurisdiction over the parties and the subject matter of this action.
5. Pursuant to IC 13-30-3-3, IDEM issued a Notice of Violation (“NOV”) via Certified Mail to:

Thomas Collins III, President & Registered Agent for
Luke Oil Co., Inc.
3592 N. Hobart Road
Hobart, Indiana 46342

Thomas Collins III, President & Registered Agent for
Gateway Triangle Corp.
3592 N. Hobart Road
Hobart, Indiana 46342

7. During an investigation including an inspection on January 28, 2020, conducted by a representative of IDEM, the following violations were found:
 - a. Pursuant to 329 Indiana Administrative Code (“IAC”) 9-2-2(c), an owner required to submit a notification under this section shall provide:
 - (1) a notification for each UST owned.
 - (2) complete information required on the form for each UST owned; and
 - (3) if applicable, a separate notification form for each separate place of operation at which the USTs are located.

As noted during the inspection, a corrected notification form was required and the notification form submitted on February 17, 2020 was rejected on August 18, 2020. An updated form has not been submitted.

- b. Pursuant to 40 Code of Federal Regulations (“CFR”) 280.34, owners and operators of UST systems must cooperate fully with inspections, monitoring and testing conducted by the implementing agency, as well as requests for document submission, testing, and monitoring by the owner or operator pursuant to section 9005 of Subtitle I of the Solid Waste Disposal Act, as amended.

As noted during the inspection, Respondents failed to perform the monitoring or testing required by the rules and/or submit the requested documentation as required.

- c. Pursuant to 329 IAC 9-8-11(a), an owner or operator may satisfy the financial responsibility requirements of section 4 of this rule by participation in the excess liability trust funder under 328 IAC 1. Reimbursement from the fund is determined by compliance with 328 IAC 1. Pursuant to 329 IAC 9-8-11(b), an owner or operator of:
 - (1) twelve (12) or fewer USTs shall demonstrate the ability to pay the applicable deductible amount under IC 13-23-9-1.3; or

- (2) more than twelve (12) USTs shall demonstrate the ability to pay two (2) times the applicable deductible amount under IC 13-23-9-1.3.

As noted during the inspection, Respondents failed to demonstrate the ability to pay the applicable deductible.

- d. Pursuant to 40 CFR 280.20(c)(1)(ii), to prevent spilling and overfilling associated with product transfer to the UST system, owners and operators must use the following spill and overfill prevention equipment:
 - (ii) Overfill prevention equipment that will:
 - (A) Automatically shut off flow into the tank when the tank is no more than 95 percent full; or
 - (B) Alert the transfer operator when the tank is no more than 90 percent full by restricting the flow into the tank or triggering a high-level alarm; or
 - (C) Restrict flow 30 minutes prior to overfilling, alert the transfer operator with a high-level alarm one minute before overfilling, or automatically shut off flow into the tank so that none of the fittings located on top of the tank are exposed to product due to overfilling.

As noted during the inspection, auto shutoff devices were not observed in the fill ports, but previous notification forms indicated auto shut off devices were present.

- e. Pursuant to 40 CFR 280.32(a), owners and operators must use an UST system made of or lined with materials that are compatible with the substance stored in the UST system.

As noted during inspection, Respondents failed to demonstrate that the UST system or tank liners are fully compatible with the product stored in the tanks.

- f. Pursuant to 40 CFR 280.240, not later than October 13, 2018, all owners and operators of UST systems must ensure they have designated Class A, Class B, and Class C operators who meet the requirements of this subpart.

As noted during the inspections, Respondent failed to have designated Class A, Class B, or Class C operators at the Site.

- g. Pursuant to 40 CFR 280.41(a)(1), considering previous Indiana rule at 329 IAC 9-3-1.3 (repealed 2018), tanks installed on or before September 2, 2009 must be monitored for releases at least every 30 days using one of the methods listed in § 280.43(d) through (i).

As noted during the inspection, 12-months of release detection records or tank tightness tests for the USTs were not provided. The premium UST also contained three inches of water.

- h. Pursuant to 40 CFR 280.41(b)(1)(i)(A), considering previous Indiana rules at 329 IAC 9-2-1(2)(D) and 329 IAC 9-3-1.3 (both repealed 2018), pressurized underground piping installed on or before September 2, 2009 that routinely contains regulated substances must be equipped with an automatic line leak detector conducted in accordance with § 280.44(a).

As noted during the inspection, the leak detection test was not provided for the regular unleaded UST. The premium STP did not appear to have a functioning leak detector present.

- h. Pursuant to 40 CFR 280.41(b)(1)(i)(B), considering previous Indiana rules at 329 IAC 9-2-1(2)(D) and 329 IAC 9-3-1.3 (both repealed 2018), pressurized underground piping installed on or before September 2, 2009 that routinely contains regulated substances must have an annual line tightness test conducted in accordance with § 280.44(b) or have monthly monitoring conducted in accordance with § 280.44(c).

As noted during the inspection, Respondents failed to provide line tightness test results or monthly monitoring records.

8. Orders of the Commissioner are subject to administrative review by the Office of Environmental Adjudication under IC 4-21.5; however, in recognition of the settlement reached, Respondents acknowledge notice of this right and waives any right to administrative and judicial review of this Agreed Order.

II. ORDER

1. This Agreed Order shall be effective (“Effective Date”) when it is approved by Complainant or Complainant’s delegate, and has been received by Respondents. This Agreed Order shall have no force or effect until the Effective Date.
2. Respondents shall comply with the rules listed in the findings of fact above.
3. Within thirty (30) days of the Effective Date, Respondents shall comply with 329 IAC 9-2-2(c). Specifically, Respondents shall download, complete, and submit the “*Notification Form for Underground Storage Tanks*,” State Form from IDEM webpage: <https://www.in.gov/idem/5157.htm>, under “Underground Storage Tank (UST) Program.” Once downloaded the form may be completed on-line or by hand and emailed to USTRegistration@idem.in.gov. The completed form will not be accepted by mail.
4. Immediately upon the Effective Date, Respondents shall cooperate fully with inspections, monitoring and testing conducted by the implementing agency, as well as requests for document submission, testing, and monitoring by the owner or operator pursuant to section 9005 of Subtitle I of the Solid Waste Disposal Act, as amended to IDEM.

5. Within the thirty (30) days of the Effective Date, Respondents shall comply with 329 IAC 9-8-11(a) & (b). Specifically, Respondents shall submit documentation of the ability to pay the applicable deductible to IDEM.
6. Within thirty (30) days of the Effective Date, Respondents shall comply with 40 CFR 280.20(c)(1)(ii). Specifically, Respondents shall submit to IDEM documentation verifying type of overfill protection being utilized for all USTs at the Site.
7. Within thirty (30) days of the Effective Date, Respondents shall submit documentation proving the UST system or tank liners are fully compatible with the product found stored in the tanks during the inspection. If compatibility cannot be proved, Respondents must immediately cease storing the substance in the UST system until such a time as compatibility can be proved, the UST system upgraded, or the product is switched to one that is compatible.
8. Within thirty (30) days of the Effective Date, Respondents shall have any UST or line that contains a regulated amount of product and found not to have been monitored every thirty (30) days tightness tested and submit the results within forty-five (45) days of the Effective Date. Respondent shall continue to perform proper monthly release detection and submit the results monthly for a period of six (6) months after the Effective Date.
9. Within thirty (30) days of the Effective Date, Respondents shall have any piping that contains a regulated amount of product and found to not have had appropriate monthly monitoring or an annual line tightness test within the 12 months prior to inspection tightness tested.
10. Within thirty (30) days of the Effective Date, Respondents shall submit a list of those employees designated to be Class A, Class B and Class C operators. Those so designated must be trained and certification of that training submitted.
11. All submittals required by this Agreed Order, unless Respondent are notified otherwise in writing by IDEM, shall be sent to:

Jillian Henderson, Enforcement Case Manager
Office of Land Quality
Indiana Department of Environmental Management
100 North Senate Avenue
Indianapolis, IN 46204-2251
12. Respondents are assessed and agree to pay a civil penalty of Forty Thousand One Hundred Dollars (\$40,100).. Respondents are jointly and severally liable for all civil penalty assessments, including stipulated penalties. Said penalty amount shall be due and payable to the "Underground Petroleum Storage Tank Trust Fund" within thirty (30) days of the Effective Date; the 30th day being the "Due Date."

13. In the event the terms and conditions of the following paragraphs are violated, Complainant may assess and Respondents shall pay a stipulated penalty in the following amount:

<u>Paragraph</u>	<u>Penalty</u>
Order paragraph #3	\$100.00 per week
Order paragraph #5	\$100.00 per week
Order paragraph #6	\$100.00 per week
Order paragraph #7	\$100.00 per week
Order paragraph #8	\$100.00 per week
Order paragraph #9	\$100.00 per week
Order paragraph #10	\$100.00 per week

14. Stipulated penalties shall be due and payable no later than the 30th day after Respondents receive written notice that Complainant has determined a stipulated penalty is due; the 30th day being the “Due Date.” Complainant may notify Respondents at any time that a stipulated penalty is due. Failure to notify Respondents in writing in a timely manner of stipulated penalty assessment shall not waive Complainant’s right to collect such stipulated penalty or preclude Complainant from seeking additional relief against Respondents for violation of this Agreed Order. Neither assessment nor payment of stipulated penalties shall preclude Complainant from seeking additional relief against Respondents for a violation of this Agreed Order; such additional relief includes any remedies or sanctions available pursuant to Indiana law, including, but not limited to, civil penalties pursuant to IC 13-30-4. Respondents are jointly and severally liable for all stipulated penalty assessments.
15. Civil and stipulated penalties are payable by check to the “Underground Petroleum Storage Tank Trust Fund.” Checks shall include the Case Number of this action and shall be mailed to:
- Indiana Department of Environmental Management
Accounts Receivable
IGCN, Room 1340
100 North Senate Avenue
Indianapolis, IN 46204
16. In the event that the monies due to IDEM pursuant to this Agreed Order are not paid on or before their Due Date, Respondents shall pay interest on the unpaid balance at the rate established by IC 24-4.6-1. The interest shall be computed as having accrued from the Due Date until the date that Respondents pay any unpaid balance. Such interest shall be payable to the the “Underground Petroleum Storage Tank Trust Fund,” and shall be payable to IDEM in the manner specified in Paragraph 16, above.
17. Signatories to this Agreed Order certify that they are fully authorized to execute this Agreed Order and legally bind the party they represent.

18. This Agreed Order shall apply to and be binding upon Respondents and all successors and assigns. Respondents shall provide a copy of this Agreed Order, if in force, to any subsequent owners, successors, or assigns before ownership rights are transferred.
19. No change in ownership, corporate, or partnership status of Respondents shall in any way alter the Respondents' status or responsibilities under this Agreed Order.
20. Respondents shall ensure that all contractors, firms, and other persons performing work under this Agreed Order comply with the terms of this Agreed Order.
21. In the event that any terms of this Agreed Order are found to be invalid, the remaining terms shall remain in full force and effect and shall be construed and enforced as if this Agreed Order did not contain the invalid terms.
22. This Agreed Order is not and shall not be interpreted to be a permit or a modification of an existing permit. This Agreed Order, and IDEM's review or approval of any submittal made by Respondents pursuant to this Agreed Order, shall not in any way relieve Respondents of the obligation to comply with the requirements of any applicable permits or any applicable Federal or State laws or regulations.
23. Complainant does not, by its approval of this Agreed Order, warrant or aver in any manner that Respondents' compliance with any aspect of this Agreed Order will result in compliance with the provisions of any permit, order, or any applicable Federal or State law or regulation. Additionally, IDEM or anyone acting on its behalf shall not be held liable for any costs or penalties Respondents may incur as a result of Respondents' efforts to comply with this Agreed Order.
24. Nothing in this Agreed Order shall prevent or limit IDEM's rights to obtain penalties or injunctive relief under any applicable Federal or State law or regulation, except that IDEM may not, and hereby waives its right to, seek additional civil penalties for the violations specified in the NOV.
25. Nothing in this Agreed Order shall prevent IDEM or anyone acting on its behalf from communicating with the U.S. Environmental Protection Agency (U.S. EPA) or any other agency or entity about any matters relating to this enforcement action. IDEM or anyone acting on its behalf shall not be held liable for any costs or penalties Respondents may incur as a result of such communications with the U.S. EPA or any other agency or entity.
26. This Agreed Order shall remain in effect until IDEM issues a Resolution of Case letter to Respondents.

REMAINDER OF PAGE LEFT BLANK INTENTIONALLY

TECHNICAL RECOMMENDATION:
Department of Environmental Management

By: Jennifer Reno
Jennifer Reno, Chief
Land Enforcement Section
Compliance Branch
Office of Land Quality

Date: 11/30/2021

RESPONDENT:

By: _____
Printed: _____
Title: _____

Date: _____

COUNSEL FOR RESPONDENT:

By: _____
Printed: _____
Date: _____

APPROVED AND ADOPTED BY THE INDIANA DEPARTMENT OF ENVIRONMENTAL
MANAGEMENT THIS _____ DAY OF _____, 20____

For the Commissioner:

Peggy Dorsey
Assistant Commissioner
Office of Land Quality

SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

60-02L (1833) dbates
Mr. Thomas M. Collins III
President and Registered Agent
Luke Oil Co., Inc.
3592 North Hobart Road
Hobart, Indiana 46342

COMPLETE THIS SECTION ON DELIVERY

A. Signature

X BWS RR1 C19

- ☐ Agent
☐ Addressee

B. Received by (Printed Name)

S. Bonilla

C. Date of Delivery

1-6-22

- D. Is delivery address different from item 1? ☐ Yes
If YES, enter delivery address below: ☐ No

3. Service Type

- ☒ Certified Mail ☐ Express Mail
☐ Registered ☐ Return Receipt for Merchandise
☐ Insured Mail ☐ C.O.D.

4. Restricted Delivery? (Extra Fee) ☐ Yes

7007 1490 0000 0839 2518

PS Form 3811, February 2004

Domestic Return Receipt

102595-02-M-1540

SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

60-02L (1833) dbates
Mr. Thomas M. Collins III
President and Registered Agent
Gateway Triangle Corp.
3592 North Hobart Road
Hobart, Indiana 46342

COMPLETE THIS SECTION ON DELIVERY

A. Signature

X BWS RR1 C19

- ☐ Agent
☐ Addressee

B. Received by (Printed Name)

S. Bonilla

C. Date of Delivery

1-6-22

- D. Is delivery address different from item 1? ☐ Yes
If YES, enter delivery address below: ☐ No

3. Service Type

- ☒ Certified Mail ☐ Express Mail
☐ Registered ☐ Return Receipt for Merchandise
☐ Insured Mail ☐ C.O.D.

4. Restricted Delivery? (Extra Fee) ☐ Yes

7007 1490 0000 0839 2525

PS Form 3811, February 2004

Domestic Return Receipt

102595-02-M-1540