



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

100 N. Senate Avenue • Indianapolis, IN 46204
(800) 451-6027 • (317) 232-8603 • www.idem.IN.gov

Eric J. Holcomb
Governor

Brian C. Rockensuess
Commissioner

March 22, 2023

VIA ELECTRONIC MAIL

Mr. R. Daniel Stevens, Director of Administration
Hamilton County Building Corporation
1 Hamilton County Square, Suite 157
Noblesville, Indiana 46060

Dear Mr. Stevens:

Re: 327 IAC 3 Construction
Permit Application
Bakers Corner WWTP
Permit Approval No. 24943
Bakers Corner, Indiana
Hamilton County

The application, plans and specifications, and supporting documents for the above-referenced project have been reviewed and processed in accordance with rules adopted under 327 IAC 3. Enclosed is the Construction Permit (Approval No. 24943), which applies to the construction of the above-referenced proposed water pollution treatment/control facility to be located approximately 750 feet south and 600 feet west of the intersection of East 241st Street and U.S. Route 31 near the unincorporated community of Bakers Corner.

Please review the enclosed permit carefully and become familiar with its terms and conditions. In addition, it is imperative that the applicant, consulting architect/engineer (A/E), inspector, and contractor are aware of these terms and conditions.

It should be noted that any person affected or aggrieved by the agency's decision in authorizing the construction of the above-referenced facility may, within fifteen (15) days from date of mailing, appeal by filing a request with the Office of Environmental Adjudication for an adjudicatory hearing in accordance with IC 4-21.5-3-7 and IC 13-15-6. The procedure for appeal is outlined in more detail in Part III of the attached construction permit.

Plans and specifications were prepared by Wessler Engineering, and certified by Ms. Kathleen M. Ziino, P.E., and submitted for review on December 9, 2022, with additional information submitted on February 1, 17, 28, and March 3, and 8.

Any technical/engineering questions concerning this permit may be addressed to Ms. Alissa O'Donnell, of our staff, at 317/232-8646.

Sincerely,

A handwritten signature in black ink that reads "Kevin D. Czerniakowski". The signature is written in a cursive style with a large, stylized 'K' and 'C'.

Kevin D. Czerniakowski, P.E.
Section Chief
Facility Construction and
Engineering Support Section
Office of Water Quality

Project No. P-25686

Enclosures

cc: Hamilton County Health Department
Wessler Engineering

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
AUTHORIZATION FOR CONSTRUCTION OF
WATER POLLUTION TREATMENT/CONTROL FACILITY
UNDER 327 IAC 3

DECISION OF APPROVAL

The Hamilton County Building Corporation, in accordance with the provisions of IC 13-15 and 327 IAC 3 is hereby issued a permit to construct the water pollution treatment/control facility to be located approximately 750 feet south and 600 feet west of the intersection of East 241st Street and U.S. Route 31 near the unincorporated community of Bakers Corner. The permittee is required to comply with requirements set forth in Parts I, II and III hereof. The permit is effective pursuant to IC 4-21.5-3-4(d). If a petition for review and a petition for stay of effectiveness are filed pursuant to IC 13-15-6, an Environmental Law Judge may be appointed for an adjudicatory hearing. The force and effect of any contested permit provision may be stayed at that time.

NOTICE OF EXPIRATION DATE

Authorization to initiate construction of this pollution treatment/control facility shall expire at midnight one year from the date of issuance of this permit. In order to receive authorization to initiate construction beyond this date, the permittee shall submit such information and forms as required by the Indiana Department of Environmental Management. It is requested that this information be submitted sixty (60) days prior to the expiration date to initiate construction. This permit shall be valid for a period of five (5) years from the date below for full construction completion.

Issued on March 22, 2023, for the Indiana Department of Environmental Management.



Kevin D. Czerniakowski, P.E.
Section Chief
Facility Construction and
Engineering Support Section
Office of Water Quality

WATER POLLUTION TREATMENT/CONTROL FACILITY DESCRIPTION

Bakers Corner is currently an unsewered community in Hamilton County. The Indiana Department of Transportation (INDOT) is converting the intersections of 236th and 276th Streets with US-31 to interchanges. The INDOT US-31 project is anticipated to increase access to and encourage commercial and residential development in the Bakers Corner community and surrounding areas. To accommodate this growth, sanitary infrastructure will need to be built, and the Hamilton County Building Corporation intends to construct a new wastewater treatment plant (WWTP). The proposed WWTP average and peak hourly flow capacities will be 0.5 MGD and 2.25 MGD, respectively. The proposed project will include but is not limited to the following:

- Construction of a new outdoor screening structure with a mechanical in-channel fine screen and removable manually cleaned coarse bar bypass screen
- Construction of a new 8 ft x 8 ft x 11 ft RAS feed structure
- Construction of two (2) single channel oxidation ditches with fine bubble membrane diffusers, two (2) 6.2-HP submersible mixers, and three (3) positive displacement blowers capable of 164 cfm, each
- Construction of a new control building which houses the laboratory, office, bathroom, electrical room, and chemical phosphorus removal facilities
- Installation of two (2) 250 gallon chemical totes, 535 gallon spill containment unit, two (2) 0-31 GPH chemical metering pumps, 3/4-inch PVC chemical feed tubing inside 6-inch PVC carrier piping, and combination safety shower/eyewash unit.
- Construction of two (2) 40 ft diameter secondary clarifiers
- Construction of a new RAS/WAS pump station and installation of three (3) submersible pumps (2 duty, 1 standby) each capable of 175 gpm
- Construction of a new RAS/WAS metering structure and installation of two (2) 4-inch electromagnetic flow meters (one on each line to either the RAS feed structure or the polymer dewatering building)
- Construction of a new ultraviolet (UV) light disinfection and cascade post-aeration structure and installation of a new parshall flume effluent flow meter
- Construction of a new polymer dewatering building and installation of a 55 gallon polymer drum, 66 gallon spill containment unit, chemical pump, and static mixer
- Construction of a new 30 ft x 31 ft concrete dewatering pad with trench draining and installation of two (2) roll-off dumpsters w/ geotextile bags
- Construction of a new plant drain pump station and installation of two (2) submersible pumps each capable of 200 gpm
- Installation of a standby 200 kW diesel generator

CONDITIONS AND LIMITATIONS TO THE AUTHORIZATION FOR
CONSTRUCTION OF WATER POLLUTION TREATMENT/CONTROL FACILITY

During the period beginning on the effective date of this permit and extending until the expiration date, the permittee is authorized to construct the above described water pollution treatment/control facility. Such construction shall conform to all provisions of State Rule 327 IAC 3 and the following specific provisions:

PART I

SPECIFIC CONDITIONS AND LIMITATIONS TO THE CONSTRUCTION PERMIT

Unless specific authorization is otherwise provided under the permit, the permittee shall comply with the following conditions:

1. Additional treatment facilities shall be installed if the proposed facilities prove to be inadequate or cannot meet applicable federal or state standards.
2. Any local permits required for this project, along with zoning or easement acquisition, shall be obtained before construction is initiated.
3. If pollution or nuisance conditions are created, immediate corrective action will be taken by the permittee.
4. If construction is located within a floodway, a permit may also be required from The Department of Natural Resources prior to the start of construction. It is the permittee's responsibility to coordinate with that agency and obtain any required approvals if applicable. Questions may be directed to the Technical Services Section, Division of Water at 317/232-4160.
5. Plans for the outfall structure shall be submitted to the Department of Natural Resources for consideration of approval prior to the start of construction.

Failure to meet guidelines as set forth in the above conditions could be subject to enforcement proceedings as provided by 327 IAC 3-5-3.

PART II

GENERAL CONDITIONS

1. No significant or material changes in the scope of the plans or construction of this project shall be made unless the following provisions are met:
 - a. Request for permit modification is made 60 days in advance of the proposed significant or material changes in the scope of the plans or construction;
 - b. Submit a detailed statement of such proposed changes;
 - c. Submit revised plans and specifications including a revised design summary; and
 - d. Obtain a revised construction permit from this agency.
2. This permit may be modified, suspended, or revoked for cause including, but not limited to the following:
 - a. Violation of any term or conditions of this permit:
 - b. Obtaining this permit by misrepresentation or failure to disclose fully all relevant facts.
3. Nothing herein shall be construed as guaranteeing that the proposed water pollution treatment/control facility shall meet standards, limitations or requirements of this or any other agency of state or federal government, as this agency has no direct control over the actual construction and/or operation of the proposed project.

PART III

NOTICE OF RIGHT TO ADMINISTRATIVE REVIEW

Anyone wishing to challenge this construction permit must do so by filing a Petition for Administrative Review with the Office of Environmental Adjudication (OEA), and serving a copy of the petition upon IDEM. The requirements for filing a Petition for Administrative Review are found in IC 4-21.5-3-7, IC 13-15-6-1 and 315 IAC 1-3-2. A summary of the requirements of these laws is provided below.

A Petition for Administrative Review must be filed with the Office of Environmental Adjudication (OEA) within fifteen (15) days of the issuance of this notice (eighteen (18) days if notice was received by U.S. Mail), and a copy must be served upon IDEM. Addresses are:

Director
Office of Environmental Adjudication
Indiana Government Center North
Room 103
100 North Senate Avenue
Indianapolis, Indiana 46204

Commissioner
Indiana Department of Environmental
Management
Indiana Government Center North
Room 1301
100 North Senate Avenue
Indianapolis, Indiana 46204

The petition must contain the following information:

1. The name, address and telephone number of each petitioner.
2. A description of each petitioner's interest in the permit.
3. A statement of facts demonstrating that each petitioner is:
 - a. a person to whom the order is directed;
 - b. aggrieved or adversely affected by the permit; or
 - c. entitled to administrative review under any law.
4. The reasons for the request for administrative review.
5. The particular legal issues proposed for review.
6. The alleged environmental concerns or technical deficiencies of the permit.
7. The permit terms and conditions that the petitioner believes would be appropriate and would comply with the law.
8. The identity of any persons represented by the petitioner.
9. The identity of the person against whom administrative review is sought.
10. A copy of the permit that is the basis of the petition.
11. A statement identifying petitioner's attorney or other representative, if any.

Failure to meet the requirements of the law with respect to a Petition for Administrative Review may result in a waiver of the Petitioner's right to seek administrative review of the permit. Examples are:

1. Failure to file a Petition by the applicable deadline;
2. Failure to serve a copy of the Petition upon IDEM when it is filed; or
3. Failure to include the information required by law.

If Petitioner seeks to have a permit stayed during the administrative review, he or she may need to file a Petition for a Stay of Effectiveness. The specific requirements for such a Petition can be found in 315 IAC 1-3-2 and 315 IAC 1-3-2.1.

Pursuant to IC 4-21.5-3-17, OEA will provide all parties with notice of any pre-hearing conferences, preliminary hearings, hearings, stays, or orders disposing of the review of this action. Those who are entitled to notice under IC 4-21.5-3-5(b) and would like to obtain notices of any pre-hearing conferences, preliminary hearings, hearings, stays, or orders disposing of the review of this action without intervening in the proceeding must submit a written request to OEA at the address above.

More information on the review process is available at the website for the Office of Environmental Adjudication at <http://www.in.gov/oea>.

Wastewater Treatment Facility Design Summary

I. GENERAL

1. Applicant: Hamilton County Building Corporation
2. Facility Name: Bakers Corner Wastewater Treatment Plant
3. Project Type: New facility
4. Project Title: Bakers Corner WWTP
5. Project Location: Approximately 750 feet south and 600 feet west of the intersection of East 241st Street and U.S. Route 31
6. Construction Permit Number: 24943
7. Design Engineer: Ms. Kathleen M. Ziino, P.E.
8. Engineering Company: Wessler Engineering
9. NPDES Permit Number: Pending
10. Preliminary Effluent Limitations: March 4, 2022
11. Project Scope
 - A. Description of existing treatment facilities: Bakers Corner is currently an unsewered community in Hamilton County.
 - B. Description of project needs: The Indiana Department of Transportation (INDOT) is converting the intersections of 236th and 276th Streets with US-31 to interchanges. The INDOT US-31 project is anticipated to increase access to and encourage commercial and residential development in the Bakers Corner community and surrounding areas. To accommodate this growth, sanitary infrastructure will need to be built, and the Hamilton County Building Corporation intends to construct a new wastewater treatment plant (WWTP).
 - C. The proposed project will include but is not limited to the following:
 - Construction of a new outdoor screening structure with a mechanical in-channel fine screen and removable manually cleaned coarse bar bypass screen
 - Construction of a new 8 ft x 8 ft x 11 ft RAS feed structure
 - Construction of two (2) single channel oxidation ditches with fine bubble membrane diffusers, two (2) 6.2-HP submersible mixers, and three (3) positive displacement blowers capable of 164 cfm, each
 - Construction of a new control building which houses the laboratory, office, bathroom, electrical room, and chemical phosphorus removal facilities
 - Installation of two (2) 250 gallon chemical totes, 535 gallon spill containment unit, two (2) 0-31 GPH chemical metering pumps, 3/4-inch PVC chemical feed tubing inside 6-inch PVC carrier piping, and combination safety shower/eyewash unit.

- Construction of two (2) 40 ft diameter secondary clarifiers
 - Construction of a new RAS/WAS pump station and installation of three (3) submersible pumps (2 duty, 1 standby) each capable of 175 gpm
 - Construction of a new RAS/WAS metering structure and installation of two (2) 4-inch electromagnetic flow meters (one on each line to either the RAS feed structure or the polymer dewatering building)
 - Construction of a new ultraviolet (UV) light disinfection and cascade post-aeration structure and installation of a new parshall flume effluent flow meter
 - Construction of a new polymer dewatering building and installation of a 55 gallon polymer drum, 66 gallon spill containment unit, chemical pump, and static mixer
 - Construction of a new 30 ft x 31 ft concrete dewatering pad with trench draining and installation of two (2) roll-off dumpsters w/ geotextile bags
 - Construction of a new plant drain pump station and installation of two (2) submersible pumps each capable of 200 gpm
 - Installation of a standby 200 kW diesel generator
- D. Is project part of an Agreed Order?: No
- E. How facility will maintain treatment during construction: Private septic systems will be maintained until the new plant is operational
12. Source of Funding: Indiana Finance Authority State Water Infrastructure Fund (via American Rescue Plan Act) and Local Funds
13. Estimated Total Project Cost: \$16,000,000

II. DESIGN DATA

The facility is anticipating flows as low as 0.08 MGD during the initial start-up and near term conditions before significant development can occur in the area.

1. Design Average Flow: 0.5 MGD
 - A. Domestic: 0.18 MGD
 - B. Industrial/Commercial: 0.32 MGD
 - C. Infiltration/Inflow: Minimal
2. Design Peak Hourly Flow: 2.25 MGD
3. Design Waste Strength
 - A. CBOD: 200 mg/L
 - B. TSS: 200 mg/L
 - C. NH₃-N: 25 mg/L
 - D. P: 6 mg/L
4. Design Population Equivalent: 4,906 (based on 0.17 lb CBOD/PE influent loading)

5. NPDES Permit Limitation on Effluent Quality
 - A. CBOD₅: 10 mg/L (monthly average)
 - B. TSS: 12 mg/L (monthly average)
 - C. NH₃-N: 1.1 mg/L summer and 1.6 mg/L winter (monthly average)
 - D. P: 1.0 mg/L
 - E. pH: 6.0 s.u. (daily min) and 9.0 s.u. (daily max)
 - F. DO: 6.0 mg/L (daily min)
 - G. *E. coli*: 125 count/100 mL (monthly average), 235 count/100 mL (daily max)
6. Sampling Method (Grab or Automatic Sampler) and Location
 - A. Influent: Automatic, screening structure
 - B. Effluent: Automatic, UV disinfection and cascade structure
7. Receiving Stream
 - A. Name: Baker Ditch (tributary to Hinkle Creek)
 - B. Stream Uses: Full body contact recreational use and shall be capable of supporting a well-balanced warm water aquatic community
 - C. 7-day, 1-in-10 year low flow: 0.0 CFS

III. PLANT DETAILS

1. Laboratory type (e.g., on site, third-party testing): On-site
2. Plant site fence provided: Yes, chain-link fence
3. Handrail/grating provided where necessary: Yes, where applicable
4. Flood hazard elevation at 100 year flood: 897.74 ft (estimated)
5. Provisions for mechanical/electrical protection at 100 year flood: Yes, typical structure floor elevation is more than 7 ft above the 100-year flood elevation
6. Type and rating of standby power equipment: 200 kW diesel generator
7. Provisions for removing heavy equipment: Yes, davit cranes (screening, oxidation ditches, RAS/WAS pump station, UV disinfection, and plant drain pump station)
8. Septage/leachate receiving facilities: None

IV. TREATMENT UNITS

Influent Flow Meter (Proposed)

1. Type and size: 9-inch electromagnetic
2. Location description: On the 10-inch effluent line from Lift Station 1
3. Indicating, recording, and totalizing: Yes, SCADA

Screening (Proposed)

1. Type of screening: Mechanical fine screen (in-channel screw)
2. Location description: New screening structure
3. Bypass bar screen provision: Yes, manual bar screen

4. Number and rated capacity: One (1) @ 2.25 MGD
5. Clear opening sizes, bar or perforations: 0.25-inch
6. Slope of unit: 35°
7. Method of unit cleaning: Automated wash-water rinse
8. Method of screening disposal: Dumpster to landfill
9. Method of unit isolation: None, single unit (screen can pivot out of channel)
10. Method of flow split control: None, single unit
11. Additional information: When not in use, the bypass screen is completely removed from the channel (same channel as mechanical). The intention for future plant expansion is to abandon this structure in favor of a larger capacity headworks structure that includes separate screening channels.

RAS Feed Structure (Proposed)

1. Dimensions: 8 ft x 8 ft x 11 ft (5,260 gallons)
2. Additional information: Incoming screened raw influent flows will be mixed with RAS (from the RAS/WAS pump station) and plant drain pump station flows.

Oxidation Ditch (Proposed)

1. Number and dimensions of unit: Two (2)
 - A. Ditch Type: Single channel, non-concentric, no center island
 - B. Ditch Dimensions: 60 ft L x 11 ft W (straight) and 11.5 ft (outer radius)
 - C. Concrete Wall Thickness: 1.16 ft W
 - D. Side water depth and freeboard: 16 ft SWD and 2 ft FB
 - E. Volume: 0.208 MGD, each (0.415 MGD total)
2. Process: Sanitaire Bioloop; Simultaneous Nitrification and Denitrification (SNDN)
3. Hydraulic detention time: 19.9 hrs
4. Organic loading: 15 lb CBOD/1000 ft³
5. Design MLSS concentration: 2,900 mg/L
6. Design solids retention time: 12.9 days
7. Design F/M ratio: 0.111 lb CBOD/day/lb MLVSS
8. Aeration equipment
 - A. Fine bubble diffusers with efficiency of 2.9 lb O₂/HP-hr (~2.2 scfm/diffuser)
 - B. Three (3) PD rotary lobe blowers @ 164 cfm, each (2 duty, 1 standby)
9. Oxygen requirement
 - A. CBOD removal: 917 lb O₂/day
 - B. NH₃-N removal: 480 lb O₂/day
10. Total air demand: 1,397 lb O₂/day (AOR) || 2,328 lb O₂/day (SOR)
11. Flow velocity in ditch: 1.17 ft/sec
12. Number and capacity of return sludge pumps: Three (3) @ 175 gpm, each
13. Method of return sludge rate control: Telescopic valves control the rate of RAS removal from clarifiers. Submersible RAS pumps draw from RAS wet well and pump it to the RAS/WAS metering structure (controls where it goes).
14. Return sludge rate as % of design average flow: 50 – 150 %

15. Provisions for return rate metering
 - A. Type and size: 4-inch electromagnetic
 - B. Location: RAS/WAS meter structure
16. Return sludge discharge location: RAS feed structure (after screening)
17. Method of unit isolation: Plug valves on each oxidation ditch influent piping
18. Method of flow split control: N/A; operated in series
19. Additional information: Until the time when flows necessitate having both oxidation ditches operate in series, only one ditch will be in operation and the pass-through gate will be closed. The oxidation ditch influent pipes are designed such that the ditches can be operated with one tank out of service.

Secondary Clarification (Proposed)

1. Type of clarifier: Circular, center feed
2. Number and dimensions of unit: Two (2) @ 40 ft dia.
3. Side water depth and freeboard of unit: 12 ft SWD and 2 ft FB
4. Surface overflow rate
 - A. at design average flow: 398 gpd/ft² (one clarifier operating)
 - B. at design peak hourly flow: 895 gpd/ft² (both clarifiers operating)
5. Hydraulic detention time
 - A. at design average flow: 5.4 hrs (one clarifier operating)
 - B. at design peak hourly flow: 2.4 hrs (both clarifiers operating)
6. Weir loading rate at design peak hourly flow: 9,766 gpd/lin-ft
7. Location of overflow weir: Circular weir, 1 ft 8 in from edge of tank
8. Method of scum collection: Skimmer with beach
9. Method of scum disposal: Drained to RAS/WAS pump station
10. Type of sludge removal mechanism: Scraper with telescoping valves
11. Method of unit isolation: Slide gates (influent splitter box)
12. Method of flow split control: Fixed weirs (influent splitter box)

Chemical Phosphorus Removal (Proposed)

1. Chemical properties
 - A. Chemical name: Alum (Aluminum Sulfate)
 - B. Weight concentration in solution: 48.5
 - C. Specific gravity: 1.335
2. Chemical storage container
 - A. Type: Polyethylene tank
 - B. Volume: 2,000 gal
 - C. Expected storage supply: 46 days
3. Secondary containment
 - A. Type: Walled concrete containment pad
 - B. Dimensions or volume: 12 ft L x 12 ft W x 2 ft H (2,150 gallons)
4. Number and capacity of chemical feed pumps: Two (2) @ 31.7 gph, each
5. Design chemical feed rate: 2.4 GPH
6. Location(s) of chemical injection: RAS feed structure and oxidation ditch effluent
7. Provisions for adequate mixing at injection point: Added in turbulent conditions

8. Chemical building
 - A. Method of ventilation control: Power vented
 - B. Method of temperature control: Electric Heater
 - C. Safety shower/eyewash equipment: Yes
9. Additional information: Near term flows are anticipated to be very low which would create an excessive storage period if the 2,000 gallon storage tank was installed. As a result, two (2) 250 gallon chemical totes will be installed on top of polyethylene spill containment pallets for near term needs. As the influent flow increases, a new 2,000 gallon storage tank inside a new walled concrete containment pad will be installed.

Ultraviolet Disinfection (Proposed)

1. Open channel or closed-vessel: Open channel
2. Vertical, horizontal, or diagonal lamp orientation: Horizontal
3. Lamp type: Low pressure, high intensity
4. Number of banks: Two (2)
5. Number of modules per bank: Three (3)
6. Number of lamps per module: Four (4)
7. Dosage: 30,000 $\mu\text{Ws}/\text{cm}^2$
8. Transmittance: 65% minimum
9. Provisions for intensity monitoring: Yes, sensor
10. Type of level control provisions: Serpentine weir
11. Type of bypass provisions: None, banks can be pulled out of channel
12. Type of safety equipment: Yes, face shield, goggles, gloves
13. Automatic or manual cleaning equipment: Automatic

Effluent Flow Meter (Proposed)

1. Type and size: 6-inch throat Parshall flume
2. Location description: In the structure for UV disinfection and post-aeration
3. Indicating, recording, and totalizing: Yes, SCADA

Cascade Post-Aeration (Proposed)

1. Number of steps: Seven (7)
2. Dimensions of steps: 1 ft tall x 1 ft deep x 4 ft wide
3. Total fall: 7 ft

Aerobic Digester (Proposed)

1. Number and dimensions of unit: One (1) @ 36 ft diameter x 24 ft H
2. Side water depth and freeboard of unit: 20.4 ft SWD and minimum 1 ft FB
3. Volume: 155,330 gal (operating at SWD); 182,700 gal (total)
4. Total design sludge loading: 483 lbs/day (includes +15% chemical sludge)
5. Volatile solids percentage: 70% VSS/TSS
6. Design solids retention time: 43 days
7. Type and efficiency of diffusers: Coarse bubble and 0.75 % SOTE
8. Dedicated or shared plant blowers: Dedicated

9. Type and rated capacity of blowers: Two (2) PD rotary lobe @ 623, each
10. Decanting method: Telescoping valve
11. Discharge location of supernatant: Plant drain pump station
12. Additional information: Near term sludge production is anticipated to be very low which would create an excessive retention time if the digester was installed. As a result, only the sludge dewatering bag system will be utilized for near term needs. As the influent flow increases, this digester will be installed to assist in sludge management.

Sludge Dewatering Bag System (Proposed)

1. Number and volume of unit: Two (2) 20 yd³ roll-off dumpster w/ geotextile bag
2. Type of chemicals added: Polymer
3. Expected solids content of dewatered sludge: 12-14 %
4. Drainage containment provisions: Sloped concrete pad with trench drain
5. Discharge location of drainage: Plant drain lift station (to RAS feed structure)

Final Sludge Disposal (Proposed)

1. Ultimate disposal method of sludge: Landfill
2. Expected solids content of sludge (by the principal method of disposal): 12-14 %
3. Location of disposal site: Licensed third-party hauler
4. Ownership of the disposal site: Licensed third-party hauler
5. Availability of sludge transport equipment: Licensed third-party hauler

Plant Drain Pump Station (Proposed)

1. Location description: WWTP, south of screening structure
2. Type of pump: Submersible, non-clog, centrifugal pumps
3. Number of pumps: Two (2)
4. Constant or variable speed: Constant
5. Design operating capacity and TDH: 200 gpm @ 31 ft (single pump)
6. Operating volume of the wet well: 6,027 gal
7. Detention time in the wet well: 30 min
8. Shutoff valve and check valve in the discharge line: Yes
9. Shutoff valve on suction line: N/A
10. Type of ventilation: Free standing air vent
11. Type of standby power: Plant generator
12. Type of alarm: SCADA
13. Type of bypass or overflow provisions: None
14. Additional information: Discharges enter the RAS feed structure

PROJECT NO.
P-25686

INTRA-OFFICE MEMO

FROM: 327 IAC Construction Permit Coordinator
Engineering Plan Review Section
Office of Water Quality

TO: AJO

permit 24943

SUBJECT: **Project:** Bakers Corner WWTP
Location: Bakers Corner, Hamilton County
Units: New WWTP – Influent screening, return activated sludge feed structure, oxidation ditches, secondary clarifiers, RAS/WAS pump station and meter, UV disinfection, cascade aeration, parshall flume, biosolids dewatering, polymer feed system, chemical feed system, laboratory, office, plant drain pump, process and yard piping, valves, emergency power generator, HVAC, electrical, instrumentation, controls mechanical, SCADA system, paving, and landscaping

Received On: 12/9/2022

Wastewater Treatment By: Bakers Corner WWTP

Maintenance Provided By: Hamilton County Building Corporation

WWTP Design Summary -----	<input checked="" type="checkbox"/>	Should be completely filled out, And match the Preliminary Limits
\$ Check-----	<input checked="" type="checkbox"/>	Not required for State or Federal projects
Signed Application -----	<input checked="" type="checkbox"/>	Signed by applicant for SRF projects
Plans and Specifications -----	<input checked="" type="checkbox"/>	Each page must be signed or sealed by an Indiana P.E.
Potentially Affected Person List ----	<input checked="" type="checkbox"/>	Names and addresses on signed and dated form, mailing list and mailing labels (Code 65-42FC) - 11
Preliminary Limits from NPDES-----	<input checked="" type="checkbox"/>	New one needed if more than 1 year old - it may need to include information regarding BADCT and Phosphorus Limits
Anti-degradation Assessment-----	<input checked="" type="checkbox"/>	Verification from NPDES Section that a preliminary approval is complete



APPLICATION FOR WASTEWATER TREATMENT PLANT CONSTRUCTION PERMIT PER 327 IAC 3

State Form 53160 (R8 / 6-22)

Approved by State Board of Accounts, 2022

P-25686
Indiana Department of Environmental Management
Office of Water Quality
Facility Construction & Engineering Support Section,
Mail Code 65-42FC
100 North Senate Avenue, Room N1255
Indianapolis, IN 46204-2251

APPLICANT		APPLICANT'S ENGINEER	
Name <input checked="" type="checkbox"/> Mr. or <input type="checkbox"/> Ms. R. Daniel Stevens		Name <input checked="" type="checkbox"/> Mr. or <input type="checkbox"/> Ms. Kathleen M. Ziino	
Name of Organization Hamilton County Building Corporation		Name of Company Wessler Engineering	
Address (number and street, city, state, and ZIP) 1 Hamilton County Square, Suite 157, Noblesville, IN 46060		Address (number and street, city, state, and ZIP) 1130 AAA Way, Carmel, IN 46032	
Telephone Number (317) 776-9719		Telephone Number (317) 788-4551	
E-Mail Address Dan.Stevens@hamiltoncounty.in.gov		E-Mail Address katez@wesslerengineering.com	
NAME AND LOCATION OF PROPOSED FACILITY		PROJECT DESCRIPTION	
Name Bakers Corner Wastewater Treatment Plant		Describe the scope and/or purpose of this project The project can be described as construction of a new wastewater treatment plant to provide a more efficient means of wastewater treatment for the citizens of Hamilton County. Major components of the WWTP construction include influent screening structure, return-activated sludge (RAS) feed structure, oxidation ditches, secondary clarifiers, RAS/WAS pump station, UV disinfection and cascade aeration, parshall flume, RAS/WAS meter structure, biosolids dewatering, polymer feed system, chemical feed system, laboratory, office, plant drain pump station, process and yard piping, valves; emergency power generator; HVAC; electrical; instrumentation and controls; mechanical; SCADA system; paving; and landscaping.	
Location or Project Boundaries Northwest corner of US31 highway and 236 th Street, 0.1 miles West of US31 Highway and 0.4 miles North of 236th street			
City or Town Bakers Corner, Adams Township			
County Hamilton County			
FACILITY TYPE		PROJECT TYPE	
<input checked="" type="checkbox"/> Municipal wastewater treatment facility <input type="checkbox"/> Semipublic wastewater treatment facility		<input checked="" type="checkbox"/> New facility <input type="checkbox"/> Expansion or modification of existing facility <input type="checkbox"/> LTCP improvements	
SOURCE OF FUNDING			
<input type="checkbox"/> IFA's Wastewater State Revolving Fund Loan Program <input type="checkbox"/> OCRA's Community Development Block Grant <input type="checkbox"/> USDA's Rural Development Loan and Grant Assistance		<input checked="" type="checkbox"/> Local Funds <input type="checkbox"/> Private Funds <input checked="" type="checkbox"/> Other: ARPA Funding	
CERTIFICATION AND SIGNATURE			
I swear or affirm, under penalty of perjury as specified by IC 35-44.1-2-1 and other penalties specified by IC 13-30-10 and IC 13-15-7-1(3), that the statements and representations in this application are true, accurate, and complete.			
Printed Name of Person Signing R. DANIEL STEVENS			
Title Director of Administration			

Check No. 48713
\$1,350.00/12-8-22
Wessler Eng. Inc.

12-9-22

Signature of Applicant 	Date Signed (month / day / year) 12 / 7 / 2022
---	---

(Please refer to IC 13-30-10 for penalties of submission of false information.)

WASTEWATER TREATMENT PLANT CONSTRUCTION PERMIT FEES

I. The applicants listed below must remit a fee of one hundred dollars (\$100) as required by 327 IAC 3-5-5. These applications must be signed by an official of the entity. (Check all that apply.)

- | | |
|-------------------------------------|---|
| <input type="checkbox"/> | County, Municipality, or Township which is defined as a unit under IC 36-1-2-23 |
| <input type="checkbox"/> | A Nonprofit Organization |
| <input type="checkbox"/> | A Conservancy District |
| <input type="checkbox"/> | A School Corporation that operates a sewage treatment facility |
| <input checked="" type="checkbox"/> | A Regional Water or Sewage District |

II. All other applications (including semi-public) will pay the following fees per project type as required by 327 IAC 3-5-5:

New Wastewater Treatment Plant (not including industrial)

- | | | |
|-------------------------------------|---|------------|
| <input checked="" type="checkbox"/> | A. Up to 500,000 gallons per day | \$1,250.00 |
| <input type="checkbox"/> | B. Greater than 500,000 gallons per day | \$2,500.00 |

Wastewater Treatment Plant Expansion*

- | | | |
|--------------------------|---|------------|
| <input type="checkbox"/> | A. Up to fifty percent (50%) design capacity: | |
| <input type="checkbox"/> | 1. Greater than 500,000 gallons per day | \$1,250.00 |
| <input type="checkbox"/> | 2. Up to 500,000 gallons per day | \$625.00 |
| <input type="checkbox"/> | B. Greater than fifty percent (50%) design capacity | |
| <input type="checkbox"/> | 1. Greater than 500,000 gallons per day | \$2,500.00 |
| <input type="checkbox"/> | 2. Up to 500,000 gallons per day | \$1,250.00 |

*** NOTE: Modifications of existing facilities which do not include an increase in design capacity (or for reductions of design capacity) are considered to be expansions of 0% design capacity and should remit the appropriate fee per the above fee schedule.**

Only one (1) of the fees will apply. Checks for the applicable fee shall be made payable to the **Indiana Department of Environmental Management**. Fees shall not be refundable once staff review and processing of the Permit Application has commenced.

WASTEWATER TREATMENT PLANT DESIGN SUMMARY**I. General**

1. Applicant: Hamilton County Building Corporation

2. Facility Name: Bakers Corner Wastewater Treatment Plant

3. Project Title: US31 Corridor Infrastructure Investment Project Phase 1A and 1B, Division 1 - Wastewater Treatment Plant

4. Project Location: Northwest corner of US31 highway and 236th Street, 0.1 miles West of US31 Highway and 0.4 miles North of 236th street

5. Design Engineer: Wessler Engineering

6. Engineering Company: Wessler Engineering

7. NPDES Permit Number: New Facility

A. Effective date (*month / day / year*): TBD / TBD / TBDB. Expiration date (*month / day / year*): TBD / TBD / TBD

8. Project Scope

A. Description of existing treatment facilities:

Privately owned septic systems are currently responsible for the wastewater treatment of customers to be served by the new WWTP in Hamilton County, Indiana

B. Description of project needs:

The Bakers Corner community is currently unsewered, with each home and business having an individual groundwater well and a septic system. The intersection of US31 and 236th Street is in the process of being upgraded by Indiana Department of Transportation (INDOT) to an interchange, and the supporting frontage roads that will be created are likely to spur growth in the Bakers Corner area. To facilitate this growth, as well as the expected growth at the intersection of US 31 and 276th Street, supporting sanitary and water infrastructure will need to be developed. The proposed WWTP is Division 1 of a project to provide wastewater and water utility services to the area that encompasses the United States Highway 31 (US31) corridor from 216th Street to the Hamilton/Tipton County line in northern Hamilton County. The Division 2 project (separate) will include water and sewer systems.

C. Description of proposed facilities:

Major components of the WWTP construction include influent screening structure, return-activated sludge (RAS) feed structure, oxidation ditches, secondary clarifiers, RAS/WAS pump station, UV disinfection and cascade aeration, parshall flume, RAS/WAS meter structure, biosolids dewatering, polymer feed system, chemical feed system, laboratory, office, plant drain pump station, process and yard piping, valves; emergency power generator; HVAC; electrical; instrumentation and controls; mechanical; SCADA system; paving; and landscaping.

D. Is project part of an Agreed Order?: ☐ Yes ☒ No

E. How facility will maintain treatment during construction:

Private septic systems will be maintained until startup of the new plant.

9. Source of Funding: ARPA and Local Funds

10. Estimated Total Project Cost: 16,000,000

Certification Seal, Signature, and Date

Printed Name of Engineer

Kathleen M. Ziino, P.E.

Signature



Date Signed (month / day / year)

03 / 07 / 2023

**II. Design Data**

1. Design Average Flow (MGD): 0.5 MGD

A. Domestic: 0.18 MGD (36%)

B. Industrial/Commercial: 0.32 MGD (64%)

C. Infiltration/Inflow: Minimal

2. Design Peak Hourly Flow (MGD): 2.25 MGD

3. Maximum Flow Capacity (MGD): 2.25 MGD

A. Combination of treatment plant + EQ volume: 2.25 MGD

B. Other explanation: N/A

4. Design Waste Strength

A. CBOD: 200 mg/L

B. TSS: 200 mg/L

C. NH₃-N: 25 mg/L

D. P: 6 mg/L

E. Other: N/A

5. Design Population Equivalent (PE): 4,906 (based on 0.17 lb CBOD/PE influent loading)

6. NPDES Permit Limitation on Effluent Quality

A. CBOD₅: Monthly: 10 mg/L; Weekly: 15 mg/L

B. TSS: Monthly: 12 mg/L; Weekly: 18 mg/L

C. NH₃-N: Summer Monthly: 1.1 mg/L; Winter Monthly: 1.6 mg/L

D. P: 1 mg/L

E. pH: Daily minimum 6.0 s.u.; Daily Maximum: 9.0 s.u.

F. DO: Daily minimum: 6.0 mg/L

G. Total Residual Chlorine: N/A (UV Disinfection utilized at this facility) mg/L

H. *E.coli*: Monthly Average: 125 count/100mL

I. Other: N/A

7. Sampling Method (Grab or Automatic Sampler) and Location

A. Influent: Automatic Sampler; Screening Structure

B. Effluent: Automatic Sampler; UV Disinfection and Cascade Structure

8. Receiving Stream

A. Name: Baker Ditch tributary to Hinkle Creek

B. Stream Uses: Full body contact recreational use and shall be capable of supporting a well-balanced warm water aquatic community

☐ and designated as salmonid water and shall be capable of supporting a salmonid fishery

	<input type="checkbox"/> and designated as an impaired water <input type="checkbox"/> and classified as an outstanding state resource water (OSRW) <input type="checkbox"/> and classified as an outstanding national resource water (ONRW)
C. 7-day, 1-in-10 year low flow: 0 CFS (0 MGD)	
III. PLANT DETAILS	
1.	Laboratory type (e.g., on site, third-party testing): On site
2.	Plant site fence provided: Yes, chain-link fence
3.	Handrail/grating provided where necessary: Yes where applicable
4.	Flood hazard elevation (ft) at 100 year flood: 897.74'
5.	Provisions for mechanical/electrical component protection at 100 year flood: Typical structure floor elevation is set at 908.00, more than 7 ft above the 100-year flood elevation
6.	Type and rating (kW) of standby power equipment: 200 kW emergency generator
7.	Provisions for removing heavy equipment: Yes, davit crane at the screenings structure (fine screen), oxidation ditch (mixers), RAS/WAS pump station, plant drain pump station, and UV disinfection (bulbs)
8.	Septage/leachate receiving facilities
	A. Type of preliminary treatment: N/A
	B. Storage and controlled feed provisions: N/A
	C. Location of discharge to treatment process: N/A
IV. Treatment Units	
Plant Site Lift Station	<input checked="" type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input type="checkbox"/> N/A
1.	Location description: Plant Drain Lift Station
2.	Type of pump: Submersible non-clog centrifugal pumps
3.	Number of pumps: 2 Pumps
4.	Constant or variable speed: Constant Speed
5.	Design operating capacity (gpm) and TDH (ft): 200 gpm at 31' TDH (Single pump running)
6.	Operating volume of the wet well (gal): 845.96 gal (Total Wet Well Volume: 6027.75 gal)
7.	Detention time in the wet well (min): N/A
8.	Shutoff valve and check valve in the discharge line: Yes
9.	Shutoff valve on suction line: N/A
10.	Type of ventilation: Free standing air vent
11.	Type of standby power: Generator
12.	Type of alarm: Plant SCADA system shall monitor and display the following alarms: Pump (1,2) Fail, High Level, and Low Level
13.	Type of bypass or overflow provisions: N/A
14.	Additional Information:
Flow Equalization	<input type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input checked="" type="checkbox"/> N/A
1.	Type of structure:
2.	Number and dimensions (ft) of unit:
3.	Side water depth and freeboard (ft) of unit:
4.	Volume (gal):
5.	Type and size (HP) of mixing equipment:
6.	Type of aeration provisions (if applicable):
7.	Description of flow return methods and controls:
8.	Type of sludge removal provisions:

9. Type and thickness of lagoon liner (if applicable):	
10. Additional information:	
Influent Flow Meter	<input checked="" type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input type="checkbox"/> N/A
1. Type and size (in): 8-inch Magnetic Flow Meter	
2. Location description: 10-inch effluent line of Lift Station 1 - see Additional Information	
3. Indicating, recording and totalizing: Yes, using Plant SCADA System	
4. Additional information: Flow meter is part of Division 2 - Water and Sewer of this project	
Fat, Oil, and Grease Separation	<input type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input checked="" type="checkbox"/> N/A
1. Type:	
2. Location description:	
3. Additional information:	
Grit Removal	<input type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input checked="" type="checkbox"/> N/A
1. Type of grit removal system:	
2. Location description:	
3. Number and dimensions (ft) of unit:	
4. Side water depth and freeboard (ft) of unit:	
5. Rated capacity (gpd):	
6. Type of bypass provisions:	
7. Type of aeration provisions (if applicable):	
8. Method of unit isolation:	
9. Method of flow split control:	
10. Additional information:	
Comminutor	<input type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input checked="" type="checkbox"/> N/A
1. Type of comminutor:	
2. Location description:	
3. Rated capacity (gpd):	
4. Bypass bar screen provision:	
5. Additional information:	
Screening	<input checked="" type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input type="checkbox"/> N/A
1. Type of screening: In-channel Screw Fine Screen	
2. Location description: Screenings Structure	
3. Bypass bar screen provision: Yes, manual bar screen with 1.75-inch O.C. bar spacing	
4. Number and rated capacity (gpd): One (1) at 2.25 MGD	
5. Clear opening sizes, bar or perforations (in): 0.25-inch openings	
6. Slope of unit (°): 35 degrees	
7. Method of unit cleaning: Spiral screw unit removes debris from channel with automated wash-water to rinse debris prior to compaction	
8. Method of screening disposal: Landfill	
9. Method of unit isolation: Screen can be pivoted out of channel for maintenance	
10. Method of flow split control: N/A	
11. Additional information: N/A	

Primary Clarification	<input type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input checked="" type="checkbox"/> N/A
1. Type of clarifier:	
2. Number and dimensions (ft) of unit:	
3. Side water depth and freeboard (ft) of unit:	
4. Surface overflow rate (gpd/ft ²)	
A. At design average flow:	
B. At design peak hourly flow:	
5. Hydraulic detention time (hrs)	
A. At design average flow:	
B. At design peak hourly flow:	
6. Weir loading rate at design peak hourly flow (gpd/lin·ft):	
7. Location of overflow weir:	
8. Method of scum collection:	
9. Method of scum disposal:	
10. Type of sludge removal mechanism:	
11. Method of unit isolation:	
12. Method of flow split control:	
13. Additional information:	

Anoxic Component of Biological Nutrient Removal or Selector Tank	<input type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input checked="" type="checkbox"/> N/A
1. Number and dimensions (ft) of anoxic unit/zone:	
2. Side water depth and freeboard (ft) of anoxic unit/zone:	
3. Hydraulic detention time (hrs):	
4. Number and capacity of mixed liquor recycle pumps (gpm):	
5. Method of mixed liquor recycle rate control:	
6. Mixed liquor recycle rate as % of design average flow:	
7. Provisions for mixed liquor recycle rate metering	
A. Type and size:	
B. Location:	
8. Mixed liquor recycle discharge location:	
9. Method of unit isolation:	
10. Method of flow split control:	
11. Additional information:	
Anaerobic Component of Biological Nutrient Removal or Selector Tank	<input type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input checked="" type="checkbox"/> N/A
1. Number and dimensions (ft) of anaerobic unit/zone:	
2. Side water depth and freeboard (ft) of anaerobic unit/zone:	
3. Hydraulic detention time (hrs):	
4. CBOD/TP Ratio:	
5. Readily Biodegradable BOD/TP Ratio:	
6. Type and size (HP) of mixing equipment:	
7. Method of unit isolation:	
8. Method of flow split control:	

9. Additional information:	
Activated Sludge	<input type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input checked="" type="checkbox"/> N/A
1. Conventional or extended aeration:	
2. Number and dimensions (ft) of unit:	
3. Side water depth and freeboard (ft) of unit:	
4. Hydraulic detention time (hrs):	
5. Organic loading at design average flow (lb CBOD/1000 ft ³):	
6. Design MLSS concentration (mg/L):	
7. Design solids retention time (days):	
8. Design F/M ratio (lb CBOD/day/lb MLVSS):	
9. Type and efficiency of diffusers (% per ft submergence):	
10. Dedicated or shared plant blowers:	
11. Type and rated capacity of blowers (cfm):	
12. Constant or variable speed blowers:	
13. Oxygen requirement (lb O ₂ /day)	
A. CBOD removal:	
B. NH ₃ -N removal:	
14. Total air demand (cfm):	
15. Firm blower capacity (cfm):	
16. Type of ventilation in blower room:	
17. Number and capacity of return sludge pumps (gpm):	
18. Method of return sludge rate control:	
19. Return sludge rate as % of design average flow:	
20. Provisions for return rate metering	
A. Type and size:	
B. Location:	
21. Return sludge discharge location:	
22. Method of unit isolation:	
23. Method of flow split control:	
24. Additional information:	
Oxidation Ditch	<input checked="" type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input type="checkbox"/> N/A
1. Number and dimensions (ft) of unit: Two (2) in series Oxidation Ditches, 11-ft channel width by 60-ft straight wall length (208,000 gallons each)	
2. Side water depth and freeboard (ft) of unit: 16-ft SWD; 2-ft freeboard	
3. Hydraulic detention time (hrs): 20 hours at ADF; 4.4 hours at PHF (both basins in operation)	
4. Organic loading (design average flow, lb CBOD/1000 ft ³): 15 lb BOD/1000 ft ³	
5. Design MLSS concentration (mg/L): 2,900 mg/L	
6. Design solids retention time (days): 12.9 days	
7. Design F/M ratio (lb CBOD/day/lb MLVSS): 0.111 lb CBOD/day/lb MLVSS	
8. Aeration equipment	
A. Type and number: Three (3) positive displacement rotary lobe blowers (2 duty + 1 standby) @ 164 scfm each	
B. Efficiency (lb O ₂ /HP-hr): 2.9 lb O ₂ /HP-hr	
9. Oxygen requirement (lb O ₂ /day)	
A. CBOD removal: 917 lb O ₂ /day	

B. NH ₃ -N removal: 476 lb O ₂ /day	
10. Oxygen provided (lb O ₂ /day): 1394 lb O ₂ /day	
11. Flow velocity in ditch (ft/sec): 1.17 ft/sec	
12. Number and capacity of return sludge pumps (gpm): Three (3) Pumps total; two pumps running in parallel to do 350 GPM at 31.8-ft TDH	
13. Method of return sludge rate control: Telescopic Valves control rate of RAS removal from Clarifiers, submersible RAS pumps operate off of the level of the RAS wet well and pump RAS to the RAS/WAS meter structure where manual valves are used to direct RAS/WAS based upon WAS flow calculations.	
14. Return sludge rate as % of design average flow: 50 - 100%	
15. Provisions for return rate metering	
A. Type and size: 4" Magnetic Flow Meter	
B. Location: RAS/WAS Meter Structure	
16. Return sludge discharge location: RAS Feed Structure	
17. Method of unit isolation: Plug valves on each Oxidation Ditch influent piping	
18. Method of flow split control: The influent plug valves upstream of the ditches, the pass through gate, and the oxidation ditch effluent slide gates will be used as the method for flow split control.	
19. Additional information: The ditches are designed to operate in series during flows equal to and greater than the average design flow of 0.5 MGD. The facility is anticipating flows as low as 0.08 MGD during the initial start-up of the plant before significant development can occur in the area. The influent pipes are designed such that the ditches can be operated in parallel, or with one tank out of service during the initial start-up phase.	
Trickling Filter	<input type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input checked="" type="checkbox"/> N/A
1. Number and dimensions (ft) of unit:	
2. Freeboard (ft) of unit:	
3. Type of media:	
4. Media specific surface area (ft ² /ft ³):	
5. Hydraulic loading (gpm/ft ²):	
6. Organic loading (design average flow, lb CBOD/1000 ft ³):	
7. Type of recirculation system:	
8. Type of ventilation system:	
9. Additional information:	
Rotating Biological Contactor	<input type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input checked="" type="checkbox"/> N/A
1. Number and dimensions (ft) of unit:	
2. Freeboard (ft) of unit:	
3. Type of media:	
4. Hydraulic detention time (min):	
5. Hydraulic loading (gpm/ft ²):	
6. Organic loading (design average flow, lb CBOD/1000 ft ²):	
7. Method of shaft drive:	
8. Supplemental air:	
9. Method of unit isolation:	
10. Method of flow split control:	
11. Additional information:	
Sequential Batch Reactor	<input type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input checked="" type="checkbox"/> N/A

1. Type of SBR process:	
2. Number and dimensions (ft) of unit:	
3. Side water depth and freeboard (ft) and volume (gal) of unit	
A. At low water level:	
B. At avg water level:	
C. At high water level:	
4. Cycle Time (min)	
A. Fill:	
B. React:	
C. Settle:	
D. Decant and idle:	
5. Hydraulic detention time (hrs)	
A. At low water level:	
B. At avg water level:	
C. At high water level:	
6. Organic loading (lb CBOD/1000 ft ³)	
A. At low water level:	
B. At avg water level:	
C. At high water level:	
7. Peak decant rate (gpm):	
8. Design MLSS concentration (mg/L):	
9. Design solids retention time (days):	
10. Design F/M ratio (lb CBOD/day/lb MLVSS):	
11. Type and efficiency of diffusers (% per ft submergence):	
12. Provisions for retrievable diffusers (when applicable):	
13. Number and rating of mixers (HP):	
14. Oxygen requirement (lb O ₂ /day)	
A. CBOD removal:	
B. NH ₃ -N removal:	
15. Total air demand (cfm):	
16. Dedicated or shared plant blowers:	
17. Type and rated capacity of blowers (cfm):	
18. Constant or variable speed blowers:	
19. Firm blower capacity (cfm):	
20. Type of ventilation in blower room:	
21. Method of sludge transfer between tanks:	
22. Number and capacity of waste sludge pumps (gpm):	
23. Post-equalization or disinfection at peak decanter rate:	
24. Method of unit isolation:	
25. Method of flow split control:	
26. Additional information:	
Rotating Algal Reactor	<input type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input checked="" type="checkbox"/> N/A
1. Process Description:	
2. Number and dimensions (ft) of tanks:	
3. Wheel and media characteristics	

A. Wheel diameter (ft):	
B. Wheel surface area (ft ² /wheel):	
C. Internal wheel volume (ft ³):	
D. Percent fill of wheel (%):	
E. Media specific surface area (ft ² /ft ³):	
F. Internal media surface area (ft ² /wheel):	
4. First stage BOD removal	
A. Number of wheels:	
B. Total effective surface area (ft ²):	
C. CBOD loading (lbs CBOD/1,000 ft ²):	
5. Second stage NH ₃ -N removal	
A. Number of wheels:	
B. Total effective surface area (ft ²):	
C. NH ₃ -N loading (lbs NH ₃ -N/1,000 ft ²):	
6. Hydraulic detention time (hrs):	
7. Hydraulic loading (gpd/ft ²):	
8. Type and efficiency of diffusers (SOTE %):	
9. Operational blowers	
A. Air required to move wheel (cfm):	
B. Number of blowers:	
C. Type and rated capacity (cfm):	
D. Constant or variable speed:	
E. Firm blower capacity (cfm):	
10. Scouring blower	
A. Air required to scour (cfm):	
B. Type and rated capacity (cfm):	
C. Constant or variable speed:	
11. Process building	
A. Method of ventilation:	
B. Method of temperature control:	
12. Method of unit isolation:	
13. Method of flow split control:	
14. Additional information:	
Facultative Lagoon	
<input type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input checked="" type="checkbox"/> N/A	
1. Continuous or controlled discharge:	
2. Treatment cells	
A. Number:	
B. Dimensions (ft):	
C. Maximum water depth (ft):	
D. Freeboard at maximum water depth (ft):	
E. Volume (gal):	
F. Hydraulic detention time (days):	
G. Organic loading (lbs CBOD/acre/day):	
3. Storage cell (controlled discharge only)	
A. Dimensions (ft):	

B. Maximum water depth (ft):	
C. Freeboard at maximum water depth (ft):	
D. Volume (gal):	
E. Hydraulic storage time (days):	
4. Influent pipe location:	
5. Effluent pipe location:	
6. Slope ratio of embankment (H:V) and top width (ft):	
7. Type and thickness of lagoon liner:	
8. Method of effluent flow control:	
9. Method of stream flow measurement:	
10. Type of facilities for multi-level lagoon discharge:	
11. Type of mixing equipment (if applicable):	
12. Additional information:	
Aerated Lagoon	<input type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input checked="" type="checkbox"/> N/A
1. Treatment cell	
A. Number:	
B. Dimensions (ft):	
C. Maximum water depth (ft):	
D. Freeboard at maximum water depth (ft):	
E. Volume (gal):	
F. Hydraulic detention time (day):	
G. Organic loading (lbs CBOD/day):	
H. Complete or partial mix:	
I. Uncovered or covered/insulated:	
2. Settling cell or settling zone within aeration cell	
A. Dimensions (ft):	
B. Maximum water depth (ft):	
C. Freeboard at maximum water depth (ft):	
D. Volume (gal):	
E. Hydraulic detention time (day):	
F. Uncovered or covered/insulated:	
3. Aeration equipment	
A. Type and number:	
B. Rated capacity:	
4. Oxygen demand:	
5. Influent pipe location:	
6. Effluent pipe location:	
7. Slope ratio of embankment (H:V) and top width (ft):	
8. Type and thickness of lagoon liner:	
9. Type of facilities for multi-level lagoon discharge:	
10. Additional information:	
Secondary Clarification	<input checked="" type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input type="checkbox"/> N/A
1. Type of clarifier: Circular Mechanical Clarifier	
2. Number and dimensions (ft) of unit: Two (2) 40-ft diameter clarifiers	

3. Side water depth and freeboard (ft) of unit: 12-ft SWD; 2-ft freeboard	
4. Surface overflow rate (gpd/ft ²)	
A. at design average flow: 199 gpd/ft ²	
B. at design peak hourly flow: 895 gpd/ft ²	
5. Hydraulic detention time (hrs)	
A. at design average flow: 5.41 hours with one unit offline	
B. at design peak hourly flow: 1.97 hrs hours with one unit offline	
6. Weir loading rate at design peak hourly flow (gpd/lin·ft): 9,766 gpd/ft	
7. Location of overflow weir: 90 degree V-Notches (quantity: 230) in circular weir, 1' from the edge of the tank.	
8. Method of scum collection: Collected in scum trough by surface skimmer assembly	
9. Method of scum disposal: Drained to RAS/WAS Pump Station	
10. Type of sludge removal mechanism: Siphon header with telescoping valve	
11. Method of unit isolation: Slide gates in influent splitter box	
12. Method of flow split control: Influent splitter box with fixed weirs	
13. Additional information:	
Submerged Biological Rock Bed Reactor	<input type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input checked="" type="checkbox"/> N/A
1. Process description and seasonal operational procedure:	
2. Design unit influent quality (at highest monthly loading from lagoon)	
A. CBOD (mg/L):	
B. NH ₃ -N (mg/L):	
C. TSS (mg/L):	
3. Number and dimensions (ft) of units:	
4. Side water depth (ft):	
5. Media type, depth (ft), and size distribution (in):	
6. Media porosity (%):	
7. Insulation layer material and thickness (in):	
8. Liner type and thickness (mil):	
9. Effective wastewater (media pore) volume in reactor (ft ³):	
10. Hydraulic detention time (hrs):	
11. CBOD flux rate (lbs CBOD/100 ft ² media cross-section):	
12. NH ₃ -N loading rate (lbs NH ₃ -N/1,000 ft ³ media):	
13. Type and efficiency of diffusers (SOTE %):	
14. Oxygen requirement (lb O ₂ /day)	
A. CBOD removal:	
B. NH ₃ -N removal:	
15. Total air demand (cfm):	
16. Type and rated capacity of blowers (cfm):	
17. Constant or variable speed blowers:	
18. Firm blower capacity (cfm):	
19. Type of ventilation in blower room:	
20. Method of unit isolation:	
21. Method of flow split control:	
22. Additional information:	

Fixed Media Polishing Reactor	<input type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input checked="" type="checkbox"/> N/A
1. Process description and seasonal operational procedure:	
2. Design unit influent quality (at highest monthly loading from upstream treatment unit)	
A. CBOD (mg/L):	
B. NH ₃ -N (mg/L):	
C. TSS (mg/L):	
3. Number and dimensions (ft) of tanks:	
4. Side water depth (ft):	
5. Insulation layer material and thickness (in):	
6. Media specific surface area for BOD (ft ² /ft ³):	
7. BOD loading rate (lbs CBOD/100 ft ² media):	
8. Number of BOD media modules:	
9. Media specific surface area for NH ₃ -N (ft ² /ft ³):	
10. NH ₃ -N loading rate (lbs NH ₃ -N/100 ft ² media):	
11. Number of NH ₃ -N media modules:	
12. Type and efficiency of diffusers (SOTE %):	
13. Oxygen requirement (lb O ₂ /day)	
A. CBOD removal:	
B. NH ₃ -N removal:	
14. Total air demand (cfm):	
15. Type and rated capacity of blowers (cfm):	
16. Constant or variable speed blowers:	
17. Firm blower capacity (cfm):	
18. Type of ventilation in blower room:	
19. Method of unit isolation:	
20. Method of flow split control:	
21. Additional information:	

Rapid Sand Filtration	<input type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input checked="" type="checkbox"/> N/A
1. Number and dimensions (ft) of unit:	
2. Freeboard (ft) of unit:	
3. Filtration rate (gpm/ft ²)	
A. at design average flow:	
B. at design peak hourly flow:	
4. Type, depth (inch), and size distribution (mm) of filter media:	
5. Backwash	
A. Type of backwash mechanism:	
B. Number and rated capacity of pumps (gpm):	
C. Constant or variable speed:	
D. Source of backwash water:	
E. Discharge location of backwash water:	
6. Air scour (cfm):	
7. Capability to chlorinate ahead of the filter:	
8. Method and provisions for solids removal:	

9. Method of unit isolation:	
10. Method of flow split control:	
11. Additional information:	
Rotating Disc Filter	<input type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input checked="" type="checkbox"/> N/A
1. Process Description:	
2. Number and dimensions (ft) of cells:	
3. Outside-in or inside-out flow:	
4. Number of discs:	
5. Effective submerged filter area (ft ²) per disc:	
6. Total submerged filter area (ft ²):	
7. Type and filter media pore size (µm):	
8. Filtration rate (gpm/ft ²)	
A. at design average flow:	
B. at design peak hourly flow:	
9. Solids loading rate (lbs TSS/ft ²)	
A. at design average flow:	
B. at design peak hourly flow:	
10. Backwash	
A. Type of backwash mechanism:	
B. Number and rated capacity of pumps (gpm):	
C. Constant or variable speed:	
D. Source of backwash water:	
E. Discharge location of backwash water:	
11. Air scour (cfm):	
12. Method and provisions for cell bottom solids removal:	
13. Method of unit isolation:	
14. Method of flow split control:	
15. Additional information:	
Chemical Phosphorus Removal	<input checked="" type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input type="checkbox"/> N/A
1. Chemical properties	
A. Chemical name: Aluminum Sulfate (Alum)	
B. Weight concentration in solution (%): 48.5%	
C. Specific gravity: 1.335	
2. Chemical storage container	
A. Type: Design: 2000 gal tank; Near-term: HDPE Totes - 2-250 gal	
B. Volume (gal): Design: 2000 gal, Near-term: 250 gallons each, 500 gal total	
C. Expected storage supply (days): 30 days - see Additional information	
3. Secondary containment	
A. Type: Design: walled concrete containment pad; Near-term: Polyethylene spill containment pallet	
B. Dimensions (ft) or volume (gal): Design: 12-ft L x 12-ft W x 2-ft H, 2150 gal capacity; Near-term: 5.17-ft L x 5.17-ft W x 2.34-ft H, 535 gal	
4. Number and capacity of chemical feed pumps (gpm): Two (2) (1 duty + 1 standby), each with a maximum flow rate of 31.7 gph	
5. Design chemical feed rate: 2.4 gph, with no Biological Phosphorous removal at ADF	

6. Location(s) of chemical injection: RAS Feed Structure and Oxidation Ditch Effluent	
7. Provisions for adequate mixing at injection point: Chemical injection will occur under turbulent conditions at the application site	
8. Chemical building	
A. Method of ventilation control: Powered Vent	
B. Method of temperature control: Electric Heater	
C. Safety shower/eyewash equipment: Yes	
9. Additional information: Near term flows are anticipated to be very low which would create an excessive storage period if the 2000 gal tank was installed in the near term (almost 220 days). Therefore, totes are being installed in the near term to provide a storage supply anticipated to be just under 30 days. As influent flow increase, increasing chemical usage and decreasing the storage period of the totes, intent is to replace totes with the 2000 gal storage tank outside of the Chemical Room in a walled concrete containment pad. Calculations indicate that the totes will reach 10 days of storage around 0.37 MGD (75% of design capacity) - this is when the 2000 gal tank is intended to be installed.	
Two-Day Polishing Pond	<input type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input checked="" type="checkbox"/> N/A
1. Number and dimensions (ft) of ponds:	
2. Hydraulic detention time (days):	
3. Type and thickness of pond liner:	
4. Type of scum control:	
5. Additional information:	
Chlorine Disinfection	<input type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input checked="" type="checkbox"/> N/A
1. Chemical properties	
A. Gas, Liquid, or Tablet:	
B. Compound name:	
C. Weight concentration in solution (%):	
D. Specific gravity:	
2. Contact Tank	
A. Dimensions (ft):	
B. Freeboard (ft):	
C. Volume (gal):	
D. Contact time at design peak hourly flow (min):	
E. Type of scum control:	
F. Type of bypass provisions:	
3. Method of chemical feed	
A. Type:	
B. Location:	
C. Design rate capacity (gpm):	
D. Dosage (mg/L):	
4. Source of the disinfectant feed water:	
5. Breakwater tank for the feed water:	
6. Chemical storage container	
A. Type:	
B. Volume (gal):	
C. Expected storage supply (days):	
7. Secondary containment (if applicable)	

A. Type:	
B. Dimensions (ft) or volume (gal):	
8. Chemical building	
A. Method of ventilation control:	
B. Method of temperature control:	
C. Safety shower/eyewash equipment:	
9. Other safety equipment	
A. Type:	
B. Location:	
10. Additional information:	
Dechlorination	<input type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input checked="" type="checkbox"/> N/A
1. Chemical properties	
A. Gas, Liquid, or Tablet:	
B. Compound name:	
C. Weight concentration in solution (%):	
D. Specific gravity:	
2. Method of chemical feed	
A. Type:	
B. Location:	
C. Design rate capacity (gpm):	
D. Dosage (mg/L):	
3. Chemical storage container	
A. Type:	
B. Volume (gal):	
C. Expected storage supply (days):	
4. Secondary containment (if applicable)	
A. Type:	
B. Dimensions (ft) or volume (gal):	
5. Chemical building	
A. Method of ventilation control:	
B. Method of temperature control:	
C. Safety shower/eyewash equipment:	
6. Other safety equipment	
A. Type:	
B. Location:	
7. Additional information:	
Ultraviolet Disinfection	<input checked="" type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input type="checkbox"/> N/A
1. Open channel or closed-vessel: Open Channel	
2. Vertical, horizontal, or diagonal lamp orientation: Horizontal	
3. Lamp type: High Intensity Low Pressure Lamps	
4. Number of banks: Two (2)	
5. Number of modules per bank: Three (3)	
6. Number of lamps per module: Four (4)	
7. Dosage (μ Ws/cm ²): 30,000 μ Ws/cm ²	

8. Transmittance (%): 65 % minimum	
9. Provisions for intensity monitoring: Yes, with low UV intensity alarm	
10. Type of level control provisions: 336-in Serpentine Weir	
11. Type of bypass provisions: UV banks can be pulled out of channel for maintenance	
12. Type of safety equipment: Covered channel grating, operator PPE, and warning signs	
13. Automatic or manual cleaning equipment: Automatic self-cleaning system	
14. Additional information: N/A	
Cascade Post-Aeration	<input checked="" type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input type="checkbox"/> N/A
1. Number of steps: Seven (7)	
2. Dimensions of steps (ft): 1-ft tall x 1-ft deep x 4-ft wide	
3. Total fall (ft): 7-ft	
4. Additional information: N/A	
Diffused Air Post-Aeration	<input type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input checked="" type="checkbox"/> N/A
1. Number and dimensions (ft) of unit:	
2. Side water depth and freeboard (ft) of unit:	
3. Type and efficiency of diffusers (SOTE %):	
4. Dedicated or shared plant blowers:	
5. Type and rated capacity of blowers (cfm):	
6. Additional information:	
Effluent Flow Meter	<input checked="" type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input type="checkbox"/> N/A
1. Type and size (in): 6" Parshall Flume	
2. Location description: UV Disinfection Structure - Upstream of Cascade Aeration System	
3. Indicating, recording and totalizing: Yes, via Plant SCADA System	
4. Additional information: N/A	
Sludge Thickening	<input type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input checked="" type="checkbox"/> N/A
1. Type of sludge thickeners:	
2. Number and dimensions (ft) of unit:	
3. Hydraulic capacity (gpm):	
4. Solids capacity (lb/hr):	
5. Type of chemicals added:	
6. Expected solids content of sludge (%):	
7. Additional information:	

Anaerobic Digester	<input type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input checked="" type="checkbox"/> N/A
1. Number and dimensions (ft) of unit:	
2. Side water depth and freeboard (ft) of unit:	
3. Volume (gal):	
4. Total design sludge loading (lbs/day):	
5. Volatile solids percentage (%):	
6. Design solids retention time (days):	
7. Type and size (HP) of mixing equipment:	

8. Internal or external heating:	
9. Decanting method:	
10. Discharge location of supernatant:	
11. Additional information:	
Aerobic Digester	<input checked="" type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input type="checkbox"/> N/A
1. Number and dimensions (ft) of unit: 1 above ground tank, 36 ft in diameter, 24 ft high	
2. Side water depth and freeboard (ft) of unit: 20.4 ft side water depth, at least 1 foot freeboard	
3. Volume (gal): Storage capacity - 182,800 gal, Operating volume - 155,400 gal	
4. Total design sludge loading (lbs/day): 900 lb/d	
5. Volatile solids percentage (%): 39	
6. Design solids retention time (days): 30	
7. Type and efficiency of diffusers (SOTE %): Coarse bubble, 15.7% SOTE	
8. Dedicated or shared plant blowers: Dedicated	
9. Type and rated capacity of blowers (cfm): Two (2) positive displacement rotary lobe blowers (1 duty + 1 standby) @ 623 cfm each	
10. Decanting method: Telescoping valve within tank	
11. Discharge location of supernatant: Plant drain system	
12. Additional information: The future aerobic digester will not be installed under near-term conditions. The future aerobic digester will be installed as influent flows reach plant capacity to assist in sludge management.	
Aerated Sludge Holding Tank	<input type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input checked="" type="checkbox"/> N/A
1. Number and dimensions (ft) of unit:	
2. Side water depth and freeboard (ft) of unit:	
3. Volume (gal):	
4. Total design sludge loading (lbs/day):	
5. Sludge storage retention time (days):	
6. Type and efficiency of diffusers (SOTE %):	
7. Dedicated or shared plant blowers:	
8. Type and rated capacity of blowers (cfm):	
9. Decanting method:	
10. Discharge location of supernatant:	
11. Additional information:	
Sludge Drying Bed	<input type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input checked="" type="checkbox"/> N/A
1. Number and dimensions (ft) of unit:	
2. Method of unit isolation:	
3. Concrete ramp and runway provisions:	
4. Discharge location of drainage:	
5. Additional information:	
Mechanical Dewatering	<input type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input checked="" type="checkbox"/> N/A
1. Type of dewatering unit:	
2. Number and dimensions (ft) of unit:	
3. Hydraulic capacity (gpm):	
4. Solids capacity (lb/hr):	
5. Type of chemicals added:	

6. Expected solids content of dewatered sludge (%):	
7. Discharge location of drainage:	
8. Additional information:	
Sludge Dewatering Bag System	<input checked="" type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input type="checkbox"/> N/A
1. Number and volume (yd ³) of unit: Two (2) Parallel Geobag Units, 20 yd ³ each	
2. Type of chemicals added: Polymer	
3. Expected solids content of dewatered sludge (%): 12-14%	
4. Drainage containment provisions: Dumpster on a concrete pad sloped to trench drain, which drains to the Plant Drain Pump Station	
5. Discharge location of drainage: From dumpsters to trench to plant drain lift station to RAS feed structure upstream of oxidation ditches	
6. Additional information: N/A	
Final Sludge Disposal	<input checked="" type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input type="checkbox"/> N/A
1. Ultimate disposal method of sludge: Haul Off	
2. Expected solids content of sludge (by the principal method of disposal): 12-14%	
3. Location of disposal site: Landfill	
4. Ownership of the disposal site: Contract Basis	
5. Availability of sludge transport equipment: Yes	
6. Additional information: N/A	
V. SEWER COLLECTION SYSTEM	
Lift Station	<input type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input checked="" type="checkbox"/> N/A
1. Location:	
2. Type of pump (example: submersible, dry pit):	
3. Number of pumps:	
4. Constant or variable speed:	
5. Design pump rate (gpm) and TDH (ft):	
6. Operating volume of the wet well (gal):	
7. Average detention time in the wet well (min):	
8. Type of standby power/pump provisions:	
9. Type of alarm:	
10. Additional information:	
Low Pressure Sewer Grinder Pump Station	<input type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input checked="" type="checkbox"/> N/A
1. Number of stations:	
2. Number of residential connections per simplex station (two maximum):	
3. Design pump rate (gpm) at maximum TDH (ft):	
4. Type of alarm:	
5. Privately or utility owned and maintained:	
6. Additional information:	
Vacuum Pump Station	<input type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input checked="" type="checkbox"/> N/A
1. Location:	
2. Total volume of vacuum tank (gal):	
3. Operating volume of the vacuum tank (gal):	
4. Number and size (HP) of vacuum pumps:	

5. Number and type of sewage pumps:	
6. Constant or variable speed:	
7. Design pump rate (gpm) and TDH (ft):	
8. Type of standby power/pump provisions:	
9. Type of alarm:	
10. Additional information:	
Sewer	<input type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input checked="" type="checkbox"/> N/A
1. Gravity or vacuum sewer:	
2. Type of pipe material:	
3. ASTM/AWWA Standard and SDR/DR:	
4. Diameter and length of sewer (indicate length for each size):	
5. Number of manholes:	
6. Number of vacuum valve pits (if applicable):	
7. Additional information:	
Force Main and Low Pressure Sewer	<input type="checkbox"/> Proposed <input type="checkbox"/> Existing <input type="checkbox"/> Modification <input checked="" type="checkbox"/> N/A
1. Type of pipe material:	
2. ASTM/AWWA Standard:	
3. SDR/DR and pressure class (psi):	
4. Diameter and length of sewer (indicate length for each size):	
5. Additional information:	

IDENTIFICATION OF POTENTIALLY AFFECTED PERSONS

Please list any and all persons whom you have reason to believe have a substantial or proprietary interest in this matter, or could otherwise be considered to be potentially affected under law. Failure to notify a person who is later determined to be potentially affected could result in voiding IDEM's decision on procedural grounds. To ensure conformance with Administrative Orders and Procedures Act (AOPA) and to avoid reversal of a decision, please list all such parties. The letter on the opposite side of this form will further explain the requirements under the AOPA. Attach additional names and addresses on a separate sheet of paper, as needed.

Name See attached in the end	
Address (<i>number and street</i>)	
City	
State	ZIP Code

Name	
Address (<i>number and street</i>)	
City	
State	ZIP Code

Name	
Address (<i>number and street</i>)	
City	
State	ZIP Code


Name	
Address (<i>number and street</i>)	
City	
State	ZIP Code

Name	
Address (<i>number and street</i>)	
City	
State	ZIP Code

Name	
Address (<i>number and street</i>)	
City	
State	ZIP Code

CERTIFICATION

I certify that to the best of my knowledge I have listed all potentially affected parties, as defined by IC 4-21.5-3-5.

Proposed Facility Name Bakers Corner Wastewater Treatment Plant	City Bakers Corner, Adams Township
Printed Name of Person Signing Kathleen Ziino	County Hamilton
Signature 	Date Signed (<i>month / day / year</i>) 12 / 07 / 2022

Identification of Potentially Affected Persons Instructions

The Administrative Orders and Procedures Act (AOPA), IC 4-21.5-3-5, requires that the Indiana Department of Environmental Management (IDEM) give notice of its decision on your application to the following persons:

- Each person to whom the decision is specifically directed
- Each person to whom a law requires notice be given

The following are the minimum recommendations made as to who should be included in this list:

- All adjoining landowners to the property where the proposed construction is to occur
- All persons or entities with a substantial and direct proprietary interest in the issuance of this permit
- Anyone who is known to have expressed concern or an interest in this particular project or projects in this specific area
- Anyone else whom the applicant may feel that might be potentially affected by the issuance of this permit

IC 13-15-3-1 requires IDEM to provide notice of receipt of a permit application to the following:

- The county executive of a county affected by a permit application
- The executive of a city affected by a permit application
- The executive of a town council of a town affected by a permit application

Under IC 13-15-3-1 (b) IDEM is requesting information necessary to provide such notice to the appropriate officials.

Mailing labels are required to be submitted with your project. These mailing labels need to have the names and addresses of the affected parties along with our mailing code (which is 65-42FC) listed above each affected party listing.

For Example: 65-42FC
 JOHN DEERE
 111 CIRCLE DR
 YOUR CITY IN 44444



5160®

Easy Peel® Address Labels
Bend along line to expose Pop-up Edge®**Go to avery.com/templates**
Use Avery Template 5160

65-42FC
Robert W. Holden
1130 AAA Way,
Carmel, IN 46032

65-42FC
Carolyn H Gerth
Trustee of Carolyn H Gerth Rev Trust
1806 S 200 W
Tipton, IN 46072

65-42FC
Gemini Property Group LLC
1318 E 236th Street
Arcadia, IN 46030

65-42FC
Godby Properties LP
14550 Mundy Drive
Noblesville, IN 46030

65-42FC
Michael A & Joni S Summe
1558 E 236th St
Arcadia, IN 46030

65-42FC
Nader & Claire Rezkalla Family Rev
Trust
12143 Admirals Landing Blvd
Arcadia, IN 46236

65-42FC
Daniel & Janie Spearman
1556 E 236th St
Arcadia, IN 46030

65-42FC
Judith A Boyd
1552 E 236th St
Arcadia, IN 46030

65-42FC
Estefany M Burgos, Lesly Bibiana
Burgos, & Jorge Omar Zaleta JTRS
1554 E 236th St
Arcadia, IN 46030

65-42FC
Hamilton County Board of
Commissioners
1 Hamilton County Square Suite 157
Noblesville, IN 46060

65-42FC
State of Indiana
100 N Senate Avenue Room N642
Indianapolis, IN 46204

WESSLER ENGINEERING

LETTER OF TRANSMITTAL

		DATE: 12/8/22	JOB NO: 244721
TO:	Indiana Department of Environmental Management	FROM:	Kathleen M. Ziino
	Office of Water Quality, Facility Construction and Engineering Support Section, Mail Code 65-42FC		Wessler Engineering
	100 North Senate Avenue, Rm. N1255		1130 AAA Way
	Indianapolis, Indiana 46204		Carmel, IN 46032
		PHONE:	(317) 788-4551
		E-MAIL:	katez@wesslerengineering.com
RE:	Bakers Corner Wastewater Treatment Plant		

WE ARE SENDING YOU THE FOLLOWING ITEMS: ☒ Attached ☐ Under Separate Cover via

COPIES	DATE	NO.	DESCRIPTION
1	12/8/22	1	Construction Permit Application for the Bakers Corner WWTP
1	12/8/22	2	Project Manual for the Bakers Corner WWTP
1	12/8/22	3	Design plans for the Bakers Corner WWTP
1	12/8/22	4	Check in the amount of \$1,350 for the application fee
1	12/8/22	5	List of Potentially Affected Persons and mailing labels

THESE ARE TRANSMITTED as checked below:

- | | | |
|--|---|---|
| <input checked="" type="checkbox"/> For approval | <input type="checkbox"/> Approved as submitted | <input type="checkbox"/> Resubmit copies for approval |
| <input type="checkbox"/> For your use | <input type="checkbox"/> Approved as noted | <input type="checkbox"/> Submit copies for distribution |
| <input type="checkbox"/> As requested | <input type="checkbox"/> Returned for corrections | <input type="checkbox"/> Return corrected prints |
| <input type="checkbox"/> For review and comment | | |
| <input type="checkbox"/> For Bids due | | |

REMARKS:

Please accept this Application for Wastewater Treatment Plant Construction Permit on behalf of Hamilton County Building Corporation.

This project includes: influent screening structure, return activated sludge (RAS) feed structure, oxidation ditches, secondary clarifiers, RAS/WAS pump station, UV disinfection and cascade aeration, Parshall flume, RAS/WAS meter structure, biosolids dewatering, polymer feed system, chemical feed system, laboratory, office, plant drain pump station, process and yard piping, valves, emergency power generator, HVAC, electrical; instrumentation and controls, mechanical; SCADA system, paving, and landscaping.

Please contact Kathleen M. Ziino for any questions on the submittal at (463) 777-8086 or katez@wesslerengineering.com

Received by:

Kathleen M Ziino

COPY TO: File, Client	NAME: Kathleen M. Ziino
	TITLE: Project Manager

IDEM-WATER QUALITY

DEC 08 2022

RECEIVED

12-9-22



INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT

We Protect Hoosiers and Our Environment.

100 N. Senate Avenue • Indianapolis, IN 46204
(800) 451-6027 • (317) 232-8603 • www.idem.IN.gov

Eric J. Holcomb
Governor

Brian C. Rockensuess
Commissioner

March 4, 2022

VIA ELECTRONIC MAIL

Ms. Kate Ziino
Wessler Engineering
1130 AAA Way
Carmel, IN 46032

Dear Ms. Ziino:

Re: Preliminary Effluent Limitations
Proposed Bakers Corner WWTP
Hamilton County

This letter is in response to your request for preliminary effluent limitations for a proposed Bakers Corner Wastewater Treatment Plant (WWTP). As indicated in your request, the average design flow of the WWTP will be 0.5 MGD. The proposed discharge location will be to Baker Ditch. The $Q_{7,10}$ low-flow of the receiving stream at the point of discharge is considered to be zero cfs.

This letter also serves as notification that supplemental information is required to fully evaluate the proposed discharge. Construction and NPDES permitting may not proceed until the supplemental information specified herein has been submitted to, and been preliminarily approved by, this Office.

Preliminary effluent limitations are impacted by numeric and narrative water quality criteria as well as antidegradation requirements. Current Indiana Antidegradation Standards at 327 IAC 2-1.3-3 contain a provision for all surface waters of the State. The existing uses and the level of water quality necessary to protect existing uses shall be maintained and protected. The antidegradation rules for Indiana are found in 327 IAC 2-1.3.

Before approving a new discharge of treated wastewater, alternatives to the proposed discharge must be evaluated to satisfy antidegradation requirements. If this office makes a preliminary determination that the new discharge is necessary on the basis of economic or social factors, the effluent limitations contained herein (developed to minimize the potential lowering of water quality) may be utilized for construction and NPDES permitting. If this office determines the discharge is not necessary on the basis of economic or social factors, the proposed new discharge will not be allowed, and construction and NPDES permits will not be issued.

ANTIDEGRADATION DEMONSTRATION REQUIREMENTS FOR AMMONIA-NITROGEN

327 IAC 2-1.3-5(a) requires every antidegradation demonstration shall include the following basic information:

- (1) The regulated pollutants known or believed to be present in the wastewater and proposed to be discharged.
- (2) The estimated concentration and mass loading of all regulated pollutants proposed to be discharged.
- (3) The location of the proposed discharge and a map of the area of the proposed discharge that shows the receiving water or waters that would be affected by the new or increased loading, including the area downstream of the proposed discharge.

Every antidegradation demonstration shall include the following necessary information:

- (1) The availability, reliability, cost-effectiveness, and technical feasibility of the following:
 - (A) No degradation.
 - (B) Minimal degradation.
 - (C) Degradation mitigation techniques or alternatives.
- (2) An analysis of the effluent reduction benefits and water quality benefits associated with the degradation mitigation techniques or alternatives required to be assessed under subdivision (1)(C), including the following:
 - (A) A review of pollution prevention alternatives and techniques that includes the following:
 - (i) A listing of alternatives and techniques, including new and innovative technologies.
 - (ii) A description of how the alternatives and techniques available to the applicant would minimize or prevent the proposed significant lowering of water quality.
 - (iii) The effluent concentrations attainable by employing the alternatives and techniques.
 - (iv) The costs associated with employing the alternatives and techniques.
 - (v) An identification of the pollution prevention alternatives and techniques selected to be employed and an explanation of why those selections were made.
 - (B) An evaluation of the feasibility and costs of connecting to an existing POTW or privately owned treatment works, within the vicinity of the proposed new or increased loading, that:
 - (i) will effectively treat the proposed discharge; and
 - (ii) is willing to accept wastewater from other entities.
 - (C) For POTWs, if the proposed significant lowering of water quality is a result of a proposed new or increased loading from one (1) or more indirect dischargers, the analysis shall also include the following:
 - (i) The requirements of clause (A) shall be completed for the

indirect discharger or dischargers as well as for the POTW. The POTW may require the indirect dischargers to prepare this information.

(ii) If one (1) or more of the indirect dischargers proposes or does discharge to a combined sewer or sanitary sewer that is connected to a combined sewer, all combined sewer overflows (CSOs) between the point of discharge to the sewer and the POTW shall be identified.

- (3) The availability, cost-effectiveness, and technical feasibility of central or regional sewage collection and treatment facilities, including long-range plans for discharges outlined in:
 - (A) state or local water quality management planning documents; and
 - (B) applicable facility planning documents.
- (4) The availability, cost-effectiveness, and technical feasibility of discharging to another waterbody that:
 - (A) is not an OSRW; or
 - (B) has a higher assimilative capacity for the regulated pollutant.

327 IAC 2-1.3-5(g) requires the antidegradation demonstration include the following social and economic analysis information:(g) For each regulated pollutant in the proposed new or increased loading associated with activities in subsection (f), each antidegradation demonstration shall include the following social and economic analysis information:

- (1) The anticipated impact on aquatic life and wildlife, considering the following:
 - (A) Endangered or threatened species.
 - (B) Important commercial or recreational sport fish species.
 - (C) Other individual species.
 - (D) The overall aquatic community structure and function.
- (2) The anticipated impact on human health.
- (3) The degree to which water quality may be lowered in waters located within the following:
 - (A) National, state, or local parks.
 - (B) Preserves or wildlife areas.
 - (C) OSRWs or ONRWs.
- (4) The extent to which the resources or characteristics adversely impacted by the lowered water quality are unique or rare within the locality or state.
- (5) Where relevant, the anticipated impact on economic and social factors, including the following:
 - (A) Creation, expansion, or maintenance of employment.
 - (B) The unemployment rate.
 - (C) The median household income.
 - (D) The number of households below the poverty level.
 - (E) Community housing needs.
 - (F) Change in population.
 - (G) The impact on the community tax base.
 - (H) Provision of fire departments, schools, infrastructure, and other necessary public services.
 - (I) Correction of a public health, safety, or environmental problem.

- (J) Production of goods and services that protect, enhance, or improve the overall quality of life and related research and development.
- (K) The impact on the quality of life for residents in the area.
- (L) The impact on the fishing, recreation, and tourism industries.
- (M) The impact on endangered or threatened species.
- (N) The impact on economic competitiveness.
- (O) Demonstration by the applicant that the factors identified and reviewed under clauses (A) through (N) are necessary to accommodate important social or economic development despite the proposed significant lowering of water quality.
- (P) Inclusion by the applicant of additional factors that may enhance the social or economic importance associated with the proposed discharge, such as an approval that recognizes social or economic importance and is given to the applicant by:
 - (i) a legislative body; or
 - (ii) other government officials.

In determining whether a proposed discharge is necessary to accommodate important economic or social development in the area in which the waters are located under antidegradation standards and implementation procedures, the commissioner will give substantial weight to any applicable determinations by governmental entities.

Once an antidegradation demonstration has been received by this Office and determined complete, the antidegradation demonstration will be public noticed for a thirty day period requesting comment in accordance with 327 IAC 5-2-11.2. If this office makes a tentative determination to approve the submitted antidegradation demonstration, then construction and NPDES permitting may proceed with the understanding that a final determination will not be made until public input on the tentative decision has been considered. This office will seek public input on the tentative decision during the public participation process for the issuance of the NPDES permit. **It should be noted that the public participation process and/or permit appeal process included in the rules for the issuance of NPDES permits could alter (and possibly make more stringent) the limits that are established in the final NPDES permit or result in the denial of the request.** Should the tentative decision be to deny the antidegradation demonstration, the tentative decision for denial will be public noticed for a thirty day period requesting comment in accordance with 327 IAC 5-2-11.2. The public process for an antidegradation demonstration can be found at 327 IAC 2-1.3-6.

Preliminary Effluent Limitations for Sanitary-Type Wastewater

Table 1

Parameter	Summer		Winter		Units
	Monthly Average	Weekly Average	Monthly Average	Weekly Average	
CBOD5	10	15	10	15	mg/l
TSS	12	18	12	18	mg/l
Ammonia-N	1.1	1.6	1.6	2.4	mg/l
Phosphorus	1.0	----	1.0	----	mg/l

Table 2

Parameter	Daily Minimum	Monthly Average	Daily Maximum	Units
pH	6.0	----	9.0	s.u
Dissolved Oxygen	6.0	----	----	mg/l
<i>E. coli</i>	----	125	235	count/100mL

The effluent flow must be measured. The mass limits for CBOD₅, NH₃-N, and TSS are calculated by multiplying the average design flow (in MGD) by the concentration value and by 8.345. Summer effluent limits apply from May 1 through November 30 of each year. Winter effluent limits apply December 1 through April 30 of each year.

*The effluent limitations for *E. coli* are 125 colonies/100 ml as a monthly average calculated as a geometric mean and 235 colonies/100 ml as a daily maximum. **Ultraviolet light disinfection or disinfection by other non-halogen compounds is required as a consideration in antidegradation. Disinfection by chlorination or other halogen compounds will require the applicant to demonstrate that disinfection by ultraviolet light is either not technically feasible or that it is not affordable.**

If the preliminary effluent limitations specified above are not acceptable to the discharger, then alternate limitations may be pursued. To pursue alternate limitations, an assessment of alternative feasible treatment technologies comparing the expected effluent concentrations with the expected capital and maintenance costs for each alternative, and the corresponding expected new or increased loading above the level generated by the effluent limits specified above must be submitted for review. The assessment must also include an affordability analysis and justification for selecting the most cost-effective treatment plant design that is affordable. In no case will limitations be approved which will result in exceedances of State water quality standards.

In addition, Indiana Code 13-18-26 requires the permit applicant to certify that the following documents have been prepared and completed for new facilities and/or facility expansions with a design capacity above 0.10 MGD:

- A Life Cycle Cost-Benefit Analysis, as described in IC 13-18-26-3;
- A Capital Asset Management Plan, as described in IC 13-18-26-4; and
- A Cybersecurity Plan, as described in IC 13-18-26-5.

The certification of completion must be submitted to IDEM along with the permit application and must be notarized. IDEM will not issue a permit to an applicant that is subject to IC 13-18-26 if the required certification is not included with the application packet, as required by IC 13-18-26-1(b).

The plans and analyses must be reviewed and revised (as necessary) at least once every five years. A new certification must be submitted to IDEM (with the NPDES renewal application) if any plan or analysis is revised during the five-year review.

Ms. Kate Ziino
Page 6 of 6

If there are any questions regarding design requirements of the construction permit, please contact Ms. Missy Nunnery at 317/232-5579. The NPDES permit will not be issued until the construction permit is finalized.

If there are any questions regarding the antidegradation requirements or NPDES permit requirements, please feel free to contact Jay Hanco at Jhanco@idem.IN.gov or 317/233-0704.

Sincerely,

A handwritten signature in black ink that reads "Leigh Voss". The signature is written in a cursive style with a large, stylized "L" and "V".

Leigh Voss, Chief
Municipal NPDES Permits Section
Office of Water Quality

Enclosures

EXAMPLE

IC 13-18-26 Certification of Completion Wastewater

Indiana Code 13-18-26 requires the permit applicant to certify that the following documents have been prepared and completed:

- A Life Cycle Cost-Benefit Analysis, as described in IC 13-18-26-3;
- A Capital Asset Management Plan, as described in IC 13-18-26-4; and
- A Cybersecurity Plan, as described in IC 13-18-26-5.

The certification of completion must be submitted to IDEM along with the permit application, and must be notarized. The plans and analyses must be reviewed and revised (as necessary) at least once every five years. A new certification must be submitted to IDEM (with the NPDES renewal application) if any plan or analysis is revised during the five-year review.

I hereby certify that I am an authorized representative for the permit applicant and pursuant to IC 13-18-26, the permit applicant has developed and completed a life cycle cost-benefit analysis; a capital asset management plan; and a cybersecurity plan that meet the requirements of IC 13-18-26-3, IC 13-18-26-4, and IC 13-18-26-5. To the extent required under IC 13-18-26-6, the plans and analyses are available for public inspection.

Permit Applicant (Printed)

Signature

Date

Authorized Representative (Printed)

Signature

Date

Notary (Printed)

Signature

My Commission Expires: _____
(seal)



LETTER OF TRANSMITTAL

		DATE: 3/8/23	JOB NO: 244721
TO:	Indiana Department of Environmental Management	FROM: Kathleen M. Ziino	
	Office of Water Quality, Facility Construction and Engineering Support Section, Mail Code 65-42FC	Wessler Engineering	
	100 North Senate Avenue, Rm. N1255	1130 AAA Way	
	Indianapolis, Indiana 46204	Carmel, IN 46032	
		PHONE:	(317) 788-4551
		E-MAIL:	katez@wesslerengineering.com
RE:	Bakers Corner Wastewater Treatment Plant		

WE ARE SENDING YOU THE FOLLOWING ITEMS: ☒ Attached ☐ Under Separate Cover via

COPIES	DATE	NO.	DESCRIPTION
1	3/8/23	1	Response to IDEM Comments on 12/8/22 Application
1	3/8/23	2	Attachments associated with individual responses to comments
1	3/8/23	3	Attachment A - Revised Construction Permit Application
1	3/8/23	4	Attachment B - Updated and New Specification for Project Manual
1	3/8/23	5	Attachment C - Updated and New plan sheets for the design plans

THESE ARE TRANSMITTED as checked below:

- | | | |
|--|---|--|
| <input checked="" type="checkbox"/> For approval | <input type="checkbox"/> Approved as submitted | <input checked="" type="checkbox"/> Resubmit copies for approval |
| <input type="checkbox"/> For your use | <input type="checkbox"/> Approved as noted | <input type="checkbox"/> Submit copies for distribution |
| <input type="checkbox"/> As requested | <input type="checkbox"/> Returned for corrections | <input type="checkbox"/> Return corrected prints |
| <input type="checkbox"/> For review and comment | | |
| <input type="checkbox"/> For Bids due | | |

REMARKS:

Please accept this response to the comments associated with the Deficiency Notice received January 18, 2022. Included in this package is our response letter and accompanying attachments along with separate attachments that include the revised construction permit application, along with updated and new specifications and plan sheets for inclusion/replacement in the Project Manual and Design Plans originally submitted on December 8, 2022.

Please contact Kathleen M. Ziino for any questions on the submittal at (463) 777-8086 or katez@wesslerengineering.com

Received by: IDEM WATER QUALITY MAR 08 2023	
COPY TO: File, Client RECEIVED	NAME: Kathleen M. Ziino
	TITLE: Project Manager

February 1, 2023
Updated March 8, 2023

Ms. Alissa O'Donnell
Indiana Department of Environmental Management
100 N. Senate Avenue, Suite 1200
Indianapolis, IN 46204

Re: Hamilton County US 31 WWTP
IDEM Construction Permit Review

IDEM-WATER QUALITY

MAR 08 2023

Dear Ms. O'Donnell:

RECEIVED

This letter is in response to the technical comments provided in the Deficiency Notice for the Construction Permit Application, Bakers Corner WWTP, Bakers Corner, Indiana, Hamilton County, Project No. P-25686, dated January 18, 2023. This response incorporates updates based on the additional information requested in the February 13, 2023, email from you to Kate Ziino, and as discussed at the meeting held February 20, 2023. Each of the individual items noted in your letter are addressed below. Some responses include updates to the IDEM Construction Permit Application, the Project Manual, and the Design Plans originally submitted on December 8, 2022. For ease in replacing individual sections of these documents, the updated information has been grouped together in the following attachments:

Attachment A: Revised IDEM Construction Permit Application
Attachment B: Updated and New Project Manual Specifications
Attachment C: Updated and New Design Plan Sheets

1. *Please revise the design summary sheet as it appears to contain incorrect or incomplete information. Please send a revised design summary and ensure that it is signed, dated, and stamped. Otherwise provide justification for the following:*
 - a. *Plant Details. Please describe the plant's mechanical/electrical protection against a 100-year flood (e.g., proposed levee or buildings constructed 3 feet above floodplain elevation). This information is needed to confirm that the proposed design includes protection against a 100-year flood.*

Based on information available, the majority of the Bakers Corner WWTP site is outside the floodplain (see Attachment 1A-1, FEMA National Flood Hazard Layer FIRMette map for the floodplain boundary). However, at the time of the submittal of the IDEM Construction Permit Application for the Bakers Corner WWTP, flood elevations were not available on the Indiana Department of Natural Resources (DNR) or Indiana Floodplain Mapping websites.

Thus, Wessler estimated the 100-year flood elevation shown in the project documents (897.74') utilizing the base flood elevations found in the "IDNR Construction in a Floodway Assessment" Report associated with approved IDNR permit #FW-30671. The IDNR assessment is included in Attachment 1A-2 and the calculations are included in Attachment 1A-3. The 100-year flood elevations for the Bakers Ditch floodway found in the IDNR report were at points downstream of the plant's proposed discharge location, therefore, the 100-year flood elevation was estimated at the desired discharge point. At this 100-year flood elevation (897.74'), the WWTP structures/equipment closest to the floodplain, such as the UV power distribution centers, the UV modules, and the UV storage building, will all be located above this

elevation. Typical structure floor elevation is set at 908.00, more than 7 ft above the 100-year flood elevation. Attachment 1A-4 notes the comparison of the 100-year flood elevation to structure elevations as shown on Sheets 6C2 and 10A1 of the complete drawing set. All other WWTP structures, electrical, and mechanical equipment will also be protected from physical damage by the historical 100-year flood.

Attachment 1A-1: FEMA Floodway Report for Hamilton County

Attachment 1A-2: IDNR Construction in a Floodway Assessment

Attachment 1A-3: 100-year Flood Elevation Calculation

Attachment 1A-4: Reference Sheets 6C2 and 10A1

- b. *Treatment Unit, Plant Site Lift Station. IDEM is looking for a different type of alarm to be listed in this section (e.g., visual/audio, telemetry, SCADA).*

The plant SCADA system shall monitor and display the following alarms for the Plant Site Lift Station (Plant Drain Lift Station) as per specification section 13400 2.12 D. 2. And 4.:

- a. Pump (1,2) Fail
- b. Low Level Alarm
- c. High Level Alarm

Additional information has been included in the Plant Site Lift Station section of the design summary. Please see Attachment A, Revised IDEM Construction Permit Application.

The operating volume of the wet well has also been updated to 845.96 gallons from 6027.75 gallons (which represented the total wet well volume).

- c. *Treatment Unit, Influent Flow Meter. Please list what is used for indicating, recording, and totalizing (e.g., circular chart).*

The Bakers Corner WWTP is not designed to accept gravity flow into the plant and will only receive flow from Lift Station No. 1 in the collection system, located on 236th Street, west of the WWTP. The collection system project is Division 2, Water and Sewer, submitted separately from the Bakers Corner WWTP project. Lift Station No. 1 is designed to include a flow meter. The flow meter data shall be indicated, recorded, and totaled at the WWTP using SCADA as per specification section 13400 2.01.

Details of Lift Station No. 1, including location in the collection system, site plan, and pump data sheet from Specification 11200 of the Division 2, Water and Sewer, Project Manual are included in Attachment 1C-1 for reference. Please note that the collection system will also include Lift Station No. 2, however, Lift Station No. 2 will direct flow to Lift Station No. 1, which will pump the combined flow from the two stations to the WWTP.

Attachment 1C-1: Division 2 Lift Station No. 1 details (FOR REFERENCE ONLY)

- d. *Treatment Unit, Effluent Flow Meter. This section was left blank and should be filled out because a Parshall flume appears to be part of the design.*

The design summary has been updated in the revised IDEM Construction Permit Application (Attachment A) to include the same.

2. *Please provide all treatment process design calculations as this is a new wastewater treatment plant. This includes, but is not limited to, aeration, chemical phosphorus removal, and sludge calculations. Please note that there may be approximately 15 to 20% additional chemical sludge (by weight) generated due to phosphorous removal by chemical precipitation.*

The following design calculations are provided with this response letter:

- Hydraulic Calculations: see response to Comment 3
- Pump Curves and Backup Calculations: see response to Comment 4
- Attachment 2-1: Air Demand Calculations
- Attachment 2-2: Bioloop System Calculations
- Attachment 2-3: Clarifier Design Calculations
- Attachment 2-4: Chemical Phosphorus – Dose and Storage Calculations
- Attachment 2-5: Cascade Aeration Calculations
- Attachment 2-6: Sludge Calculations

3. *Please provide the hydraulic calculations to support the water surface elevations as shown on the hydraulic profile sheet 1G6.*

Hydraulic Calculations are attached for your use in Attachment 3-1.

4. *Please provide pump performance curves as well as superimposed TDH curves for the proposed lift station pumps. Please also send representative system TDH calculations using a design C factor of 120. The expected pump capacity will be located at the point where the TDH system curve intersects the pump performance curve. This information is necessary to verify the lift station pump capacities.*

Please find the pump curves and backup calculations for the Plant Drain Pump Station in Attachment 4-1 and for the RAS/WAS Pump Station in Attachment 4-2. Regarding the RAS/WAS Pump Station curves: The RAS wet well should normally run closer to the HWL since the wet well is connected to the clarifiers and the clarifiers each have a t-valve that will discharge into the wet well close to that height. The only times that the RAS/WAS pumps will be at the LWL (the traditional level associated with sizing pumps) is when the clarifiers or the wet well is being drained and is nearly complete in that process. Under that draining scenario, the pump will move back on its curve and will pump at a reduced rate, which is acceptable, just reduced from the peak RAS rate.

Attachment 4-1: Plant Drain Pump Station Curves and Backup Calculation

Attachment 4-2: RAS/WAS Pump Station Curves and Backup Calculations

5. *The proposed new screening structure raises a number of concerns. Please see the criteria listed below that IDEM utilizes when reviewing treatment plant designs. Please provide sufficient justification for the following questions as to why the guidelines cannot be met and/or revise the design to address any concerns.*
- a. *Ten State Standards 61.123 states that dual channels shall be provided and equipped with the necessary gates to isolate flow from any screening unit. For both the proposed fine screen and coarse screen, the design only provides one channel. The coarse bar screen bypass should be kept separate from the fine screen. Please explain how the plant will continue to operate if the coarse screen become blinded because it is located in the same channel.*

Our understanding of the intent behind the need for two channels is to allow for continued screening even while screening equipment is out of operation. The design of the screw press screen allows for it to be rotated out of the channel flow for maintenance, with no disruption to flow. The manual maintenance bar screen meets the intent of Ten State Standards 61.124, which states that "Where a single mechanically cleaned screen is used, an auxiliary manually cleaned screen shall be provided." Normally the manual maintenance bar screen will be stored on site. The maintenance bar screen will need regular monitoring and cleaning as needed to prevent it from blinding while the screw press screen is rotated out of the channel being serviced.

Also note that for future plant expansion, the intent is to abandon the Screenings Structure and construct a larger capacity headworks structure in the location identified on Sheet 2Y2 as "Future Headworks" west of the Screenings Structure. The future headworks structure would have at least two screens in separate channels and may also include a grit removal system.

- b. According to Sheet 3G1, the manual coarse screen will be used only when the mechanical screen is removed. It's unclear whether the coarse bypass screen is a permanent fixture in the channel or if it'll be removed when not in use. If it's detachable, how will the operator get it into the channel with the Davit crane located over the mechanical fine screen? IDEM has only approved permanent bypass structures in a separate channel, as far as I am aware.*

The bar screen is removed from the channel entirely when not in use. Drawing Sheets 3G1, 3C1, and 3C2, included in Attachment C, Updated and New Design Plan Sheets, have been updated as follows: 1) the name of the screen as been changed to "MAINTENANCE BAR SCREEN", 2) more details have been added to clarify what is permanent and what is removable, and 3) an additional davit crane base will be installed and the davit crane will be portable. In addition, a temporary drainage plate has been added so that when the maintenance bar screen is being cleaned, the screenings are captured.

- c. Ten State Standards 61.125 states that the screen channel invert should be 3 to 6 inches below the invert of the incoming sewer. This is not possible with the proposed design, which has the incoming sewer coming up through the screening channel's ground. Is there any concern that screenings will not be pushed along (swirling near the piping) and will instead accumulate and block the incoming flows?*

The flow from the plant is being pumped into the screenings structure, which is anticipated to keep the screenings in solution. In addition, the expectation is that flow will hydraulically follow the path of least resistance through the screen towards the screening structure effluent drop pipe. In case of any blockage in the piping ahead of the discharge point due to screenings or solids buildup, a cleanout is provided on the force main just upstream of the screenings structure as shown on updated Sheet 3C1 (see Attachment C, Updated and New Design Plan Sheets).

- d. *Ten State Standards 61.128 states that screening devices and screening storage areas shall be protected from freezing. The design is located outside rather than inside a building, and specification 11331 (cylindrical fine screen) does not appear to mention any freeze protection.*

The description of the components of the fine screen included in Part 1.01.B of specification 11331 notes that a weather protection package is being provided. A "weather protection package" is not explicitly called out, but is represented by the individual components described in Section 2.02.H on page 11331-5:

The transport tube, press zone, discharge section, and drain tube shall be fitted with 10 watt per foot, self-regulating heating cable, ¾" to 1-1/2" thick closed cell foam insulation, and a 20-gauge type 304 stainless steel jacket. Provide heat trace, insulation, and SS cladding for the screen.

- e. *Ten State Standards 61.22 states that two fine screens shall be provided and their capacity shall treat design peak instantaneous flow with one unit out of service. The design includes only one screen, with no explanation as to why a redundant screen is not included for a plant with peak flows of up to 2.25 MGD. Please explain how the plant will operate if this mechanical fine screen is out of service for an extended period of time.*

When the mechanical fine screen is out of service, it will be rotated out of the influent flow and the manual maintenance bar screen will be installed. The maintenance bar screen will need regular monitoring and cleaning as needed to prevent it from blinding while the screw press screen is being serviced. The temporary drainage plate will prevent screenings from falling back into the flow when the maintenance bar screen is being cleaned.

6. *Ten State Standards 65.1 states that the use of flow equalization should be considered where significant variations in organic and hydraulic loadings are expected. When the average design flow to peak hourly design flow ratio is greater than or equal to 3.0, IDEM looks for flow equalization. The proposed design ratio is 4.5. Please adequately justify why no equalization is included.*

The primary driver for the peak/average ratio is the incorporation of a proposed Indiana National Guard armory in the flow projections. Due to the nature of their proposed operations, the facility will have large numbers of visitors at the facility over the course of abbreviated periods of time. This skews the peak/average ratio. However, the equipment for each of the WWTP liquid treatment processes was selected specifically to provide treatment through the anticipated range of design flows and loads (minimum 0.08 MGD through the peak 2.25 MGD). Therefore, flow equalization is not required.

7. *The proposed biological nutrient removal system resembles a previous Sanitaire design that I reviewed (Bioloop oxidation ditch). While I recognize the importance of aerobic and anoxic zones, the proposed new oxidation ditches raise several concerns. Please provide sufficient justification for the following questions and/or revise the design to address any concerns.*
 - a. *The design summary states that there are "two (2) in series oxidation ditches," but the process flow diagram (sheet 1G5) and oxidation ditch plan (sheet 4C1) show the oxidation ditches in parallel. Furthermore, the design summary indicates that there is no method for flow split control.*

The ditches are designed to operate in series during flows equal to and greater than the average design flow of 0.5 MGD. A pass-through slide gate (OD-SG01) is provided between the two ditches (shown on Sheet 4C2) to allow for series operation of the oxidation ditches. Please see Attachment 7A-1 for a

diagram that shows which valves or gates will be normally open (N.O.) or normally closed (N.C.) during the series operation of the ditches.

The facility is anticipating flows as low as 0.08 MGD during the initial start-up of the plant before significant development can occur in the area. The oxidation ditch influent pipes are designed such that the ditches can be operated in parallel, or with one tank out of service. Until the time when flows necessitate having both oxidation ditches operate in series, only one ditch will be in operation and the pass-through gate will be closed. The influent plug valves (OD-PV01 and OD-PV02) upstream of the ditches and the oxidation ditch effluent slide gates (OD-SG02 and OD-SG03) will be used as the method for flow split control. RAS will be fed upstream to the RAS Feed Structure to allow the operational flexibility when one or both oxidation ditches are in service since the RAS will be fed to a location that is independent of the oxidation ditch flow split control. The piping immediately upstream of the oxidation ditches is arranged to further extend this flexibility, with the intent that one of the influent plug valves will be open and the other one closed to direct flow to either of the oxidation ditches for the low flow conditions or for maintenance. Once the plant receives consistent high flows to necessitate the oxidation ditches running in series, one of the influent valves will be closed. Please see Attachment 7A-2 for a diagram that shows which valves or gates will be normally open (N.O.) or normally closed (N.O.) during the parallel (or one tank out of service) operation of the ditches.

Additional information including method for flow split control, has been added to the design summary (see Attachment A, Revised IDEM Construction Permit Application).

- b. According to the design summary, the F/M ratio is 0.0581 lb CBOD/day/lb MLVSS. However, IDEM calculates an F/M ratio of 0.111 based on the provided information that the design MLSS concentration will be 2,900 mg/L and IDEM's assumption that MLVSS is approximately 75% of MLSS. The F/M ratio should be between 0.05 and 0.10 for an extended aeration design.*

The design summary has been corrected to indicate an F/M ratio of 0.111 lb CBOD/day/lb MLVSS at design conditions. Based on information provided in Attachment 2-2, Bioloop System Calculations, the F/M ratio is 0.103 lb CBOD/day/lb MLVSS at near-term conditions.

Ten State Standards recommend an F/M of 0.05-0.1 for single-stage extended aeration processes and an F/M of 0.2-0.5 for conventional activated sludge. The Bioloop system F/M ratio falls somewhere between the two processes because it is operated as a 2-stage nitrification process (operating the 2 ditches in series). This has been proven at other installations, specifically the Muncie Water Pollution Control Facility WPCF) and Fond du Lac, WI. See Attachment 7B-1 for details on these two facilities. The Muncie WPCF system is similar to the proposed Bakers Corner WWTP as it does not have anaerobic basins upstream of the Bioloop oxidation ditches. See the summary of 2017 Monthly Reports of Operation for the Muncie WPCF and estimated F/M calculations in Attachment 7B-2. In reviewing the 2017 average primary effluent CBOD and MLSS, the F/M ratio calculates to 0.138 lb CBOD/lb MLVSS/day while achieving low effluent CBOD and TSS values (3 mg/L and 5 mg/L, respectively). The F/M ratio at the Bakers Corner WWTP at near-term and design conditions is also included in Attachment 7B-2 for reference.

Attachment 7B-1: Bioloop Reference Plants

Attachment 7B-2: Reference Plant F/M Ratio Review

- c. According to the design summary, the oxygen requirement for CBOD removal is listed as 872 lb O₂/day. Ten States Standards 92.331 specifies the oxygen requirements for activated sludge as*

1.1 lb O₂/lb BOD, with the exception of 1.5 lb O₂/lb BOD for extended aeration. Neither of these is equal to the oxygen requirement stated in the design summary. The oxygen requirement for CBOD in an extended aeration plant is calculated by IDEM to be 1,251 lbs/O₂.

The Bioloop system is not a typical extended aeration system – it is an aerobic/anoxic system. Therefore, the oxygen requirements for activated sludge of 1.1 lb O₂/lb BOD is the appropriate value to use under design conditions. The initial calculations assumed some BOD would remain in the effluent. We have corrected this assumption to provide enough air to remove all BOD and NH₃-N. Based on this correction, the oxygen requirement for CBOD removal is 917 lbs O₂/lb BOD. The corrected air demand is presented in Attachment 2-1, Air Demand Calculations. As shown in Attachment 2-1, the corrected air demand under design conditions required a minor correction in the aeration blowers capacity as well. Updated values have been provided in the revised IDEM Construction Permit Application (see Attachment A), as well as the Design Summary on Sheet 1G5 (see Attachment C).

At the near-term flows, this system may be operated as an extended aeration system, rather than the Bioloop aerobic/anoxic system. Therefore, air demand calculations have been developed at oxygen requirements of 1.1 (activated sludge system) and 1.5 lb O₂/lb BOD (extended aeration system). Attachment 2-1, Air Demand Calculations, includes the calculated air demand under near-term conditions at both oxygen requirement assumptions. In addition, the blower curve has been provided in Attachment 2-1, which confirms the specified blowers will be able to meet the air demand for both near-term and design conditions. The blowers have VFDs to adjust air supply across the anticipated range of design flows.

Note that the air demand calculations presented in Attachment 2-1 are higher than those included in Attachment 2-2, Bioloop Calculations, for design conditions and a little less for near-term conditions. Under design conditions, Sanitaire included a credit for denitrification that reduced their calculated air demand. The air demand calculations in Attachment 2-1, which are the calculations that sized the blowers, did not include this credit and, therefore, are more conservative under design conditions. Under near-term conditions, the assumptions used are slightly different; however, the calculated air demands are within 10% of each other.

- d. The design on sheet 4C1 proposes a limited number of diffusers. The diffusers are shown to occupy roughly one-third of one straight side of the oxidation ditches, accounting for about 14% of the total oxidation ditch volume. There are concerns that there will not be enough diffusers to provide the necessary aeration for treatment without having design calculations to examine.*

Per the Bioloop Sanitaire calculations provided during design (Attachment 2-2), seventy-five (75) fine bubble diffusers will be provided per oxidation ditch (total of 150 diffusers). Sanitaire indicated that each diffuser is designed to provide up to 4 scfm. As part of the air demand calculations included in Attachment 2-1, the capacity of the diffusers was compared against the demand of the system and the number of diffusers was confirmed to be sufficient (air supplied is an average of 2.2 scfm/diffuser).

- e. Aside from concerns about adequate treatment, there is a large portion of the oxidation ditches where solids could settle. The submersible mixer is placed diagonally on the opposite side, about one-third of the way in on the opposite straight side of the oxidation ditch. There are reservations that the ditch will be unable to keep solids suspended between the diffusers and the submersible mixer, particularly as it travels around the curved wall. According to the design summary, the flow velocity in the ditch is listed as 0.009 ft/sec. According to Ten States Standards 92.333, all*

mechanical aeration systems should have an average velocity of 1 ft/s in order to keep all biological solids suspended. Please clarify the discrepancies.

The original information included in the design summary is velocity through the ditch if the flow was left to its own devices, i.e. $Q=V/A$. However, the mixers impart a velocity on the flow by mechanically increasing the speed of the flow through the ditch, so the calculated low value is incorrect for the system. Sanitaire has provided velocity data for the mixers as part of the Bioloop design calculations, which are included in Attachment 2-2. The correct velocity, 1.17 ft/s for each oxidation ditch, has been updated in the design summary in the revised IDEM Construction Permit Application (Attachment A).

8. *The proposed chemical phosphorus removal design raises some concerns. The additional information under the chemical phosphorus removal states that "near- term flows are anticipated to be very low with storage supply anticipated to be just under 30 days with toes. As influent flow reaches design ADF, increasing chemical usage, intent is to replace totes with storage tank." The proposed chemical phosphorus building's design does not include any final buildout design details.*
- a. *Rather than explaining that there will be a future capacity increase, the construction permit application is for the full average design flow, and thus the chemical removal facilities must reflect the full flow.*
 - i. *Final building information such as storage tank volume and secondary containment, as well as design chemical feed rate and expected storage days, are not included in the design summary and construction drawings.*

The design summary has been updated in Attachment A, Revised IDEM Construction Permit Application to note the needed storage volume at design flow and the anticipated location for the additional storage and containment, which is anticipated to be located outside east of the Chemical Room of the Plant Control Building. Sheets 2Y2, 2Y3, and 9C1 have been updated to show location of additional chemical storage, presented in Attachment C, Updated and New Design Plan Sheets.

Backup calculations for the information provided in Attachment A, Revised IDEM Construction Permit Application and shown on the updated drawings are included in Attachment 2-4.

- b. *Because the design essentially calls for both an initial and final buildout, IDEM must see the temporary and permanent chemical removal facilities. This is because IDEM must approve the plant's final design because, even with assurances, it cannot be guaranteed that another construction permit will be submitted in the future when these final buildout changes are needed.*

Attachment C includes updated Sheets 2Y2, 2Y3, and 9C1, which show the planned location for additional chemical storage east of the Chemical Room of the Plant Control Building.

- c. *Please demonstrate how a chemical dose and chemical feed pumping rate were established and that it will be adequate to bring the effluent phosphorus concentration to under 1.0 mg/L. Stoichiometric calculations will need to be included as part of the design basis.*

Backup calculation for the information requested is included in Attachment 2-4.

- d. *Because the storage tank volume is not provided, please provide assurance of a regional supplier and the expected chemical delivery schedule if the total storage volume is less than 10 days.*

The backup calculations included in Appendix 2-4 show that the intent is to provide at least 10 days storage at all times. The two 250 gal totes will provide 30 days storage under near term conditions. As the storage time reduces to 10 days (calculated to be when plant reaches approximately 75% capacity), a 2,000-gal tank will be installed in the approximate location shown on updated Sheets 2Y2, 2Y3, and 9C1 in Attachment C, Updated and New Design Plan Sheets.

9. *The RAS/WAS pump station (sheet 5G1) is shown in the design going directly into the polymer feed building (sheet 8C1), which then directs wasted sludge to the geobags for dewatering (sheet 10C1). Please explain why an aerated sludge holding tank was not included as part of the sludge treatment train. How would the plant function if the biosolids dewatering structure and/or geobags were out of commission for an extended period of time? The volume of the RAS/WAS pump station is the only "backup" storage.*

The solids handling system is generally a passive system with polymer injected into the flow as sludge is pumped to the geotextile bags. Two geotextile bags are provided so that one can be filled while the other is under maintenance. The plug valves BDS-PV01 and BDS-PV02 will be used to feed and isolate the geotextile bags as needed. The polymer injection system can be bypassed in the event that the system is out of commission, by opening plug valve PLM-PV03 and closing plug valve PLM-PV02 in the Polymer Feed Building. Additionally, the RAS/WAS wet well has also been sized for average (0.5 MGD) and peak design (2.25 MGD) flows and could help to store sludge during low flow conditions if needed.

The proposed Bakers Corner WWTP is expected to see flow as low as 0.08 MGD during the initial start-up and near-term conditions. Sludge production is anticipated to be very low during this period (less than 3,000 gallons per day). The geotextile bags are designed to receive sludge flow of approximately 100 gpm, which equates to wasting 3.5 hours per 7-day week, with each geotextile bag anticipated to take a month to fill under near-term conditions. Based on these design calculations, the sludge dewatering geotextile bags will be sufficient to handle the sludge wasting directly from the RAS/WAS pump station under near-term conditions.

Under design conditions of 0.5 MGD, the anticipated wasting schedule is 21.7 hours per 7-day week without an aerobic digester for sludge storage. Each geotextile bag is anticipated to be filled in 5 days with WAS pumped 7-8 hours per day for 3 days per 7-day week. As flows increase to the WWTP, the Hamilton County Regional Utility District will need to perform a cost analysis to determine when adding aerobic digester(s) upstream of the polymer feed building and downstream of the RAS/WAS meter structure is more cost effective than hauling geotextile bags to the landfill. With an aerobic digester storage tank sized for 30 days of storage, wasting is calculated to occur less than 5 hours per 7-day week, with each geotextile bag anticipated to take 23 days to fill under design conditions.

The plans and specifications have been updated as follows to include information regarding the future aerobic digester: The process flow diagram and design summary have been updated on Sheet 1G5, included in Appendix C, Updated and New Design Plan Sheets. The overall site plan (Sheet 2Y2, also included in Appendix C) and the Site Piping Plan (Sheet 2Y3) have been updated to indicate the proposed location of the future digester, along with future sludge piping and associated pump station, to be installed when sludge management warrants the need. In addition, both sheets indicate the space reserved for the future sludge storage area over and above the future digester for additional sludge management. Sheets have been added to Area 8 for the future digester (8G2, 8C3, and 8C4).

Specifications 11335 - Glass-lined Wastewater Treatment Tank, and 11374 - Coarse Bubble Aeration Equipment, have been added to the Project Manual, the blower associated with the aerobic digester has been added to the data sheet in Specification 11370 - Positive Displacement Blowers and Accessories, and the Table of Contents has been updated. The design summary has been updated in the revised IDEM Construction Permit Application in Appendix A to include information on the future aerobic digester.

The calculations to develop the design are included in Attachment 2-6. Updates to the design summary are included in Attachment A, Revised IDEM Construction Permit Application. The new specifications and updated table of contents are included in Attachment B, Updated and New Project Manual Specifications. Updated Sheets 1G5, 2Y2, 2Y3, and the new future digester sheets are included in Attachment C, Updated and New Design Plan Sheets.

10. *According to the process flow diagram (sheet 1G5), the RAS feed structure has a volume of 1,088 ft³. The internal dimensions of the RAS feed structure plan (sheet 10C1) are 8 ft x 8 ft x 11 ft (704 ft³) and the external dimensions are 9.25 ft x 9.25 ft x 11 ft (941 ft³). The dimensions shown on the plans do not match the volume stated on sheet 1G5. Please clarify the discrepancies.*

The volume shown on the process flow diagram on Sheet 1G5 was a calculation error and has been corrected to match the internal RAS Feed Structure dimensions and a volume of 704 ft³. This value has also been updated on Sheet 1G5 in Attachment C, Updated and New Design Plan Sheets.

11. *The 100-year flood water elevation is marked on the hydraulic profile (sheet 1G6) as 897.74 ft. At this elevation, it appears that half of the cascade post-aeration steps, the effluent piping, and the outfall are all submerged. How would the wastewater treatment plant function in these circumstances? Please also revise the design to include backflow prevention on the effluent line to prevent the Baker Ditch tributary from flooding the effluent piping.*

The receiving water body is a ditch, not a pond or lake. Therefore, the hydraulics were calculated based on the expectation that the water in Baker Ditch is flowing, even under flood conditions. Since the 100-year flood elevation is lower than the elevations of the UV structure and Parshall flume, as discussed in the response to Comment 1A, flow will continue to flow out of the WWTP. The effluent hydraulics and piping have been designed to account for any back pressure associated with a flooded ditch condition, which will allow plant effluent to flow to the ditch during a 100-year flood condition. The effluent will continue to receive some aeration across the unflooded steps.

Since the system is designed to allow the effluent flow to always flow away from the WWTP, we do not feel a backflow preventer to the effluent line is necessary. In addition, a backflow preventor would create additional headloss that would make effluent hydraulics worse. Other WWTPs around the state have submerged effluent pipes under 100-year flood conditions without backflow prevention. Examples of this configuration include Newton County Regional Water and Sewer District WWTP and Town of Whiteland WWTP.

12. *Specification 11200 (submersible non-clog centrifugal pumps) was not included. Please provide this missing specification as the project manual progresses from 10523 (fire extinguishers) to 11260 (UV disinfection equipment).*

Please see Attachment B, Updated and New Project Manual Specifications, for Specification 11200 missing from the project manual submitted with the original IDEM Construction Permit Application.



More than a Project™

Sincerely,

WESSLER ENGINEERING

A handwritten signature in blue ink that reads 'Kathleen Ziino'.

Kathleen Ziino, P.E.
Senior Project Manager

SG/ALT/KMZ:\\mdwa.local\\wessler\\Clients\\Hamilton County\\Projects\\244721 Hamilton Co Bakers Corner\\04-001 Design\\L Permits\\IDEM
WWTP Construction Permit\\IDEM Response of Letter 01_18_23\\IDEM Response 03-08-23.docx

cc: File, Client

Question 1 Attachments

Attachment 1A-1

National Flood Hazard Layer FIRMeTte

86°31'W 40°8'27"N



Legend

SEE FIS REPORT FOR DETAILED LEGEND AND INDEX MAP FOR FIRM PANEL LAYOUT

SPECIAL FLOOD HAZARD AREAS

- Without Base Flood Elevation (BFE)
Zone A, V, AE, AO, AH, VE, AR
With BFE or Depth Zone AE, AO, AH, VE, AR
Regulatory Floodway

OTHER AREAS OF FLOOD HAZARD

- 0.2% Annual Chance Flood Hazard, Area of 1% annual chance flood with average depth less than one foot or with draining areas of less than one square mile Zone X
- Future Conditions 1% Annual Chance Flood Hazard Zone X
- Area with Reduced Flood Risk due to Levee, See Notes, Zone X
- Area with Flood Risk due to Levee Zone D

OTHER AREAS

- NO SCREEN Area of Minimal Flood Hazard Zone X
- Effective LOMRs
- Area of Undetermined Flood Hazard Zone

GENERAL STRUCTURES

- Channel, Culvert, or Storm Sewer
- Levee, Dike, or Floodwall

AREA OF MINIMAL FLOOD HAZARD
Zone X
18057C00206
eff. 11/19/2014

HAMILTON COUNTY
180080

Zone A

18057C00406
eff. 11/19/2014

OTHER FEATURES

- 20.2 Cross Sections with 1% Annual Chance Water Surface Elevation
- 17.5 Coastal Transect
- Base Flood Elevation Line (BFE)
- Limit of Study
- Jurisdiction Boundary
- Coastal Transect Baseline
- Profile Baseline
- Hydrographic Feature

MAP PANELS

- Digital Data Available
- No Digital Data Available
- Unmapped

The pin displayed on the map is an approximate point selected by the user and does not represent an authoritative property location.



This map complies with FEMA's standards for the use of digital flood maps if it is not void as described below. The basemap shown complies with FEMA's basemap accuracy standards

The flood hazard information is derived directly from the authoritative NFHL web services provided by FEMA. This map was exported on 3/30/2022 at 9:49 AM and does not reflect changes or amendments subsequent to this date and time. The NFHL and effective information may change or become superseded by new data over time.

This map image is void if the one or more of the following map elements do not appear: basemap imagery, flood zone labels, legend, scale bar, map creation date, community identifiers, FIRM panel number, and FIRM effective date. Map images for unmapped and undetermined areas c be used for regulatory purposes.

0 250 500 1,000 1,500 2,000 Feet

1:6,000

86°31'W 40°8'27"N

Attachment 1A-2



Indiana Department of Natural Resources Division of Water



Construction in a Floodway Assessment

As mandated by the regulations of the Flood Control Act, IC 14-28-1 and the Floodplain Management rules, 312 IAC 10, a construction project in a floodway requires a permit application review that includes a hydrologic and hydraulic evaluation to determine the effect a project may have on the base flood elevation and an environmental review to determine the impact a construction project may have on fish, wildlife, and botanical resources.

Hydrologic and Hydraulic Evaluation

The Division of Water assesses the change to the effective cross sectional flow area resulting from proposed construction projects in order to minimize cumulative effects on the base flood elevation. Construction projects located in a floodway can result in varying degrees of loss to the effective cross sectional flow area. The Division of Water developed non-modeling hydraulic assessment worksheets to assess specific construction projects that result in negligible loss of the effective cross sectional flow area. If negligible loss cannot be demonstrated through a non-modeling assessment approach or if a cumulative loss of the effective cross sectional flow area exists from other construction projects, computer modeling will be required to be submitted to evaluate the effects the proposed project will have on the base flood elevation. For more information on computer modeling, refer to General Guidelines for the Hydrologic-Hydraulic Assessment of Floodplains in Indiana at www.in.gov/dnr/water/3483.htm.

Non-Modeling Hydraulic Assessment Worksheets

Specific to each non-modeling assessment approach, examples of typical project types are provided on each worksheet to assist you in selecting the appropriate worksheet for your specific project. For more information about what project types are used in each non-modeling assessment approach, refer to the Construction in a Floodway Assessment User Guide.

- 1) No Change in Effective Cross Sectional Flow Area Non-Modeling Worksheet (State Form 55238)
- 2) Change in Effective Cross Sectional Flow Area Non-Modeling Worksheet (State Form 55236)
 - a) Companion Worksheet A ([State Form 55237](#))
- 3) Ineffective Area of the Contraction or Expansion Reach of a Stream Crossing Non-Modeling Worksheet (State Form 55235)
- 4) Bridge Replacement in Kind Non-Modeling Worksheet (State Form 55233) *and* associated Companion worksheets
 - a) Bridge Replacement-in-Kind Companion Worksheet B ([State Form 55234](#)), or
 - b) INDOT Bridge Replacement in Kind Assessment Worksheet (INDOT bridge work only)
- 5) Bridge Resurfacing Checklist

Fish, Wildlife, and Botanical Impact Assessment

In the permit application review process, the Divisions of Fish and Wildlife, Nature Preserves, and Outdoor Recreation assess the cumulative impacts that construction projects in the floodway may have on fish, wildlife, and botanical resources. Each Non-Modeling Hydraulic Assessment Worksheet includes the minimum plan requirements and computations necessary to assess impacts on flora and fauna and the potential for required mitigation.

These worksheets serve to communicate the framework used to evaluate a project's cumulative impacts to the effective cross sectional flow area and fish, wildlife, and botanical resources in the floodway. These worksheets are meant to relay the information needed to evaluate the vast majority of projects but cannot describe the information needed for all scenarios and all potential projects. The purpose of the worksheet is to balance the need for transparency of the evaluation methods and information needed for a particular project; the preparer's discernment is still needed when preparing an application and supporting documents for review to meet the statutory requirements.

For more information, Non-Modeling Hydraulic Assessment Worksheets, Companion Worksheets, Construction in a Floodway Assessment User Guide, Worksheet Examples, General Guidelines for the Hydrologic-Hydraulic Assessment of Floodplains in Indiana, Mitigation Guidelines, the permit Application Manual and training videos are available on our webpage at www.in.gov/dnr/water.



NO CHANGE IN EFFECTIVE CROSS SECTIONAL FLOW AREA NON-MODELING WORKSHEET

State Form 55238 (4-13)

For Division of Water use: Application # FW-_____



An assessment using the No Change in Effective Cross Sectional Flow Area Non-Modeling Worksheet is appropriate to use to assess non-bridge projects that will result in no discernable loss of the effective cross sectional flow area. Project examples include bank stabilization, restoration projects, excavation, or fill of 6" or less when comparing pre-construction to post-construction conditions such as a trail, parking lot, access drive, or sidewalk.

The minimum documentation and computations specified below in this document must be submitted to the Division of Water along with a completed, signed, and dated application form ([State Form 42946](#)) and the appropriate [application fee](#).

Unless the instructions in this document direct you otherwise, all plan details, questions and computations in this worksheet must be addressed to adequately evaluate a project under a non-modeling assessment approach.

Minimum Plan Details and Computation Requirements:

1) Plan Details and Supporting Documentation

For each of the minimum plan details described in the following chart, complete Column 1 and Column 2. The required plan view items can be combined into one or more plan drawings if the information is clearly defined.

<u>Column 1</u> Indicate with ✓ if item is included in application submittal	<u>Column 2</u> Indicate page or sheet # for each required item	<u>Column 3</u> Minimum Plans Required	<u>Column 4</u> For Division of Water use only
<input checked="" type="checkbox"/>	pg 8: project site map	A map that clearly identifies the location of the proposed project site in relationship to the waterway and surrounding roadways	<input type="checkbox"/> Accepted <input type="checkbox"/> Item Not Clear
<input checked="" type="checkbox"/>	pg 12 disturbed area drawing	An aerial plan view that illustrates disturbed area of the project site	<input type="checkbox"/> Accepted <input type="checkbox"/> Item Not Clear
<input checked="" type="checkbox"/>	pg 19-30: plan sheets	A plan view that illustrates the proposed project's construction components. Indicate permanent and temporary components throughout the project site	<input type="checkbox"/> Accepted <input type="checkbox"/> Item Not Clear
<input checked="" type="checkbox"/>	pg 112: cross section view of Baker Ditch floodplain	A cross section view(s) showing an overlay comparison of the pre-construction and post-construction conditions of the effective cross sectional flow area at the most restrictive segment(s) of the encroachment. Typical cross sections should be extended perpendicularly to the limits of the project. Cross sections should be stationed left to right, looking downstream, and oriented perpendicular to flow. Additional cross sections <u>if requested in question # 4 in this worksheet</u> . <i>Note: Assumed elevations can be used for the cross section(s)</i>	<input type="checkbox"/> Accepted <input type="checkbox"/> Item Not Clear

Plan Details and Supporting Documentation continued

<input checked="" type="checkbox"/>	pg 111: cross section view	A plan view that clearly marks the location(s) and label of the cross section(s)	<input type="checkbox"/> Accepted <input type="checkbox"/> Item Not Clear
<input checked="" type="checkbox"/>	pg 13-18: photo orientation map and photo log	Photos that illustrate the natural and manmade surroundings, e.g.: 1) from the project site, a downstream view of the channel 2) from the project site, an upstream view of the channel 3) from a downstream streambank, a view of the project site 4) from an upstream streambank, a view of the project site Label orientation of each photo	<input type="checkbox"/> Accepted <input type="checkbox"/> Item Not Clear
<input checked="" type="checkbox"/>	pg 20-23: plan sheets	Plans require horizontal and vertical scale, north arrow, labels, stations, and date	<input type="checkbox"/> Accepted <input type="checkbox"/> Item Not Clear

Computation Requirements

2) Is all proposed construction work above top of bank?

☒ Yes. No further computations are needed to assess the loss to the cross sectional flow area. Skip questions #3 and #4. Proceed to question #5 and #6.

☐ No. Proceed to question #3.

3) Compute and record the post-construction and pre-construction cross sectional areas **at the most restrictive segment(s) of the project** by completing Columns 1 and 2 in this chart. Use a separate sheet to record multiple restrictive cross sections of the project.

Cross sectional area at the most restricted segment of the project	<u>Column 1</u> Area (square feet)	<u>Column 2</u> Indicate the Cross Section letter and plan sheet #
Pre-construction condition	_____ sq ft	
Post-construction condition	_____ sq ft	
If the post-construction area is equal to or greater than the pre-construction area, skip question #4 and proceed to questions #5 and #6.		

Computation Requirements continued

- 4) When the post-construction cross sectional area condition is smaller than the pre-construction cross section area condition, the restriction to the cross sectional area at the site could result in an increase to the upstream or downstream base flood elevation. To determine whether the proposed project will not have an adverse effect on the upstream or downstream base flood elevation, provide:
- An upstream and downstream typical cross section, and
 - Compute and record the upstream and downstream cross sectional areas in this chart. Use a separate sheet to record additional upstream and downstream cross sectional areas if there is more than one restrictive segment of the project.

Cross Section	<u>Column 1</u> Area (square feet)	<u>Column 2</u> Indicate the Cross Section letter and plan sheet #
Upstream of project	_____ sq ft	
Downstream of project	_____ sq ft	

If the post-construction cross sectional area at the most restrictive segment(s) of the project as computed in question #3 is smaller than the upstream and downstream cross sectional areas computed in question #4, the potential for a change to the base flood elevation could result; therefore, the No Change in Effective Cross Sectional Flow Area Non-Modeling Worksheet cannot be used to evaluate the project.

We suggest that you review the Change in Effective Cross Sectional Flow Area Non-Modeling Worksheet, State Form 55236, and Companion Worksheet A, State Form 55237, to determine if another non-modeling assessment approach can be utilized for this project to demonstrate that computer modeling is not required.

5) **Additional Justification/ Comments, if needed: (Use a separate sheet if needed)**

Flow of Baker Ditch crosses US 31 north of the project area and flows south and parallel to US 31 improvements and the roadway profile of the floodway. There will be no grade raise from the existing road grade. The base flood elevation is within 3.0-8.0 ft. of the roadway elevation, so the flow in this portion of the floodway is insignificant although the low lying ground on the northeast side of the existing/proposed roadway embankment would be flooded. The floodway of Baker Ditch is approximately 225 ft. wide, with this impact being on the fringe of the floodway, with no over the road conveyance capacity. The minor amount of fill added to the floodplain is less than the volume cut, creating a permanent impact of -53 cys of proposed fill in the Baker Ditch floodplain over 0.25 acres. Two critical cross-sectional areas of the Baker Ditch floodplain were evaluated. The upstream analysis of the existing floodplain shows its area to be 385 sq. ft. The total fill to the existing floodplain cross section will impact 3 sq. ft, and cut will impact 15 sq. ft. The total net floodplain impact of the fill in this upstream cross section will be less than 5%. The downstream cross-sectional analysis of the existing floodplain shows its area to be 479 sq. ft. The total fill to the existing floodplain cross section will impact 44.5 sq. ft. and the total cut will impact 27 sq. ft. The total net floodplain impact of the fill associated with the 236th intersection improvements of US 31 on the Baker Ditch floodplain will be less than 5%.

6) **Fish, Wildlife, and Botanical Impact Assessment**

If a delineated floodway exists at the project site, compute the disturbance values in the following charts. For sources of delineated floodways, refer to the Indiana Floodplain Information Portal at www.INFIP.dnr.in.gov or FEMA Map Service Center at <https://msc.fema.gov/>.

If a floodway delineation is not available at the project site, skip Question #6.

If the proposed construction exceeds the disturbance thresholds outlined in the Floodway Habitat Mitigation, a mitigation plan is likely to be required. During the permit application review process, a Division of Fish and Wildlife biologist will contact you if a mitigation plan is required. For information concerning mitigation requirements, refer to the Natural Resources Commission Bulletin # 17, <http://www.in.gov/legislative/iac/20120801-IR-312120434NRA.xml.pdf>.

Total number acres in floodway disturbed by project construction = 0.26 acres

Riparian habitat disturbance computation:

Type of Riparian Habitat	Number acres in floodway disturbed by project construction
A) Non wetland tree removal in rural area	0.70
B) Non wetland tree removal in urban area	0
C) Early successional habitat	0
Total A, B, & C	0.70

In-stream disturbance computation:

Total number of linear feet of in-stream disturbed by project construction = 0 linear feet

Wetlands disturbance computation:

Type of Riparian Habitat	Number acres in floodway disturbed by project construction
A) Palustrine Forested wetlands	0.042
B) Palustrine Scrub-shrub wetlands	0
C) Palustrine Emergent wetlands	0.012
Total A, B, & C	0.054

Be aware that after reviewing the submitted plans and computations in the worksheet, the IDNR staff may request additional documentation if sufficient evidence has not been provided that clearly demonstrates the effect that the project may have on the base flood elevation or impacts to fish, wildlife, and botanical resources in the floodway.

Claudia McAllister-Peterson

Name of Preparer


3/25/2020


Date (month, day, year)

BAKER DITCH FLOODPLAIN CROSS SECTIONAL ANALYSIS LOCATION LAYOUT

US 31 & 236th Interchange
Des. No. 1702149


scale: 1" = 100'





CROSS SECTIONAL ANALYSIS
 CROSS-SECTIONAL EXIST. FLOODPLAIN AREA = 385 SFT
 CROSS-SECTIONAL CUT = 15 SFT
 CROSS-SECTIONAL FILL = 3 SFT
 NET FLOODPLAIN IMPACT = -3.12%

FLOODWAY CROSS SECTION A



CROSS SECTIONAL ANALYSIS
 CROSS-SECTIONAL EXIST. FLOODPLAIN AREA = 479 SFT
 CROSS-SECTIONAL CUT = 27 SFT
 CROSS-SECTIONAL FILL = 44.5 SFT
 NET FLOODPLAIN IMPACT = 3.65%

FLOODWAY CROSS SECTION B

NOT FOR
 CONSTRUCTION

DESIGNED BY	DESIGN ENGINEER	DATE
06/06/2019	06/11/2019	
CHECKED BY	CHECKED BY	DATE
06/14/2019	06/14/2019	

INDIANA DEPARTMENT
 OF TRANSPORTATION
 US 31 AND 236TH ST
 INTERSECTION IMPROVEMENTS

SCALE	BRIDGE FILE
1"=30'	DESIGNATION
SURVEY BOOK	1707/18
ELECTRONIC	SHEETS
CONTRACT	d / j
	PROJECT
	1709-42-01

Attachment 1A-3

US 31 WWTP Design


Estimate Q100 elevation using Data Provided in IDNR Construction in a Floodway Assessment, dated 3/25/2020

a) Length between sections A and B:

Hamilton County GIS estimated length – 387 ft


Nancy's PDF estimated length between sections A and B – 400 ft

Google Earth (screenshot below) length – 382 ft




b) Length between discharge point and section A:


GIS measured length – 571.6 ft



Nancy's PDF length – 560+ ft (Does not show till that point but it should be higher than 560+ ft)



Google Earth pro length btw discharge location and section A – 546 ft



Used Google Earth lengths for calculations

Base flood elevation at Section A: 894.81' (Ref Nancy's file)

Base flood elevation at Section B: 892.76' (Ref Nancy's file)

Base flood changing (ft) per feet = $(894.81 - 892.76) / 382 = 0.005366$ ft/ft

Estimated base flood elevation at discharge point:

Assume x is the base flood elevation at the anticipated discharge point

$(x - 894.81) / 546 = 0.005366$

$x = 897.74$ ft **UPDATED HYDRAULICS TO USE THIS ELEVATION**

Previously estimated base flood elevation during hydraulics calculations was: 888 ft

Attachment 1A-4



NOTE:
1. CONTRACTOR TO FIELD VERIFY INVERT OF DITCH. ADJUSTMENT OF 16" EFFLUENT PIPE INVERT MAY BE REQUIRED AT DITCH CONNECTION.

SCALE VERIFICATION	DRAWN BY JL	NO.	DATE	INITIALS	REVISION DESCRIPTION
CHECKED BY KIMZ					
APPROVED BY RWH					
BAR CODE HOLDING ON ORIGINAL DRAWING					
ISSUED DATE NOVEMBER 2022					
PROJECT NUMBER 244721-04-001					
					
<div style="text-align: center;">  WESSLER ENGINEERING <i>More than a Project™</i> </div>					
US 31 CORRIDOR INFRASTRUCTURE INVESTMENT PROJECT					SHEET NO. 6C2
PHASE 1A AND 1B DIVISION 1 - WASTEWATER TREATMENT PLANT					PAGE NUMBER 48
UV DISINFECTION AND CASCADE AERATION STRUCTURE - SECTIONS					

SCALE VERIFICATION	DRAWN BY JL	NO.	DATE	INITIALS	REVISION DESCRIPTION
CHECKED BY ALT					
APPROVED BY KMW					
DATE NOVEMBER 2022					
PROJECT NUMBER 244721-04-001					

ROBERT W. KILBY
No. 10000096
Professional Engineer
State of Texas
11-000000

W
WESSLER
ENGINEERING
More than a Project™

US 31 CORRIDOR INFRASTRUCTURE INVESTMENT PROJECT





DIVISION 1 - WASTEWATER TREATMENT PLANT

PHASE 1A AND 1B

UV STORAGE BUILDING - PLAN, SECTION AND ELEVATIONS


SHEET NO.
10A1

PAGE NUMBER
74




SECTION
10A1

PLAN
10A1



Attachment 1C-1



HORIZONTAL AND VERTICAL CONTROL INFORMATION



1. A FIELD SURVEY WAS PERFORMED IN JUNE AND SEPTEMBER 2022).
2. COORDINATES (INDIANA STATE PLANE, EAST ZONE, NAD 83) AND ELEVATIONS (NAVD 88) ARE BASED ON INCORS.
3. UNITS ARE U.S. SURVEY FEET.
4. CONTROL POINTS WERE SET USING GPS.
5. A LEVEL LOOP WAS PERFORMED ON THE CONTROL, POINTS AND TBMAS.

BENCHMARK DESCRIPTION:

1. TBM NO. 9001 - 8-1/2" ROAD SPIKE SET IN WEST SIDE OF POWER POLE

CONTROL POINTS			ELEVATION			DESCRIPTION		
POINT	NORTHING	EASTING	POINT	NORTHING	EASTING	POINT	NORTHING	EASTING
CP1	177869.42	183111.48	CP15	177827.48	185651.77	CP29	177531.57	189227.41
CP2	177870.41	184300.12	CP16	177827.48	186870.30	CP30	177528.49	189825.53
CP3	177871.41	184630.24	CP17	177827.50	188282.54	CP31	177525.50	190444.67
CP4	177872.41	185036.04	CP18	177828.50	189789.26	CP32	177522.50	191063.81
CP5	177873.41	185402.77	CP19	177829.50	190789.43	CP33	177519.50	191682.95
CP6	177874.41	185789.04	CP20	177830.50	191897.14	CP34	177516.50	192302.09
CP7	177885.00	186357.51	CP21	177831.50	193004.82	CP35	177513.50	192921.23
CP8	177834.53	186911.88	CP22	177832.50	194096.57	CP36	177510.50	193540.37
CP9	177858.91	187509.75	CP23	177833.50	195188.31	CP37	177507.50	194159.51
CP10	177874.42	188655.51	CP24	177834.50	196280.01	CP38	177504.50	194778.65
CP11	177872.43	191205.95	CP25	177835.50	197371.76	CP39	177501.50	195397.79
CP12	177759.52	196421.00	CP26	177836.50	198463.46	CP40	177498.50	196016.93
CP13	177729.52	197515.77	CP27	177837.50	199555.19	CP41	177495.50	196636.07
CP14	177727.48	197975.37	CP28	177838.50	200646.92	CP42	177492.50	197255.21
CP15	177724.80	198500.23	CP29	177839.50	201738.66	CP43	177489.50	197874.35
CP16	177722.40	199025.21	CP30	177840.50	202830.41	CP44	177486.50	198493.49
CP17	177720.40	199550.20	CP31	177841.50	203922.15	CP45	177483.50	199112.63
CP18	177718.40	200075.19	CP32	177842.50	205013.90	CP46	177480.50	199731.77
CP19	177716.40	200600.18	CP33	177843.50	206105.64	CP47	177477.50	200350.91
CP20	177714.40	201130.43	CP34	177844.50	207197.39	CP48	177474.50	200970.05
CP21	177712.40	201660.68	CP35	177845.50	208289.14	CP49	177471.50	201589.19
CP22	177710.40	202190.93	CP36	177846.50	209380.88	CP50	177468.50	202208.33
CP23	177708.40	202721.18	CP37	177847.50	210472.63	CP51	177465.50	202827.47
CP24	177706.40	203251.43	CP38	177848.50	211564.38	CP52	177462.50	203446.61
CP25	177704.40	203781.68	CP39	177849.50	212656.13	CP53	177459.50	204065.75
CP26	177702.40	204311.93	CP40	177850.50	213747.88	CP54	177456.50	204684.89
CP27	177700.40	204842.18	CP41	177851.50	214839.63	CP55	177453.50	205304.03
CP28	177698.40	205372.43	CP42	177852.50	215931.38	CP56	177450.50	205923.17
CP29	177696.40	205902.68	CP43	177853.50	217023.13	CP57	177447.50	206542.31
CP30	177694.40	206432.93	CP44	177854.50	218114.88	CP58	177444.50	207161.45
CP31	177692.40	206963.18	CP45	177855.50	219206.63	CP59	177441.50	207780.59
CP32	177690.40	207493.43	CP46	177856.50	220298.38	CP60	177438.50	208399.73
CP33	177688.40	208023.68	CP47	177857.50	221390.13	CP61	177435.50	209018.87
CP34	177686.40	208553.93	CP48	177858.50	222481.88	CP62	177432.50	209638.01
CP35	177684.40	209084.18	CP49	177859.50	223573.63	CP63	177429.50	210257.15
CP36	177682.40	209614.43	CP50	177860.50	224665.38	CP64	177426.50	210876.29
CP37	177680.40	210144.68	CP51	177861.50	225757.13	CP65	177423.50	211495.43
CP38	177678.40	210674.93	CP52	177862.50	226848.88	CP66	177420.50	212114.57
CP39	177676.40	211205.18	CP53	177863.50	227940.63	CP67	177417.50	212733.71
CP40	177674.40	211735.43	CP54	177864.50	229032.38	CP68	177414.50	213352.85
CP41	177672.40	212265.68	CP55	177865.50	230124.13	CP69	177411.50	213971.99
CP42	177670.40	212795.93	CP56	177866.50	231215.88	CP70	177408.50	214591.13
CP43	177668.40	213326.18	CP57	177867.50	232307.63	CP71	177405.50	215210.27
CP44	177666.40	213856.43	CP58	177868.50	233399.38	CP72	177402.50	215829.41
CP45	177664.40	214386.68	CP59	177869.50	234491.13	CP73	177399.50	216448.55
CP46	177662.40	214916.93	CP60	177870.50	235582.88	CP74	177396.50	217067.69
CP47	177660.40	215447.18	CP61	177871.50	236674.63	CP75	177393.50	217686.83
CP48	177658.40	215977.43	CP62	177872.50	237766.38	CP76	177390.50	218305.97
CP49	177656.40	216507.68	CP63	177873.50	238858.13	CP77	177387.50	218925.11
CP50	177654.40	217037.93	CP64	177874.50	239949.88	CP78	177384.50	219544.25
CP51	177652.40	217568.18	CP65	177875.50	241041.63	CP79	177381.50	220163.39
CP52	177650.40	218098.43	CP66	177876.50	242133.38	CP80	177378.50	220782.53
CP53	177648.40	218628.68	CP67	177877.50	243225.13	CP81	177375.50	221401.67
CP54	177646.40	219158.93	CP68	177878.50	244316.88	CP82	177372.50	222020.81
CP55	177644.40	219689.18	CP69	177879.50	245408.63	CP83	177369.50	222639.95
CP56	177642.40	220219.43	CP70	177880.50	246500.38	CP84	177366.50	223259.09
CP57	177640.40	220749.68	CP71	177881.50	247592.13	CP85	177363.50	223878.23
CP58	177638.40	221279.93	CP72	177882.50	248683.88	CP86	177360.50	224497.37
CP59	177636.40	221810.18	CP73	177883.50	249775.63	CP87	177357.50	225116.51
CP60	177634.40	222340.43	CP74	177884.50	250867.38	CP88	177354.50	225735.65
CP61	177632.40	222870.68	CP75	177885.50	251959.13	CP89	177351.50	226354.79
CP62	177630.40	223400.93	CP76	177886.50	253050.88	CP90	177348.50	226973.93
CP63	177628.40	223931.18	CP77	177887.50	254142.63	CP91	177345.50	227593.07
CP64	177626.40	224461.43	CP78	177888.50	255234.38	CP92	177342.50	228212.21
CP65	177624.40	224991.68	CP79	177889.50	256326.13	CP93	177339.50	228831.35
CP66	177622.40	225521.93	CP80	177890.50	257417.88	CP94	177336.50	229450.49
CP67	177620.40	226052.18	CP81	177891.50	258509.63	CP95	177333.50	230069.63
CP68	177618.40	226582.43	CP82	177892.50	259601.38	CP96	177330.50	230688.77
CP69	177616.40	227112.68	CP83	177893.50	260693.13	CP97	177327.50	231307.91
CP70	177614.40	227642.93	CP84	177894.50	261784.88	CP98	177324.50	231927.05
CP71	177612.40	228173.18	CP85	177895.50	262876.63	CP99	177321.50	232546.19
CP72	177610.40	228703.43	CP86	177896.50	263968.38	CP100	177318.50	233165.33
CP73	177608.40	229233.68	CP87	177897.50	265060.13			
CP74	177606.40	229763.93	CP88	177898.50	266151.88			
CP75	177604.40	230294.18	CP89	177899.50	267243.63			
CP76	177602.40	230824.43	CP90	177900.50	268335.38			
CP77	177600.40	231354.68	CP91	177901.50	269427.13			
CP78	177598.40	231884.93	CP92	177902.50	270518.88			
CP79	177596.40	232415.18	CP93	177903.50	271610.63			
CP80	177594.40	232945.43	CP94	177904.50	272702.38			
CP81	177592.40	233475.68	CP95	177905.50	273794.13			
CP82	177590.40	234005.93	CP96	177906.50	274885.88			
CP83	177588.40	234536.18	CP97	177907.50	275977.63			
CP84	177586.40	235066.43	CP98	177908.50	277069.38			
CP85	177584.40	235596.68	CP99	177909.50	278161.13			
CP86	177582.40	236126.93	CP100	177910.50	279252.88			
CP87	177580.40	236657.18						
CP88	177578.40	237187.43						
CP89	177576.40	237717.68						
CP90	177574.40	238247.93						
CP91	177572.40	238778.18						
CP92	177570.40	239308.43						
CP93	177568.40	239838.68						
CP94	177566.40	240368.93						
CP95	177564.40	240899.18						
CP96	177562.40	241429.43						
CP97	177560.40	241959.68						
CP98	177558.40	242489.93						
CP99	177556.40	243020.18						
CP100	177554.40	243550.43						

LOCATION AND SCOPE OF WORK PLAN




SCALE VERIFICATION		NO.		DATE		REVISION DESCRIPTIONS	
DESIGNED BY	JRW						
CHECKED BY	TPH						
APPROVED BY	DCU						
ISSUE DATE							
NOVEMBER 2022							
PROJECT NUMBER							
244721-04-001							



WESSLER
ENGINEERING
More than a Project™

**331 CORRIDOR INFRASTRUCTURE INVESTMENT PROJECT PHASE 1A AND 1B
DIVISION 2 - WATER AND SEWER
HAMILTON COUNTY, INDIANA**

SHEET NO.
1G4
PAGE NO.



SCALE: 1" = 20'

W
WESSLER
ENGINEERING
More than a Project™

US 31 CORRIDOR INFRASTRUCTURE INVESTMENT PROJECT PHASE 1A AND 1B

DIVISION 2 - WATER AND SEWER

HAMILTON COUNTY, INDIANA

NEW LIFT STATION NO. 1 - SITE PLAN

US 31 CORRIDOR INFRASTRUCTURE INVESTMENT PROJECT PHASE 1A AND 1B

HAMILTON COUNTY, INDIANA

NEW LIFT STATION NO. 1 - SITE PLAN

SHEET NO.

3Y1

PAGE NO.

**90% DESIGN DRAWINGS
NOT FOR CONSTRUCTION**

1/16/2023










3Y1


PAGE NO.

KEYED NOTES

- D ASPHALT DRIVE REPAIR
- D ASPHALT COMMERCIAL DRIVE REPAIR
- D ASPHALT DRIVE REPAIR
- D CRACKED DRIVE SURFACE REPAIR
- X POTENTIAL UTILITY CONFLICT FIELD VERIFICATION FOR CONSTRUCTION
- S NEW SERVICE METER AND METER PIT
- P BORE/RECEIVING PIT
- F2 TEMPORARY SALT PENCE OR FILTER TUBE
- I INLET PROTECTION
- T REMOVE EXISTING TREE

LEGEND

	ASPHALT ROAD REPAIR
	NEW ASPHALT DRIVE
	CONCRETE DRIVE REPAIR
	CRUSHED STONE DRIVE REPAIR
	INLET PROTECTION
	CONCRETE WASHOUT
	EROSION CONTROL BLANKET
	TEMPORARY SILT FENCE
	FILTER TUBE



ITEM NO.	DESCRIPTION	UNIT
1	BASE GRAVEL 150MM	CU M
2	BASE GRAVEL 150MM	CU M
3	BASE GRAVEL 150MM	CU M
4	BASE GRAVEL 150MM	CU M
5	BASE GRAVEL 150MM	CU M
6	BASE GRAVEL 150MM	CU M
7	BASE GRAVEL 150MM	CU M
8	BASE GRAVEL 150MM	CU M
9	BASE GRAVEL 150MM	CU M
10	BASE GRAVEL 150MM	CU M
11	BASE GRAVEL 150MM	CU M
12	BASE GRAVEL 150MM	CU M
13	BASE GRAVEL 150MM	CU M
14	BASE GRAVEL 150MM	CU M
15	BASE GRAVEL 150MM	CU M
16	BASE GRAVEL 150MM	CU M
17	BASE GRAVEL 150MM	CU M
18	BASE GRAVEL 150MM	CU M
19	BASE GRAVEL 150MM	CU M
20	BASE GRAVEL 150MM	CU M
21	BASE GRAVEL 150MM	CU M
22	BASE GRAVEL 150MM	CU M
23	BASE GRAVEL 150MM	CU M
24	BASE GRAVEL 150MM	CU M
25	BASE GRAVEL 150MM	CU M
26	BASE GRAVEL 150MM	CU M
27	BASE GRAVEL 150MM	CU M
28	BASE GRAVEL 150MM	CU M
29	BASE GRAVEL 150MM	CU M
30	BASE GRAVEL 150MM	CU M
31	BASE GRAVEL 150MM	CU M
32	BASE GRAVEL 150MM	CU M
33	BASE GRAVEL 150MM	CU M
34	BASE GRAVEL 150MM	CU M
35	BASE GRAVEL 150MM	CU M
36	BASE GRAVEL 150MM	CU M
37	BASE GRAVEL 150MM	CU M
38	BASE GRAVEL 150MM	CU M
39	BASE GRAVEL 150MM	CU M
40	BASE GRAVEL 150MM	CU M
41	BASE GRAVEL 150MM	CU M
42	BASE GRAVEL 150MM	CU M
43	BASE GRAVEL 150MM	CU M
44	BASE GRAVEL 150MM	CU M
45	BASE GRAVEL 150MM	CU M
46	BASE GRAVEL 150MM	CU M
47	BASE GRAVEL 150MM	CU M
48	BASE GRAVEL 150MM	CU M
49	BASE GRAVEL 150MM	CU M
50	BASE GRAVEL 150MM	CU M
51	BASE GRAVEL 150MM	CU M
52	BASE GRAVEL 150MM	CU M
53	BASE GRAVEL 150MM	CU M
54	BASE GRAVEL 150MM	CU M
55	BASE GRAVEL 150MM	CU M
56	BASE GRAVEL 150MM	CU M
57	BASE GRAVEL 150MM	CU M
58	BASE GRAVEL 150MM	CU M
59	BASE GRAVEL 150MM	CU M
60	BASE GRAVEL 150MM	CU M
61	BASE GRAVEL 150MM	CU M
62	BASE GRAVEL 150MM	CU M
63	BASE GRAVEL 150MM	CU M
64	BASE GRAVEL 150MM	CU M
65	BASE GRAVEL 150MM	CU M
66	BASE GRAVEL 150MM	CU M
67	BASE GRAVEL 150MM	CU M
68	BASE GRAVEL 150MM	CU M
69	BASE GRAVEL 150MM	CU M
70	BASE GRAVEL 150MM	CU M
71	BASE GRAVEL 150MM	CU M
72	BASE GRAVEL 150MM	CU M
73	BASE GRAVEL 150MM	CU M
74	BASE GRAVEL 150MM	CU M
75	BASE GRAVEL 150MM	CU M
76	BASE GRAVEL 150MM	CU M
77	BASE GRAVEL 150MM	CU M
78	BASE GRAVEL 150MM	CU M
79	BASE GRAVEL 150MM	CU M
80	BASE GRAVEL 150MM	CU M
81	BASE GRAVEL 150MM	CU M
82	BASE GRAVEL 150MM	CU M
83	BASE GRAVEL 150MM	CU M
84	BASE GRAVEL 150MM	CU M
85	BASE GRAVEL 150MM	CU M
86	BASE GRAVEL 150MM	CU M
87	BASE GRAVEL 150MM	CU M
88	BASE GRAVEL 150MM	CU M
89	BASE GRAVEL 150MM	CU M
90	BASE GRAVEL 150MM	CU M
91	BASE GRAVEL 150MM	CU M
92	BASE GRAVEL 150MM	CU M
93	BASE GRAVEL 150MM	CU M
94	BASE GRAVEL 150MM	CU M
95	BASE GRAVEL 150MM	CU M
96	BASE GRAVEL 150MM	CU M
97	BASE GRAVEL 150MM	CU M
98	BASE GRAVEL 150MM	CU M
99	BASE GRAVEL 150MM	CU M
100	BASE GRAVEL 150MM	CU M

[illegible]

DATA SHEET
SUBMERSIBLE NON-CLOG CENTRIFUGAL PUMPS

A. Lift Station 1

1. TITLE: Pumps No. 1 & 2
2. LOCATION: 236th Street, Sheridan, IN 46069.
3. QUANTITY: Two (2)
4. OPERATING CONDITIONS: The pumps shall operate within the entire pumping range specified without cavitation and exceeding the vibration limits established by the Hydraulic Institute.
 - a. Material to be Pumped: Unscreened Raw Sewage within temperature range of 32° - 100°F.
 - b. Pump Curve

<u>Condition</u>	<u>Discharge Rate</u>	<u>TDH</u>	<u>Pump Speed</u>	<u>Pump Efficiency</u>
1 st Curve Point	200 gpm	84'	60 Hz	36%
Design Point	550 gpm	61'	60 Hz	70%
3 rd Curve Point	900 gpm	43'	60 Hz	56%

5. SPECIFICATIONS:

- a. Type: Submersible
 - b. Minimum Sphere Diameter: 3"
 - c. Pump Speed: 1,755 rpm
 - d. Discharge Connection: 4"
 - e. Impeller: Stainless steel
 - f. Motor Data:
 - 1) Horsepower: 15
 - 2) Speed: 1,755 rpm
 - 3) Voltage: 460
 - 4) Phase: 3
 - 5) Hertz: 60
 - 6) Service Factor: 1.15
 - 7) Inverter-Duty Rated
 - g. Classification: Pumps shall meet Class I, Division I, Groups C & D requirements
6. MANUFACTURERS: Flygt, Model NP 3153 HT 3~ 456 (229mm Impeller)

B. Lift Station 2

1. TITLE: Pumps No. 1 & 2
2. LOCATION: Englewood Road, Jackson Township, IN 46034.
3. QUANTITY: Two (2)

4. OPERATING CONDITIONS: The pumps shall operate within the entire pumping range specified without cavitation and exceeding the vibration limits established by the Hydraulic Institute.

a. Material to be Pumped: Unscreened Raw Sewage within temperature range of 32° - 100°F.

b. Pump Curve

<u>Condition</u>	<u>Discharge Rate</u>	<u>TDH</u>	<u>Pump Speed</u>	<u>Pump Efficiency</u>
1 st Curve Point	100 gpm	72'	60 Hz	36%
Design Point	280 gpm	48'	60 Hz	63%
3 rd Curve Point	500 gpm	46'	60 Hz	69%

5. SPECIFICATIONS:

a. Type: Submersible

b. Minimum Sphere Diameter: 3"

c. Pump Speed: 1,745 rpm

d. Discharge Connection: 4"

e. Impeller: Stainless steel

f. Motor Data:

1) Horsepower: 10

2) Speed: 1,745 rpm

3) Voltage: 460

4) Phase: 3

5) Hertz: 60

6) Service Factor: 1.15

7) Inverter-Duty Rated

g. Classification: Pumps shall meet Class I, Division I, Groups C & D requirements

6. MANUFACTURERS: Flygt, Model NP 3127 HT 3~ Adaptive 488 (195 mm Impeller)

-END-

Question 2 Attachments

Attachment 2-1

Air Demand Calculations - DESIGN AVERAGE DAY

Project Name: US31 Hamilton County WWTP
Date: 10/13/2022
Updated: 1/24/2023

Design Influent Characteristics

Total Design Average Flow:		0.500	MGD
Avg. Day Loadings:			
cBOD5:	200	mg/L	834
TSS:	200	mg/L	834
NH3-N:	25	mg/L	104
TKN:	38	mg/L	158
tot-P:	6	mg/L	25

SOTR Constants:

Alpha:	0.65
Beta:	0.98
C _r :	10.07
C:	2
Csat,20:	9.08
Theta:	1.024
T:	15

Typical values range from 0.4 to 0.8 for diffused aeration (ME, 4th Ed, Section 5-11, p 429),
DO saturation concentration at T @760 mm of Hg (ME, 4th Ed., pg.1747)
Operating DO in aeration basin, Ten State Standard
DO saturation concentration at 20 C @760 mm of Hg (ME, 4th Ed., pg.1747)

Water temperature at site, deg C

Fine Bubble Diffusers

SOTE: 2.25% %/ft
Aeration Tank Depth: 15.00 ft

SOTE from 10/23/22 email (use lower SOTE to be conservative) Ditch 1 34.90%
Ditch 2 33.70%
Source: Email from Rick Kochera to Kate Zlino, 10/23/22 (Typ. 2%/ft is used for fine bubble)
Source: Diffuser Submergence as per Bioloop's proposal (depth to diffusers, not to tank invert)

Conversion Factors

Density of air, lb/ft³ 0.075
Weight % of O₂ in air 0.232

Aeration Basins

O₂ Requirements

Average:

	lbs substrate/day	lb O ₂ required/ lb substrate	lbs O ₂ /day	lbs O ₂ /hr	lbs O ₂ /min
BOD Removal:	834	1.1	917	38	0.6
NH3-N Removal:	104	4.57	476	20	0.3
Actual Oxygen Requirement:			1,394	58	1.0
Standard Oxygen Requirement:			2,763	115	1.9
SOR = AOR / ((Beta x (C _r - C)) / Csat,20) x theta ^(1 - 20/T) x alpha					

Air Flow Required:

Average Loading Fine Bubble
Loading = SOR / (SOTE x Depth x Air Density x Weight % O₂)
SCFD 471,267 SCFH 19,636 SCFM 327 2 Blowers: 164 scfm, each

Diffuser Check:

Diffuser capacity: 4 scfm/diffuser per Sanitaire
150 diffusers (75 per Oxidation Ditch)
2.18 scfm/diffuser OKAY

Air Demand Calculations - NEAR-TERM AVERAGE DAY

Project Name: US31 Hamilton County WWTP

Date: 10/13/2022

Updated: 1/24/2023

Near-Term Influent Characteristics

Total Design Average Flow:		0.080	MGD
Avg. Day Loadings:			
cBOD5:	200	mg/L	133
TSS:	200	mg/L	133
NH3-N:	25	mg/L	17
TKN:	38	mg/L	25
tot-P:	6	mg/L	4
		Effluent Limits:	
cBOD5:	10	mg/L	7
TSS:	10	mg/L	7
NH3-N:	1	mg/L	1
TKN:	NA	mg/L	NA
tot-P:	1	mg/L	1

SOTR Constants:

Alpha:	0.65
Beta:	0.98
C _r :	10.07
C:	2
Csat,20:	9.08
Theta:	1.024
T:	15

Typical values range from 0.4 to 0.8 for diffused aeration (ME, 4th Ed, Section 5-11, p 429,

DO saturation concentration at T @760 mm of Hg (ME, 4th Ed., pg.1747)

Operating DO in aeration basin, Ten State Standard

DO saturation concentration at 20 C @760 mm of Hg (ME, 4th Ed., pg.1747)

Water temperature at site, deg C

SOTE from 10/23/22 email (use lower SOTE to be conservative)

Ditch 1	34.90%
Ditch 2	33.70%

Fine Bubble Diffusers
SOTE: 2.25% %/ft
Aeration Tank Depth: 15.00 ft

Source: Email from Rick Kochera to Kate Ziino, 10/23/22 (Typ. 2%/ft is used for fine bubble)
Source: Diffuser Submergence as per Bioloop's proposal (depth to diffusers, not to tank invert)

Conversion Factors

Density of air, lb/ft³ 0.075
Weight % of O₂ in air 0.232

Aeration Basins

O₂ Requirements

Average:

	lbs substrate/day	lb O ₂ required/ substrate	lbs O ₂ /day	lbs O ₂ /hr	lbs O ₂ /min
BOD Removal:	133	1.1	147	6	0.1
NH3-N Removal:	17	4.57	76	3	0.1
Actual Oxygen Required:			223		0.2
Standard Oxygen Requirement:			444	18	0.3
SOR= AOR/((Beta x (C _r -C))/Csat,20) x theta ^(T-20) x alpha)					

Air Flow Required:

Average Loading	Fine Bubble	SCFD	SCFH	SCFM	1 Blower, see Blower Capacity Chart
Loading = SOR/(SOTE x Depth x Air Density x Weight % O ₂)		75.635	3.151	53	
Diffuser Check:	Diffuser capacity:	4 scfm/diffuser per Sanitaire			Only 1 ditch in operation 75 diffusers (75 per Oxidation Ditch) 0.70 scfm/diffuser OKAY

Air Demand Calculations - NEAR-TERM AVERAGE DAY

Project Name: US31 Hamilton County WWTP
Date: 10/13/2022
Updated: 1/24/2023

Near-Term Influent Characteristics

Total Design Average Flow: 0.080 MGD					
Avg. Day Loadings:					
CBOD ₅ :	200 mg/L	133	lbs/day	Effluent Limits:	CBOD ₅ : 10 mg/L
TSS:	200 mg/L	133	lbs/day		TSS: 10 mg/L
NH ₃ -N:	25 mg/L	17	lbs/day		NH ₃ -N: 1 mg/L
TKN:	38 mg/L	25	lbs/day		TKN: NA mg/L
tot-P:	6 mg/L	4	lbs/day		tot-P: 1 mg/L

SOTR Constants:

Alpha:	0.65	Typical values range from 0.4 to 0.8 for diffused aeration (ME, 4th Ed, Section 5-11, p 429), DO saturation concentration at T @760 mm of Hg (ME, 4th Ed., pg.1747) Operating DO in aeration basin, Ten State Standard DO saturation concentration at 20 C @760 mm of Hg (ME, 4th Ed., pg.1747)
Beta:	0.98	
C _T :	10.07	
C:	2	
Csat,20:	9.08	
Theta:	1.024	Water temperature at site, deg C
T:	15	

Fine Bubble Diffusers

SOTE: 2.25% %/ft
Aeration Tank Depth: 15.00 ft

SOTE from 10/23/22 email (use lower SOTE to be conservative) Ditch 1 34.90%
Ditch 2 33.70%
Source: Email from Rick Kochera to Kate Ziino, 10/23/22 (Typ. 2%/ft is used for fine bubble)
Source: Diffuser Submergence as per Bioloop's proposal (depth to diffusers, not to tank invert)

Conversion Factors

Density of air, lb/ft³ 0.075
Weight % of O₂ in air 0.232

Aeration Basins

O₂ Requirements

Average:

	lbs substrate/day	lb O ₂ required/ lb substrate	lbs O ₂ /day	lbs O ₂ /hr	lbs O ₂ /min
BOD Removal:	133	1.5	200	8	0.1
NH ₃ -N Removal:	17	4.57	76	3	0.1
Actual Oxygen Requirement:			276		0.2
Standard Oxygen Requirement:			550	23	0.4

$$SOR = AOR / ((\text{Beta} \times (C_T - C)) / C_{sat,20}) \times \text{theta}^{(T-20)} \times \text{alpha}$$

Air Flow Required:

Average Loading Fine Bubble
Loading = SOR/(SOTE x Depth x Air Density x Weight % O₂)

Diffuser Check:

Diffuser capacity:


4 scfm/diffuser per Sanitaire

Only 1 ditch in operation

75 diffusers (75 per Oxidation Ditch)

0.87 scfm/diffuser OKAY

Blower Capacity



Attachment 2-2

Bioloop Calculations Design Flow (0.5 MGD)

Bioloop® Design Proposal - SNDN Process

Bakers Corner, IN Sanitaire #od31015-21

INFLUENT WASTEWATER CHARACTERISTICS AND SITE CONDITIONS

Number of Parallel Biological Trains

1

	Per Biological Train	Total all Bio. trains
Average Annual Flow	0.50 MGD	0.50 MGD
Maximum Month Influent Flow	0.50 MGD	0.50 MGD
Peak Hourly Flow	2.25 MGD	2.25 MGD
BOD ₅ (20°C)	200 mg/l	
BOD ₅ (20°C)	834 lb/d	
Suspended Solids	200 mg/l	
TKN	38 mg/l	
Total Phosphorus	6 mg/l	
Max Wastewater Temperature	20 °C	
Min Wastewater Temperature	10 °C	
Ambient Air Temperature	20 - 90 °F	
Site Elevation	910 ft	

Bioloop® SNDN PROCESS EFFLUENT QUALITY (MONTHLY AVERAGE)

BOD ₅ (20°C)	10 mg/l
Suspended Solids	10 mg/l
NH ₃ -N	1 mg/l
Total Phosphorus*	1 mg/l

*Requires chemical precipitation

Bioloop® SNDN PROCESS DESIGN CRITERIA

F / M	0.083 lb BOD ₅ / lb MLSS / day
SVI (after 30 minutes settling)	150 ml/g
Biological Mixed Liquor Suspended Solids (MLSS) conc.	2,900 mg/l
Waste Sludge Produced (Approx.)	780 lb/d
Volume of Sludge Produced (Approx. 0.58% solids)	16,128 gpd
Aerated Hydraulic Retention Time	19.93 Hrs
Sludge Age	12.9 Days
Sufficient Alkalinity must be provided to maintain basin pH of 6.8	
Chemical dosage (as Alum)	37 mg/l
RAS Pumping Rate	100% of Maximum Month Flow

0.111 lb BOD₅/lb MLVSS/day
(assume 75% VS)

Bioloop® SNDN PROCESS BASIN DESIGN DETAILS (PER TRAIN)

Oxidation Ditches operated in Series

	Ditch 1	Ditch 2
Basin Quantity	1	1
Volume/Basin (MG)	0.208	0.208
Basin Length (ft) - *	60.0	60.0
Basin Width (ft)	11.0	11.0
Basin Depth (ft)	16.0	16.0

* - For oxidation ditches, basin length above is straight section length for Side by Side Ditch Type (see ref. drawing)

Bioloop® SNDN PROCESS EQUIPMENT

Oxidation Ditches operated in Series

	Ditch 1	Ditch 2
Mixer Motor Hp	6.2	6.2
Fine Bubble Diffuser Quantity / Basin / Train	75	75
Biological blower (scfm/basin/train)	123	159

Biological Blowers (PD type) 2 Duty + 1 Standby with 10 Hp Motor

OSCAR Control Panel

Instruments and Valves in Basins			Quantity
Location	Ditch 1	Ditch 2	
ORP probe	Yes		1
DO probe	Yes	Yes	2
Air modulating valve	1@4 inch	1@4 inch	2
Airflow meter	1@4 inch	1@4 inch	2
Other Instruments and Valves			
Location	Size		
Air pressure transmitter	Bio Blower Discharge		1

Bioloop® SNDN AERATION/MIXING POWER REQUIREMENTS (TOTAL FOR ALL TRAINS)

	<u>Oxidation Ditches operated in Series</u>		kW-hr/d
	Ditch 1	Ditch 2	
Basin Quantity	1	1	
Bio Blowers Operating Power	2	at 8.8 Hp	315

Total kW-hr/d 315

Bioloop® Detailed Design Calculations
SNDN Process

Project Name: *Bakers Corner, IN*
Project Number: *od31015-21*

Designer: *Designer*
Date: *10/17/2022*

Design Parameters

Number of Parallel Process Trains 1

Flow

	Per process train	Total for all trains
Average Annual Flow	0.50 MGD	0.50 MGD
Maximum Month Flow	0.50 MGD	0.50 MGD
Peak Hourly Flow	2.25 MGD	2.25 MGD

Treatment

	Units	Influent Quality	Effluent Requirement
BOD ₅ (20°C)	mg/l	200	10
Suspended Solids	mg/l	200	10
TKN	mg/l	38	N/A
NH ₃ -N	mg/l	N/A	1.0
Phosphorus	mg/l	6.0	1.0

Environment

Sufficient Alkalinity must be provided to maintain basin pH of 6.8

Max. Wastewater Temperature	20	°C
Min. Wastewater Temperature	10	°C
Ambient Air Temperature	20 - 90	°F
Site Elevation	910	ft

Bioloop® Design Parameters

F / M	0.08	lb BOD ₅ / lb MLSS / day
Aerated HRT	19.93	hrs
SVI (after 30 minutes settling)	150	ml/g
Number of Aerated Reactors in Series	2	
Water Depth	16.0	ft
RAS Pumping Rate	100%	of Maximum Month Flow

Bioloop® Detailed Design Calculations
SNDN Process

Project Name: **Bakers Corner, IN**Designer: **Designer**Project Number: **od31015-21**Date: **10/17/2022****Process Calculations****Nitrification Kinetics**

Refer to Metcalf and Eddy, Edition IV pages 614 and 705

Constants and Temperature Corrections:

Coefficient	Base Value	Theta	Temperature Corrected	Symbol
Maximum Specific Growth Rate of Nitrifying bacteria, g/ VSS/g VSS•day	0.75	1.07	0.38126	$\mu_{nm}(T)$
Half-Velocity constant for nitrifiers	0.74	1.053	0.44152	$K_n(T)$
Nitrifier decay rate	0.08	1.04	0.05405	$K_{dn}(T)$
Dissolved Oxygen in final reactor	2.00		2.00	DO
Half-Velocity Constant for Dissolved Oxygen, mg/l	0.5		0.5	K_o
Minimum Water Temperature, °C	10		10	T
Safety Factor	2.0		2.0	SF

Calculations

$$\mu_n = \left(\mu_{nm}(T) \times \frac{TENH_3}{TENH_3 + K_n(T)} \times \frac{DO}{DO + K_o} \right) - K_{dn}(T)$$

$$\mu_n = \left(0.381 \times \frac{1.0}{1.0 + 0.44} \times \frac{2}{2.0 + 0.5} \right) - 0.054 = 0.16 \text{ days}^{-1}$$

$$SRT_{min} = \frac{1}{\mu_n} = \frac{1}{0.16} = 6.3 \text{ days}^{-1}$$

$$SRT_{aerobic} = SRT_{min} \times SF = 6.3 \times 2.0 = \mathbf{12.9 \text{ days}}$$

Where: $\mu_{nm}(T)$ = Maximum Temperature Corrected Nitrifier Growth Rate (days^{-1}) μ_n = Specific Nitrifier Growth rate at Temperature, DO, and Effluent NH_3 (days^{-1})

SRTmin = Minimum Sludge age required for Nitrification (days)

SRTaerobic = Design Aerobic Sludge Age (days)

SF = Safety Factor

TENH3 = Anticipated Effluent Ammonia (mg/l)

Bioloop® Detailed Design Calculations
SNDN Process

Project Name: **Bakers Corner, IN**Designer: **Designer**Project Number: **od31015-21**Date: **10/17/2022****Sludge Yield**

Refer to WEF MOP/8 4th Edition, pg 11-11, Eqn 11.7

$$\Delta M = \left(\frac{Y \times (\text{BOD}_{\text{in}} - \text{BOD}_{\text{out}})}{1 + (B \times \theta^{(T-20)}) \times \text{SRT}} + \text{Z}_{\text{io}} + \text{Z}_{\text{no}} \right) \times Q \times 8.34 + \text{CS}$$

$$\Delta M = \left(\left(\frac{0.6 \times (200 - 10)}{1 + (0.07 \times 1.04^{(10-20)}) \times 12.9\text{d}} + 40.0 + 60.0 \right) \times 0.50 \times 8.34 \right) + 68 = 780 \text{ lb/day}$$

where: ΔM = Mass of Sludge Produced (lb/day)

Y = Volatile Cell Yield (VSS/BOD Removed)

 θ = Arrhenius Temperature Correction FactorB = Decay Rate (day^{-1})BOD_{out} = Anticipated Effluent BOD (mg/l)

SRT = Solids Retention Time (days)

Z_{io} = Influent Nonvolatile Suspended Solids (mg/l)Z_{no} = Influent Volatile Nonbiodegradable Solids (mg/l)

Q = Maximum month flow, MGD

T = Minimum Wastewater Temperature ($^{\circ}\text{C}$)

CS = Chemical Sludge from Phosphorus Precipitation with Alum (lb/day)

(see chemical sludge production calculations below)

$$\text{BODL} = \frac{Q \times \text{BOD} \times 8.34}{1,000,000} = \frac{0.500 \times 200 \times 8.34}{1,000,000} = 834 \text{ lb/day}$$

where: Q = Max month flow, MGD

BOD = BOD concentration, mg/l

$$\text{Sludge Yield, } Y_s = \Delta M / \text{BOBL} = 780 / 834 = 0.94$$

Chemical Dosing

Initial estimate of phosphorus in WAS, based on assumed % of MLVSS as P

$$\text{Pw} = (\text{BOD}_{\text{in}} - \text{BOD}_{\text{out}}) \times Y_s \times \text{MLVSS} \times \text{Psa} = (200 - 10) \times 0.94 \times 0.70 \times 0.020 = 2.5 \text{ mg/l}$$

Where: Pw = Phosphorus removed with WAS, mg/l as P

BOD_{in} = Influent BOD, mg/lBOD_{out} = Anticipated Effluent BOD (mg/l)

MLVSS = Mixed Liquor Volatile Suspended Solids Concentration

Psa = Assumed % of MLVSS as P

Based on Assumed % of MLSS, estimate phosphorus concentration to be removed with metal salt

$$\text{Pmb} = \text{Tpi} - \text{Pw} - \text{Pe} = 6.00 - 2.50 - 1.00 = 2.51 \text{ mg/l}$$

Where: Pmb = Phosphorus concentration to be removed with metal salt, mg/l

Tpi = Influent Phosphorus concentration, mg/l

$$\text{CD} = \text{MolR} \times \text{Pmb} / \text{Ion} \times \text{MWRatio} =$$

Where: CD = Required Alum dosing rate, mg/l

MolR = Mole Ratio (Actual Dose required vs. Stoichiometric Dose)

Ion = Fraction Metal Ion in Alum

MWRatio = Ratio of Molecular Weights, Al:P

Bioloop® Detailed Design Calculations
SNDN Process

Project Name: **Bakers Corner, IN**

Designer: **Designer**

Project Number: **od31015-21**

Date: **10/17/2022**

Mass of Chemical Sludge

$$CS = Q \times Pmb \times MP \times 8.34 = 0.50 \times 2.51 \times 6.48 \times 8.34 = 68 \text{ lb/d/train}$$

Where: MP = Mass of Precipitate formed per Mass of P removed

Aerated Process Volume

$$Vaer_design = \frac{\Delta M \times SRT}{MLSS \times 8.34} = \frac{780 \times 12.9}{2,900 \times 8.34} = 0.415 \text{ MG}$$

where: Vaer_design = Volume of Aeration Tank, MG

MLSS = Aeration Tank Mixed Liquor Suspended Solids Concentration, mg/l

Reactor	Actual volume		
Ditch 1	0.208 MG		
Ditch 2	0.208 MG		
Total	0.416 MG		

Anoxic Process Volume

Operate first aerated reactors as aerated anoxic for aerated anoxic vol. = 207,608 gallons

Bioloop® Detailed Design Calculations
SNDN Process

Project Name: **Bakers Corner, IN**
 Project Number: **od31015-21**

Designer: **Designer**
 Date: **10/17/2022**

Nitrogen Balance

Constants

Coefficient	Value	Symbol
VSS/TSS	69.9%	
Sludge N	0.070	Ns
Effluent Dissolved Organic Nitrogen, mg/l	1.0	EDON

$$\text{TKN}_{\text{ox}} = \text{TKN} - \text{EDON} - \text{TENH3} - N_{\text{assim}} - N_{\text{part}} = 38.0 - 1.0 - 1 - 13.1 - 0.49 = \mathbf{22.2 \text{ mg/l}}$$

where: TKN_{ox} = TKN available for oxidation (mg/l)

TKN = Influent TKN (mg/l)

TENH3 = Effluent $\text{NH}_3\text{-N}$ (mg/l)

N_{assim} = Nitrogen assimilated into sludge (mg/l)

N_{part} = Nitrogen bound to VSS portion of effluent TSS (mg/l)

$$N_{\text{assim}} = \frac{\Delta M \times N_s}{Q \times 8.34} = \frac{780 \times 0.07}{0.50 \times 8.34} = \mathbf{13.1 \text{ mg/l}}$$

$$N_{\text{part}} = \text{TESS} \times N_s \times \text{VSS/TSS} = 10 \times 0.07 \times 0.70 = \mathbf{0.49 \text{ mg/l}}$$

where TESS = Effluent Total Suspended Solids (mg/l)

$$\text{TENoxN} = \text{TKN}_{\text{ox}} \times (1 - \text{Denite}\%) = 22.2 \times (1 - 0.76) = \mathbf{5.3}$$

where: TENox = Total effluent nitrate + nitrite nitrogen (mg/l)

Denite % = Predicted denitrification %, based on Anoxic Process Volume and SNDR

SNDR = See Assumed Denitrification Rates in table below

$$\text{TN} = \text{TENH3} + \text{TENox} + \text{EDON} + N_{\text{part}} = 1 + 5.3 + 1 + 0.49 = \mathbf{7.79}$$

where: TN = Effluent Total Nitrogen (mg/l)

Bioloop® Detailed Design Calculations
SNDN Process

Project Name: **Bakers Corner, IN**Designer: **Designer**Project Number: **od31015-21**Date: **10/17/2022****Assumed Denitrification Rates**

Check Assumed Denite Rate in each Zone

Reactor	1	2	
Description	Ditch	Ditch	
NO3-N mass to remove	66.35	0	lb/d
Mass of MLVSS	3512	3512	lb
Required Denite Rate (SNDR)	0.0189	0.0000	mass NO3-N/mass MLVSS/d
Theoretical Denite Rate at 20C	0.06	0.06	mass NO3-N/mass MLVSS/d
DO Switch Function	1	0.091	At design DO concentration
Temperature Correction	0.463	0.463	At design water temperature
Adjusted Theoretical Denite Rate	0.028	0.003	mass NO3-N/mass MLVSS/d
Assumed Denite rate OK?	YES	YES	

Actual Oxygen Demand

$$AOR_T = AOR_C + AOR_N = 1001 + 225 = \mathbf{1225 \text{ lb/day}}$$

where: AOR_T = Total Actual Oxygen Demand, lb/day AOR_C = Carbonaceous Oxygen Demand, lb/day AOR_N = Nitrogen Oxygen Demand (Including any denitrification credit), lb/day**Carbonaceous Oxygen Demand**

$$AOR_C = BOD_L \times O_{2carb} = 834 \times 1.2 = \mathbf{1001 \text{ lb/day}}$$

where: O_{2carb} = O_2/BOD

Bioloop® Detailed Design Calculations
SNDN Process

Project Name: **Bakers Corner, IN**Designer: **Designer**Project Number: **od31015-21**Date: **10/17/2022****Nitrogen Oxygen Demand**

$$\text{AOR}_N = \text{TKN}_{\text{ox(Mass)}} \times 4.6 - \text{DNC} = 93 \times 4.6 - 202 = \mathbf{225 \text{ lb/day}}$$

where: 4.6 = O₂/NH₃

DNC = Denitrification Credit

$$\text{TKN}_{\text{ox(Mass)}} = \text{TKN}_{\text{ox}} \times Q = 22.2 \times 0.50 \times 8.34 = 93 \text{ lb/day}$$

$$\text{DNC} = \text{NO}_3\text{-N}_{\text{removed}} \times Q \times 2.86 \times \text{DN} \times 8.34 = 16.9 \times 0.50 \times 2.86 \times 1 \times 8.34 = 202 \text{ lb/day}$$

where: DN = Fraction NO₃-N_{removed} used to calculate denitrification credit = 100%

Based on 76% denitrification in SNDN process

NO₃-N_{removed} = 16.9 mg/l**Standard Oxygen Demand**

$$\text{SOR} = \frac{\text{AOR}}{\text{AOR/SOR}} = \mathbf{2412 \text{ lb/day}}$$

where: SOR = Standard Condition Oxygen Transfer (20°C, 1 atm, α = β = 1), lb/day

AOR / SOR = Conversion Factor Actual to Standard condition oxygen

$$\frac{\text{AOR}}{\text{SOR}} = \frac{\alpha \times \theta^{(T_{\text{site}} - 20)} (C^*_{\text{sat}20} \times \beta \times P_{\text{site}} / P_{\text{std}} \times C_T / C_{20} - \text{DO})}{C^*_{\text{sat}20}}$$

where: α = Alpha factor = 0.6

θ = Temperature coefficient = 1.024

T_{site} = Water temperature, °C = 20

β = Beta factor = 0.98

P_{site} = Site Atmospheric PressureP_{std} = Standard atmospheric pressure, psiaC*_{sat20} = Dissolved oxygen solubility at standard conditions, mg/lC_T = Dissolved oxygen solubility at site water temperature, mg/lC₂₀ = Dissolved oxygen solubility at 20°C, mg/l

DO = Residual dissolved oxygen concentration, mg/l

Aeration Design

Reactor	1	2	Total
DO, mg/l	0.0	2	
AOR, lb/d	613	613	1225
AOR/SOR	0.571	0.458	
SOR	1074	1338	2412

Bioloop® Detailed Design Calculations
SNDN Process

Project Name: **Bakers Corner, IN**Designer: **Designer**Project Number: **od31015-21**Date: **10/17/2022****Clarifier Sizing**

$$A_{\text{design, Max Mo}} = Q_{\text{avg}} / O_{\text{avg}} / \text{No. Clarifiers} = 500,000 / 198.4 / 2 = 1260 \text{ ft}^2$$

$$A_{\text{design, Peak}} = Q_{\text{avg}} / O_{\text{avg}} / \text{No. Clarifiers} = 2,250,000 / 892.9 / 2 = 1260 \text{ ft}^2$$

where: Q = Flow, gpd

A = Area per clarifier, ft²O = Surface overflow rate, gpd/ft²Use Larger Area = 1260 ft²


$$\text{Dia. design } [A / \pi \times 4]^{(1/2)} = [1260 / 3.142 \times 4]^{(1/2)} = 40 \text{ ft}$$

Use Clarifier Diameter = 40 ft

Use Clarifier Quantity = 2

Max. Mo. Condition = 2,900 mg/l MLSS and 5,800 mg/l RAS concentration

Peak Condition = 2,900 mg/l MLSS and 11,600 mg/l RAS concentration

State Point Analysis

Max Month State Point is below the settling curve.

Pk Hr State Point is below the settling curve.

Pk Hr Underflow underflow is below the settling curve.

Clarifier design is adequate.

MIXING SELECTION REPORT

Quote Number: 3556-230125-001 (Rev. 0)
Project:
Position: Bakers Corner - Ditch 1

INPUT DATA

Wastewater Treatment > Biological Treatment Mixing

Biological Treatment	Aerobic - Aeration
Type of pre-treatment	No screening or screen > ½ inch
Outlet location in tank	Top
Recommended average velocity	1.17 ft/s
Accept recommended avg. velocity	Yes
Oxygen transfer guarantee	No
Type of diffuser	9" Sanitaire (Fine)
Diffusers per aerated area	0.24 #/ft ²
Covered bottom area fraction	17.76 %
Covered bottom area	308.669 ft ²
Total number of diffusers	74
Number of aerated zones	1
Flow per diffuser	1.89 scfm@20°C
Total air flow	139.86 scfm@20°C

TANK DIMENSIONS

Closed Ditch

Total length	158 ft
Width	11 ft
Depth	16 ft
Bend losses	1.2
Friction losses	0.48



PRODUCT DATA

Mixer type	4530 without Jetring
Number of mixers	1
Thrust produced/mixer	1959 N
Total thrust produced	1959 N
Total thrust required	1934 N
Power uptake / mixer	4.19 kW (24 % margin to input power)
Total power uptake	4.19 kW
Propeller diameter	47.24 in
Propeller speed	138 RPM
Number of blades	3
Rec. min Submergence	2.62ft
Hub design	Open
Propeller material	Stainless steel
Propeller code	440

MOTOR DATA

Rated Shaft Power	6.2 Hp
Mains frequency	60 Hz
Number Of Phases	3
Rated voltage	460 V D
Number Of Poles	4
Max Input Power	5.5 kW
Approval	STD
Rated Temperature	40 °C / 104 °F

ISO 21630 VALUES

Nominal thrust	2240 N
ISO Input Power	4.32 kW
Efficiency	519 N/kW

Mixer performance data are based on the configuration 400 V Y for 50 Hz and 460 V Y for 60 Hz, for other configurations the data may be different. For mixer performance tolerances, refer to the mixer data chart. Xylem guarantees that the proposed mixer selection will perform the specified duty when all mixers are operating positioned according to Xylem's recommendation. The selection is a function of the input data and the supplier of the data is fully responsible for its correctness.



SANITAIRE®



Xylem Inc.

MIXING SELECTION REPORT

Quote Number: 3556-230125-001 (Rev. 0)
Project:
Position: Bakers Corner - Ditch 2

INPUT DATA


Wastewater Treatment > Biological Treatment Mixing

Biological Treatment	Aerobic - Aeration
Type of pre-treatment	No screening or screen > ½ inch
Outlet location in tank	Top
Recommended average velocity	1.17 ft/s
Accept recommended avg. velocity	Yes
Oxygen transfer guarantee	No
Type of diffuser	9" Sanitaire (Fine)
Diffusers per aerated area	0.24 #/ft²
Covered bottom area fraction	17.76 %
Covered bottom area	308.669 ft²
Total number of diffusers	75
Number of aerated zones	1
Flow per diffuser	2.43 scfm@20°C
Total air flow	182.25 scfm@20°C

TANK DIMENSIONS

Closed Ditch

Total length	158 ft
Width	11 ft
Depth	16 ft
Bend losses	1.2
Friction losses	0.48



PRODUCT DATA

Mixer type	4530 without Jetring
Number of mixers	1
Thrust produced/mixer	1959 N
Total thrust produced	1959 N
Total thrust required	1941 N
Power uptake / mixer	4.19 kW (24 % margin to input power)
Total power uptake	4.19 kW
Propeller diameter	47.24 in
Propeller speed	138 RPM
Number of blades	3
Rec. min Submergence	2.62ft
Hub design	Open
Propeller material	Stainless steel
Propeller code	440

MOTOR DATA

Rated Shaft Power	6.2 Hp
Mains frequency	60 Hz
Number Of Phases	3
Rated voltage	460 V D
Number Of Poles	4
Max Input Power	5.5 kW
Approval	STD
Rated Temperature	40 °C / 104 °F

ISO 21630 VALUES

Nominal thrust	2240 N
ISO Input Power	4.32 kW
Efficiency	519 N/kW

Mixer performance data are based on the configuration 400 V Y for 50 Hz and 460 V Y for 60 Hz, for other configurations the data may be different. For mixer performance tolerances, refer to the mixer data chart. Xylem guarantees that the proposed mixer selection will perform the specified duty when all mixers are operating positioned according to Xylem's recommendation. The selection is a function of the input data and the supplier of the data is fully responsible for its correctness.



Bioloop Calculations Near-Term Flow (0.08 MGD)

Bioloop® Design Proposal - NIT Process

Bakers Corner, IN Sanitaire #od31015-21

INFLUENT WASTEWATER CHARACTERISTICS AND SITE CONDITIONS

Number of Parallel Biological Trains

1

	Per Biological Train	Total all Bio. trains
Average Annual Flow	0.08 MGD	0.08 MGD
Maximum Month Influent Flow	0.08 MGD	0.08 MGD
Peak Hourly Flow	1.50 MGD	1.50 MGD
BOD ₅ (20°C)	200 mg/l	
BOD ₅ (20°C)	133 lb/d	
Suspended Solids	200 mg/l	
TKN	38 mg/l	
Total Phosphorus	6 mg/l	
Max Wastewater Temperature	20 °C	
Min Wastewater Temperature	10 °C	
Ambient Air Temperature	20 - 90 °F	
Site Elevation	700 ft	

Bioloop® NIT PROCESS EFFLUENT QUALITY (MONTHLY AVERAGE)

BOD ₅ (20°C)	10 mg/l
Suspended Solids	10 mg/l
NH ₃ -N	1 mg/l
TN	mg/l
Total Phosphorus*	1 mg/l

*Requires chemical precipitation

Bioloop® NIT PROCESS DESIGN CRITERIA

F / M	0.077 lb BOD ₅ / lb MLSS / day
SVI (after 30 minutes settling)	150 ml/g
Biological Mixed Liquor Suspended Solids (MLSS) conc.	1,000 mg/l
Waste Sludge Produced (Approx.)	123 lb/d
Volume of Sludge Produced (Approx. 0.20% solids)	7,402 gpd
Aerated Hydraulic Retention Time	62.28 Hrs
Sludge Age	14.0 Days
Sufficient Alkalinity must be provided to maintain basin pH of 6.8	
Chemical dosage (as Alum)	38 mg/l
RAS Pumping Rate	100% of Maximum Month Flow

0.103 lb BOD₅/lb MLVSS/day
(assume 75% VS)

Bioloop® NIT PROCESS BASIN DESIGN DETAILS (PER TRAIN)

	Ditch 1
Basin Quantity	1
Volume/Basin (MG)	0.208
Basin Length (ft) - *	60.0
Basin Width (ft)	11.0
Basin Depth (ft)	16.0

* - For oxidation ditches, basin length above is straight section length for Side by Side Ditch Type (see ref. drawing)

Bioloop® NIT PROCESS EQUIPMENT

	Ditch 1
Mixer Quantity/Basin	1
Mixer Motor Hp	6.2
Fine Bubble Diffuser Quantity / Basin / Train	75
Biological blower (scfm/basin/train)	50

Biological Blowers (PD type) 1 Duty + 1 Standby with 5 Hp Motor

OSCAR Control Panel

Instruments and Valves in Basins		Quantity
Location	Ditch 1	
ORP probe	Yes	1
DO probe	Yes	1
Air modulating valve	1@4 inch	1
Airflow meter	1@4 inch	1

Other Instruments and Valves

Location	Size	
Air pressure transmitter	Bio Blower Discharge	1

Bioloop® NIT AERATION/MIXING POWER REQUIREMENTS (TOTAL FOR ALL TRAINS)

		Oxidation Ditches operated in Series		kW-hr/d
		Ditch 1		
Basin Quantity		1		
Mixers / Basin		1		
Mixer Op. Hp		4.0		72
Bio Blowers Operating Power	1 at	3.8 Hp		68
Total kW-hr/d				140

Bioloop® Detailed Design Calculations
NIT Process

Project Name: *Bakers Corner, IN*
Project Number: *od31015-21*

Designer: *Designer*
Date: *2/28/2022*

Design Parameters

Number of Parallel Process Trains 1

Flow

	Per process train	Total for all trains
Average Annual Flow	0.08 MGD	0.08 MGD
Maximum Month Flow	0.08 MGD	0.08 MGD
Peak Hourly Flow	1.50 MGD	1.50 MGD

Treatment

	Units	Influent Quality	Effluent Requirement
BOD ₅ (20°C)	mg/l	200	10
Suspended Solids	mg/l	200	10
TKN	mg/l	38	N/A
NH ₃ -N	mg/l	N/A	1.0
TN	mg/l	N/A	0
Phosphorus	mg/l	6.0	1.0

Environment

Sufficient Alkalinity must be provided to maintain basin pH of 6.8

Max. Wastewater Temperature	20	°C
Min. Wastewater Temperature	10	°C
Ambient Air Temperature	20 - 90	°F
Site Elevation	700	ft

Bioloop® Design Parameters

F / M	0.08	lb BOD ₅ / lb MLSS / day
Aerated HRT	62.28	hrs
SVI (after 30 minutes settling)	150	ml/g
Number of Aerated Reactors in Series	1	
Water Depth	16.0	ft
RAS Pumping Rate	100%	of Maximum Month Flow

Bioloop® Detailed Design Calculations**NIT Process**Project Name: **Bakers Corner, IN**Designer: **Designer**Project Number: **od31015-21**Date: **2/28/2022****Process Calculations****Nitrification Kinetics**

Refer to Metcalf and Eddy, Edition IV pages 614 and 705

Constants and Temperature Corrections:

Coefficient	Base Value	Theta	Temperature Corrected	Symbol
Maximum Specific Growth Rate of Nitrifying bacteria, g/ VSS/g VSS•day	0.75	1.07	0.38126	$\mu_{nm}(T)$
Half-Velocity constant for nitrifiers	0.74	1.053	0.44152	$K_n(T)$
Nitrifier decay rate	0.08	1.04	0.05405	$K_{dn}(T)$
Dissolved Oxygen in final reactor	2.00		2.00	DO
Half-Velocity Constant for Dissolved Oxygen, mg/l	0.5		0.5	K_o
Minimum Water Temperature, °C	10		10	T
Safety Factor	2.2		2.2	SF

Calculations

$$\mu_n = \left(\mu_{nm}(T) \times \frac{TENH_3}{TENH_3 + K_n(T)} \times \frac{DO}{DO + K_o} \right) - K_{dn}(T)$$

$$\mu_n = \left(0.381 \times \frac{1.0}{1.0 + 0.44} \times \frac{2}{2.0 + 0.5} \right) - 0.054 = 0.16 \text{ days}^{-1}$$

$$SRT_{min} = \frac{1}{\mu_n} = \frac{1}{0.16} = 6.3 \text{ days}^{-1}$$

$$SRT_{aerobic} = SRT_{min} \times SF = 6.3 \times 2.2 = \mathbf{14.0 \text{ days}}$$

Where: $\mu_{nm}(T)$ = Maximum Temperature Corrected Nitrifier Growth Rate (days^{-1}) μ_n = Specific Nitrifier Growth rate at Temperature, DO, and Effluent NH_3 (days^{-1})

SRTmin = Minimum Sludge age required for Nitrification (days)

SRTaerobic = Design Aerobic Sludge Age (days)

SF = Safety Factor

TENH3 = Anticipated Effluent Ammonia (mg/l)

Bioloop® Detailed Design Calculations**NIT Process**Project Name: **Bakers Corner, IN**Designer: **Designer**Project Number: **od31015-21**Date: **2/28/2022****Sludge Yield**

Refer to WEF MOP/8 4th Edition, pg 11-11, Eqn 11.7

$$\Delta M = \left(\frac{Y \times (\text{BOD}_{\text{in}} - \text{BOD}_{\text{out}})}{1 + (B \times \theta^{\frac{(T-20)}{10}} \times \text{SRT})} + Z_{\text{io}} + Z_{\text{no}} \right) \times Q \times 8.34 + \text{CS}$$

$$\Delta M = \left(\left(\frac{0.6 \times (200 - 10)}{1 + (0.07 \times 1.04^{\frac{(10-20)}{10}} \times 14.0\text{d})} + 40.0 + 60.0 \right) \times 0.08 \times 8.34 \right) + 11 = 123 \text{ lb/day}$$

where: ΔM = Mass of Sludge Produced (lb/day)

Y = Volatile Cell Yield (VSS/BOD Removed)

 θ = Arrhenius Temperature Correction FactorB = Decay Rate (day^{-1})BOD_{out} = Anticipated Effluent BOD (mg/l)

SRT = Solids Retention Time (days)

Z_{io} = Influent Nonvolatile Suspended Solids (mg/l)Z_{no} = Influent Volatile Nonbiodegradable Solids (mg/l)

Q = Maximum month flow, MGD

T = Minimum Wastewater Temperature ($^{\circ}\text{C}$)

CS = Chemical Sludge from Phosphorus Precipitation with) Alum (lb/day)

(see chemical sludge production calculations below)

$$\text{BODL} = \frac{Q \times \text{BOD} \times 8.34}{1,000,000} = \frac{0.080 \times 200 \times 8.34}{1,000,000} = 133 \text{ lb/day}$$

where: Q = Max month flow, MGD

BOD = BOD concentration, mg/l

Sludge Yield, Y_s , = $\Delta M / \text{BOBL} = 123 / 133 = 0.93$ **Chemical Dosing**

Initial estimate of phosphorus in WAS, based on assumed % of MLVSS as P

$$P_w = (\text{BOD}_{\text{in}} - \text{BOD}_{\text{out}}) \times Y_s \times \text{MLVSS} \times P_{\text{sa}} : (200 - 10) \times 0.93 \times 0.69 \times 0.020 = 2.4 \text{ mg/l}$$

Where: P_w = Phosphorus removed with WAS, mg/l as PBOD_{in} = Influent BOD, mg/lBOD_{out} = Anticipated Effluent BOD (mg/l)

MLVSS = Mixed Liquor Volatile Suspended Solids Concentration

 P_{sa} = Assumed % of MLVSS as P

Based on Assumed % of MLSS, estimate phosphorus concentration to be removed with metal salt

$$P_{\text{mb}} = T_{\text{pi}} - P_w - P_e : 6.00 - 2.40 - 1.00 = 2.56 \text{ mg/l}$$

Where: P_{mb} = Phosphorus concentration to be removed with metal salt, mg/l T_{pi} = Influent Phosphorus concentration, mg/l

$$CD = \text{MolR} \times P_{\text{mb}} / \text{Ion} \times \text{MWRatio} =$$

Where: CD = Required Alum dosing rate, mg/l

MolR = Mole Ratio (Actual Dose required vs. Stoichiometric Dose)

Ion = Fraction Metal Ion in Alum

MWRatio = Ratio of Molecular Weights, Al:P

Bioloop® Detailed Design Calculations**NIT Process**Project Name: **Bakers Corner, IN**Designer: **Designer**Project Number: **od31015-21**Date: **2/28/2022****Mass of Chemical Sludge**

$$CS = Q \times Pmb \times MP \times 8.34 = 0.08 \times 2.56 \times 6.47 \times 8.34 = 11 \text{ lb/d/train}$$

Where: MP = Mass of Precipitate formed per Mass of P removed

Aerated Process Volume

$$Vaer_design = \frac{\Delta M \times SRT}{MLSS \times 8.34} = \frac{123 \times 14.0}{1,000 \times 8.34} = 0.208 \text{ MG}$$

where: Vaer_design = Volume of Aeration Tank, MG

MLSS = Aeration Tank Mixed Liquor Suspended Solids Concentration, mg/l

Reactor	Actual volume		
Ditch 1	0.208 MG		
Total	0.208 MG		

Anoxic Process Volume

Bioloop® Detailed Design Calculations
NIT Process

Project Name: **Bakers Corner, IN**Designer: **Designer**Project Number: **od31015-21**Date: **2/28/2022****Nitrogen Balance**

Constants

Coefficient	Value	Symbol
VSS/TSS	69.5%	
Sludge N	0.069	N _s
Effluent Dissolved Organic Nitrogen, mg/l	1.0	EDON

$$\text{TKN}_{\text{ox}} = \text{TKN} - \text{EDON} - \text{TENH}_3 - \text{N}_{\text{assim}} - \text{N}_{\text{part}} = 37.5 - 1.0 - 1 - 12.9 - 0.48 = \mathbf{22.0 \text{ mg/l}}$$

where: TKN_{ox} = TKN available for oxidation (mg/l)

TKN = Influent TKN (mg/l)

TENH₃ = Effluent NH₃-N (mg/l)N_{assim} = Nitrogen assimilated into sludge (mg/l)N_{part} = Nitrogen bound to VSS portion of effluent TSS (mg/l)

$$\text{N}_{\text{assim}} = \frac{\Delta M \times \text{N}_s}{Q \times 8.34} = \frac{123 \times 0.07}{0.08 \times 8.34} = 12.9 \text{ mg/l}$$

$$\text{N}_{\text{part}} = \text{TESS} \times \text{N}_s \times \text{VSS/TSS} = 10 \times 0.07 \times 0.69 = \mathbf{0.48 \text{ mg/l}}$$

where TESS = Effluent Total Suspended Solids (mg/l)

$$\text{TENoxN} = \text{TKN}_{\text{ox}} \times (1 - \text{Denite}\%) = 22 \times (1 - 0.05) = 20.95$$

where: TEN_{ox} = Total effluent nitrate + nitrite nitrogen (mg/l)

Denite % = Predicted denitrification %, based on Anoxic Process Volume and SNDR

SNDR = See Assumed Denitrification Rates in table below

$$\text{TN} = \text{TENH}_3 + \text{TENox} + \text{EDON} + \text{Npart} = 1 + 20.95 + 1 + 0.48 = \mathbf{23.43}$$

where: TN = Effluent Total Nitrogen (mg/l)

Bioloop® Detailed Design Calculations**NIT Process**Project Name: **Bakers Corner, IN**Designer: **Designer**Project Number: **od31015-21**Date: **2/28/2022**

Description

Ditch

Actual Oxygen Demand

$$\text{AOR}_T = \text{AOR}_C + \text{AOR}_N = 160 + 67 = \mathbf{227 \text{ lb/day}}$$

where: AOR_T = Total Actual Oxygen Demand, lb/day AOR_C = Carbonaceous Oxygen Demand, lb/day AOR_N = Nitrogen Oxygen Demand (Including any denitrification credit), lb/day**Carbonaceous Oxygen Demand**

$$\text{AOR}_C = \text{BODL} \times \text{O}_{2\text{carb}} = 133 \times 1.2 = \mathbf{160 \text{ lb/day}}$$

where: $\text{O}_{2\text{carb}}$ = O_2/BOD

Bioloop® Detailed Design Calculations
NIT Process

Project Name: **Bakers Corner, IN**Designer: **Designer**Project Number: **od31015-21**Date: **2/28/2022****Nitrogen Oxygen Demand**

$$\text{AOR}_N = \text{TKN}_{\text{ox(Mass)}} \times 4.6 - \text{DNC} \quad 15 \times 4.6 - 0 = \quad \mathbf{67 \text{ lb/day}}$$

where: $4.6 = \text{O}_2/\text{NH}_3$

DNC = Denitrification Credit

$$\text{TKN}_{\text{ox(Mass)}} = \text{TKN}_{\text{ox}} \times Q = 22.0 \times 0.08 \times 8.34 = 15 \text{ lb/day}$$

$$\text{DNC} = \text{NO}_3\text{-N}_{\text{removed}} \times Q \times 2.86 \times \text{DN} \quad 8 \times 2.86 \times 0.1185174337636730 = 2.86 \text{ lb/day}$$

where: DN = Fraction $\text{NO}_3\text{-N}_{\text{removed}}$ used to calculate denitrification credit = 12%

Based on 5% denitrification in NIT process

 $\text{NO}_3\text{-N}_{\text{removed}} = 1.0 \text{ mg/l}$ **Standard Oxygen Demand**

$$\text{SOR} = \frac{\text{AOR}}{\text{AOR/SOR}} = \quad \mathbf{492 \text{ lb/day}}$$

where: SOR = Standard Condition Oxygen Transfer (20°C , 1 atm, $\alpha = \beta = 1$), lb/day

AOR / SOR = Conversion Factor Actual to Standard condition oxygen

$$\frac{\text{AOR}}{\text{SOR}} = \frac{\alpha \times \theta^{(T_{\text{site}} - 20)} (C^*_{\text{sat}20} \times \beta \times P_{\text{site}} / P_{\text{std}} \times C_T / C_{20} - \text{DO})}{C^*_{\text{sat}20}}$$

where: α = Alpha factor = 0.6 θ = Temperature coefficient = 1.024 T_{site} = Water temperature, $^\circ\text{C}$ = 20 β = Beta factor = 0.98 P_{site} = Site Atmospheric Pressure P_{std} = Standard atmospheric pressure, psia $C^*_{\text{sat}20}$ = Dissolved oxygen solubility at standard conditions, mg/l C_T = Dissolved oxygen solubility at site water temperature, mg/l C_{20} = Dissolved oxygen solubility at 20°C , mg/l

DO = Residual dissolved oxygen concentration, mg/l

Aeration Design

Reactor	1
DO, mg/l	2.0
AOR, lb/d	227
AOR/SOR	0.462
SOR	492

Bioloop® Detailed Design Calculations**NIT Process**Project Name: **Bakers Corner, IN**Designer: **Designer**Project Number: **od31015-21**Date: **2/28/2022****Clarifier Sizing**

$$A_{\text{design, Max Mo}} = Q_{\text{avg}} / O_{\text{avg}} / \text{No. Clarifiers} = 80,000 / 50.3 / 1 = 1590 \text{ ft}^2$$

$$A_{\text{design, Peak}} = Q_{\text{avg}} / O_{\text{avg}} / \text{No. Clarifiers} = 1,500,000 / 943.4 / 1 = 1590 \text{ ft}^2$$

where: Q = Flow, gpd

A = Area per clarifier, ft²O = Surface overflow rate, gpd/ft²Use Larger Area : 1590 ft²


$$\text{Dia. design } [A / \pi \times 4]^{(1/2)} = [1590 / 3.142 \times 4]^{(1/2)} = 45 \text{ ft}$$

Use Clarifier Diameter = 45 ft

User Clarifier Quantity = 1

Max. Mo. Condition = 1,000 mg/l MLSS and 2,000 mg/l RAS concentration

Peak Condition = 1,000 mg/l MLSS and 13,500 mg/l RAS concentration

State Point Analysis

Max Month State Point is below the settling curve.

Pk Day State Point is below the settling curve.

Pk Day Underflow underflow is below the settling curve.

Clarifier design is adequate.

Attachment 2-3

US 31 WWTP Design
Clarifier Sizing Calculations

Created 5/15/2022
Updated 11/17/2022

	Oxidation Ditch	Oxidation Ditch
	Avg Flow	Low Flow
Clarifier Diameter (ft)	40	40
Weir Diameter (ft)	36.67	36.67
Surface Area (ft ²)	1257	1257
SWD (ft)	12	12
Volume (ft ³)	15080	15080
Volume (MG)	0.1128	0.1128
ADF (MGD)	0.5	0.1
PHF (MGD)	2.25	0.36
RAS Flow Rate (MGD)	0.5	0.1
Number of Units	2	1
Process Flow per Unit @ ADF (MGD)	0.25	0.08
Process Flow per Unit @ PHF (MGD)	1.13	0.36
RAS Flow Rate Per Unit (MGD)	0.25	0.08
Total Flow to Each Unit (MGD)- Avg	0.50	0.16
Total Flow to Each Unit (MGD)- Peak	1.38	0.44
MLSS (mg/L)	2900	2600
Detention Time (hrs)- Average	5.41	16.92
Detention Time (hrs)- Peak	1.97	6.15
Surface Overflow Rate @ PHF (gpd/ft ²)	895	286
Weir Overflow Rate (gal/day/ft)	9,766	3,125
Solids Loading Rate (lbs/day/ft ²)	26.46	7.59

Channel Width (ft) 1
Channel Wall Thickness (ft) 0.67

Attachment 2-4

Chemical Precipitation for Phosphorus Removal: DESIGN CONDITIONS **US31 Hamilton County Wastewater Treatment Plant**

Assumes Chemical applied during or after secondary (biological) treatment; not to be used to calculate CEPT

By: Wessler Engineering

Date: 7/14/2022 Updated: 1/25/2023

<-- VERIFY DATA WITH CHEMICAL SUPPLIER

<-- INSERT DATA

ALUM

Flow, ADF: 0.5 MGD
 Flow, PHF: 2.25 MGD Changed to 2.25 MGD to match the current
 Flow, Low: 0.08 MGD
 Raw or Primary Effl Total-P*: 6 mg/L
 Effluent P Limit: 1.0 mg/L
 Effluent P Design Goal: 0.8 mg/L **ASSUME NO P REMOVED IN WAS**

Effluent TSS Goal: 10 mg/L Eff limit: 12 mg/L
 Effluent particulate P*: 0.25 mg/L
 *Assumes that ~2.5% of effluent TSS is particulate P
 Effluent orthophosphate limit: 0.6 mg/L

Al/P ratio*: 1.51

*Refer to WEF MOP 34, Figure 7.7

C_{P,in} (ortho-P)*: 5.2 mg/L

*Assumes that nonorthophosphate and particulate phosphorus are at least partially hydrolyzed during biological treatment to orthophosphate

C_{P,res}: 0.6 mg/L
 Al: 26.98 g/mol
 P: 30.97 g/mol
 Mass of P to remove: 22 lbs/day

$$Al_{dose} = (Al/P) \times (C_{P,in} - C_{P,res}) \times [(26.98 \text{ g Al/mol} / (30.97 \text{ g P/mol})]$$

Al_{dose}: 6.84 mg/L

Al_{req} at ADF: 29 lbs/day

Alum solution formula: Al₂(SO₄)₃ 14 H₂O as supplied by chemical distributor

Alum solution: 594.4 g/mol

Al₂ in Alum Solution: 4.54% Al/Alum Solution MW Ratio

Alum_{solution}: 48.5% as supplied by chemical distributor

Alum_{specific wt}: 11.05 lbs/gal as supplied by chemical distributor

Alum_{req} @ ADF: 628 lbs/day Concentration: 150.68 mg/L

$$Alum_{req, gal/day} = (Alum_{req, lbs/day}) / [(Alum_{specific wt, lbs/gal}) (Alum_{sol, \%})]$$

Alum_{req} @ ADF: 57 gal/day

20,755 gal/year

PUMPING:

At Avg. Flow	2.4 gal/hr	Avg Feed Rate
At Avg. Flow	0.04 gal/min	Avg Feed Rate
At Peak Flow	0.18 gal/min	Max Feed Rate
At Peak Flow	10.66 gal/hr	Max Feed Rate
At Low Flow	0.01 gal/min	Max Feed Rate
At Low Flow	0.38 gal/hr	Max Feed Rate

STORAGE

Desired Storage Period: 30 days

Safety Factor*: 15%

*safety factor accounts for headspace/freeboard in tanks

DESIGN

TOTAL TANK VOLUME REQ'D: 2,000 Gallons

Design Tank sizing:	Volume (gal)	Diameter (ft)	Height (ft)
	2,000	7.0	7.00

Under low flow (near term) conditions: Storage Period **219.83 days**
Too long

O&M COST

Chemical Cost: \$ 0.11 per lb assumed

Cost at ADF: \$ 69 per day

COST AT ADF: \$ 25,200 per year

Al: 26.982 g/mol	O: 15.999 g/mol
S: 32.066 g/mol	H: 1.00794 g/mol
Fe: 55.847 g/mol	Cl: 35.4527 g/mol
Na: 22.990 g/mol	

Elemental Weights taken from "Aquatic Chemistry, Stumm & Morgan, 3rd Edition, 1996"

Chemical Supplier used for design: Liquid Alum Safety Data Sheet (SDS) - Supplier: JMN Special

Chemical Precipitation for Phosphorus Removal: NEAR TERM CONDITONS **US31 Hamilton County Wastewater Treatment Plant**

Assumes Chemical applied during or after secondary (biological) treatment; not to be used to calculate CEPT

By: Wessler Engineering

Date: 7/14/2022 Updated: 1/25/2023

<-- VERIFY DATA WITH CHEMICAL SUPPLIER

<-- INSERT DATA

ALUM

Flow, ADF: 0.08 MGD
 Flow, PHF: 0.36 MGD Changed to 2.25 MGD to match t
 Raw or Primary Effl Total-P*: 6 mg/L
 Effluent P Limit: 1.0 mg/L
 Effluent P Design Goal: 0.8 mg/L **ASSUME NO P REMOVED IN W**

Effluent TSS Goal: 10 mg/L Eff limit: 12 mg/L
 Effluent particulate P*: 0.25 mg/L
 *Assumes that ~2.5% of effluent TSS is particulate P
 Effluent orthophosphate limit: 0.6 mg/L

Al/P ratio*: 1.51

*Refer to WEF MOP 34, Figure 7.7

$C_{P,in}$ (ortho-P)*: 5.2 mg/L

*Assumes that nonorthophosphate and particulate phosphorus are at least partially hydrolyzed during biological treatment to orthophosphate

$C_{P,res}$: 0.6 mg/L
 Al: 26.98 g/mol
 P: 30.97 g/mol
 Mass of P to remove: 3 lbs/day

$$Al_{dose} = (Al/P) \times (C_{P,in} - C_{P,res}) \times [(26.98 \text{ g Al/mol} / (30.97 \text{ p P/mol}))]$$

Al_{dose} : 6.84 mg/L

Al_{req} at ADF: 5 lbs/day

Alum solution formula: $Al_2(SO_4)_3 \cdot 14 H_2O$ as supplied by chemical distribut

Alum solution: 594.4 g/mol

$Al_{\%}$ in Alum Solution: 4.54% Al/Alum Solution MW Ratio

$Al_{solution}$: 48.5% as supplied by chemical distribut

$Al_{specific\ wt}$: 11.05 lbs/gal as supplied by chemical distribut

$Alum_{req}$ @ ADF: 101 lbs/day Concentration: 150.68

$$Alum_{req} \text{ gal/day} = (Alum_{req} \text{ lbs/day}) / [(Alum_{specific\ wt} \text{ lbs/gal}) (Alum_{sol} \text{ } ^\circ$$

$Alum_{req}$ @ ADF: 9 gal/day
 3,321 gal/year

PUMPING:

At Avg. Flow	0.4 gal/hr	Avg Feed Rate
At Avg. Flow	0.01 gal/min	Avg Feed Rate
At Peak Flow	0.03 gal/min	Max Feed Rate
At Peak Flow	1.71 gal/hr	Max Feed Rate

STORAGE

Desired Storage Period: 30 days

Safety Factor*: 15%

*safety factor accounts for headspace/freeboard in tanks

DESIGN

TOTAL TANK VOLUME REQ'D: 400 Gallons

Near Term Storage: 2 - 250 gal totes

O&M COST

Chemical Cost: \$ 0.11 per lb assumed

Cost at ADF: \$ 11 per day

COST AT ADF: \$ 4,000 per year

Al: 26.982 g/mol	O: 15.999 g/mol
S: 32.066 g/mol	H: 1.00794 g/mol
Fe: 55.847 g/mol	Cl: 35.4527 g/mol
Na: 22.990 g/mol	

Elemental Weights taken from "Aquatic Chemistry, Stumm & Morgan, 3rd Edition, 1996"

Chemical Supplier used for design: Liquid Alum Safety Data Sheet (SDS) - Supplier: JMN

Chemical Precipitation for Phosphorus Removal: Storage Review **US31 Hamilton County Wastewater Treatment Plant**

Date: 1/25/2023

Background:	Flow	Alum Addition
Design	0.5 MGD	57 gal/day
Near Term	0.08 MGD	9 gal/day
Storage needed under Design Flow Conditions:		2000 gallons
Under Near Term Conditions, storage period:		220 days
THIS IS TOO LONG		

In Near Term, chemical storage needed for 30 days:	400 gallons
Provided by: 2 totes, each	250 gallons

Recommend increase size when storage time reaches	10 days
---	---------

Volume Available (minus 15% safety factor)	425 gallons
Alum Usage at which reach 10 days storage	42.5 gal/day

Flow at which storage becomes limited:	0.37 MGD	75% design capacity
--	----------	---------------------

Storage period at limiting flow for Design Storage Tank	47 days	for 2000 gal tank
ok		

Containment: Title 40 CFR part 264.193: the area to "contain 100% of the capacity of the largest tank within its boundary"

Totes: Two 250-gal totes sits on a twin containment pallet: specified pallet, Ultratech 1144
 Containment provided: 535 gal > 500 gal total storage, ok

Tank Details:

Tank installed outside of chemical room, 2000 gallons, 7' diameter, 7' height

Tank Containment:

Length (ft)	Width (ft)	Depth (ft)	Total (cf)	Volume (gal)
12	12	2	288	2154.24 > 2000 gal tank, ok

Attachment 2-5

Design Flows

ADF	0.5	MGD	0.77	CFS
PHF	2.25	MGD	3.48	CFS

Cascade Aeration

$$H = \frac{R - 1}{0.11ab(1 + 0.046 * T)}$$

$$R = \frac{C_s - C_0}{C_s - C}$$

Cs: Dissolved O₂ Saturation Concentration @ Temp, mg/l

C₀: Dissolved O₂ Concentration of the Post Disinfection Influent,mg/l

C: Permitted Dissolved O₂ Concentration,mg/l

a: water quality parameter, 0.8 for treated wastewater effluent

b: Weir Geometry Parameter

Weir: 1

Steps: 1.1

Step Weir: 1.3

T: Water Temperature, °C

Summer 20 Winter 12

H: Height through which water falls, ft

Cs: 9.08 mg/l Summer
11.28 mg/l Winter

C₀: 2 mg/l

C: 6 mg/l Summer
6 mg/l Winter

Summer NPDES Permit (March 4, 2022)
Winter NPDES Permit (March 4, 2022)

R= 2.299 Summer
1.758 Winter

a: 0.8
b: 1.1

T: 20 °C, Summer
10 °C, Winter

H=	6.99	ft, Summer
	5.36	ft, Winter

Attachment 2-6

US 31 WWTP Design
Estimate of Biosolids Production

Created 4/13/2022
Updated 3/7/2023

BIOSOLIDS DATA

	Average Daily Flow, MGD	Low	Avg
Influent BOD Concentration, mg/L	200	0.08	0.500
Organic Loading, lb BOD/day	133	834	200
Sludge Yield, lb/lb BOD	0.935	0.935	0.935
Organic Sludge Yield, lb/day	125	780	200
Influent TSS Concentration, mg/L	200	0.0%	0.0%
Influent TNVSS fraction, Percent	0.0%	-	-
Influent TNVSS Concentration, mg/L	-	-	-
TNVSS Loading, lb TS/day	-	-	-
Total WAS Produced w/o Chem P removal, lb TS/day	125	780	200
Chemical Addition, lb TS/day	19	119	898
Total WAS Produced w/Chem P Removal, lb TS/day	144	898	18579
WAS % TS, from clarifier(s)	0.58%	0.58%	0.58%
WAS Flow, gal/day	2,973	18,579	539
WAS, @60% VS, lb VS/day	86		

ANNUAL DISPOSAL QUANTITIES

Gallons Per Year	1,085,009	6,781,305
Dry Tons Per Year	26.2	163.9

WAS STORAGE: FUTURE AEROBIC DIGESTER

Minimum Residence Time under aeration, days	52.2	8.4
Mean Temperature, degree C	15	15
Volatile Solids Destruction, %	55.0%	39.0%
Volatile Solids Destruction, lb VS/day	47	210
Solids Loading after WAS Storage, lb TS/day	96	688
Estimated WAS %TS after storage	2.0%	2.0%
Sludge after WAS Storage, gal/day	577	4,125
Additional Volume needed with Supernatant, gal/day	722	5,157
Future Digester/Biosolids Storage, Capacity, gal	155,320	155,320
Effective Storage Time, days	215	30
Aeration Required for Mixing, scfm	623	623

Notes

- Based upon flow and loads spreadsheet
- As per Bioloop Calculations
- Yield provided in Bioloop Calculations already includes VSS yield
- Set to zero since VSS already included in sludge yield fraction
- TNVSS = Total Non-Volatile Suspended Solids
- Estimate of Additional Sludge Production due to Chem-P Removal
- Based on temperature x solids retention time, Figure 20.51 from 2006 Water Environment Federation
- Additional 25% volume added for supernatant per 10 State Standards, Sec 85.31
- Storage Capacity based on liquid depth (ft) of 20.4 and diameter (ft) of 36
- Note: Assumption for sizing is that solids are landfilled, not land applied, which needs 60 day storage.
- If land application is considered when aerobic digester installed in the future, double number of digesters.
- Aeration based on 10 State Standards, Sec 85.5
- 30 cfm of air required per 1000 cf of storage volume

digester = 555 - (388 x 40%)
 399 lb/day
 415% chemical sludge
 + 83.2 lb/day
 = 483 lb/day
 detention time = 43 days
 sludge = (834 - 47) x 0.7
 555 lb/day
 volatile = 555 x 70%
 388 lb/day
 influent - permit
 200 mg/L - 100 mg/L
 IDEM uses 40%
 IDEM uses 0.7
 IDEM uses 70% VSS | TSS

US 31 WWTP Design
Estimate of Additional Sludge Production due to Chem-P Removal

Created 4/13/2022
Updated 1/25/2023

Description	Bio-P Removal?		Low Flow Condition 0.08 MGD		Comments
	Design Avg. Condition 0.5 MGD	NO	Design Conditions	Unit	
Flow Rate	0.5 MGD		0.08 MGD		
Influent Phosphorus Concentration	6 mg/L		6 mg/L		
Post EBPR Phosphorus Concentration	NA mg/L		NA mg/L		
Effluent Phosphorus Goal	0.8 mg/L		0.8 mg/L		Set below 1.0 mg/L to be conservative
Amount of Phosphorus to be Removed	21.7 lbs/day		3.5 lbs/day		$Q^*8.34^*AP$
MW of Phosphorus	30.974 lbm/lbmole		30.974 lbm/lbmole		
moles of Phosphorus to be removed	0.70 moles/day		0.11 moles/day		mass/molar mass
Al/P Mole Ratio	1.51		1.51		WEF MOP 34 Figure 7.7
MW of Al	26.982 lbm/lbmole		26.982 lbm/lbmole		
moles of Al added for Phosphorus Removal	1.06 moles/day		0.17 moles/day		molar ratio (Al/P) * moles of P
MW of $Al_0.6(H_2PO_4)(OH)_{1.1}$	142.40 lbm/lbmole		142.40 lbm/lbmole		WEF MOP 34 page 266
Stoichiometric Al required for Phosphorus Removal (to produce $Al_0.6(H_2PO_4)(OH)_{1.1}$)	0.56 moles/day		0.09 moles/day		WEF MOP 34 page 266 (0.5* Moles P removed)
Excess Al added (produces $Al(OH)_3$)	0.50 moles/day		0.08 moles/day		Total Al added - Amount required for Phosphorus Removal
MW of $Al(OH)_3$	78 lbm/lbmole		78 lbm/lbmole		
$Al_0.6(H_2PO_4)(OH)_{1.1}$ produced	79.75 lbs/day		12.76 lbs/day		MW of $Al_0.6(H_2PO_4)(OH)_{1.1}$ * moles of $Al_0.6(H_2PO_4)(OH)_{1.1}$
lbs of $Al(OH)_3$ produced	38.77 lbs/day		6.20 lbs/day		MW of $Al(OH)_3$ * moles of $Al(OH)_3$
Amount of Additional Sludge Produced	119 lbs/day		19 lbs/day		Total $Al_0.6(H_2PO_4)(OH)_{1.1}$ and $Al(OH)_3$ produced
Additional Volume of Sludge Produces at 1.0% WAS	1421 gal/day		227 gal/day		

Estimated WAS production without Chem-P
% increase with Chem-P

16,128 gal/day
8.51%

2,580 gal/day
8.51%

Sources:
Periodic Table
WEF Manual of Practice No. 34, Page 266
Liquid Alum Safety Data Sheet (SDS) - Supplier: JMN Specialties, Inc

Element	MW
P	30.974
Al	26.982
O	15.999
H	1.008

BIO-SOLIDS DATA

	Low	No Aerobic Digester Avg	Aerobic Digester Avg
Average Daily Flow, MGD	0.08	0.500	0.500
WAS Sludge Production, lb/day	144	898	688
Daily Sludge Volume, gal	2,973	18,579	4,125

SOLIDS PRODUCTION

Weekly Sludge Volume, gal.	20,808	130,052	28,877
Monthly Sludge Volume, gal.	89,179	557,368	123,760
Annual Sludge Volume, gal.	1,085,009	6,781,305	1,505,750
Annual Sludge Weight, dry tons	26.2	163.9	125.6
WAS wasting schedule, hrs/week @ 100 gpm rate	3.5	21.7	4.8

DEWATERING BAG REQUIREMENTS

20cy Container Bag Capacity, gal.	96,000	96,000	96,000
Typical Polymer Feed Rate, gph.	0.915	0.915	0.915
Days to fill a bag	32	5	23
Bags per Year, #	12	71	16
Polymer Usage per Year, gal.	165	1034	230
Polymer Usage, per bag gal.	14	15	14
Polymer Dilution Water Req., gpm	15	0	15
Max Dilution Water Vol., gal	13,563	0	14,116
Bag Sludge Concentration, percent	13.1%	13.8%	47.1%

Notes

- From Estimate of Sludge Production spreadsheet - note this value is for sludge after WAS storage for Aerobic Digester column.
- Recommended sludge pumping rate into geotextile bags per Blue River, is 100 gpm. Preferred wasting schedule is 8 hours a day, 1-2 days for a 7-day week. Sludge storage, in the form of an aerobic digester, will be considered once wasting exceed 16 hours per 7-day week.
- See Table A: Container Bag Capacity (Blue River) on Geotextile Capacity spreadsheet, estimated based on WAS TS % provided in Bioloop Calculations
- See Table B: Typical Polymer Usage (Blue River) on Geotextile Capacity spreadsheet, estimated based on WAS TS % provided in Bioloop Calculations and 100 gpm. feed rate
- Container Bag Capacity divided by the Daily Sludge Volume
- Annual sludge capacity divided by the container bag capacity.
- The annual sludge volume produced by the plant divided by the 100 gpm. rate of sludge dewatering multiplied by the usage rate of polymer.
- Polymer usage per year divided by the number of bags per year
- per Blue River (Mike Conwell) - 4/7/18
- Maximum volume of water required to initially fill the bag. The maximum volume will need to be multiplied if more than one bag is being filled. Example: 15 gpm. x 60min per hr. x 14 gal / .915 gph = 13,563 gal of H₂O
- Theoretical goal for dewatered sludge concentration in bags. (Dry tons per bag divided by the expected weight each bag could carry.)

Table A: Container Bag Capacity (Blue River)

Percent Solids	Container Bag (gal.)
1.00%	56,000
1.50%	37,000
2.00%	28,000
2.50%	23,250
3.00%	18,500

Percent TS based on Bioloop Calculations:
0.58% 96,000 calculated





Table B: Typical Polymer Usage (Blue River)

Percent Solids	100 GPM Flow (gph)
1.0%	1.50
1.5%	2.00
2.0%	2.75
2.5%	3.38
3.0%	4.00

Percent TS based on Bioloop Calculations:
0.58% 0.9145 calculated



Question 3 Attachment 3-1

Project Location: Hamilton County, Indiana (Bakers Corner)
Project: US 31 Wastewater Treatment Plant
Project #: 244721.04.001

Calculated by: SG
Date: July 11, 2022
Checked by: ALT
Date: August 10, 2022

Minor Loss Coefficients

Value	Fitting	Source
0.3	90-deg bend	Metcalf & Eddy Collection & Pumping of Wastewater pg 417
0.2	45-deg bend	Metcalf & Eddy Collection & Pumping of Wastewater pg 417
0.1	11.25-deg bend	Metcalf & Eddy Collection & Pumping of Wastewater pg 418
0.5	Entrance	Metcalf & Eddy Collection & Pumping of Wastewater pg 419
1.0	Submerged Exit	Metcalf & Eddy Collection & Pumping of Wastewater pg 420
0.3	45-deg Wye (flow through)	Applied Hydraulics In Engineering pg 114
1.8	Tee (flow through branch)	Applied Hydraulics In Engineering pg 115
0.3	Tee (flow through run)	Applied Hydraulics In Engineering pg 116
0.8	45° Wye, through side outlet	Applied Hydraulics In Engineering pg 117
0.3	45° Wye, straight run	Applied Hydraulics In Engineering pg 118
0.8	Plug Valve	
2.5	Check Valve (swing check)	
Varies	Increaser	Cameron Hydraulic Data for friction loss due to change in pipe size (Uses Equation) - $K=2.6*(\sin(q/2))*(1-(d_1^2/d_2^2))^2$; when $q<45$ -deg; d_1 = small pipe; d_2 = large pipe; based on velocity in small pipe
Varies	Reducer	Cameron Hydraulic Data for friction loss due to change in pipe size (Uses Equation) - $K=0.8*(\sin(q/2))*(1-(d_1^2/d_2^2))$; when $q<45$ -deg; d_1 = small pipe; d_2 = large pipe; based on velocity in small pipe
5.55	Screen (assume 1/4" spacing, 1/4" bars = 2.0 open:obstruction ratio)	

Pipe Losses (Solve Hazen Williams Equation)

$$h_L = ((4.73L)/(d^{4.87})) * ((Q/C)^{1.852})$$

Where: h_L = Friction Headloss (ft)
 Q = Flow (cfs)
 C = Roughness coefficient
 d = Pipe Dia. (ft)
 L = Pipe length (ft)

Hydraulic Design Handbook, pg 10.9, Equation 10.11a
 $V = 1.318 * C * R^{0.63} * S^{0.54}$
 $S = h_L / L$

Channel Losses (Solve Manning's Equation)

$$h_L = ((L * (n^2) * (Q^2)) / ((2.08)(R^{4/3}) * (A^2)))$$

Where: h_L = Friction Headloss (ft)
 Q = Flow (cfs)
 n = Roughness coefficient
 R = Hydraulic Radius (ft)
 $R = (d * w / (w + 2d))$ for rectangular channel
 $R = (d * w / (2w + 2d))$ for rectangular conduit
 A = Area (ft²)
 L = Pipe length (ft)

Hydraulic Design Handbook, pg 10.11, Equation 10.14
Civil Engineering Reference Manual, pg 19-4
 $V = (1.49/n) * R^{2/3} * S^{1/2}$
 $V = Q/A$
 $S = h_L / L$

Minor Losses

$$h_m = K(V^2 / 2g)$$

Where: h_m = Minor Headloss (ft)

K = minor loss expression

V = velocity (ft/s)

Loss Across Sluice Gate

$$H = v^2 / 2g * (1 / C_d^2)$$

Where: v = velocity (ft/s)

g = gravity acceleration (ft/s²)

C_d = sluice gate coefficient (assume = 0.7)

Head over weir (ISCO Open Channel Flow Measurement Handbook, 6th Ed.)

$$Q = KH^{2.5} \text{ for } 90^\circ \text{ V-Notch weirs}$$

Where: Q_u = flow per v-notch

K = constant (2.500 for units in cfs)

$$Q = KLH^{1.5} \text{ for rectangular weirs without end contractions}$$

Where: Q = flow (cfs)

K = constant (3.330 for units in cfs)

L = crest length

$$Q = K(L - 0.2H) * H^{1.5} \text{ for rectangular weirs with end contractions}$$

Where: Q = flow (cfs)

K = constant (3.330 for units in cfs)

L = crest length

Equivalent Pipe Diameter (Civil Engineering Reference Manual, 9th Ed.)

$$D_e = (2 * L_1 * L_2) / (L_1 + L_2) \text{ (for rectangular conduit flowing full)}$$

Where: D_e = equivalent diameter (ft)

L_1 = width (ft)

L_2 = height (ft)

$$D_e = (4 * h * L) / (L + 2 * h) \text{ (for rectangular conduit flowing partially full)}$$

D_e = equivalent diameter (ft)

L = width (ft)

h = depth (ft)

Parshall Flumes (ISCO Open Channel Flow Measurement Handbook, 6th Ed.)

Percent Submergence

$$\text{Submergence Ratio} = H_b / H_a$$

Where: H_a = head upstream of throat (ft)

H_b = head at throat (ft)

0.8 Max allowable submergence for flumes 8 to 50 feet wide for discharge to not be reduced

Discharge Equation (for flumes 8 to 50 feet wide)

$$Q = (3.688 * W + 2.5) * H^{1.6}$$

Where: Q = flow (cfs)

W = throat width (ft)

H = head upstream of throat (ft)

Headloss through flume

$$H_L = H_a - H_b$$

Cutthroat Flumes (ISCO Open Channel Flow Measurement Handbook, 6th Ed.)

Percent Submergence	Throat Size	Transition Submergence for free flow
Submergence Ratio = H_b / H_a	1.0	79.0%
Where: H_a = head upstream of throat (ft)	1.5	81.0%
H_b = head downstream of throat (ft)	2.0	83.0%
Discharge Equations	2.5	84.0%
$Q = KW^{1.025} H^n = CH^n$	3.0	85.0%
Where: Q = flow (cfs)	4.0	86.0%
W = throat width (ft)	5.0	87.0%
H = head upstream of throat (ft)	6.0	88.0%
K = free-flow coefficient		
C = free-flow coefficient		
n = free-flow exponent		

Table 1 of "Design and Calibration of Submerged Open Channel Flow Measurement Structures, Part 3 - Cutthroat Flumes" by Skogerboe, Gaylord, et.al, Utah Water Research Laboratory, 1967

Orifice (Cameron Hydraulic Data)(when $d_1/d_2 < 0.3$; d_2 = diameter of pipe in which orifice is placed)

$$h = (Q / (19.635 * C * d_1^2))^2$$

(when $d_1/d_2 > 0.3$; d_2 = diameter of pipe in which orifice is placed)

$$h = (Q / (19.635 * C * d_1^2))^2 * (1 - (d_1/d_2)^4)$$

Where:

 Q = flow (gpm) C = Discharge coefficient (0.61 for sharp-edged) d_1 = Diameter of orifice (in) h = differential head (ft)**Bar Screens**

$$H_L = \beta (w/b)^{1.33} h \sin \Phi$$

$$h_L = (V^2 - V^1) / (2g + (1/0.7))$$

Kirschmer's Equation Where,

 H_L = Headloss β = Bar Shape Factor w = maximum cross-sectional width of bars facing upstream (0.31" for Bar Spacing \leq 3/8" and 0.47" for bar spacing $>$ 3/8") b = minimum clear spacing of bars h = upstream velocity head Φ = angle of bar screen with horizontal

Note that while using the Kirschmer's Equation for calculating the Headloss,

use the Bar Shape Factor as 1 instead of 0.76 and this is done in order to account for a factor of safety.

Net Positive Suction Head

$$NPSH_A = S - H_s + (P_{atm} - P_{vp}) \times 2.31 / SG$$

Where:

 S = Static Suction Head (ft) H_s = Head Losses in Suction System (ft) P_{atm} = Pressure Head (psi) P_{vp} = Vapor Pressure of Liquid (psi) SG = Specific Gravity

Project Location: Hamilton County, Indiana (Bakers Corner)
 Project: US 31 Wastewater Treatment Plant
 Project #: 244721.04.001

Calculated by: SG
 Date: July 11, 2022
 Checked by: ALT
 Date: August 10, 2022

Hazen Williams roughness coefficient (C Factor) = 120
 Manning's roughness coefficient (n) = 0.013

		FLOW				
		Low	ADF	PDF	PDF OTOOS	Future PDF
Influent Flow	mgd	0.08	0.5	2.25	2.25	6.0
Return Activated Sludge (RAS) Percentage	%	100%	100%	100%	100%	100%
RAS Flow	mgd	0.08	0.5	0.5	0.5	1.5
Total Flow	mgd	0.16	1.0	2.8	2.8	7.5
Influent Junction Structure		WSE	WSE	WSE	WSE	WSE
		914.05	914.39	914.38	914.86	915.81
A	Screening Influent	914.05	914.39	914.37	914.85	915.72
	Screening Effluent	913.55	913.64	913.86	913.86	914.21
	Screening Building Effluent	912.07	912.20	912.84	913.01	913.00
	Oxidation Ditch Elevation	912.07	912.15	912.30	912.48	912.38
	Secondary Splitter Box	912.07	912.15	912.29	912.47	912.36
	Secondary Splitter Box Weir	Adjustable	912.00			
	Splitter Box Effluent		910.54	910.58	910.78	911.34
	Final Clarifier Influent		910.53	910.55	910.60	910.63
	Final Clarifier Weir	Adjustable	910.50			
	Final Clarifier Effluent		905.19	905.23	905.69	906.16
	Disinfection Tank Influent		905.19	905.22	905.34	905.34
	Disinfection Weir	Adjustable	905.00			
	Disinfection Tank Effluent		902.67	903.04	903.89	903.89
	Cascade Aeration Effluent		897.74	897.79	898.60	898.60
	Ditch Effluent		897.74			899.21
	25 Yr Flood					
	100 Yr Flood	X	897.74			

NOTES:

- Ground elevation varies between ~ 905-908'
- 100 yr flood elevation was chosen as 897.74 ft based on the calcs and using the downstream 100 yr elevation data provided in IDNR report.
- OTOOS: One tank out of service

= Conditions where free drop is greater than 6-inches at we
 = Conditions where free drop is less than 6-inches at weir
 = Conditions where weir is submerged

Project Location: Hamilton County, Indiana (Bakers Corner)			Calculated by: SG				
Project: US 31 Wastewater Treatment Plant			Date: July 11, 2022				
Project #: 244721.04.001			Checked by: ALT				
			Date: August 10, 2022				
			C Factor: 120				
			Manning's coefficient (n): 0.013				
Influent Flow	mgd	0.08	0.50	2.25	2.25	6.00	
	cfs	0.12	0.77	3.48	3.48	9.28	
Headworks Influent Elevation			914.05	914.39	914.37	914.85	915.72
Screening Building							
Channel Width, ft	2.00						
Channel Height, ft	1.50						
Channel Length, ft	35						
Conduit Area, ft ²	3.00						
Wetted Perimeter, ft	5.00						
Hydraulic Radius, ft	0.60						
Percentage of Flow		100%	100%	100%	100%	50%	
Flow (cfs)	Influent Flow	0.12	0.77	3.48	3.48	4.64	
Velocity (fps)		0.04	0.26	1.16	1.16	1.55	
Velocity Head (ft) = $V^2 / 2g$		0.00	0.00	0.02	0.02	0.04	
Minor Losses		Qty	K	Total			
	Entrance	0	0.5	0			
	Submerged exit	0	1	0			
	Total			0.00	0.00	0.00	0.00
Equipment Losses							
	Screen Loss			0.50	0.75	0.50	0.98
$h_L = ((L) * (n^2) * (Q^2)) / ((2.208) * (R^{4/3}) * (A^2))$				0.00	0.00	0.01	0.01
Total losses for section				0.50	0.75	0.51	0.99
Screen Channel Effluent			913.55	913.64	913.86	913.86	914.21
Screen Channel Invert			913.5				
Screen Building Effluent Pipe Water Surface Elevation			912.07	912.20	912.84	913.01	913.33

Project Location:				Hamilton County, Indiana (Bakers Corner)		Calculated by: SG			
Project:				US 31 Wastewater Treatment Plant		Date: July 11, 2022			
Project #:				244721.04.001		Checked by: ALT			
						Date: August 10, 2022			
						C Factor: 120			
						Manning's coefficient (n): 0.013			
Influent Flow				mgd	0.08	0.50	2.25	2.25	6.00
				cfs	0.12	0.77	3.48	3.48	9.28
Return Activated Sludge Flow				mgd	0.08	0.50	0.50	0.50	1.50
				cfs	0.12	0.77	0.77	0.77	2.32
Total Flow				mgd	0.16	1.00	2.75	2.75	7.50
				cfs	0.25	1.55	4.26	4.26	11.61
Screen Building Effluent Pipe Water Surface Elevation					912.07	912.20	912.84	913.01	913.33
Screening Building to RAS Feed Structure									
Pipe Material	Ductile Iron - 250 psi								
Pipe Diameter, in	16								
Pipe Diameter, ft	1.33								
Inside Diameter, ft	1.40								
Pipe Length, ft	50								
Percentage of Flow					100%	100%	100%	100%	50%
Flow (cfs)				Influent Flow	0.12	0.77	3.48	3.48	4.64
Velocity (fps)					0.08	0.50	2.26	2.26	3.01
Velocity Head (ft) = V ² /2g					0.00	0.00	0.08	0.08	0.14
Minor Losses		Qty	K	Total					
	Entrance	1	0.5	0.5					
	90 Degree Bend		0.3	0					
	Exit	1	1	1					
	Total			1.5	0.00	0.01	0.12	0.12	0.21
$h_L = ((4.73L)/(d^{4.87})) * ((Q_t/C)^{1.852})$					0.00	0.00	0.07	0.07	0.11
Total losses for section					0.00	0.01	0.19	0.19	0.32
RAS Feed Effluent Elevation					912.07	912.20	912.65	912.83	913.00
RAS Feed Structure to Oxidation Ditch									
Pipe Material	Ductile Iron - 250 psi								
Pipe Diameter, in	18								
Pipe Diameter, ft	1.50								
Inside Diameter, ft	1.57								
Pipe Length, ft	70								
Percentage of Flow					100%	100%	100%	100%	50%
Flow (cfs)				Total Flow	0.25	1.55	4.26	4.26	5.80
Velocity (fps)					0.13	0.80	2.19	2.19	2.98
Velocity Head (ft) = V ² /2g					0.00	0.01	0.07	0.07	0.14
Minor Losses		Qty	K	Total					
	Entrance	1	0.5	0.5					
	90 Degree Bend	1	0.3	0.3					
	Tee	1	1.8	1.8					
	Exit	1	1	1					
	Total			3.6	0.00	0.04	0.27	0.27	0.50
$h_L = ((4.73L)/(d^{4.87})) * ((Q_t/C)^{1.852})$					0.00	0.01	0.08	0.08	0.13
Total losses for section					0.00	0.05	0.35	0.35	0.63
Aeration Basin Influent Elevation					912.07	912.15	912.30	912.48	912.38
Oxidation Ditch Pass-Through Slide Gate									
Percentage of Flow					100.0%	100.0%	100.0%	100.0%	50.0%
Flow				Total Flow	0.25	1.55	4.26	4.26	5.80
Length, ft	3								
Width, ft	3								

Project Location:				Hamilton County, Indiana (Bakers Corner)		Calculated by: SG			
Project:				US 31 Wastewater Treatment Plant		Date: July 11, 2022			
Project #:				244721.04.001		Checked by: ALT			
						Date: August 10, 2022			
						C Factor: 120			
						Manning's coefficient (n): 0.013			
Influent Flow				mgd	0.08	0.50	2.25	2.25	6.00
				cfs	0.12	0.77	3.48	3.48	9.28
Return Activated Sludge Flow				mgd	0.08	0.50	0.50	0.50	1.50
				cfs	0.12	0.77	0.77	0.77	2.32
Total Flow				mgd	0.16	1.00	2.75	2.75	7.50
				cfs	0.25	1.55	4.26	4.26	11.61
Area, sq ft				9					
Cd constant				0.7					
Velocity (fps)				0.03		0.17	0.47	0.47	0.64
Head through gate $H = (Q/(Cd*A))^2 / (2g)$				0.00		0.00	0.00	0.00	0.00
Total losses for section				0.00		0.00	0.00	0.00	0.00
				912.07		912.15	912.30	912.48	912.37
Oxidation Ditch Effluent Slide Gate									
Percentage of Flow				100.0%		100.0%	100.0%	100.0%	50.0%
Flow				Total Flow	0.25	1.55	4.26	4.26	5.80
Length, ft				2					
Width, ft				2					
Area, sq ft				4					
Cd constant				0.7					
Velocity (fps)				0.06		0.39	1.06	1.06	1.45
Head through gate $H = (Q/(Cd*A))^2 / (2g)$				0.00		0.00	0.01	0.01	0.01
Total losses for section				0.00		0.00	0.01	0.01	0.01
				912.07		912.15	912.29	912.47	912.36
Splitter Box Weir Loss									
Percentage of Flow				100.0%		50.0%	50.0%	100.0%	25.0%
Flow				Total Flow	0.25	0.77	2.13	4.26	2.90
Rectangular Weir, ft				4					
K constant (for cfs units)				3.33					
Head over weir $H = (Q_n / (KL))^{(1/1.5)}$				0.07		0.15	0.29	0.47	0.36
Total losses for section				0.07		0.15	0.29	0.47	0.36
Splitter Box Weir				912.00					
Splitter Box Effluent				910.54		910.58	910.78	911.34	910.95

Project Location:			Hamilton County, Indiana (Bakers Corner)			Calculated by:		SG	
Project:			US 31 Wastewater Treatment Plant			Date:		July 11, 2022	
Project #:			244721.04.001			Checked by:		ALT	
						Date:		August 10, 2022	
						C Factor:		120	
						Manning's coefficient (n):		0.013	
Influent Flow			mgd	0.08	0.50	2.25	2.25	6.00	
			cfs	0.12	0.77	3.48	3.48	9.28	
Return Activated Sludge Flow			mgd	0.08	0.50	0.50	0.50	1.50	
			cfs	0.12	0.77	0.77	0.77	2.32	
Total Flow			mgd	0.16	1.00	2.75	2.75	7.50	
			cfs	0.25	1.55	4.26	4.26	11.61	
Splitter Box Effluent Elevation				910.54	910.58	910.78	911.34	910.95	
Splitter Box to Final Clarifier									
Pipe Material	Ductile Iron - 250 psi			Ductile Iron - 250 psi					
Pipe Diameter, in	14			14					
Pipe Diameter, ft	1.17			1.17					
Inside Diameter, ft	1.23			1.23					
Pipe Length, ft	80								
Percentage of Flow			100%	50%	50%	100%	25%		
Flow (cfs)	Total Flow	0.25	0.77	2.13	4.26	2.90			
Velocity (fps)		0.21	0.65	1.80	3.59	2.45			
Velocity Head (ft) = V ² /2g		0.00	0.01	0.05	0.20	0.09			
Minor Losses	Qty	K	Total						
	Entrance	1	0.5						
	90 Degree Bend	2	0.3						
	Exit	1	1						
	Total		2.1	0.00	0.01	0.11	0.42	0.20	
h _L = ((4.73L)/(d ^{4.87}))*((Q _i /C) ^{1.852})			0.00	0.01	0.08	0.29	0.14		
Total losses for section			0.00	0.02	0.19	0.71	0.34		
Clarifier Basin Influent Elevation				910.53	910.55	910.60	910.63	910.61	
Final Clarifier weir loss									
Percentage of Flow			100.0%	50.0%	50.0%	100.0%	25.0%		
Flow	Influent Flow	0.12	0.39	1.74	3.48	2.32			
V-notch spacing, in	6								
Number of V-notches per foot of Weir	2.00								
Clarifier Diameter, ft	40								
Effluent Trough Width, ft	1								
Trough Wall Width, ft	0.67								
Clarifier Weir Diameter, ft	36.67								
Effluent Weir Length, ft	115								
Total Number of V-notch Weirs/Clarifier	230								
Flow Per V-notch (Q _n), cfs		0.00	0.00	0.01	0.02	0.01			
K constant (for cfs units)		2.50							
Head over weir H = (Q/K) ^(1/2.5)		0.03	0.05	0.10	0.13	0.11			
Total losses for section			0.03	0.05	0.10	0.13	0.11		
Clarifier Basin Weir			910.50						
			905.20	905.26	905.80	906.38	906.39		
Final Clarifier 12" x 12" Opening to Effluent Box									
Percentage of Flow			100.0%	50.0%	50.0%	100.0%	25.0%		
Flow	Influent Flow	0.12	0.39	1.74	3.48	2.32			
Depth, ft	0.5								
Width, ft	1								
Area, sq ft	0.5								
Cd constant	1								
Velocity (fps)		0.25	0.77	3.48	6.96	4.64			
Head through gate H = (Q/(Cd*A)) ² /(2g)		0.01	0.02	0.11	0.22	0.14			

Project Location:			Hamilton County, Indiana (Bakers Corner)			Calculated by: SG	
Project:			US 31 Wastewater Treatment Plant			Date: July 11, 2022	
Project #:			244721.04.001			Checked by: ALT	
						Date: August 10, 2022	
						C Factor: 120	
						Manning's coefficient (n): 0.013	
Influent Flow			mgd	0.08	0.50	2.25	6.00
			cfs	0.12	0.77	3.48	9.28
Return Activated Sludge Flow			mgd	0.08	0.50	0.50	1.50
			cfs	0.12	0.77	0.77	2.32
Total Flow			mgd	0.16	1.00	2.75	7.50
			cfs	0.25	1.55	4.26	11.61
Total losses for section				0.01	0.02	0.11	0.14
Clarifier Basin Effluent Elevation				905.19	905.23	905.69	906.24

Project Location:			Hamilton County, Indiana (Bakers Corner)			Calculated by: SG		
Project:			US 31 Wastewater Treatment Plant			Date: July 11, 2022		
Project #:			244721.04.001			Checked by: ALT		
						Date: August 10, 2022		
						C Factor: 120		
						Manning's coefficient (n): 0.013		
Influent Flow			mgd	0.08	0.50	2.25	2.25	6.00
			cfs	0.12	0.77	3.48	3.48	9.28
Clarifier effluent elevation			905.19	905.23	905.69	906.16	906.24	
Final Clarifier Effluent Box to Final Clarifier Junction Manhole								
Pipe Material	Ductile Iron - 250 psi							
Pipe Diameter, in	12							
Pipe Diameter, ft	1.00							
Inside Diameter, ft	1.03							
Pipe Length, ft	40							
Percentage of Flow			100%	50%	50%	100%	25%	
Flow (cfs)		Influent Flow	0.12	0.39	1.74	3.48	2.32	
Velocity (fps)			0.15	0.46	2.08	4.15	2.77	
Velocity Head (ft) = V ² /2g			0.00	0.00	0.07	0.27	0.12	
Minor Losses	Qty	K	Total					
	Entrance	1	0.5	0.5				
	Exit	1	1	1				
	Total		1.5	0.00	0.00	0.10	0.40	0.18
h _L = ((4.73L)/(d ^{4.87}))*((Q ₁ /C) ^{1.852})			0.00	0.00	0.06	0.23	0.11	
Total losses for section			0.00	0.00	0.16	0.63	0.29	
Manhole Effluent Elevation			905.19	905.23	905.53	905.53	905.96	
Final Clarifier Combination Manhole to UV								
Pipe Material	Ductile Iron - 250 psi						Ductile Iron - 250 psi	
Pipe Diameter, in	16						16	
Pipe Diameter, ft	1.33						1.33	
Inside Diameter, ft	1.40						1.40	
Pipe Length, ft	55							
Percentage of Flow			100%	100%	100%	100%	50%	
Flow (cfs)		Influent Flow	0.12	0.77	3.48	3.48	4.64	
Velocity (fps)			0.08	0.50	2.26	2.26	3.01	
Velocity Head (ft) = V ² /2g			0.00	0.00	0.08	0.08	0.14	
Minor Losses	Qty	K	Total					
	Entrance	1	0.5	0.5				
	45 Degree Bend		0.2	0				
	Exit	1	1	1				
	Total		1.5	0.00	0.01	0.12	0.12	0.21
h _L = ((4.73L)/(d ^{4.87}))*((Q ₁ /C) ^{1.852})			0.00	0.00	0.07	0.07	0.12	
Total losses for section			0.00	0.01	0.19	0.19	0.33	
UV Disinfection Influent Elevation			905.19	905.22	905.34	905.34	905.62	
UV Channel								
Channel Width, ft	1.00							
Channel Height, ft	1.56							
Channel Length, ft	26.00							
Channe Area, ft ²	1.56							
Wetted Perimeter, ft	4.12							
Hydraulic Radius, ft	0.38							
Percentage of Flow			100%	100%	100%	100%	100%	
Flow (cfs)		Influent Flow	0.12	0.77	3.48	3.48	9.28	
Velocity (fps)			0.08	0.50	2.23	2.23	5.95	
Velocity Head (ft) = V ² /2g			0.00	0.00	0.08	0.08	0.55	
Minor Losses	Qty	K	Total					
	90 degrees bend	0	0.3	0				
	Submerged exit	0	1	0				
	Reducer	1	0.1	0.1				
	Total		0.10	0.00	0.00	0.01	0.01	0.05
h _L = ((L)*(n ²)*(Q ²))/((2.208)(R ^{4/3})*(A ²))			0.00	0.00	0.04	0.04	0.26	


Project Location: Hamilton County, Indiana (Bakers Corner)				Calculated by: SG			
Project: US 31 Wastewater Treatment Plant				Date: July 11, 2022			
Project #: 244721.04.001				Checked by: ALT			
				Date: August 10, 2022			
				C Factor: 120			
				Manning's coefficient (n): 0.013			
Influent Flow	mgd	0.08	0.50	2.25	2.25	6.00	
	cfs	0.12	0.77	3.48	3.48	9.28	
Total losses for section		0.00	0.00	0.05	0.05	0.31	
UV bulb loss		0.18	0.18	0.18	0.18	0.18	
UV WSE Elevation		905.01	905.04	905.11	905.11	905.13	
UV Disinfection Weir Losses							
Flow	Influent Flow	0.12	0.77	3.48	3.48	9.28	
Level Control Weir, ft	28.0					60.00	
K constant (for cfs units)	3.33						
Head over weir $H = (Q_n / (KL))^{1/1.5}$		0.01	0.04	0.11	0.11	0.13	
Total losses for section		0.01	0.04	0.11	0.11	0.13	
Disinfection Tank Weir	905.00						
UV Effluent		902.67	903.04	903.89	903.89	903.60	
UV to Cascade Aeration							
Channel Width, ft	4.00						
Channel Height, ft	1.65						
Channel Length, ft	20.00						
Channel Area, ft ²	6.60						
Wetted Perimeter, ft	7.30						
Hydraulic Radius, ft	0.90						
Percentage of Flow		100%	100%	100%	100%	100%	
Flow (cfs)	Influent Flow	0.12	0.77	3.48	3.48	9.28	
Velocity (fps)		0.02	0.12	0.53	0.53	1.41	
Velocity Head (ft) = $V^2 / 2g$		0.00	0.00	0.00	0.00	0.03	
Minor Losses	Qty K	Total					
Entrance	0 0.5	0					
90 degrees bend	0 0.3	0					
Submerged exit	0 1	0					
Total		0.00	0.00	0.00	0.00	0.00	
$h_L = ((L) * (n^2) * (Q^2)) / ((2.208) * (R^{4/3}) * (A^2))$		0.00	0.00	0.00	0.00	0.00	
Total losses for section		0.00	0.00	0.00	0.00	0.00	
Cascade Aeration Influent		902.67	903.04	903.89	903.89	903.60	
Parshall Flume Loss							
6" Parshall Flume Head Loss		0.17	0.54	1.39	1.39	1.10	
HL = $(Q/2.06)^{1/1.58}$ - for 6" Parshall Flume							
Level Floor of Parshall Flume		902.50	902.50	902.50	902.50	902.50	
		901.24	901.29	902.10	902.10	902.71	
Cascade Aeration Loss							
Cascade aeration Loss (ft)	3.50						
WSE at effluent from Cascade Aeration		897.74	897.79	898.60	898.60	899.21	
Cascade Aeration to Discharge							
Pipe Material	Ductile Iron - 250 psi					Ductile Iron - 250 psi	
Pipe Diameter, in	16					16	
Pipe Diameter, ft	1.33					1.33	
Inside Diameter, ft	1.40					1.40	
Pipe Length, ft	520						
Percentage of Flow		100%	100%	100%	100%	50%	
Flow (cfs)	Influent Flow	0.12	0.77	3.48	3.48	4.64	
Velocity (fps)		0.08	0.50	2.26	2.26	3.01	
Velocity Head (ft) = $V^2 / 2g$		0.00	0.00	0.08	0.08	0.14	
Minor Losses	Qty K	Total					
Entrance	1 0.5	0.5					

Project Location:					Hamilton County, Indiana (Bakers Corner)		Calculated by: SG			
Project:					US 31 Wastewater Treatment Plant		Date: July 11, 2022			
Project #:					244721.04.001		Checked by: ALT			
							Date: August 10, 2022			
							C Factor: 120			
							Manning's coefficient (n): 0.013			
Influent Flow					mgd	0.08	0.50	2.25	2.25	6.00
					cfs	0.12	0.77	3.48	3.48	9.28
45 degrees bend					4	0.2				
Exit					1	1				
Total						2.3	0.00	0.01	0.18	0.32
$h_L = ((4.73L)/(d^{4.87}))*((Q_1/C)^{1.852})$						0.00	0.04	0.68	0.68	1.15
Total losses for section						0.00	0.05	0.86	0.86	1.47
100 yr flood elevation						897.74	897.74	897.74	897.74	897.74
Invert of 12'' at Cascade Aeration Effluent						892.75	892.75	892.75	892.75	893.75
Ditch IE						890.91	890.91	890.91	890.91	890.91

Question 4 Attachments

Attachment 4-1

Hamilton County Pump Station - Plant Drain Pumps
- Submersible Pumps (200 gpm per pump)



Project Location: US31 Hamilton County WWTP
 Pump Location: Plant Drain Pump Station
 Project #: 244721.04.001

Calculated by: SG
 Date: August, 10 2022
 Checked by: KMZ
 Date: August, 17 2022

Minor Loss Coefficients

Value	Fitting	Source
0.3	90-deg bend	Metcalf & Eddy Collection & Pumping of Wastewater pg 417
0.2	45-deg bend	Metcalf & Eddy Collection & Pumping of Wastewater pg 417
0.1	11.25-deg bend	Metcalf & Eddy Collection & Pumping of Wastewater pg 418
0.5	Entrance	Metcalf & Eddy Collection & Pumping of Wastewater pg 419
1.0	Submerged Exit	Metcalf & Eddy Collection & Pumping of Wastewater pg 420
0.3	45-deg Wye (flow through)	Applied Hydraulics In Engineering pg 114
1.8	Tee (flow through branch)	Applied Hydraulics In Engineering pg 115
0.3	Tee (flow through run)	Applied Hydraulics In Engineering pg 116
0.8	45° Wye, through side outlet	Applied Hydraulics In Engineering pg 117
0.3	45° Wye, straight run	Applied Hydraulics In Engineering pg 118
0.8	Plug Valve	
2.5	Check Valve (swing check)	
Varies	Increaser	Cameron Hydraulic Data for friction loss due to change in pipe size (Uses Equation) - $K=2.6*(\sin(q/2))*(1-(d_1^2/d_2^2))^2$; when $q<45$ -deg; d_1 = small pipe; d_2 = large pipe; based on velocity in small pipe
Varies	Reducer	Cameron Hydraulic Data for friction loss due to change in pipe size (Uses Equation) - $K=0.8*(\sin(q/2))*(1-(d_1^2/d_2^2))$; when $q<45$ -deg; d_1 = small pipe; d_2 = large pipe; based on velocity in small pipe
5.55	Screen (assume 1/4" spacing, 1/4" bars = 2.0 open:obstruction ratio)	

Pipe Losses (Solve Hazen Williams Equation)

$$h_L = ((4.73L)/(d^{4.87})) * ((Q/C)^{1.852})$$

Hydraulic Design Handbook, pg 10.9, Equation 10.11a

Where: h_L = Friction Headloss (ft)

$$V = 1.318 * C * R^{0.63} * S^{0.54}$$

Q = Flow (cfs)

$$S = h_L / L$$

C = Roughness coefficient

d = Pipe Dia. (ft)

L = Pipe length (ft)

Channel Losses (Solve Manning's Equation)

$$h_L = ((L * (n^2) * (Q^2)) / ((2.208) * (R^{4/3}) * (A^2)))$$

Hydraulic Design Handbook, pg 10.11, Equation 10.14

Where: h_L = Friction Headloss (ft)

Civil Engineering Reference Manual, pg 19-4

Q = Flow (cfs)

$$V = (1.49/n) * R^{2/3} * S^{1/2}$$

n = Roughness coefficient

$$V = Q/A$$

R = Hydraulic Radius (ft)

$$S = h_L / L$$

$R = (d * w / (w + 2d))$ for rectangular channel

$R = (d * w / (2w + 2d))$ for rectangular conduit

A = Area (ft²)

L = Pipe length (ft)

Minor Losses

$$h_m = K(V^2 / 2g)$$

Where: h_m = Minor Headloss (ft)

K = minor loss expression

V = velocity (ft/s)

Loss Across Sluice Gate

$$H = v^2 / 2g * (1/C_d^2)$$

Where: v = velocity (ft/s)

g = gravity acceleration (ft/s²)

C_d = sluice gate coefficient (assume = 0.7)

Head over weir (ISCO Open Channel Flow Measurement Handbook, 6th Ed.)

$$Q = KH^{2.5} \text{ for } 90^\circ \text{ V-Notch weirs}$$

Where: Q_n = flow per v-notch

K = constant (2.500 for units in cfs)

$$Q = KLH^{1.5} \text{ for rectangular weirs without end contractions}$$

Where: Q = flow (cfs)

K = constant (3.330 for units in cfs)

L = crest length

$$Q = K(L - 0.2H) * H^{1.5} \text{ for rectangular weirs with end contractions}$$

Where: Q = flow (cfs)

K = constant (3.330 for units in cfs)

L = crest length

Equivalent Pipe Diameter (Civil Engineering Reference Manual, 9th Ed.)

$$D_e = (2 * L_1 * L_2) / (L_1 + L_2) \text{ (for rectangular conduit flowing full)}$$

Where: D_e = equivalent diameter (ft)

L_1 = width (ft)

L_2 = height (ft)

$$D_e = (4 * h * L) / (L + 2 * h) \text{ (for rectangular conduit flowing partially full)}$$

D_e = equivalent diameter (ft)

L = width (ft)

h = depth (ft)

Parshall Flumes (ISCO Open Channel Flow Measurement Handbook, 6th Ed.)

Percent Submergence

Submergence Ratio = H_b/H_a

Where: H_a = head upstream of throat (ft)

H_b = head at throat (ft)

0.8 Max allowable submergence for flumes 8 to 50 feet wide for discharge to not be reduced

Discharge Equation (for flumes 8 to 50 feet wide)

$Q = (3.688*W + 2.5)*H^{1.6}$

Where: Q = flow (cfs)

W = throat width (ft)

H = head upstream of throat (ft)

Headloss through flume

$H_L = H_a - H_b$

Cutthroat Flumes (ISCO Open Channel Flow Measurement Handbook, 6th Ed.)

Percent Submergence

Submergence Ratio = H_b/H_a

Where: H_a = head upstream of throat (ft)

H_b = head downstream of throat (ft)

Discharge Equations

$Q = KW^{1.025}H^n = CH^n$

Where: Q = flow (cfs)

W = throat width (ft)

H = head upstream of throat (ft)

K = free-flow coefficient

C = free-flow coefficient

n = free-flow exponent

Headloss through flume

$H_L = H_a - H_b$

Throat Size	Transition Submergence for free flow
1.0	79.0%
1.5	81.0%
2.0	83.0%
2.5	84.0%
3.0	85.0%
4.0	86.0%
5.0	87.0%
6.0	88.0%

Table 1 of "Design and Calibration of Submerged Open Channel Flow Measurement Structures, Part 3 - Cutthroat Flumes" by Skogerboe, Gaylord, et.al, Utah Water Research Laboratory, 1967

Orifice (Cameron Hydraulic Data)*(when $d_1/d_2 < 0.3$; d_2 = diameter of pipe in which orifice is placed)*

$$h = (Q / (19.635 * C * d_1^2))^2$$

(when $d_1/d_2 > 0.3$; d_2 = diameter of pipe in which orifice is placed)

$$h = (Q / (19.635 * C * d_1^2))^2 * (1 - (d_1/d_2)^4)$$

Where:

 Q = flow (gpm) C = Discharge coefficient (0.61 for sharp-edged) d_1 = Diameter of orifice (in) h = differential head (ft)**Bar Screens**

$$H_L = \beta (w/b)^{1.33} h \sin \Phi$$

$$h_L = (V^2 - V^1) / (2g + (1/0.7))$$

Kirschmer's Equation Where,

 H_L = Headloss β = Bar Shape Factor w = maximum cross-sectional width of bars facing upstream (0.31" for Bar Spacing $\leq 3/8$ " and 0.47" for bar spacing $> 3/8$ ") b = minimum clear spacing of bars h = upstream velocity head Φ = angle of bar screen with horizontal

Note that while using the Kirschmer's Equation for calculating the Headloss,

use the Bar Shape Factor as 1 instead of 0.76 and this is done in order to account for a factor of safety.

Net Positive Suction Head

$$NPSH_A = S - H_s + (P_{atm} - P_{vp}) \times 2.31 / SG$$

Where:

 S = Static Suction Head (ft) H_s = Head Losses in Suction System (ft) P_{atm} = Pressure Head (psi) P_{vp} = Vapor Pressure of Liquid (psi) SG = Specific Gravity

Project Location:	US31 Hamilton County WWTP	Calculated by: SG
Pump Location:	Plant Drain Pump Station	Date: August, 10 2022
Project #:	244721.04.001	Checked by: KMZ
		Date: August, 17 2022
Wet Well High Water Level:	886.50	C Factor #1: 120
Wet Well Low Water Level:	882.50	C Factor #2: 140
Max Downstream Elevation:	912.65	Pump Centerline: 882
TOTAL DYNAMIC HEAD		

Flow Scenarios	FLOW						
	gpm	0	100	200	300	400	500
	mgd	0.000	0.144	0.288	0.432	0.576	0.720
	cfs	0.000	0.223	0.446	0.668	0.891	1.114
C = 120 - LWL WET WELL		30.150	30.403	31.110	32.233	33.790	35.753
C = 120 - HWL WET WELL		26.150	26.403	27.110	28.233	29.790	31.753
C = 140 - LWL WET WELL		30.150	30.373	30.990	31.993	33.370	35.123
C = 140 - HWL WET WELL		26.150	26.373	26.990	27.993	29.370	31.123

$$NPSH_A = S - H_s + (P_{atm} - P_{vp}) \times 2.31 / SG$$

Specific Gravity	1.00
Liquid Vapor Pressure (at 70-degree F), psi	0.363
Pressure Head, psi	14.7
At Low Wet Well Level	33.62

Number of Pumps Running	1	1	1	1	1	1
-------------------------	---	---	---	---	---	---

STATION LOSSES

Pipe Section Pump Column/Valves

Pipe Material	Ductile Iron - 250 psi									
Pipe Diameter, in	6									
Pipe Diameter, ft	0.50									
Inside Diameter, ft:	0.52									
Pipe Length, ft	40									
Percentage of Flow		100%	100%	100%	100%	100%	100%	100%	100%	
Flow (cfs)		0.00	0.22	0.45	0.67	0.89	1.11			
Velocity (fps)		0.00	1.06	2.11	3.17	4.22	5.28			
Velocity Head (ft) = V ² /2g		0.00	0.02	0.07	0.16	0.28	0.43			
Minor Losses		Qty	K	Total						
	Entry Loss	1	0.5	0.5						
	90 Degree Bend	2	0.3	0.6						
	6x4 reducer	0	0.1	0						
	Check Valve	1	2.5	2.5						
	Plug Valve	1	0.8	0.8						
	Total		4.4		0.00	0.08	0.30	0.69	1.22	1.90
$h_L = ((4.73L)/(d^{4.87})) * ((Q_1/C)^{1.852})$					0.00	0.04	0.15	0.31	0.53	0.80
Total losses for section (C = 120)					0.00	0.12	0.45	1.00	1.75	2.70
$h_L = ((4.73L)/(d^{4.87})) * ((Q_1/C)^{1.852})$					0.00	0.03	0.11	0.23	0.40	0.60
Total losses for section (C = 140)					0.00	0.11	0.41	0.92	1.62	2.50

Total Station Losses (C = 120)	0.00	0.12	0.45	1.00	1.75	2.70
Total Station Losses (C = 140)	0.00	0.11	0.41	0.92	1.62	2.50

DISCHARGE (SYSTEM) LOSSES

Pipe Combine to RAS Feed Structure


Pipe Material	PVC SDR21					
Pipe Diameter, in	6					
Pipe Diameter, ft	0.50					
Inside Diameter, ft:	0.51					
Pipe Length, ft	80					
Percentage of Flow		100%	100%	100%	100%	100%
Flow (cfs)		0.00	0.22	0.45	0.67	0.89
Velocity (fps)		0.00	1.09	2.19	3.28	4.37
Velocity Head (ft) = V ² /2g		0.00	0.02	0.07	0.17	0.30
Minor Losses						
		Qty	K	Total		
	45-deg Wye (flow through)	1	0.3	0.3		
	45° Wye, through side outlet	1	0.8	0.8		

TOTAL DYNAMIC HEAD					FLOW						
					gpm	0	100	200	300	400	500
					mgd	0.000	0.144	0.288	0.432	0.576	0.720
					cfs	0.000	0.223	0.446	0.668	0.891	1.114
Flow Scenarios											

TOTAL DYNAMIC HEAD			FLOW				
Flow Scenarios	gpm	0	100	200	300	400	500
	mgd	0.000	0.144	0.288	0.432	0.576	0.720
	cfs	0.000	0.223	0.446	0.668	0.891	1.114
<i>Total Dynamic Head = Total Dynamic Discharge Head - Total Dynamic Suction Head</i>							
C = 140 - HWL WET WELL							
Pump Centerline	882						
Static Suction Head (Well WSE - Pump Center Line)		4.50	4.50	4.50	4.50	4.50	4.50
Static Discharge Head (Discharge Elev. - Pump Center Line))		30.65	30.65	30.65	30.65	30.65	30.65
Total Dynamic Suction Head (Static Suction Head - Suction Losses)		4.50	4.50	4.50	4.50	4.50	4.50
Total Dynamic Discharge Head (Static Discharge Head + Station + Discharge Losses)		30.65	30.87	31.49	32.49	33.87	35.62
TOTAL DYNAMIC HEAD		26.15	26.37	26.99	27.99	29.37	31.12
<i>Total Dynamic Head = Total Dynamic Discharge Head - Total Dynamic Suction Head</i>							

Attachment 4-2

US 31 WWTP - RAS/WAS Pumps



Project Location: US 31 Hamilton County
 Pump Location: RAS/WAS Pump Station
 Project #: 244721

Calculated by: SG
 Date: July 5, 2022
 Checked by: ALT
 Date: August 23, 2022

Minor Loss Coefficients

Value	Fitting	Source
0.3	90-deg bend	Metcalf & Eddy Collection & Pumping of Wastewater pg 417
0.2	45-deg bend	Metcalf & Eddy Collection & Pumping of Wastewater pg 417
0.1	11.25-deg bend	Metcalf & Eddy Collection & Pumping of Wastewater pg 418
0.5	Entrance	Metcalf & Eddy Collection & Pumping of Wastewater pg 419
1.0	Submerged Exit	Metcalf & Eddy Collection & Pumping of Wastewater pg 420
0.3	45-deg Wye (flow through)	Applied Hydraulics In Engineering pg 114
1.8	Tee (flow through branch)	Applied Hydraulics In Engineering pg 115
0.3	Tee (flow through run)	Applied Hydraulics In Engineering pg 116
0.8	45° Wye, through side outlet	Applied Hydraulics In Engineering pg 117
0.3	45° Wye, straight run	Applied Hydraulics In Engineering pg 118
0.8	Plug Valve	
2.5	Check Valve (swing check)	
Varies	Increaser	Cameron Hydraulic Data for friction loss due to change in pipe size (Uses Equation) - $K=2.6*(\sin(q/2))*(1-(d_1^2/d_2^2))^2$; when $q<45$ -deg; d_1 = small pipe; d_2 = large pipe; based on velocity in small pipe
Varies	Reducer	Cameron Hydraulic Data for friction loss due to change in pipe size (Uses Equation) - $K=0.8*(\sin(q/2))*(1-(d_1^2/d_2^2))$; when $q<45$ -deg; d_1 = small pipe; d_2 = large pipe; based on velocity in small pipe
5.55	Screen (assume 1/4" spacing, 1/4" bars = 2.0 open:obstruction ratio)	

Pipe Losses (Solve Hazen Williams Equation)	
$h_L = ((4.73L)/(d^{4.87})) * ((Q/C)^{1.852})$ <p>Where: h_L = Friction Headloss (ft) Q = Flow (cfs) C = Roughness coefficient d = Pipe Dia. (ft) L = Pipe length (ft)</p>	<p><i>Hydraulic Design Handbook, pg 10.9, Equation 10.11a</i> $V = 1.318 * C * R^{0.63} * S^{0.54}$ $S = h_L / L$</p>
Channel Losses (Solve Manning's Equation)	
$h_L = ((L * (n^2) * (Q^2)) / ((2.208) * (R^{4/3}) * (A^2)))$ <p>Where: h_L = Friction Headloss (ft) Q = Flow (cfs) n = Roughness coefficient R = Hydraulic Radius (ft) $R = (d * w / (w + 2d))$ for rectangular channel $R = (d * w / (2w + 2d))$ for rectangular conduit A = Area (ft²) L = Pipe length (ft)</p>	<p><i>Hydraulic Design Handbook, pg 10.11, Equation 10.14</i> <i>Civil Engineering Reference Manual, pg 19-4</i> $V = (1.49/n) * R^{2/3} * S^{1/2}$ $V = Q/A$ $S = h_L / L$</p>
Minor Losses	
$h_m = K(V^2 / 2g)$ <p>Where: h_m = Minor Headloss (ft) K = minor loss expression V = velocity (ft/s)</p>	

Loss Across Sluice Gate

$$H = v^2 / 2g * (1/C_d^2)$$

Where: v = velocity (ft/s)

g = gravity acceleration (ft/s²)

C_d = sluice gate coefficient (assume = 0.7)

Head over weir (ISCO Open Channel Flow Measurement Handbook, 6th Ed.)

$$Q = KH^{2.5} \text{ for } 90^\circ \text{ V-Notch weirs}$$

Where: Q_u = flow per v-notch

K = constant (2.500 for units in cfs)

$$Q = KLH^{1.5} \text{ for rectangular weirs without end contractions}$$

Where: Q = flow (cfs)

K = constant (3.330 for units in cfs)

L = crest length

$$Q = K(L - 0.2H) * H^{1.5} \text{ for rectangular weirs with end contractions}$$

Where: Q = flow (cfs)

K = constant (3.330 for units in cfs)

L = crest length

Equivalent Pipe Diameter (Civil Engineering Reference Manual, 9th Ed.)

$$D_e = (2 * L_1 * L_2) / (L_1 + L_2) \text{ (for rectangular conduit flowing full)}$$

Where: D_e = equivalent diameter (ft)

L_1 = width (ft)

L_2 = height (ft)

$$D_e = (4 * h * L) / (L + 2 * h) \text{ (for rectangular conduit flowing partially full)}$$

D_e = equivalent diameter (ft)

L = width (ft)

h = depth (ft)

Parshall Flumes (ISCO Open Channel Flow Measurement Handbook, 6th Ed.)

Percent Submergence

Submergence Ratio = H_b/H_a

Where: H_a = head upstream of throat (ft)

H_b = head at throat (ft)

0.8 Max allowable submergence for flumes 8 to 50 feet wide for discharge to not be reduced

Discharge Equation (for flumes 8 to 50 feet wide)

$Q = (3.688 \cdot W + 2.5) \cdot H^{1.6}$

Where: Q = flow (cfs)

W = throat width (ft)

H = head upstream of throat (ft)

Headloss through flume

$H_L = H_a - H_b$

Cutthroat Flumes (ISCO Open Channel Flow Measurement Handbook, 6th Ed.)

Percent Submergence

Submergence Ratio = H_b/H_a

Where: H_a = head upstream of throat (ft)

H_b = head downstream of throat (ft)

Discharge Equations

$Q = KW^{1.025}H^n = CH^n$

Where: Q = flow (cfs)

W = throat width (ft)

H = head upstream of throat (ft)

K = free-flow coefficient

C = free-flow coefficient

n = free-flow exponent

Headloss through flume

$H_L = H_a - H_b$

Throat Size	Transition Submergence for free flow
1.0	79.0%
1.5	81.0%
2.0	83.0%
2.5	84.0%
3.0	85.0%
4.0	86.0%
5.0	87.0%
6.0	88.0%

Table 1 of "Design and Calibration of Submerged Open Channel Flow Measurement Structures, Part 3 - Cutthroat Flumes" by Skogerboe, Gaylord, et.al, Utah Water Research Laboratory, 1967

Orifice (Cameron Hydraulic Data)

(when $d_1/d_2 < 0.3$; d_2 = diameter of pipe in which orifice is placed)

$$h = (Q / (19.635 * C * d_1^2))^2$$

(when $d_1/d_2 > 0.3$; d_2 = diameter of pipe in which orifice is placed)

$$h = (Q / (19.635 * C * d_1^2))^2 * (1 - (d_1/d_2)^4)$$

Where:

Q = flow (gpm)

C = Discharge coefficient (0.61 for sharp-edged)

d_1 = Diameter of orifice (in)

h = differential head (ft)

Bar Screens

$$H_L = \beta (w/b)^{1.33} h \sin \Phi$$

$$h_L = (V^2 - V^1) / (2g + (1/0.7))$$

Kirschmer's Equation Where,

H_L = Headloss

β = Bar Shape Factor

w = maximum cross-sectional width of bars facing upstream (0.31" for Bar Spacing $\leq 3/8$ " and 0.47" for bar spacing $> 3/8$ ")

b = minimum clear spacing of bars

h = upstream velocity head

Φ = angle of bar screen with horizontal

Note that while using the Kirschmer's Equation for calculating the Headloss,

use the Bar Shape Factor as 1 instead of 0.76 and this is done in order to account for a factor of safety.

Net Positive Suction Head

$$NPSH_A = S - H_s + (P_{atm} - P_{vp}) \times 2.31 / SG$$

Where:

S = Static Suction Head (ft)

H_s = Head Losses in Suction System (ft)

P_{atm} = Pressure Head (psi)

P_{vp} = Vapor Pressure of Liquid (psi)

SG = Specific Gravity

Project Location: US 31 Hamilton County
 Pump Location: RAS/WAS Pump Station
 Project #: 244721

Calculated by: SG
 Date: July 5, 2022
 Checked by: ALT
 Date: August 23, 2022

Wet Well High Water Level: 907.60
 Wet Well Low Water Level: 907.60
 Max Downstream Elevation: 910.10
 TOTAL DYNAMIC HEAD

C Factor #1: 120
 C Factor #2: 140
 Pump Centerline: 891.5

Flow Scenarios	gpm mgd cfs	FLOW							
		0	85	185	250	350	500	700	1000
C = 120 - LWL WET WELL	2.500	0.000	0.122	0.266	0.360	0.504	0.720	1.008	1.440
C = 120 - HWL WET WELL	2.500	0.000	0.189	0.412	0.557	0.780	1.114	1.560	2.228
C = 140 - LWL WET WELL	2.500	4.906	12.906	20.859	31.797	59.662	109.940	212.297	
C = 140 - HWL WET WELL	2.500	4.906	12.906	20.859	31.797	59.662	109.940	212.297	
C = 140 - LWL WET WELL	2.500	4.426	10.886	17.319	25.597	47.672	87.560	168.997	
C = 140 - HWL WET WELL	2.500	4.426	10.886	17.319	25.597	47.672	87.560	168.997	

$$NPSH_A = S - H_s + (P_{atm} - P_{vp}) \times 2.31 / SG$$

Specific Gravity: 1.00
 Liquid Vapor Pressure (at 70-degree F), psi: 0.363
 Pressure Head, psi: 14.7

At Low Wet Well Level: 49.22 49.22 49.22 49.22 49.22 49.22 49.22 49.22

Number of Pumps Running

1 1 1 1 2 2 2 2

STATION LOSSES

From pump (east) to upstream of second wye

Pipe Material: Ductile Iron - 250 psi
 Pipe Diameter, in: 4
 Pipe Diameter, ft: 0.33
 Inside Diameter, ft: 0.35
 Pipe Length, ft: 30

Percentage of Flow	100%	100%	100%	100%	50%	50%	50%	50%
Flow (cfs)	0.00	0.19	0.41	0.56	0.39	0.56	0.78	1.11
Velocity (fps)	0.00	2.01	4.37	5.90	4.13	5.90	8.26	11.80
Velocity Head (ft) = $V^2 / 2g$	0.00	0.06	0.30	0.54	0.27	0.54	1.06	2.16

Minor Losses

Qty	K	Total
90 Degree Bend	2	0.3
Check Valve	1	2.5
Plug Valve	1	0.8
Wye (branch flow)	1	0.8
Total	4.7	0.00

$$h_L = ((4.73L) / (d^{4.87})) * ((Q / C)^{1.852})$$

0.00	0.16	0.67	1.18	0.61	1.18	2.20	4.25
------	------	------	------	------	------	------	------

$$h_L = ((4.73L) / (d^{4.87})) * ((Q / C)^{1.852})$$

0.00	0.12	0.51	0.89	0.46	0.89	1.65	3.20
------	------	------	------	------	------	------	------

0.00	0.41	1.90	3.43	1.71	3.43	6.63	13.37
------	------	------	------	------	------	------	-------

0.00	0.45	2.06	3.72	1.86	3.72	7.18	14.42
------	------	------	------	------	------	------	-------

0.00	0.41	1.90	3.43	1.71	3.43	6.63	13.37
------	------	------	------	------	------	------	-------

DISCHARGE (SYSTEM) LOSSES

From second wye through tee in meter room

Pipe Material: PVC SDR21
 Pipe Diameter, in: 4
 Pipe Diameter, ft: 0.33
 Inside Diameter, ft: 0.35
 Pipe Length, ft: 330

Percentage of Flow	100%	100%	100%	100%	100%	100%	100%	100%
Flow (cfs)	0.00	0.19	0.41	0.56	0.78	1.11	1.56	2.23
Velocity (fps)	0.00	2.01	4.38	5.92	8.29	11.84	16.57	23.67
Velocity Head (ft) = $V^2 / 2g$	0.00	0.06	0.30	0.54	1.07	2.18	4.26	8.70

Minor Losses

Qty	K	Total
Wye (straight run)	2	0.3
Tee (flow through run)	1	0.3
45 Degree Bend	5	0.2
Exit	1	1.0
Total	2.90	0.00

$$h_L = ((4.73L) / (d^{4.87})) * ((Q / C)^{1.852})$$

0.00	1.77	7.48	13.06	24.35	47.13	87.89	170.14
------	------	------	-------	-------	-------	-------	--------

$$h_L = ((4.73L) / (d^{4.87})) * ((Q / C)^{1.852})$$

0.00	1.33	5.62	9.81	18.30	35.43	66.06	127.89
------	------	------	------	-------	-------	-------	--------

0.00	1.51	6.48	11.39	21.39	41.74	78.43	153.13
------	------	------	-------	-------	-------	-------	--------

0.00	1.95	8.34	14.64	27.44	53.44	100.26	195.38
------	------	------	-------	-------	-------	--------	--------

0.00	1.51	6.48	11.39	21.39	41.74	78.43	153.13
------	------	------	-------	-------	-------	-------	--------

TOTAL DYNAMIC HEAD CALCULATIONS

Static Head (@ Max Static Head)	2.50	2.50	2.50	2.50	2.50	2.50	2.50
---------------------------------	------	------	------	------	------	------	------

Total Dynamic Head (calculation check)

(Static Head + Discharge Losses)

Max WSE: 2.50 4.45 10.84 17.14 29.94 55.94 102.76 197.88

TOTAL DYNAMIC HEAD									
Flow Scenarios	gpm mgd cfs	FLOW							
		0	85	185	250	350	500	700	1000
		0.000	0.122	0.266	0.360	0.504	0.720	1.008	1.440
		0.000	0.189	0.412	0.557	0.780	1.114	1.560	2.228
C = 120 - LWL WET WELL									
Pump Centerline	891.5								
Static Suction Head (Well WSE - Pump Center Line)		16.10	16.10	16.10	16.10	16.10	16.10	16.10	16.10
Static Discharge Head (Discharge Elev. - Pump Center Line)		18.60	18.60	18.60	18.60	18.60	18.60	18.60	18.60
Total Dynamic Suction Head (Static Suction Head - Suction Losses)		16.10	16.10	16.10	16.10	16.10	16.10	16.10	16.10
Total Dynamic Discharge Head (Static Discharge Head + Station + Discharge Losses)		18.60	21.01	29.01	36.96	47.90	75.76	126.04	228.40
TOTAL DYNAMIC HEAD		2.50	4.91	12.91	20.86	31.80	59.66	109.94	212.30
Total Dynamic Head = Total Dynamic Discharge Head - Total Dynamic Suction Head									
C = 120 - HWL WET WELL									
Pump Centerline	891.5								
Static Suction Head (Well WSE - Pump Center Line)		16.10	16.10	16.10	16.10	16.10	16.10	16.10	16.10
Static Discharge Head (Discharge Elev. - Pump Center Line)		18.60	18.60	18.60	18.60	18.60	18.60	18.60	18.60
Total Dynamic Suction Head (Static Suction Head - Suction Losses)		16.10	16.10	16.10	16.10	16.10	16.10	16.10	16.10
Total Dynamic Discharge Head (Static Discharge Head + Station + Discharge Losses)		18.60	21.01	29.01	36.96	47.90	75.76	126.04	228.40
TOTAL DYNAMIC HEAD		2.50	4.91	12.91	20.86	31.80	59.66	109.94	212.30
Total Dynamic Head = Total Dynamic Discharge Head - Total Dynamic Suction Head									
C = 140 - LWL WET WELL									
LOW WATER WET WELL WSE SCENARIO									
Pump Centerline	891.5								
Static Suction Head (Well WSE - Pump Center Line)		16.10	16.10	16.10	16.10	16.10	16.10	16.10	16.10
Static Discharge Head (Discharge Elev. - Pump Center Line)		18.60	18.60	18.60	18.60	18.60	18.60	18.60	18.60
Total Dynamic Suction Head (Static Suction Head - Suction Losses)		16.10	16.10	16.10	16.10	16.10	16.10	16.10	16.10
Total Dynamic Discharge Head (Static Discharge Head + Station + Discharge Losses)		18.60	20.53	26.99	33.42	41.70	63.77	103.66	185.10
TOTAL DYNAMIC HEAD		2.50	4.43	10.89	17.32	25.60	47.67	87.56	169.00
Total Dynamic Head = Total Dynamic Discharge Head - Total Dynamic Suction Head									
C = 140 - HWL WET WELL									
Pump Centerline	891.5								
Static Suction Head (Well WSE - Pump Center Line)		16.10	16.10	16.10	16.10	16.10	16.10	16.10	16.10
Static Discharge Head (Discharge Elev. - Pump Center Line)		18.60	18.60	18.60	18.60	18.60	18.60	18.60	18.60
Total Dynamic Suction Head (Static Suction Head - Suction Losses)		16.10	16.10	16.10	16.10	16.10	16.10	16.10	16.10
Total Dynamic Discharge Head (Static Discharge Head + Station + Discharge Losses)		18.60	20.53	26.99	33.42	41.70	63.77	103.66	185.10
TOTAL DYNAMIC HEAD		2.50	4.43	10.89	17.32	25.60	47.67	87.56	169.00
Total Dynamic Head = Total Dynamic Discharge Head - Total Dynamic Suction Head									

Project Location: US 31 Hamilton County
 Pump Location: RAS/WAS Pump Station
 Project #: 244721

Calculated by: SG
 Date: July 5, 2022
 Checked by: ALT
 Date: August 23, 2022

Wet Well High Water Level: 907.60
 Wet Well Low Water Level: 907.60
 Max Downstream Elevation: 913.50
TOTAL DYNAMIC HEAD

C Factor #1: 120
 C Factor #2: 140
 Pump Centerline: 891

Flow Scenarios	gpm mgd cfs	FLOW							
		0	85	185	250	350	500	700	1000
C = 120 - LWL WET WELL	5.900	0.122	0.266	0.360	0.504	0.720	1.008	1.440	
C = 120 - HWL WET WELL	5.900	0.189	0.412	0.557	0.780	1.114	1.560	2.228	
C = 140 - LWL WET WELL	5.900	7.276	11.992	16.783	21.353	47.182	64.182	121.384	
C = 140 - HWL WET WELL	5.900	7.076	11.192	15.363	19.103	42.062	56.022	105.614	
	5.900	7.076	11.192	15.363	19.103	42.062	56.022	105.614	

$$NPSH_A = S - H_s + (P_{atm} - P_{vp}) \times 2.31 / SG$$

Specific Gravity
 Liquid Vapor Pressure (at 70-degree F), psi
 Pressure Head, psi

1.00									
0.363									
14.7									
At Low Wet Well Level	49.72	49.72	49.72	49.72	49.72	49.72	49.72	49.72	49.72

Number of Pumps Running

1	1	1	1	2	2	2	2
---	---	---	---	---	---	---	---

STATION LOSSES

From pump (east) to upstream of second wye

Pipe Material Ductile Iron - 250 psi
 Pipe Diameter, in 4
 Pipe Diameter, ft 0.33
 Inside Diameter, ft: 0.35
 Pipe Length, ft 30

Percentage of Flow	100%	100%	100%	100%	50%	100%	50%	50%
Flow (cfs)	0.00	0.19	0.41	0.56	0.39	1.11	0.78	1.11
Velocity (fps)	0.00	2.01	4.37	5.90	4.13	11.80	8.26	11.80
Velocity Head (ft) = $V^2 / 2g$	0.00	0.06	0.30	0.54	0.27	2.16	1.06	2.16

Minor Losses	Qty	K	Total
90 Degree Bend	2	0.3	0.6
Check Valve	1	2.5	2.5
Plug Valve	1	0.8	0.8
Wye (branch flow)	1	0.8	0.8
	Total		4.7

$h_L = ((4.73L)/(d^{4.87})) * ((Q_1/C)^{1.852})$	0.00	0.29	1.39	2.54	1.25	10.17	4.98	10.17
Total losses for section (C = 120)	0.00	0.45	2.06	3.72	1.86	14.42	7.18	14.42
$h_L = ((4.73L)/(d^{4.87})) * ((Q_1/C)^{1.852})$	0.00	0.12	0.51	0.89	0.46	3.20	1.65	3.20
Total losses for section (C = 140)	0.00	0.41	1.90	3.43	1.71	13.37	6.63	13.37

Total Station Losses (C = 120)	0.00	0.45	2.06	3.72	1.86	14.42	7.18	14.42
Total Station Losses (C = 140)	0.00	0.41	1.90	3.43	1.71	13.37	6.63	13.37

DISCHARGE (SYSTEM) LOSSES

From second wye through tee in meter str to Biosolids Dewatering Structure Header

Pipe Material PVC SDR21
 Pipe Diameter, in 4
 Pipe Diameter, ft 0.33
 Inside Diameter, ft: 0.35
 Pipe Length, ft 115

Percentage of Flow	100%	100%	100%	100%	100%	100%	100%	100%
Flow (cfs)	0.00	0.19	0.41	0.56	0.78	1.11	1.56	2.23
Velocity (fps)	0.00	2.01	4.38	5.92	8.29	11.84	16.57	23.67
Velocity Head (ft) = $V^2 / 2g$	0.00	0.06	0.30	0.54	1.07	2.18	4.26	8.70

Minor Losses	Qty	K	Total
90-deg bend	4	0.3	1.2
Wye (straight run)	2	0.3	0.6
Tee (branch flow)	1	1.8	1.8
45 Degree Bend	1	0.2	0.2
Exit	1	1.0	1
	Total		4.80

$h_L = ((4.73L)/(d^{4.87})) * ((Q_1/C)^{1.852})$	0.00	0.30	1.43	2.61	5.12	10.44	20.47	41.78
Total losses for section (C = 120)	0.00	0.62	2.60	4.55	8.48	16.42	30.63	59.29
$h_L = ((4.73L)/(d^{4.87})) * ((Q_1/C)^{1.852})$	0.00	0.46	1.96	3.42	6.38	12.35	23.02	44.57
Total losses for section (C = 140)	0.00	0.76	3.39	6.03	11.50	22.79	43.49	86.35

Total Discharge Loss, ft (C = 120)	0.00	0.92	4.03	7.16	13.60	26.86	51.10	101.07
Total Discharge Loss, ft (C = 140)	0.00	0.76	3.39	6.03	11.50	22.79	43.49	86.35



TOTAL DYNAMIC HEAD CALCULATIONS

Static Head (@ Max Static Head)	5.90	5.90	5.90	5.90	5.90	5.90	5.90	5.90
Total Dynamic Head (calculation check)								
(Static Head + Discharge Losses)	Max WSE	5.90	6.82	9.93	13.06	19.50	32.76	106.97
C = 120 - LWL WET WELL								
Pump Centerline	891							
Static Suction Head (Well WSE - Pump Center Line)	16.60	16.60	16.60	16.60	16.60	16.60	16.60	16.60

TOTAL DYNAMIC HEAD									
Flow Scenarios	gpm mgd cfs	FLOW							
		0	85	185	250	350	500	700	1000
		0.000	0.122	0.266	0.360	0.504	0.720	1.008	1.440
		0.000	0.189	0.412	0.557	0.780	1.114	1.560	2.228
Static Discharge Head (Discharge Elev. - Pump Center Line)		22.50	22.50	22.50	22.50	22.50	22.50	22.50	22.50
Total Dynamic Suction Head (Static Suction Head - Suction Losses)		16.60	16.60	16.60	16.60	16.60	16.60	16.60	16.60
Total Dynamic Discharge Head (Static Discharge Head + Station + Discharge Losses)		22.50	23.88	28.59	33.38	37.95	63.78	80.78	137.98
TOTAL DYNAMIC HEAD		5.90	7.28	11.99	16.78	21.35	47.18	64.18	121.38
Total Dynamic Head = Total Dynamic Discharge Head - Total Dynamic Suction Head									
C = 120 - HWL WET WELL									
Pump Centerline	891								
Static Suction Head (Well WSE - Pump Center Line)		16.60	16.60	16.60	16.60	16.60	16.60	16.60	16.60
Static Discharge Head (Discharge Elev. - Pump Center Line)		22.50	22.50	22.50	22.50	22.50	22.50	22.50	22.50
Total Dynamic Suction Head (Static Suction Head - Suction Losses)		16.60	16.60	16.60	16.60	16.60	16.60	16.60	16.60
Total Dynamic Discharge Head (Static Discharge Head + Station + Discharge Losses)		22.50	23.88	28.59	33.38	37.95	63.78	80.78	137.98
TOTAL DYNAMIC HEAD		5.90	7.28	11.99	16.78	21.35	47.18	64.18	121.38
Total Dynamic Head = Total Dynamic Discharge Head - Total Dynamic Suction Head									
C = 140 - LWL WET WELL									
LOW WATER WET WELL WSE SCENARIO									
Pump Centerline	891								
Static Suction Head (Well WSE - Pump Center Line)		16.60	16.60	16.60	16.60	16.60	16.60	16.60	16.60
Static Discharge Head (Discharge Elev. - Pump Center Line)		22.50	22.50	22.50	22.50	22.50	22.50	22.50	22.50
Total Dynamic Suction Head (Static Suction Head - Suction Losses)		16.60	16.60	16.60	16.60	16.60	16.60	16.60	16.60
Total Dynamic Discharge Head (Static Discharge Head + Station + Discharge Losses)		22.50	23.68	27.79	31.96	35.70	58.66	72.62	122.21
TOTAL DYNAMIC HEAD		5.90	7.08	11.19	15.36	19.10	42.06	56.02	105.61
Total Dynamic Head = Total Dynamic Discharge Head - Total Dynamic Suction Head									
C = 140 - HWL WET WELL									
Pump Centerline	891								
Static Suction Head (Well WSE - Pump Center Line)		16.60	16.60	16.60	16.60	16.60	16.60	16.60	16.60
Static Discharge Head (Discharge Elev. - Pump Center Line)		22.50	22.50	22.50	22.50	22.50	22.50	22.50	22.50
Total Dynamic Suction Head (Static Suction Head - Suction Losses)		16.60	16.60	16.60	16.60	16.60	16.60	16.60	16.60
Total Dynamic Discharge Head (Static Discharge Head + Station + Discharge Losses)		22.50	23.68	27.79	31.96	35.70	58.66	72.62	122.21
TOTAL DYNAMIC HEAD		5.90	7.08	11.19	15.36	19.10	42.06	56.02	105.61
Total Dynamic Head = Total Dynamic Discharge Head - Total Dynamic Suction Head									



Question 7 Attachments

Attachment 7A-1



SCALE VERIFICATION		DRAWN BY	JLT	NO.	DATE	INITIALS	REVISION DESCRIPTION	
CHECKED BY		ALT						
APPROVED BY		RWH						
BAA IS ONE INCH LONG ON ORIGINAL DRAWING								
<div style="background-color: black; width: 100px; height: 15px;"></div>								
ISSUE DATE		NOVEMBER 2022						
PROJECT NUMBER		244721-04-001						
<div><div>WESSLER ENGINEERING <i>More than a Project™</i></div><div><div>US 31 CORRIDOR INFRASTRUCTURE INVESTMENT PROJECT</div><div>PHASE 1A AND 1B DIVISION 1 - WASTEWATER TREATMENT PLANT</div><div>OXIDATION DITCH - PERSPECTIVE VIEW</div></div></div>								
SHEET NO. 4G1								PAGE NUMBER 24

Attachment 7A-2

[illegible]


Attachment 7B-1



SANITAIRE
a xylem brand

SNDN Process Reference Data

Muncie, IN – SNDN in Conventional Activated Sludge Process



20 MGD Conventional Activated Sludge Plant

4 parallel trains, each with 3 passes in series;
DO levels ~ 0.3 / 1.5 / 4 mg/l

Ave Influent BOD load = 13,981 lb/d (Jan 2017)

Total Basin Volume (3 trains) = 626,400 ft³

Organic Loading Rate = 22.3 #BOD/1000 ft³/d

Effluent Ammonia = 0.1 mg/l



Fond Du Lac, WI

SNDN in Conventional Activated Sludge Process

15 MGD Conventional Activated Sludge Plant

Current Average Flow = 7 to 13 MGD

3 parallel trains, each with an anaerobic zone and 3 aeration passes in series;

DO levels at ~ 0.2 / 1 / 2 mg/l


Ave Influent BOD load = 14,544 lb/d (Mar 2020)

Total Basin Volume (3 trains) = 628,763 ft³

Organic Loading Rate = 23.1 #BOD/1000 ft³/d

SRT = 8.3 days

Effluent Ammonia = 1.7 mg/l



Attachment 7B-2

Annual Summation of Monthly Reports of Operation
2017

PERCENT REMOVAL SUMMARY				
	BOD5	S.S.	Ammonia	Phosphorus
Primary Treatment	39	59		
Secondary Treatment	96	90		
Tertiary Treatment	21	5		
Overall Treatment	97	96		
			99	58

FINAL EFFLUENT																									SLUDGE TO DIGESTER			
		Flow						BOD				Total Suspended Solids				Ammonia				Other								
		Residual Chlorine - Contact Tank	Residual Chlorine - Final	E. Coli - colony/100 ml	pH	Dissolved Oxygen - mg/l	Phosphorus - mg/l	Effluent Flow Rate (MGD)	Effluent Flow Weekly Average	CBOD5 - mg/l	CBOD5 - mg/l Weekly Average	CBOD5 - lbs	CBOD5 - lbs/day Weekly Average	Susp. Solids - mg/l	Susp. Solids - mg/l Weekly Average	Susp. Solids - lbs	Susp. Solids - lbs/day Weekly Average	Ammonia - mg/l	Ammonia - mg/l Weekly Average	Ammonia - lbs	Ammonia - lbs/day Weekly Average	Oil & Grease (mg/l)		Primary Sludge Gal. x 1000	Waste Act. Sludge Gal. x 1000	Temp #5	Temp #6	
Average		1.043	0.0143	37		7.6	1.0	20.114		3.0		497.2818		5.3		909.25		0.09		15.239				30.745	11.703	84.455	89.622	
Maximum		2.21	0.04	900	7.7	9.5	1.67	32	31.143	9.3	4.3143	1351.89	796.56	14.6	8	3621.7	1693.9	0.65	0.2031	157.3	39.156	0	0	99	28.4	95	1007.3	
Minimum		0.35	0.01	10	7.1	6.1	0.4	12.3	13.086	1.1	2.0143	144.1182	282.67	2.5	2.8857	256.61	355.23	0.05	0.0577	5.4243	9.885	0	0	10	2	74	77	
Totals																												
No. of Data		214	214	214	365	365	16	365	365	365		181.507.8	365	365		331.878	365	364		55.46.9	364	364	0	0	11222	3300.3	30826	327146.9
Estimated Annual Totals (Average X 365)								7.342				181.508				331.878				5.562				365	282	365	365	

[illegible]

US 31 WWTP Design

Reference Plant F/M Ratio Review - Updated

US 31 - Design

Volume: 55615 cf Total for 2 trains in series
2017 Ave

Flow	0.5 MGD	Design
CBOD	200 mg/L	Design
MLSS	2,900 mg/L	Bioloop Calculations
Assumed VS %	75%	

Calculated

Secondary Influent CBOD	834 lb/d
MLVSS	7,546 lb
F:M	0.111 lb CBOD/lb MLVSS/day

US 31 - Near-Term

Volume: 27807 cf Total for 1 train
2017 Ave

Flow	0.08 MGD	Design
CBOD	200 mg/L	Design
MLSS	1,000 mg/L	Bioloop Calculations
Assumed VS %	75%	

Calculated

Secondary Influent CBOD	133 lb/d
MLVSS	1,301 lb
F:M	0.103 lb CBOD/lb MLVSS/day

Muncie WPCF Example

F:M Check

Background: From 2017 MRO and SNDN_reference_plant_summaries.ppt file

Upstream Primary Clarifier

No upstream anaerobic tank

Volume: 626400 cf Total for 3 trains in parallel
2017 Ave

Flow	20.114 MGD	MRO Data
Primary Effluent CBOD	65 mg/L	MRO Primary Effluent
MLSS	2,698 mg/L	MRO Mixed Liquor Sus. Solids
Assumed VS %	75%	

Calculated

Secondary Influent CBOD	10,904 lb/d
MLVSS	79,072 lb
F:M	0.138 lb CBOD/lb MLVSS/day